



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

March 4, 2011

Mr. Adam C. Heflin  
Senior Vice President and  
Chief Nuclear Officer  
Union Electric Company  
P. O. Box 620  
Fulton, MO 65251

SUBJECT: CALLAWAY PLANT, UNIT 1 – REQUEST FOR ADDITIONAL INFORMATION  
REGARDING REVISION TO THE FACILITY OPERATING LICENSE AND  
REQUEST FOR REVIEW AND APPROVAL OF THE CYBER SECURITY PLAN  
(TAC NO. ME4536)

Dear Mr. Heflin:

By letter dated August 12, 2010 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML102250075), Union Electric Company (the licensee) submitted a request for revision to the Facility Operating License No. NPF-30 and review and approval of the Cyber Security Plan (CSP) for Callaway Plant, Unit 1, in accordance with Title 10 of the *Code of Federal Regulations*, Section 73.54.

The U.S. Nuclear Regulatory Commission (NRC) staff has reviewed the information provided in your application and determined that additional information is required in order to complete its review. A draft copy of the enclosed request for additional information was provided to Mr. Tom Elwood of your staff via e-mail on March 1, 2011. Mr. Elwood informed the NRC staff on March 2, 2011, that a conference call to discuss the request for additional information is not needed and agreed to provide the response to the request for additional information within 30 days from the date of this letter.

If you have any questions, please contact me at 301-415-1476 or [mohan.thadani@nrc.gov](mailto:mohan.thadani@nrc.gov).

Sincerely,

A handwritten signature in black ink that reads "Mohan C. Thadani".

Mohan C. Thadani, Senior Project Manager  
Plant Licensing Branch IV  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket No. 50-483

Enclosure:  
As stated

cc w/encl: Distribution via Listserv

REQUEST FOR ADDITIONAL INFORMATION  
REVISION TO THE FACILITY OPERATING LICENSE AND REQUEST FOR  
REVIEW AND APPROVAL OF THE CYBER SECURITY PLAN  
UNION ELECTRIC COMPANY  
CALLAWAY PLANT, UNIT 1  
DOCKET NO. 50-483

By letter dated August 12, 2010 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML102250075), Union Electric Company (the licensee) submitted a request for revision to the Facility Operating License No. NPF-30 and review and approval of the Cyber Security Plan (CSP) for Callaway Plant, Unit 1, in accordance with Title 10 of the *Code of Federal Regulations* (10 CFR), Section 73.54, "Protection of digital computer and communication systems and networks."

The U.S. Nuclear Regulatory Commission (NRC) staff has reviewed the information provided in your application and determined that the following additional information is required in order to complete its review.

**1. Records Retention**

The regulations in 10 CFR 73.54(c)(2) requires licensees to design a cyber security program to ensure the capability to detect, respond to, and recover from cyber attacks. Furthermore, 10 CFR 73.54(e)(2)(i) requires licensees to maintain a CSP that describes how the licensee will maintain the capability for timely detection and response to cyber attacks. The ability for a licensee to detect and respond to cyber attacks requires accurate and complete records and is further supported by 10 CFR 73.54(h), which states that the licensee shall retain all records and supporting technical documentation required to satisfy the requirements of 10 CFR Section 73.54 as a record until the Commission terminates the license for which the records were developed, and shall maintain superseded portions of these records for at least 3 years after the record is superseded, unless otherwise specified by the Commission.

The licensee's CSP in Section 4.13 states that Critical Digital Asset (CDA) audit records and audit data (e.g., operating system logs, network device logs) are retained for a period of time that is less than what is required by 10 CFR 73.54(h).

Please explain the deviation from the 10 CFR 73.54(h) requirement to retain records and supporting technical documentation until the Commission terminates the license (or to maintain superseded portions of these records for at least 3 years) and how that meets the requirements of 10 CFR 73.54.

Enclosure

## 2. Implementation Schedule

The regulations in 10 CFR 73.54 require licensees to submit a CSP that satisfies the requirements of this section for Commission review and approval. Furthermore, each submittal must include a proposed implementation schedule and the implementation of the licensee's cyber security program must be consistent with the approved schedule. Paragraph 73.54(a) of 10 CFR requires licensees to provide high assurance that digital computer and communication systems and networks are adequately protected against cyber attacks, up to and including the design basis threat.

The completion of several key intermediate milestones (items (a) through (h) below) would demonstrate progress toward meeting the requirements of 10 CFR 73.54. The NRC staff's expectation is that the key intermediate milestones will be completed in a timely manner, but no later than December 31, 2012. The key CSP implementation milestones are as follows:

- (a) Establish, train and qualify Cyber Security Assessment Team, as described in Section 3.1.2, "Cyber Security Assessment Team," of the CSP.
- (b) Identify Critical Systems and CDAs, as described in Section 3.1.3, "Identification of Critical Digital Assets," of the CSP.
- (c) Implement cyber security defense-in-depth architecture by installation of [deterministic one-way] devices, as described in Section 4.3, "Defense-In-Depth Protective Strategies" of the CSP.
- (d) Implement the management, operational and technical cyber security controls that address attacks promulgated by use of portable media, portable devices, and portable equipment as described in Appendix D, Section 1.19, "Access Control for Portable and Mobile Devices," of Nuclear Energy Institute (NEI) 08-09, Revision 6.
- (e) Implement observation and identification of obvious cyber related tampering to existing insider mitigation rounds as described in Appendix E, Section 4.3, "Personnel Performing Maintenance and Testing Activities," and Appendix E, Section 10.3, "Baseline Configuration," of NEI 08-09, Revision 6.
- (f) Identify, document, and implement cyber security controls to physical security target set CDAs in accordance with Section 3.1.6, "Mitigation of Vulnerabilities and Application of Cyber Security Controls," of the CSP.
- (g) Ongoing monitoring and assessment activities will commence for those target set CDAs whose security controls have been implemented, as described in Section 4.4, "Ongoing Monitoring and Assessment," of the CSP.
- (h) Full implementation of the CSP for all safety, security, and emergency preparedness functions.

Please provide a revised CSP implementation schedule that identifies the appropriate milestones, completion dates, supporting rationale, and level of detail to allow the NRC to evaluate the licensee's proposed schedule and associated milestone dates which include the final completion date. It is the NRC's intention to develop a license condition incorporating your revised CSP implementation schedule containing the key milestone dates.

### **3. Scope of Systems**

Paragraph 73.54(a) of 10 CFR requires licensees to provide high assurance that digital computer and communication systems and networks are adequately protected against cyber attacks, up to and including the design basis threat as described in 10 CFR 73.1. In addition, 10 CFR 73.54(a)(1) states that

The licensee shall protect digital computer and communication systems and networks associated with:

- (i) Safety-related and important-to-safety functions;
- (ii) Security functions;
- (iii) Emergency preparedness functions, including offsite communications;  
and
- (iv) Support systems and equipment which, if compromised, would adversely impact safety, security, or emergency preparedness functions.

Subsequent to the issuance of the cyber security rule, the NRC stated that 10 CFR 73.54 should be interpreted to include structures, systems, and components (SSCs) in the balance of plant (BOP) that have a nexus to radiological health and safety (ADAMS Accession No. ML103490344, dated November 19, 2010). The SSCs in the BOP are those that could directly or indirectly affect reactivity of a nuclear power plant and could result in an unplanned reactor shutdown or transient and are, therefore, within the scope of important-to-safety functions described in 10 CFR 73.54(a)(1). Furthermore, the NRC issued a letter to NEI dated January 5, 2011 (ADAMS Accession No. ML103550480), that provided licensees with additional guidance on one acceptable approach to comply with the Commission's policy determination.

Please explain how the scoping of systems provided by CSP for Callaway Plant, Unit 1 meet the requirements of 10 CFR 73.54 and the additional guidance provided by the NRC.

March 4, 2011

Mr. Adam C. Heflin  
Senior Vice President and  
Chief Nuclear Officer  
Union Electric Company  
P. O. Box 620  
Fulton, MO 65251

**SUBJECT: CALLAWAY PLANT, UNIT 1 – REQUEST FOR ADDITIONAL INFORMATION REGARDING REVISION TO THE FACILITY OPERATING LICENSE AND REQUEST FOR REVIEW AND APPROVAL OF THE CYBER SECURITY PLAN (TAC NO. ME4536)**

Dear Mr. Heflin:

By letter dated August 12, 2010 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML102250075), Union Electric Company (the licensee) submitted a request for revision to the Facility Operating License No. NPF-30 and review and approval of the Cyber Security Plan (CSP) for Callaway Plant, Unit 1, in accordance with Title 10 of the *Code of Federal Regulations*, Section 73.54.

The U.S. Nuclear Regulatory Commission (NRC) staff has reviewed the information provided in your application and determined that additional information is required in order to complete its review. A draft copy of the enclosed request for additional information was provided to Mr. Tom Elwood of your staff via e-mail on March 1, 2011. Mr. Elwood informed the NRC staff on March 2, 2011, that a conference call to discuss the request for additional information is not needed and agreed to provide the response to the request for additional information within 30 days from the date of this letter.

If you have any questions, please contact me at 301-415-1476 or [mohan.thadani@nrc.gov](mailto:mohan.thadani@nrc.gov).

Sincerely,  
/RA/

Mohan C. Thadani, Senior Project Manager  
Plant Licensing Branch IV  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket No. 50-483

Enclosure:  
As stated

cc w/encl: Distribution via Listserv

**DISTRIBUTION:**

PUBLIC	RidsNrrPMCallaway Resource	RidsRgn4MailCenter Resource
LPLIV Reading	RidsNrrLAJBurkhardt Resource	PPederson, NSIR/DSP/ISCPB
RidsAcrsAcnw_MailCTR Resource	RidsNsrDsp Resource	JPolickoski, NRR/DORL/LPL4
RidsNrrDorLpl4 Resource	RidsOgcRp Resource	

**ADAMS Accession No. ML110630118**

\* Memo dated 2/18/11

OFFICE	NRR/LPL4/PM	NRR/LPL4/PM	NRR/LPL4/LA	NSIR/DSP/ISCPB/BC	NRR/LPL4/BC	NRR/LPL4/PM
NAME	JPolickoski	MThadani	JBurkhardt	CErlanger*	MMarkley	MThadani
DATE	3/3/11	3/4/11	3/4/11	2/18/11	3/4/11	3/4/11

OFFICIAL RECORD COPY