



**UNITED STATES
NUCLEAR REGULATORY COMMISSION**
REGION II
245 PEACHTREE CENTER AVENUE NE, SUITE 1200
ATLANTA, GEORGIA 30303-1257

March 4, 2011

Mr. Mano Nazar
Executive Vice President
Nuclear and Chief Nuclear Officer
Florida Power and Light Company
P.O. Box 14000
Juno Beach, FL 33408-0420

SUBJECT: ANNUAL ASSESSMENT LETTER FOR ST. LUCIE NUCLEAR PLANT, UNITS 1
AND 2 – (NRC INSPECTION REPORT NOS. 05000335/2011001 AND
05000389/2011001)

Dear Mr. Nazar:

On February 8, 2011, the NRC completed its end-of-cycle performance review of St. Lucie Nuclear Plant, Units 1 and 2. The NRC reviewed the most recent quarterly performance indicators (PIs) in addition to inspection results and enforcement actions from January 1, 2010, through December 31, 2010. This letter informs you of the NRC's assessment of your facility during this period and its plans for future inspections at your facility. This performance review and enclosed inspection plan does not include security information. A separate letter will include the NRC's assessment of your performance in the Security Cornerstone and its security-related inspection plan.

The NRC determined that overall, St. Lucie Units 1 and 2 operated in a manner that preserved public health and safety and met all cornerstone objectives. The NRC determined the performance at St. Lucie Units 1 and 2 during the most recent quarter was within the Licensee Response Column of the NRC's Reactor Oversight Process (ROP) Action Matrix because all inspection findings had very low safety significance (Green), and all PIs indicated that your performance was within the nominal, expected range (Green). Therefore, the NRC plans to conduct ROP baseline inspections at your facility.

St. Lucie Unit 1 was within the Degraded Cornerstone Column of the NRC's Action Matrix for the first three quarters of the assessment period based on the issuance of one finding classified as having moderate safety significance (Yellow), which originated in the fourth quarter of calendar year 2009. The Yellow finding was finalized in a letter dated April 19, 2010, and involved failure to identify and correct a significant condition adverse to quality affecting the Unit 1 component cooling water system. On September 30, 2010, the NRC completed a supplemental inspection, and determined that the licensee adequately addressed the Yellow finding. The results of the inspection were documented in inspection report 05000335/2010009, issued on November 3, 2010 (ML103070200). The NRC determined the performance at St. Lucie Unit 1 returned to the Licensee Response Column of the Reactor Oversight Process Action Matrix in the fourth quarter of calendar year 2010.

The staff identified a cross cutting theme for St. Lucie Units 1 and 2. Four inspection findings were documented during the current 12 month assessment period with cross-cutting aspects in the area of Problem Identification and Resolution. The common aspect associated with these

findings was failure to take appropriate and timely corrective actions (P.1(d)). All of the findings were of very low safety significance (Green). In order to determine whether a substantive cross-cutting issue should be identified, the NRC evaluated Florida Power and Light's actions to identify and investigate the causes of the cross-cutting theme, and to plan and implement corrective actions to minimize additional findings with a similar aspect. The NRC determined that a substantive cross-cutting issue does not exist because your staff took prompt action to assess the common and root causes of the issues involved. Your staff recognized the potential for a cross-cutting theme in November 2010 after a total of three findings with similar aspects were identified and initiated a Root Cause Evaluation (RCE). This RCE generated new corrective actions, but also found that several of the corrective actions initiated as a result of the Yellow finding described above would effectively address the issues involved. Those corrective actions were focused on improved screening and resolution of corrective action program issues and improved operability and root cause evaluations. The NRC reviewed the implementation of many of those corrective actions during the supplemental inspection conducted in accordance with inspection procedure 95002 in September 2010. As a result of the supplemental inspection and recent review of the RCE, NRC found that your planned corrective actions and effectiveness reviews should be effective in addressing the issues involved in the cross-cutting theme. Since the scope and progress of your efforts in addressing the cross cutting theme were adequate, the NRC determined a substantive cross-cutting issue does not exist.

The enclosed inspection plan lists the inspections scheduled through June 30, 2012. Routine inspections performed by resident inspectors are not included in the inspection plan. Please note the planned Initial Reactor Operator License Examinations. The inspections listed during the last nine months of the inspection plan are tentative and may be revised at the mid-cycle performance review. The NRC provides the inspection plan to allow for the resolution of any scheduling conflicts and personnel availability issues. The NRC will contact you as soon as possible to discuss changes to the inspection plan should circumstances warrant any changes.

In accordance with 10 CFR 2.390 of the NRC's Rules of Practice, a copy of this letter and its enclosure will be made available electronically for public inspection in the NRC Public Document Room or from the Publicly Available Records (PARS) component of NRC's document system (ADAMS). ADAMS is accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

If circumstances arise which cause us to change the inspection plan, we will contact you to discuss the change as soon as possible. Please contact Dan Rich at (404) 997-4721 with any questions you may have regarding this letter or the inspection plan.

Sincerely,

/RA/

Victor M. McCree
Regional Administrator

Docket Nos.: 50-335, 50-389
License Nos.: DPR-67, NPF-16

Enclosure: St. Lucie Nuclear Plant Inspection/Activity Plan (03/01/11 – 06/30/12)

cc w/encl.: (See page 4)

findings was failure to take appropriate and timely corrective actions (P.1(d)). All of the findings were of very low safety significance (Green). In order to determine whether a substantive cross-cutting issue should be identified, the NRC evaluated Florida Power and Light's actions to identify and investigate the causes of the cross-cutting theme, and to plan and implement corrective actions to minimize additional findings with a similar aspect. The NRC determined that a substantive cross-cutting issue does not exist because your staff took prompt action to assess the common and root causes of the issues involved. Your staff recognized the potential for a cross-cutting theme in November 2010 after a total of three findings with similar aspects were identified and initiated a Root Cause Evaluation (RCE). This RCE generated new corrective actions, but also found that several of the corrective actions initiated as a result of the Yellow finding described above would effectively address the issues involved. Those corrective actions were focused on improved screening and resolution of corrective action program issues and improved operability and root cause evaluations. The NRC reviewed the implementation of many of those corrective actions during the supplemental inspection conducted in accordance with inspection procedure 95002 in September 2010. As a result of the supplemental inspection and recent review of the RCE, NRC found that your planned corrective actions and effectiveness reviews should be effective in addressing the issues involved in the cross-cutting theme. Since the scope and progress of your efforts in addressing the cross cutting theme were adequate, the NRC determined a substantive cross-cutting issue does not exist.

The enclosed inspection plan lists the inspections scheduled through June 30, 2012. Routine inspections performed by resident inspectors are not included in the inspection plan. Please note the planned Initial Reactor Operator License Examinations. The inspections listed during the last nine months of the inspection plan are tentative and may be revised at the mid-cycle performance review. The NRC provides the inspection plan to allow for the resolution of any scheduling conflicts and personnel availability issues. The NRC will contact you as soon as possible to discuss changes to the inspection plan should circumstances warrant any changes.

In accordance with 10 CFR 2.390 of the NRC's Rules of Practice, a copy of this letter and its enclosure will be made available electronically for public inspection in the NRC Public Document Room or from the Publicly Available Records (PARS) component of NRC's document system (ADAMS). ADAMS is accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

If circumstances arise which cause us to change the inspection plan, we will contact you to discuss the change as soon as possible. Please contact Dan Rich at (404) 997-4721 with any questions you may have regarding this letter or the inspection plan.

Sincerely,
 /RA/
 Victor M. McCree
 Regional Administrator

Docket Nos.: 50-335, 50-389
 License Nos.: DPR-67, NPF-16

Enclosure: St. Lucie Nuclear Plant Inspection/Activity Plan (03/01/11 – 06/30/12)

cc w/encl.: (See page 4)

*For Previous Concurrence See Attached Sheet

X PUBLICLY AVAILABLE

☐ NON-PUBLICLY AVAILABLE

☐ SENSITIVE

X NON-SENSITIVE

ADAMS: X Yes ACCESSION NUMBER: Letter: ML110630130 Pkg: ML110630127

X SUNSI REVIEW COMPLETE

OFFICE	RII:DRP	RII:DRP	RII:DRP	RII:DRP	RII:RA	RII:RA	
SIGNATURE	/RA/	/RA/	/RA/	/RA/	/RA/	VMM	
NAME	*SNinh	*THoeg	*DRich	*RCroteau	*LWert	VMcCree	
DATE	02/17/2011	02/16/2011	02/18/2011	02/22/2011	03/01/2011	03/03/2011	
E-MAIL COPY?	YES NO	YES NO	YES NO	YES NO	YES NO	YES NO	YES NO

OFFICIAL RECORD COPY DOCUMENT NAME: G:\DRPI\RPB3\MID & EOC INFO\2010\ST. LUCIE-EOC-2010-PACKAGE\PROPOSED-ST LUCIE EOC- LETTER-2010.DOCX

cc w/encl:
Richard L. Anderson
Site Vice President
St. Lucie Nuclear Plant
Electronic Mail Distribution

Robert J. Hughes
Plant General Manager
St. Lucie Nuclear Plant
Electronic Mail Distribution

Gene St. Pierre
Vice President, Fleet Support
Florida Power & Light Company
Electronic Mail Distribution

Ronnie Lingle, Operations Manager
St. Lucie Nuclear Plant
Electronic Mail Distribution

Eric Katzman
Licensing Manager
St. Lucie Nuclear Plant
Electronic Mail Distribution

Larry Nicholson, Director
Licensing
Florida Power & Light Company
Electronic Mail Distribution

Alison Brown
Nuclear Licensing
Florida Power & Light Company
Electronic Mail Distribution

Mitch S. Ross
Vice President and Associate General
Counsel
Florida Power & Light Company
Electronic Mail Distribution

Marjan Mashhadi
Senior Attorney
Florida Power & Light Company
Electronic Mail Distribution

William A. Passetti, Chief
Florida Bureau of Radiation Control
Department of Health
Electronic Mail Distribution

Byron Koons, Director
Florida Division of Emergency Management
2555 Shumard Oaks Blvd.
Tallahassee, FL 32399

J. Kammel
Radiological Emergency Planning
Administrator
Department of Public Safety
Electronic Mail Distribution

Mano Nazar
Executive Vice President and Chief Nuclear
Officer
Nuclear Division
Florida Power & Light Company
P.O. Box 14000
Juno Beach, FL 33408

Senior Resident Inspector
St. Lucie Nuclear Plant
U.S. Nuclear Regulatory Commission
P.O. Box 6090
Jensen Beach, FL 34957-2010

Seth B. Duston, Training Manager
St. Lucie Nuclear Plant
Electronic Mail Distribution

Faye Outlaw
County Administrator
St. Lucie County
Electronic Mail Distribution

Jack Southard, Director
Public Safety Department
St. Lucie County
Electronic Mail Distribution

Letter to Mano Nazar from Victor M. McCree dated March 4, 2011

SUBJECT: ANNUAL ASSESSMENT LETTER FOR ST. LUCIE NUCLEAR PLANT, UNITS 1
AND 2 – (NRC INSPECTION REPORT NOS. 05000335/2011001 AND
05000389/2011001)

Distribution w/encl:

C. Evans, RII EICS

L. Douglas, RII EICS

OE Mail

RIDSNRRDIRS

PUBLIC

RidsNrrPMStLucie Resource

ROP Reports

Institute of Nuclear Power Operations (INPO)