

Metzger, Brian

From: Frumkin, Daniel *DKR*
Sent: Friday, October 16, 2009 3:47 PM
To: Metzger, Brian *DKR*
Subject: Oyster Creek - PHase 1

Brian,

I have looked at what Ken came up with for OC phase 1 and it looks good. I have one question that should be crafted into an RAI.

Page 18 FZ OB-FZ-10A - in the third paragraph they discuss "an enhancement." We need clarity as to whether that enhancement is part of their DID analysis -if so then it should be a commitment. Or if not, why non-full area detection suppression is acceptable for their hazards?

They can't leave this hanging out there.

Please create a concurrence package for this one using Ken's input, and any additional comments you have on his input.

Dan