

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8001140370 DOC. DATE: 80/01/07 NOTARIZED: NO DOCKET #  
 FACIL: 50-438 Bellefonte Nuclear Plant, Unit 1, Tennessee Valley Au 05000438  
 50-439 Bellefonte Nuclear Plant, Unit 2, Tennessee Valley Au 05000439  
 AUTH. NAME: MILLS, L.M. AUTHOR AFFILIATION: Tennessee Valley Authority  
 RECIPIENT NAME: RECIPIENT AFFILIATION:

SUBJECT: Sixth interim deficiency rept re failure of expansion anchors to pass qualification tests. Final resolution to NCR 871 provided in previous rept. Final resolution of NCR 898 expected 800326.

DISTRIBUTION CODE: B019S COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1  
 TITLE: Construction Deficiency Report (10CFR50.55E)

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID	CODE/NAME	L	ENCL		ID	CODE/NAME	L	ENCL
ACTION:	14	PM BOURNIA	1			15	BCLWR#3	1	
	20	LA LWR#3	1			21	AD LWR	1	
INTERNAL:	01	REG FILE	1			02	NRC PDR	1	
	05	I&E	2			07	EDO & STAFF	1	
	08	MPA	1			09	DEPY DIR DPM	1	
	10	QAB	1			11	STANDRDS DEV	1	
	12	JORDAN, E/IE	1			13	FIELD COOR/IE	1	
	16	AD FOR ENGR	1			17	AD PLANT SYS	1	
	17	AD REAC SFTY	1			22	DIR DPM	1	
	23	OELD	1				AD/SITE TECH	1	
		DIRECTOR USE	1				GEOSCIENCES BR	1	
		I&C SYS BR	1				MATL ENG BR	1	
		MECH ENG BR	1				POWER SYS BR	1	
		S HANAUER	1				STRUCT ENG BR	1	
	EXTERNAL:	03	LPDR	1				04	NSIC
24		ACRS	16	16					

JAN 15 1980

TOTAL NUMBER OF COPIES REQUIRED: LTR 47 ENCL 0

TENNESSEE VALLEY AUTHORITY

MARIETTA, TENNESSEE 37401

400 Chestnut Street Tower II

January 7, 1980

30-438

Mr. James P. O'Reilly, Director  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Region II - Suite 3100  
101 Marietta Street  
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

BELLEFONTE NUCLEAR PLANT UNITS 1 AND 2 - EXPANSION ANCHORS NOT PASSING  
QUALIFICATION TESTS - NCR 871 AND NCR 898 - SIXTH INTERIM REPORT

NCR 871 was initially reported on July 10, 1978, to R. W. Wright, NRC-OIE Region II, in accordance with 10 CFR 50.55(e). This was followed by our first interim report dated August 9, 1978. Since that time, related NCR 898 has been determined to be reportable in accordance with 10 CFR 50.55(e) and was reported in our second interim report dated January 26, 1979. This was followed by our combined interim reports dated April 9, June 7, and July 20, 1979. Final resolution to NCR 871 (without cutting rebar) was provided in our previous report. The final resolution to NCR 898 (with cutting rebar) will be resolved and reported in conjunction with the final resolution to OIE Bulletin 79-02 for Bellefonte. We expect to submit our final written report by March 26, 1980.

If you have any questions concerning this matter, please get in touch with D. L. Lambert at FTS 854-2581.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

L. M. Mills, Manager  
Nuclear Regulation and Safety

cc: Mr. Victor Stello, Jr., Director  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

Bol<sup>9</sup>  
3/10