



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

April 11, 2011

LICENSEE: Entergy Nuclear Operations, Inc.

FACILITY: Pilgrim Nuclear Power Station

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON  
MARCH 23, 2011, BETWEEN THE U.S. NUCLEAR REGULATORY  
COMMISSION AND ENTERGY NUCLEAR OPERATIONS, INC., CONCERNING  
THE PILGRIM NUCLEAR POWER STATION LICENSE RENEWAL  
APPLICATION (TAC NO. MC9669)

The U.S. Nuclear Regulatory Commission (the staff) and representatives of Entergy Nuclear Operations, Inc. (the applicant) held a telephone conference call on March 23, 2011, to discuss and clarify the staff's draft request for additional information (RAI) concerning the Pilgrim Nuclear Power Station license renewal application. The draft RAI was associated with a review of NUREG-1891, "Safety Evaluation Report Related to the License Renewal of Pilgrim Nuclear Power Station," issued on June 28, 2007, and supplemented on September 28, 2007.

The staff has identified in the enclosure, areas where additional information is needed. The telephone conference call was useful in clarifying the intent of the staff's draft RAI.

Enclosure 1 provides a listing of the participants and Enclosure 2 includes the draft RAI discussed with the applicant, including a brief description on the status of the item.

The applicant had an opportunity to comment on this summary.

A handwritten signature in black ink, appearing to read "L. M. Regner".

Lisa M. Regner, Sr. Project Manager  
Projects Branch 2  
Division of License Renewal  
Office of Nuclear Reactor Regulation

Docket No. 50-293

Enclosures:  
As stated

cc w/encls: Listserv

**TELEPHONE CONFERENCE CALL  
PILGRIM NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION**

**LIST OF PARTICIPANTS  
MARCH 23, 2011**

**PARTICIPANTS**

Lisa Regner  
William Holston  
Cliff Douth  
Joe Lynch  
Fred Mogolesko  
Dave Heard  
Paul Smith

**AFFILIATIONS**

U.S. Nuclear Regulatory Commission (NRC)  
NRC  
NRC  
Entergy Nuclear Operations, Inc. (Entergy)  
Entergy  
Entergy  
Entergy

**DRAFT REQUESTS FOR ADDITIONAL INFORMATION  
PILGRIM NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION**

**MARCH 23, 2011**

The U.S. Nuclear Regulatory Commission (the staff) and representatives of Entergy Nuclear Operations, Inc. (the applicant) held a telephone conference call on March 23, 2011, to discuss and clarify the following draft request for additional information (RAI) concerning the Pilgrim Nuclear Power Station (PNPS) license renewal application (LRA).

**DRAFT RAI Appendix A**

Background:

In a letter dated March 16, 2011, the applicant revised LRA sections associated with inspection of containment coatings, inspection of buried pipe and tanks, and aging management of low voltage cables.

Issue:

The Updated Final Safety Analysis Report supplements for the LRA sections inspection of containment coatings, inspection of buried pipe and tanks, and aging management of low voltage cables do not reflect the changes; therefore, the staff cannot confirm that the changes will become part of the current licensing basis for PNPS.

Request:

Revise the UFSAR supplement to reflect the modifications to the programs associated with inspection of containment coatings, inspection of buried pipe and tanks, and aging management of low voltage cables as reflected in Entergy letters dated January 7 and 31, and March 16, 2011.

Discussion:

The applicant stated it understands the question and will respond in a formal letter.

ENCLOSURE 2

April 11, 2011

LICENSEE: Entergy Nuclear Operations, Inc.  
FACILITY: Pilgrim Nuclear Power Station  
SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON  
MARCH 23, 2011, BETWEEN THE U.S. NUCLEAR REGULATORY  
COMMISSION AND ENTERGY NUCLEAR OPERATIONS, INC., CONCERNING  
THE PILGRIM NUCLEAR POWER STATION LICENSE RENEWAL  
APPLICATION (TAC NO. MC9669)

The U.S. Nuclear Regulatory Commission (the staff) and representatives of Entergy Nuclear Operations, Inc. (the applicant) held a telephone conference call on March 23, 2011, to discuss and clarify the staff's draft request for additional information (RAI) concerning the Pilgrim Nuclear Power Station license renewal application. The draft RAI was associated with a review of NUREG-1891, "Safety Evaluation Report Related to the License Renewal of Pilgrim Nuclear Power Station," issued on June 28, 2007, and supplemented on September 28, 2007.

The staff has identified in the enclosure, areas where additional information is needed. The telephone conference call was useful in clarifying the intent of the staff's draft RAI.

Enclosure 1 provides a listing of the participants and Enclosure 2 includes the draft RAI discussed with the applicant, including a brief description on the status of the item.

The applicant had an opportunity to comment on this summary.

*/RA/*

Lisa M. Regner, Sr. Project Manager  
Projects Branch 2  
Division of License Renewal  
Office of Nuclear Reactor Regulation

Docket No. 50-293

Enclosures:  
As stated

cc w/encls: Listserv

DISTRIBUTION:

**ADAMS Accession Number: ML110820208**

OFFICE	LA:DLR*	PM:RPB2:DLR	BC:RPB2:DLR	PM:RPB2:DLR
NAME	IKing	LRegner	DWrona	LRegner
DATE	03/31/2011	04/07/2011	04/08/2011	04/11/2011

OFFICIAL RECORD COPY

Memorandum to Entergy Nuclear Operations, Inc. from Lisa M. Regner dated April 11, 2011

**SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON  
MARCH 23, 2011, BETWEEN THE U.S. NUCLEAR REGULATORY  
COMMISSION AND ENTERGY NUCLEAR OPERATIONS, INC., CONCERNING  
THE PILGRIM NUCLEAR POWER STATION LICENSE RENEWAL  
APPLICATION (TAC NO. MC9669)**

**DISTRIBUTION:**

**HARD COPY:**

DLR R/F

**E-MAIL:**

PUBLIC

RidsNrrDlr Resource

RidsNrrDlrRpb1 Resource

RidsNrrDlrRpb2 Resource

RidsNrrDlrRer1 Resource

RidsNrrDlrRer2 Resource

RidsNrrDlrRerb Resource

RidsNrrDlrRpob Resource

RidsNrrDciCvib Resource

RidsNrrDciCpnb Resource

RidsNrrDciCsgb Resource

RidsNrrDraAfpb Resource

RidsNrrDraApla Resource

RidsNrrDeEmcb Resource

RidsNrrDeEeeb Resource

RidsNrrDssSrxb Resource

RidsNrrDssSbpb Resource

RidsNrrDssScvb Resource

RidsOgcMailCenter Resource

RidsOpaMail

-----  
L. Regner

S. Uttal, OGC

B. Harris, OGC

A. Jones, OGC

S. Schneider, RI

D. Jackson, RI

R. Conte, RI