

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8009100494 DOC. DATE: 80/09/04 NOTARIZED: NO DOCKET #  
 FACIL: 50-438 Bellefonte Nuclear Plant, Unit 1, Tennessee Valley Au 05000438  
 AUTH. NAME AUTHOR AFFILIATION  
 MILLS, L.M. Tennessee Valley Authority  
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: First interim deficiency rept re RCS pump cases out of level. Appropriate info transmitted to B&W for review. Next rept will be submitted by 801128.

DISTRIBUTION CODE: B019S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2  
 TITLE: Construction Deficiency Report (10CFR50.55E)

## NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL		RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	
ACTION:	A/D LICENSNG 04	1	1	YOUNGBLOOD, B 05	1	1
	RUSHBROOK, M. 06	1	1	BOURNIA, T. 07	1	1
INTERNAL:	AD/RCI/IE 17	1	1	AEOD 18	1	1
	ASLBP/J. HARD	1	1	D/DIR HUM FAC 15	1	1
	DIR, HUM FAC S10	1	1	EDO & STAFF 19	1	1
	EQUIP QUAL BR 11	1	1	I&E 09	2	2
	LIC QUAL BR 12	1	1	MPA 20	1	1
	NRC PDR 02	1	1	OELD 21	1	1
	PROC/TST REV 13	1	1	QA BR 14	1	1
	<del>REG FILE</del> 01	1	1	RUTHERFORD, W. IE	1	1
	STANDRDS DEV 21	1	1			
EXTERNAL:	ACRS 16	16	16	LPDR 03	1	1
	NSIC 08	1	1			

SEP 12 1980

TOTAL NUMBER OF COPIES REQUIRED: LTTR 40 ENCL 40

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

400 Chestnut Street Tower II

September 4, 1980

Mr. James P. O'Reilly, Director  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Region II - Suite 3100  
101 Marietta Street  
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

BELLEFONTE NUCLEAR PLANT UNIT 1 - REACTOR COOLING SYSTEM PUMP CASES OUT  
OF LEVEL - NCR 1231 - FIRST INTERIM REPORT

The subject nonconformance was initially reported to NRC-OIE Inspector  
F. S. Cantrell on August 5, 1980, in accordance with 10 CFR 50.55(e).  
Enclosed is our first interim report. We expect to submit our next written  
report by November 28, 1980.

If you have any questions concerning this matter, please get in touch with  
D. L. Lambert at FTS 857-2581.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

L. M. Mills, Manager  
Nuclear Regulation and Safety

Enclosure

cc: Mr. Victor Stello, Jr., Director (Enclosure) ✓  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

8009100 494

B019  
5/11

ENCLOSURE

BELLEFONTE NUCLEAR PLANT UNIT 1  
REACTOR COOLING SYSTEM PUMP CASES OUT OF LEVEL  
NCR 1231  
10 CFR 50.55(e)  
FIRST INTERIM REPORT

Description of Deficiency

The B&W level tolerance was of 0.125" total indicator reading (TIR) was exceeded on two of four reactor coolant pump casings.

Interim Progress

TVA has transmitted the appropriate information to B&W for their review and recommended disposition.