

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS) m/1

ACCESSION NBR: 8007160424 DOC. DATE: 80/07/08 NOTARIZED: NO DOCKET #  
 FACIL: 50-438 Bellefonte Nuclear Plant, Unit 1, Tennessee Valley Au ~~05000438~~  
 50-439 Bellefonte Nuclear Plant, Unit 2, Tennessee Valley Au 05000439  
 AUTH. NAME AUTHOR AFFILIATION  
 MILLS, L.M. Tennessee Valley Authority  
 RECIPIENT NAME RECIPIENT AFFILIATION

SUBJECT: Eighth interim deficiency rept re failure of expansion anchors to pass qualification tests. Final resolution to NCR 871 was provided in 79720 rept. NCR 898 will be resolved w/ final resolution to IE Bulletin 79-02. Next rept by 810114.

DISTRIBUTION CODE: B019S COPIES RECEIVED: LTR 4 ENCL 0 SIZE: 1  
 TITLE: Construction Deficiency Report (10CFR50.55E)

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID	CODE/NAME	LTR	ENCL		ID	CODE/NAME	LTR	ENCL
ACTION:	A/D	LICENSNG 21	1		YOUNGBLOOD, B	15	1		
	RUSHBROOK, M.	20	1		BOURNIA, T.	14	1		
INTERNAL:	AD/RCI/IE		1		AEOD		1		
	DIR, HUM FAC	SFY	1		EDO & STAFF	07	1		
	EQUIP QUAL	BR16	1		FIELD COOR/IE	13	1		
	HYD/GEO BR	22	1		I&E	05	2		
	LIC QUAL BR		1		MOORE, V.		1		
	MPA	08	1		NRC PDR	02	1		
	OELD	23	1		OR ASSESS BR	17	1		
	PROC/TST REV	BR	1		QA BR	10	1		
	<del>REG ED</del>	01	1		STANDRDS DEV	11	1		
EXTERNAL:	ACRS	24	16	1	LPDR	03	1	1	
	NSIC	04	1						

T

JUL 17 1980

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401  
400 Chestnut Street Tower II

50-438  
50-439

July 8, 1980

Mr. James P. O'Reilly, Director  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Region II - Suite 3100  
101 Marietta Street  
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

BELLEFONTE NUCLEAR PLANT UNITS 1 AND 2 - EXPANSION ANCHORS NOT PASSING  
QUALIFICATION TESTS - NCR 871 AND NCR 898 - EIGHTH INTERIM REPORT

NCR 871 was initially reported on July 10, 1978, to R. W. Wright, NRC-OIE Region II, in accordance with 10 CFR 50.55(e). This was followed by our first interim report dated August 9, 1978. Since that time, related NCR 898 has been determined to be reportable in accordance with 10 CFR 50.55(e) and was reported in our second interim report dated January 26, 1979. This was followed by our combined interim reports dated April 9, June 7, and July 20, 1979, and January 7 and March 25, 1980. Final resolution to NCR 871 (without cutting rebar) was provided in our July 20, 1979, report. The final resolution to NCR 898 (with cutting rebar) will be resolved and reported in conjunction with the final resolution to OIE Bulletin 79-02 for Bellefonte. We expect to submit our next written report by January 14, 1981.

If you have any questions concerning this matter, please get in touch with D. L. Lambert at FTS 857-2581.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

L. M. Mills, Manager  
Nuclear Regulation and Safety

cc: Mr. Victor Stello, Jr., Director  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

B019  
s  
1/0

8007160424