

METAL *Bellows* CORPORATION

~~AN~~
OUT
1-5-80

CR 729

DESIGN REPORT

FOR

HOSE ASSEMBLY, FLEXIBLE METAL PER
ASME BOILER AND PRESSURE VESSEL CODE
SECTION III, SUBSECTION NC, CLASS 2

FOR

TENNESSEE VALLEY AUTHORITY

KNOXVILLE, TENNESSEE

REFERENCES

MBC PART NUMBER 78153

MBC JOB NUMBER A15278


N4M-526
DATE: OCT 21 1980
PROJECT BLN CONTRACT 80KA3828398
DRAWING # CR 729
SHEET REV A UNIT 1E2
USE: FLEX HOSE ASSY FOR
INSTR. & CONTROL SYS

No. of Pages: 27

September 22, 1980

Revision A, October 17, 1980

8305100395 830504
PDR ADDCK 0500043B
A PDR



Metal Bellows Corporation

CR 729
Page i

VERIFICATION OF SPECIFICATION

Title: DESIGN REPORT FOR HOSE ASSEMBLY, FLEXIBLE METAL REPORT, CR 729,
MBC P/N 78153

Revision: *PSL*
A *10-17-80*


Reference: TENNESSEE VALLEY AUTHORITY SPECIFICATION NUMBER BNP-DS-1940-4809-R0

Prepared by: *F. Shen* Date: *9/23/80*

Checked by: *J. Huffman* Date: *9-23-80*

Quality Assurance: *PSL* Date: *24 SEPT. 1980*

This is to certify that the above document has been reviewed by me, the undersigned, and is correct, complete, and in compliance with the 1977 Edition, including the Winter of 1979 Addenda, of ASME CODE, Section III, Paragraph NC-3000 and Code Case N-188-1 and N-192.
Paragrap



Signature: *Ronald H. Nyström*

Name: Ronald H. Nyström

Number: 17261

Date: September 24 1980

TABLE OF CONTENTS

<u>Paragraph</u>		<u>Page</u>
1.0	INTRODUCTION	1
2.0	REFERENCES	2
2.1	Design Conditions	3
3.0	INSTALLATION, CONFIGURATION & MOTIONS	13
4.0	LOADING COMBINATION	18
5.0	MOTION AT CENTER DUE TO RESPONSE FROM SEISMIC INPUT	24
6.0	PIPING	26
7.0	LOADING (SUSTAINED LOAD AND OCCASIONAL LOAD)	27

INDEX OF REVISIONS

Date and Rev.	Pages Affected			Remarks	Revised By
	Revised	Added	Deleted		
10/17/80 A	Cover, i, ii	27, iii		Added loading requirement	<i>F. Allen</i> 10/17/80 <i>10-6-80 Nypson</i>

1.0 INTRODUCTION

This report, CR 729, was prepared by Metal Bellows Corporation (MBC) Chatsworth, California for the Tennessee Valley Authority, Knoxville, Tennessee, in accordance with TVA Specification Number BNP-DS-1940-4809-R0.

This report provides the design analysis for a $\frac{1}{2}$ inch hose assembly with $\frac{3}{8}$ inch tube ends, for use in Bellefonte Nuclear Plant in various locations and applications. Actual operating conditions are less than design requirements.

The analysis is in accordance with the Rules of the ASME Boiler and Pressure Vessel Code Section III, Class 2. A simplifying, conservative assumption is to analyze the hose and braid separately. Association (EJMA) performance equations and ignores the hoop support provided by the braid. The analysis of the braid is to show the stresses imposed by the pressure end loads is within Code allowables. The braid inward force vector far exceeds the squirm force created by the hose, and bellows squirm calculations are ignored.

A simplifying, conservative approach is to list the many possible motions and radius changes that will occur and perform the stress-life calculations for the single worst case. The seismic analysis is made assuming the hose is full of air and pressurized.

The mechanically induced vibration is analyzed at 10 Hz only. The other required frequencies will produce smaller displacements with resulting higher life and need not be considered.

The hose is identical to MBC P/N 73989 which has been seismic and cycle tested, reference CR 725.

2.0 REFERENCES

2.0.1 T.V.A.SPEC.NO.BNF-DS-1940-4809-R0

2.0.2 METAL BELLOWS CORP DRAWING 78153

2.0.3 ASME BOILER AND PRESSURE VESSEL CODE, SECTION III
SUBSECTION NC CLASS 2 COMPONENTS

2.0.4 STANDARDS OF THE EXPANSION JOINT MANUFACTURERS
ASSOCIATION (EJMA) FIFTH EDITION

2.0.5 ASSESSMENT OF FLEXIBLE LINE FOR FLOW INDUCED
VIBRATION - GEORGE C. MARSHAL SPACE FLIGHT CENTER
REPORT NUMBER 20M02540.

2.1 DESIGN CONDITIONS

CR729

PAGE 3

OPERATING PRESSURE	150 PSIG
DESIGN PRESSURE	150 PSIG
OPERATING TEMPERATURE	150 F
DESIGN TEMPERATURE	150 F
ROOM TEMPERATURE PROOF PRESSURE	225 PSIG
BURST PRESSURE	600 PSIG
FLOW RATE	0 LB/SEC
LINE SIZE	0.5 IPS
PRESSURE LOSS ALLOWABLE	N/A

MOTIONS

THERMAL OFFSET, DT 28.750 INCHES

CYCLE LIFE 5000 CYCLES

OBE SEISMIC OFFSET, DOBE 14.370 INCHES

CYCLE LIFE 100 CYCLES

SSE SEISMIC OFFSET, DSSE 28.750 INCHES

CYCLE LIFE 100 CYCLES

VIBRATION OFFSET DV 0.137 INCHES AT 10 HZ (.5g_o)

LIFE 40 YEARS (SEE NOTE)

ALLOWABLE LOADS

FORCE N/A LBS

MOMENT N/A IN-LBS

NOTE:

THE TERM "YEARS OF SERVICE" EXPRESSED OR IMPLIED IN THE DESIGN SPECIFICATION FOR THIS UNIT IS INTERPRETED BY METAL BELLOWS CORP TO BE A DESIGN OBJECTIVE ONLY. METAL BELLOWS ENGINEERING HAS TO THE BEST OF ITS ABILITY, BASED ON INFORMATION FURNISHED AND GENERAL APPLICATION KNOWLEDGE, TRIED TO DEFINE ALL OF THE SERVICE PARAMETERS THAT WOULD BE IMPOSED DURING "SERVICE LIFE" AND EVENTUALLY RESULT IN FATIGUE FAILURE, HOWEVER, IT MUST BE APPRECIATED THAT THERE ARE PRACTICAL LIMITATIONS IN DEFINING ALL CONDITIONS IMPOSED ON A UNIT DURING ITS "SERVICE LIFE" AND FOR THIS REASON THE UNIT WILL BE SUBJECT TO ALL TERMS AND CONDITIONS OF METAL BELLOWS CORPORATION'S STANDARD WARRANTY

2.2 HOSE DATA

CR729
PAGE 4

2.2.1 BASIC TUBE, OD 0.500 INCHES
OUTSIDE DIA, OD 0.700 INCHES
INSIDE DIA, D 0.485 INCHES
MEAN DIA, DP 0.592 INCHES
THICKNESS, T 0.016 INCHES
SPAN, W 0.108 INCHES
PITCH, Q 0.100 INCHES
LENGTH, L 36.000 INCHES
NO OF CONVOLUTIONS, N 360

2.3 PERFORMANCE CONSTANTS

$TP = T(D)EXP.5 / (DP)EXP.5$ (MATERIAL THINNING)

TP = 0.014 INCHES

Q/2W = 0.47

$Q / 2.2(DP(TP))EXP.5 = 0.49$

2.3.1 FROM FIGURE C18, EJMA STANDARDS

CF = 0.68

2.3.2 FROM FIGURE C19, EJMA STANDARDS

CF = 1.60

2.3.3 FROM FIGURE C20, EJMA STANDARDS

CD = 1.65

2.4 PERFORMANCE EQUATIONS

CR729
PAGE 3

2.4.1 BELLOWS TANGENT CIRCUMFERENTIAL PRESSURE STRESS

$$S1 = (P)(D)(EB) / 2((TC)(EC) + (N)(T)(EB))$$

$$S1 = 300 \text{ PSI}$$

CODE ALLOWABLE = 27500 PSI

2.4.2 BELLOWS CIRCUMFERENTIAL MEMBRANE PRESSURE STRESS

$$S2 = (P)(DP) / 2N(TP)(.571 + 2W/Q)$$

$$S2 = 1128 \text{ PSI}$$

CODE ALLOWABLE = 27500 PSI

2.4.3 BELLOWS MERIDIONAL PRESSURE STRESS

$$S3 = (P)(W) / 2N(TP)$$

$$S3 = 556 \text{ PSI}$$

2.4.4 BELLOWS MERIDIONAL PRESSURE BENDING STRESS

$$S4 = (P)(CP)(W/TP) \text{EXP} 2/2N$$

$$S4 = 2812 \text{ PSI}$$

2.5 EQUIVALENT AXIAL MOTION DUE TO OFFSET

CR729
PAGE 6

$$ET = 3DP(DT)/N(L) \quad (\text{THERMAL})$$

$$ET = 0.0039431 \text{ INCHES}$$

$$EOBE = 3DP(DOBE)/N(L) \quad (\text{SEISMIC-OBE})$$

$$EOBE = 0.0019709 \text{ INCHES}$$

$$ESSE = 3DP(DSSE)/N(L) \quad (\text{SEISMIC-SSE})$$

$$ESSE = 0.0039431 \text{ INCHES}$$

$$EV = 3DP(DV)/N(L) \quad (\text{VIBRATION})$$

$$EV = 0.0000188 \text{ INCHES}$$

2.6 BELLOWS MERIDIONAL MEMBRANE DEFLECTION STRESS

$$S5 = EB(TP)EXP2(ET)/2(W)EXP3(CF) \quad (\text{THERMAL})$$

$$S5 = 6220 \text{ PSI}$$

$$S5 = EB(TP)EXP2(EOBE)/2(W)EXP3(CF) \quad (\text{SEISMIC-OBE})$$

$$S5 = 3109 \text{ PSI}$$

$$S5 = EB(TP)EXP2(ESSE)/2(W)EXP3(CF) \quad (\text{SEISMIC-SSE})$$

$$S5 = 6220 \text{ PSI}$$

$$S5 = EB(TP)EXP2(EV)/2(W)EXP3(CF) \quad (\text{VIBRATION})$$

$$S5 = 29 \text{ PSI}$$

2.7 BELLOWS MERIDIONAL DEFLECTION STRESS

$$S6 = 5EB(TP)(ET)/3(W)EXP2(CD) \quad (\text{THERMAL})$$

$$S6 = 149592 \text{ PSI}$$

$$S6 = 5EB(TP)(EOBE)/3(W)EXP2(CD) \quad (\text{SEISMIC-OBE})$$

$$S6 = 74770 \text{ PSI}$$

$$S6 = 5EB(TP)(ESSE)/3(W)EXP2(CD) \quad (\text{SEISMIC-SSE})$$

$$S6 = 149592 \text{ PSI}$$

$$S6 = 5EB(TP)(EV)/3(W)EXP2(CD) \quad (\text{VIBRATION})$$

$$S6 = 712 \text{ PSI}$$

2.8 TOTAL CYCLIC STRESS

CR729
PAGE 7

$$ST = (S3+S4)+(S5+S6) \quad (\text{THERMAL})^*$$

$$ST = 159182 \text{ PSI}$$

$$ST = .7(S3+S4)+(S5+S6) \quad (\text{SEISMIC-OBE})^{**}$$

$$ST = 80237 \text{ PSI}$$

$$ST = .7(S3+S4)+(S5+S6) \quad (\text{SEISMIC-SSE})^{**}$$

$$ST = 158171 \text{ PSI}$$

$$ST = .7(S3+S4)+(S5+S6) \quad (\text{VIBRATION})$$

$$ST = 3100 \text{ PSI}$$

* MODIFIED EJMA FATIGUE ANALYSIS BASED ON CYCLING PRESSURE.

** EJMA FATIGUE ANALYSIS BASED ON CONSTANT PRESSURE.

2.9 CALCULATED LIFE

$$T_f = 1.1 \text{ (INCONEL 625)}$$

$$NC = ((C)(TF)/((ST-B))\text{EXP}3.4$$

$$NC = 24125 \text{ CYCLES} \quad (\text{THERMAL})$$

$$\text{REQUIRED LIFE} = 5000 \text{ CYCLES}$$

$$NC = 2708762 \text{ CYCLES} \quad (\text{SEISMIC-OBE})$$

$$\text{REQUIRED LIFE} = 100 \text{ CYCLES}$$

$$NC = 24931 \text{ CYCLES} \quad (\text{SEISMIC-SSE})$$

$$\text{REQUIRED LIFE} = 100 \text{ CYCLES}$$

$$NC = \text{MORE THAN } 1.0\text{EXP } 8 \text{ CYCLES} \quad (\text{VIBRATION})$$

2.10

BRAID ANALYSIS

CR729
PAGE 8

WIRE DIA, D= .0200 INCHES

NUMBER OF WIRES PER BUNDLE, N= 7

NUMBER OF BUNDLES, B= 24

ANGLE FROM HOSE AXIS, X=33 DEGREES

WEIGHT PER FOOT, BW= 0.215 LBS

2.10.1 END LOAD DUE TO PRESSURE

$$F = .7854(DP)EXP2(P)$$

$$F = 41.36 \text{ LBS}$$

2.10.2 BRAID AREA, TOTAL

$$A = .7854(D)EXP2(N)(B)$$

$$A = 0.053 \text{ SQ INCHES}$$

2.10.3 BRAID STRESS

$$ST = F/ACOSX$$

$$ST = 934 \text{ PSI}$$

CODE ALLOWABLE= 18550 PSI

2.11 SPRING RATES

2.11.1 AXIAL SPRING RATE

$$KA = 1.7(NP)(EB)(DP)(TP)EXP3/N(CF)(W)EXP3$$

$$KA = 127.80 \text{ LB/IN}$$

2.11.2 OFFSET SPRING RATE

$$KO = 1.5(DP)EXP2(KA)(F1)/(L)EXP2$$

$$KO = 0.30 \text{ LB/IN}$$

2.11.3 THERMAL DEFLECTION FORCES

$$F = (KO)(DT)$$

$$DT = 3 \text{ IN.}$$

$$F = .90 \text{ LB}$$

MAXIMUM ALLOWABLE = N/A LBS

2.11.4 DEFLECTION MOMENTS

CR729
PAGE 9

$$M = (F)(L)(F2)/2$$

$$M = 16.2 \text{ IN-LB}$$

MAXIMUM ALLOWABLE = N/A IN-LB

2.12 NATURAL FREQUENCIES

2.12.1 WEIGHT OF HOSE

$$W1 = ((OD-D)N + .57(L))3.1416D(T)(.3)$$

$$W1 = 0.716 \text{ LBS}$$

2.12.2 WEIGHT OF FLUID

$$W2 = .7854(DP)EXP2(L)(.000408)$$

$$W2 = 0.004 \text{ LBS}$$

2.12.3 WEIGHT OF BRAID

$$W3 = (BW)(L)/12$$

$$W3 = 0.645 \text{ LBS}$$

2.12.4 TOTAL WEIGHT

$$W = W1 + W2 + W3$$

$$W = 1.36 \text{ LBS}$$

2.12.5 AXIAL VIBRATION (PARALLEL TO AXIS)

$$F = 9.81(KA/W)EXP.5(F3) \quad (\text{FIRST MODE})$$

$$F = 118.7 \text{ HZ}$$

$$F = 19.6(KA/W)EXP.5(F3) \quad (\text{SECOND MODE})$$

$$F = 237.3 \text{ HZ}$$

$$F = 29.2(KA/W)EXP.5(F3) \quad (\text{THIRD MODE})$$

$$F = 356.0 \text{ HZ}$$

$$F = 38.6(KA/W)EXP.5(F3) \quad (\text{FOURTH MODE})$$

$$F = 474.6 \text{ HZ}$$

2.12.6 LATERAL VIBRATION

CR729
PAGE 10

$$F = 24.8(DP/L)(KA/W)EXP.5(F4) \quad (\text{FIRST MODE})$$

$$F = 4.9 \text{ HZ}$$

$$F = 68.2(DP/L)(KA/W)EXP.5(F4) \quad (\text{SECOND MODE})$$

$$F = 13.6 \text{ HZ}$$

$$F = 133(DP/L)(KA/W)EXP.5(F4) \quad (\text{THIRD MODE})$$

$$F = 26.5 \text{ HZ}$$

$$F = 221(DP/L)(KA/W)EXP.5(F4) \quad (\text{FOURTH MODE})$$

$$F = 44.0 \text{ HZ}$$

2.13 FLOW INDUCED VIBRATION

2.13.1 FLOW VELOCITY

2.13.1.1 SYSTEM FLOW

$$Q = FR / 0 \text{ GAL/CUFT/60SEC MIN}$$

$$Q = 0.000 \text{ CUFT/SEC}$$

2.13.1.2 FLOW AREA

$$A = .7854(D)EXP2$$

$$A = 0.0013 \text{ SQFT}$$

2.13.1.3 FLOW VELOCITY

$$V = Q/A$$

$$V = 0.00 \text{ FT/SEC}$$

2.13.2 METAL MASS

$$MM = .3DP(T)3.1416(3.1416A+H-2A)(.00258)$$

$$MM = .0000031 \text{ LB-(SEC)EXP2/(IN)EXP4}$$

2.13.2.2 FLUID MASS

$$MF1 = .000408DP(H)(3.1416)(.00258)/2((2A-T(NF)))$$

$$MF1 = .0000000 \text{ LB-(SEC)EXP2/(IN)EXP4}$$

$$MF2 = .000408DP(H)EXP3(3.1416)/3DEL$$

$$MF2 = .0000000 \text{ LB-(SEC)EXP2/(IN)EXP4}$$

2.13.2.3 BELLOWS SPRING RATE

CR729
PAGE 11

FROM PARA 2.11.1

KA= 127.80 LB/IN

2.13.2.4 ELEMENTAL SPRING RATE

KE= 2NC(KA)

KE= 92015.50 LB/IN

2.13.3 FREQUENCY RANGE (FLEX HOSE)

2.13.3.1 IN-PHASE LONGITUDINAL

FR1= (2KE/(MM+MF1))EXP.5/2(3.1416)

FR1= 38453.7 HZ

2.13.3.2 OUT-PHASE LONGITUDINAL

FR2= (2KE/(MM+MF2))EXP.5/2(3.1416)

FR2= 38330.1 HZ

2.13.3.3 FIRST BENDING MODE

FB1= (8KE/(MM+MF2))EXP.5/2(3.1416)

FB1= 76660.1 HZ

2.13.4 VORTEX SHEDDING VELOCITY

2.13.4.1 PITCH (LAMDA)= 0.100 INCHES

CONVOLUTION WIDTH (SIGMA)= 0.066 INCHES

LAMDA/SIGMA= 1.515

FROM FIGURE 1

UPPER STROUHAL NUMBER, SU= .40094

LOWER STROUHAL NUMBER, SL= .16958

2.13.4.2 FOR FR1

VU= FR1(SIGMA)/SU

VU= 6330. FT/SEC

VL= FR1(SIGMA)/SL

VL= 14966. FT/SEC

HOSE ASSEMBLY P/N 78153

3.0 INSTALLATION CONFIGURATIONS & MOTIONS




FIGURE 1

2.13.4.3 FOR FR2

CR729
PAGE 12

$$VU = FR2(SIGMA)/SU$$

$$VU = 6310. \text{ FT/SEC}$$

$$VL = FR2(SIGMA)/SL$$

$$VL = 14918. \text{ FT/SEC}$$

2.13.4.4 FOR FB1

$$VU = FB1(SIGMA)/SU$$

$$VU = 12619. \text{ FT/SEC}$$

$$VL = FB1(SIGMA)/SL$$

$$VL = 29835. \text{ FT/SEC}$$

NO OVERLAP OCCURS BETWEEN THE BELLOWS HOSE FLOW AND THE
VORTEX SHEDDING RANGE THEREFORE NO ADDITIONAL ANALYSIS
IS REQUIRED ON HOSE ASSEMBLY FOR INDUCED VIBRATION

2.14. PRESSURE DROP

2.14.1 LOSS = (FRICTION FACTOR)(L)(DENSITY)(V)EXP2/2D(G)

LOSS = 0.00 PSI/FT

PRESSURE LOSS ALLOWABLE = N/A

3.0.1. TYPICAL MOTIONS

Using configuration (D) (See Figure I) measured center line bend radii as hose was moved thru required motions:

NOTE: Configuration (D) indicated greatest changes.


Condition I: Free end moves up 5 in. (+Y), center radius changes from 7.5 in. (installed) to 4.5 inches.

Condition II: Free end moves down 5 in. (-Y), center radius changes from 7.5 in. to 10.5 in. and straight ends to 11.0 in.

Condition III: Free end moves horizontally ($\pm X$) straight hose develops same 7.5 in. radius and radius becomes straight.

Condition IV: Free end moves out of paper (Z), radius does not change and 90° to radius, hose develops 2nd radius where hose goes into offset.

3.0.2. MOTIONS DURING ANGULATION (SMALL PORTION OF HOSE)



$$\alpha = \frac{l}{.01745 r}$$

3.0.3. ANGLE CHANGE WHEN PORTION OF HOSE CHANGES RADIUS LENGTH

$$\Delta \alpha = \left(\frac{l}{.01745 r_1} - \frac{l}{.01745 r_2} \right) = \frac{l}{.01745} \left(\frac{1}{r_1} - \frac{1}{r_2} \right)$$

NOTE: When hose is straight, r_2 is considered infinity and fraction becomes \approx zero.

NUMBER OF CONVOLUTIONS IN SMALL PORTION

$$N = \frac{l}{g}$$

3.0.4 MOTION PER CONVOLUTION DUE TO ANGULATION

$$\begin{aligned}
 e_{\theta} &= \frac{d_p \cdot 0.01745\theta}{2 N'} \quad (\text{EJMA EQ 3}) \\
 &= \frac{d_p (.01745) \cdot \frac{\ell}{q} \left(\frac{1}{r_1} - \frac{1}{r_2} \right)}{2} \\
 &= .5 d_p q \left(\frac{1}{r_1} - \frac{1}{r_2} \right) \text{ (in.)}
 \end{aligned}$$

3.0.4.1. MOTION PER CONVOLUTION DUE TO ANGULATION FOR CONDITION I

$$e_{\theta} = .5 (.592) (.10) \left[\frac{1}{4.5} - \frac{1}{7.5} \right] = 2.63 \times 10^{-3}$$

3.0.4.2. MOTION PER CONVOLUTION DUE TO ANGULATION FOR CONDITION II

$$e_{\theta} = .5 (.592) (.1) \left[\frac{1}{7.5} - \frac{1}{10.5} \right] = 4.13 \times 10^{-3}$$

Or,

$$e_{\theta} = .5 (.592) (.1) \left[\frac{1}{11.0} - 0 \right] = 2.69 \times 10^{-3}$$

3.0.4.3. MOTION PER CONVOLUTION DUE TO ANGULATION FOR CONDITION III

$$e_{\theta} = .5 (.592) (.1) \left[\frac{1}{7.5} - 0 \right] = 3.94 \times 10^{-3}$$

3.0.4.4. MOTION PER CONVOLUTION DUE TO OFFSET FOR
CONDITION IV.

$$e_y = \frac{3 D_p D_T}{(N_c)(LL)}$$

$$= \frac{3 (.592)(5)}{(360)(36)}$$

$$= 6.8 \times 10^{-4}$$

3.0.4.5. THE WORST CASE FOR EQUIVALENT THERMAL OFFSET
MOTION SHALL BE UNDER CONDITION III.

$$D_T = \frac{e_0 (N_c)(LL)}{3 D_p}$$

$$= \frac{(3.94 \times 10^{-3})(360)(36)}{3 (.592)}$$

$$= 28.75 \text{ IN. (USE IN COMPUTER PROGRAM)}$$

3.1. FOR SEISMIC MOTION, THE WORST CASE SHALL BE
FREE END MOVES HORIZONTALLY ± 1 IN. STRAIGHT HOSE
DEVELOPS SAME 7.5 IN. RADIUS AND RADIUS
BECOMES STRAIGHT.

$$e_0 = .5 (.592)(.1) \left[\frac{1}{7.5} - 0 \right] = 3.94 \times 10^{-3}$$

$$DSSE = 28.75 \text{ IN.}$$

$$DOBE = 14.37 \text{ IN.}$$

METAL *Bellows* CORPORATION

20977 KNAPP STREET
CHATSORTH, CALIFORNIA 91311

ENGINEER

F. Shen

REFERENCE NUMBER

PIN 78153

DATE

9/19/80

CUSTOMER

T. V. A.

PAGE OF

17

3.2. MOVEMENT FOR VIBRATION OFFSET:

$$g = .0511 f^2 D$$

$$0.5 = 0.0511 (10)^2 D$$

$$D = .0978 \text{ IN.}$$

$$DV = \sqrt{.0978^2 + .0978^2}$$

$$= .137 \text{ IN.}$$

AT 10 HZ (WORST CONDITION)

4.0 LOADING COMBINATION:

THE WORST CASE FOR THE FORCE & MOMENT SHALL BE UNDER THE INSTALLATION CONFIGURATION (F)

4.1. SHEAR LOAD

END TUBE	= .27 LB
ADAPTOR	= .044 LB
SPRING	= .12 LB
HOSE & BRAID .5 (.716 + .645)	= .68 LB
FLUID IN HOSE .5 (.004)	= .002 LB

$$\frac{1}{2} \text{ DEAD WEIGHT} = 1.066 \text{ LB}$$

4.2. SEISMIC FORCES: (SSE)

4.2.1. DUE TO INERTIA:

$$F_y = 1.066 \times 2g's = 2.132 \text{ LB}$$

$$F_z = 1.066 \times 3g's = 3.198 \text{ LB}$$

$$F = \sqrt{2.132^2 + 3.198^2} \quad \text{REF. PARA. 4.1}$$
$$= 3.844 \text{ LB} \quad (\text{SHEAR})$$

4.2.2. DUE TO MOVEMENT:

$$F_y = F_z = .30 (1.0)$$

$$= 0.3 \text{ LB}$$

$$F = \sqrt{0.3^2 + 0.3^2} = .424 \text{ IN.}$$

METAL *Bellows* CORPORATION

20977 KNAPP STREET
CHATSORTH, CALIFORNIA 91311

ENGINEER

F. J. Allen

REFERENCE NUMBER

P/N 7815-3

DATE

9/19/80

CUSTOMER

T. V. A.

PAGE OF

19

4.3 SEISMIC FORCE : (OBE)

4.3.1. DUE TO INERTIA:

$$F_y = 1.066 \times 1.5 g = 1.599 \text{ LB}$$

$$F_z = 1.066 \times 2.0 g = 2.132 \text{ LB}$$

$$F = \sqrt{1.599^2 + 2.132^2}$$
$$= 2.66 \text{ LB (SHEAR)}$$

4.3.2. DUE TO MOVEMENT:

$$F_y = F_z = .30 (.5)$$
$$= .15 \text{ LB}$$

$$F = \sqrt{.15^2 + .15^2}$$
$$= .212 \text{ LB}$$

4.4. VIBRATION FORCES

4.4.1. DUE TO INERTIA:

$$F_y = F_z = 1.066 (.5 g's)$$
$$= .533 \text{ LB}$$

$$F = \sqrt{.533^2 + .533^2}$$
$$= .753 \text{ LB}$$

METAL *Bellows* CORPORATION

20977 KNAPP STREET
CHATSWORTH, CALIFORNIA 91311

ENGINEER

F. Shen

REFERENCE NUMBER

P/N 78153

DATE

9/19/80

CUSTOMER

T.V.A

PAGE OF

20

4.5. TOTAL SHEAR FORCE,

4.5.1. NORMAL CONDITION:

$$F = \text{DEAD WEIGHT} + \text{THERMAL EXPANSION} + \text{VIBRATION}$$

$$= 1.066 + .90 + .753$$

$$= 2.719 \text{ LB}$$

REF. PARA. 4.1. 2.11.3

4.4.1.

4.5.2. UPSET CONDITION:

$$F = \text{NORMAL} + \text{OBE}$$

$$= 2.719 + (2.66 + .212)$$

$$= 5.591 \text{ LB}$$

REF. PARA 4.5.1

4.3.1

4.3.2

4.5.3. EMERGENCY CONDITION:

$$F = \text{NORMAL} + \text{SSE}$$

$$= 2.719 + (3.844 + .424)$$

$$= 6.987 \text{ LB}$$

REF. PARA. 4.5.1

4.2.1

4.2.2

4.6. DYNAMIC MOMENT

MOMENT ARMS:

END TUBE	.22 LB	x 1.19 IN.	= .26 IN-LB
ADAPTOR	.044 LB	x 2.76 IN.	= .12 IN-LB
SPRING	.12 LB	x 5.38 IN.	= .65 IN-LB
HOSE & BRAID	.68 LB	x 12.13 IN.	= 8.25 IN-LB
FLUID IN HOSE	.002 LB	x 3.13 IN.	= .006 IN-LB
			<hr/>
			9.286 IN-LB

4.6.1. SEISMIC MOMENT: (SSE)

$$M_y = 9.286 \times 2 g's = 18.572 \text{ LB}$$

$$M_z = 9.286 \times 3 g's = 27.858 \text{ LB}$$

REF. PARA. 4.6.

$$M = \sqrt{M_y^2 + M_z^2}$$

$$= 33.481 \text{ IN-LB}$$

4.6.2. SEISMIC MOMENT: (OBE)

$$M_y = 9.286 \times 1.5 g's = 13.93 \text{ LB}$$

$$M_z = 9.286 \times 2.0 g's = 18.57 \text{ LB}$$

$$M = \sqrt{13.93^2 + 18.57^2}$$

$$= 23.214 \text{ IN-LB}$$

REF. PARA. 4.6

METAL *Bellows* CORPORATION

20977 KNAPP STREET
CHATSWORTH, CALIFORNIA 91311

ENGINEER

F. Shen

REFERENCE NUMBER

P/N 78153

DATE

9/19/80

CUSTOMER

T. V. A.

PAGE OF

22

4.6.3 MOMENT DUE TO VIBRATION:

$$M_y = M_z = 9.286 \times .5g's \\ = 4.643 \text{ IN-LB}$$

$$M = \sqrt{4.643^2 + 4.643^2} \\ = 6.566 \text{ IN-LB}$$

4.6.4 MOMENT AT TUBE

HOSE FORCE \times L (HOSE END TO TUBE)

4.6.4.1. .90 LB \times 3.13 IN. = 2.817 IN-LB THERMAL

4.6.4.2. .424 LB \times 3.13 IN. = 1.327 IN-LB SSE
REF. PARA. 4.2.2

4.6.4.3. .212 LB \times 3.13 IN. = .663 IN-LB OBE
REF. PARA. 4.3.2.

4.7. TOTAL MOMENT

4.7.1. NORMAL CONDITION

M = DEAD WEIGHT + THERMAL + VIBRATION

$$= 9.286 + (16.2 + 2.817) + 6.566$$

$$= 34.869 \text{ IN-LB}$$

REF. PARA 4.6.4

2.11.4

4.7.2. UPSET CONDITION

4.6.3

M = NORMAL + OBE

$$= 34.869 + (23.214 + .663)$$

$$= 58.746 \text{ IN-LB}$$

REF. PARA. 4.7.1

4.6.2

4.6.4.3

METAL *Bellows* CORPORATION

20977 KNAPP STREET
CHATSORTH, CALIFORNIA 91311

ENGINEER

F. J. Hen

REFERENCE NUMBER

P/N 78153

DATE

9/19/80

CUSTOMER

T. V. A.

PAGE OF

23

4.7.3. EMERGENCY CONDITION

$M = \text{NORMAL} + \text{SSE}$

$$= 34.869 + (33.481 + 1.327)$$

$$= 69.672 \text{ IN-LB}$$

REF. PARA 4.7.1.

4.6.1

4.6.4.3

5.0 MOTION AT CENTER DUE TO RESPONSE FROM SEISMIC
INPUT

5.0.1. ASSUMPTIONS

- (A) SEISMIC INPUT OF 3g
 (B) AMPLIFICATION FACTOR IS DERIVED FROM
 RESULTS OF TEST DATA IS CONSIDERED
 CONSERVATIVE

FREQ	INPUT	AMPLIFICATION	OUTPUT	DISPL.	EXCUR.
4.2	g		g	IN.	IN.
4.9	3	2	6	4.89	±2.445

5.0.2. EQUIVALENT AXIAL MOTION AT CENTER:

$$e = \frac{3 D_p \Delta}{(.5N) (.5L)} = \frac{3 (.592) (\pm 2.445)}{(.5) (360) (.5) (36)} = \pm .00134$$

5.0.3. MOTION STRESS AT CENTER:

$$S_s = \frac{E_b t_p^2 e}{2 w^3 c_f}$$

$$= \frac{(29 \times 10^6) (.014)^2}{2 (.108)^3 (1.60)} (\pm .00134) = \pm 1,889 \text{ PSI}$$

$$S_b = \frac{5 E_b t_p e}{3 w^2 c_d}$$

$$= \frac{5 (29 \times 10^6) (.014)}{3 (.108)^2 (1.65)} (\pm .00134)$$

$$= \pm 47,113 \text{ PSI}$$

METAL *Bellows* CORPORATION

20977 KNAPP STREET
CHATSORTH, CALIFORNIA 91311

ENGINEER

F. Allen

REFERENCE NUMBER

P/N 78153

DATE

9/19/80

CUSTOMER

T. V. A.

PAGE OF

25

5.0.9. TOTAL STRESS

$$\begin{aligned} S_T &= .7 (S_3 + S_4) + S_5 + S_6 \\ &= .7 (556 + 2812) + (3778 + 94226) \\ &= 100,361 \text{ PSI} \end{aligned}$$

5.0.5. CYCLE LIFE

$$\begin{aligned} N_c &= \left(\frac{T_f 1.86 \times 10^6}{S_T - 54000} \right)^{3.4} \\ &= 390,984 \text{ CYCLES} \end{aligned}$$

$T_f = 1.1$

ADEQUATE

METAL *Bellows* CORPORATION20977 KNAPP STREET
CHATSWORTH, CALIFORNIA 91311

ENGINEER

F. Hen

REFERENCE NUMBER

P/N 78153

DATE

9/19/80

CUSTOMER

T. V. A

PAGE OF

26

6.0 PIPING:

6.0.1. ADAPTORS: (P/N 74991)

$$O.D. = .71 \begin{matrix} +.00 \\ -.01 \end{matrix} \text{ IN.}$$

$$I.D. = .507 \begin{matrix} +.003 \\ -.000 \end{matrix} \text{ IN.}$$

$$t_{\min} = .095 \text{ IN.}$$

$$t_{\text{REQD}} = \frac{P D}{2(S + P y)} + A \quad (\text{NC-3641.1})$$

$$= \frac{150 (.71)}{2 [27500 + 150 (.4)]} + 0$$

$$= .00193 \text{ IN.}$$

$$t_{\min} > t_{\text{REQD}}$$

DESIGN IS ADEQUATE

6.0.2. TUBE: (P/N 78157)

$$O.D. = .375 \begin{matrix} +.00 \\ -.01 \end{matrix} \text{ IN.}$$

$$I.D. = .312 \begin{matrix} +.002 \\ -.000 \end{matrix} \text{ IN.}$$

$$t_{\min} = .0255 \text{ IN.}$$

$$t_{\text{REQD}} = \frac{P D}{2(S + P y)} + A \quad (\text{NC-3641.1})$$

$$= \frac{150 (.5)}{2 [18300 + 150 (.4)]} + 0$$

$$= .002 \text{ IN.}$$

$$t_{\min} > t_{\text{REQD}}$$

DESIGN IS ADEQUATE

7.0 LOADING: (AT VERY END OF TUBE)

7.0.1 SUSTAINED LOAD: (UPSET CONDITION)

$$S_{SL} = \frac{P D_o^*}{4 t_h^*} + \frac{.75 L M_A}{Z} \leq S_A \quad (\text{NC-3652.1})$$

WHERE: M_A = MOMENT DUE TO UPSET CONDITION

$$= \frac{150 (1.375)}{4 (1.063)} + \frac{.75 (1.8) (58.746)}{\pi (1.156)^2 (1.063)}$$

$$= 223 + 16465 \text{ (psi)}$$

$$= 16.688 \text{ ksi} < 18.3 \text{ ksi}$$

REF. PARA. 4.7.2.

7.0.2 OCCASIONAL LOAD

$$S_{OL} = \frac{P D_o^*}{4 t_h^*} + \frac{.75 L (M_A + M_B)}{Z} \leq S_A (1.2) \quad (\text{NC-3652.2})$$

$$= \frac{150 (1.375)}{4 (1.063)} + \frac{.75 (1.8) (69.677)}{\pi (1.156)^2 (1.063)}$$

$$= 223 + 19529 \text{ (psi)}$$

$$= 19.752 \text{ ksi} < 21.96 \text{ ksi}$$

 $M_A + M_B$ = MOMENT DUE TO EMERGENCY CONDITION

REF. PARA. 4.7.3.

* CALCULATION WAS BASED ON TUBE END

(.375" O.D., .063" THK GRES 304 PER SA 479, 213)

PROPRIETARY INFORMATION

NOTICE

THE ATTACHED DOCUMENT CONTAINS "PROPRIETARY INFORMATION" AND SHOULD BE HANDLED AS NRC "OFFICIAL USE ONLY" INFORMATION. IT SHOULD NOT BE DISCUSSED OR MADE AVAILABLE TO ANY PERSON NOT REQUIRING SUCH INFORMATION IN THE CONDUCT OF OFFICIAL BUSINESS AND SHOULD BE STORED, TRANSFERRED, AND DISPOSED OF BY EACH RECIPIENT IN A MANNER WHICH WILL ASSURE THAT ITS CONTENTS ARE NOT MADE AVAILABLE TO UNAUTHORIZED PERSONS.

COPY NO. _____

DOCKET NO. _____

CONTROL NO. _____

REPORT NO. _____

REC'D W/LTR DTD. _____