



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

April 6, 2011

Mr. Matthew W. Sunseri
President and Chief Executive Officer
Wolf Creek Nuclear Operating Corporation
Post Office Box 411
Burlington, KS 66839

SUBJECT: WOLF CREEK GENERATING STATION - ISSUANCE OF AMENDMENT RE:
CHANGES TO TECHNICAL SPECIFICATION (TS) 5.5.9, "STEAM GENERATOR
(SG) PROGRAM," AND TS 5.6.10, "STEAM GENERATOR TUBE INSPECTION
REPORT" (TAC NO. ME5121)

Dear Mr. Sunseri:

The U.S. Nuclear Regulatory Commission (the Commission) has issued the enclosed Amendment No. 195 to Renewed Facility Operating License No. NPF-42 for the Wolf Creek Generating Station (WCGS). The amendment consists of changes to the Technical Specifications (TSs) in response to your application dated November 30, 2010.

The amendment revises TS 5.5.9, "Steam Generator (SG) Program," to exclude portions of the tube below the top of the steam generator tubesheet from periodic steam generator tube inspections during Refueling Outage 18 and the subsequent operating cycle. In addition, the amendment revises TS 5.6.10, "Steam Generator Tube Inspection Report," to remove a reference to the previous interim alternate repair criteria and to provide reporting requirements specific to the temporary alternate repair criteria.

A copy of our related Safety Evaluation is enclosed. The Notice of Issuance will be included in the Commission's next biweekly *Federal Register* notice.

Sincerely,

A handwritten signature in black ink that reads "James R. Hall".

James R. Hall, Senior Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-482

Enclosures:

1. Amendment No. 195 to NPF-42
2. Safety Evaluation

cc w/encls: Distribution via Listserv



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

WOLF CREEK NUCLEAR OPERATING CORPORATION

WOLF CREEK GENERATING STATION

DOCKET NO. 50-482

AMENDMENT TO RENEWED FACILITY OPERATING LICENSE

Amendment No. 195
License No. NPF-42

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the Wolf Creek Generating Station (the facility) Renewed Facility Operating License No. NPF-42 filed by the Wolf Creek Nuclear Operating Corporation (the Corporation), dated November 30, 2010, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and Paragraph 2.C.(2) of Renewed Facility Operating License No. NPF-42 is hereby amended to read as follows:

- (2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 195, and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated in the license. The Corporation shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. The license amendment is effective as of its date of issuance and shall be implemented prior to MODE 4 entry during startup from Refueling Outage 18.

FOR THE NUCLEAR REGULATORY COMMISSION



Michael T. Markley, Chief
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Renewed Facility
Operating License and
Technical Specifications

Date of Issuance: April 6, 2011

ATTACHMENT TO LICENSE AMENDMENT NO. 195
RENEWED FACILITY OPERATING LICENSE NO. NPF-42
DOCKET NO. 50-482

Replace the following pages of the Renewed Facility Operating License No. NPF-42 and Appendix A Technical Specifications with the attached revised pages. The revised pages are identified by amendment number and contain marginal lines indicating the areas of change. The corresponding overleaf pages are provided to maintain document completeness.

Renewed Facility Operating License

<u>REMOVE</u>	<u>INSERT</u>
4	4

Technical Specifications

<u>REMOVE</u>	<u>INSERT</u>
5.0-12	5.0-12
5.0-13	5.0-13
5.0-28	5.0-28

- (5) The Operating Corporation, pursuant to the Act and 10 CFR Parts 30, 40 and 70, to receive, possess, and use in amounts as required any byproduct, source or special nuclear material without restriction to chemical or physical form, for sample analysis or instrument calibration or associated with radioactive apparatus or components; and
- (6) The Operating Corporation, pursuant to the Act and 10 CFR Parts 30, 40 and 70, to possess, but not separate, such byproduct and special nuclear materials as may be produced by the operation of the facility.
- C. This renewed operating license shall be deemed to contain and is subject to the conditions specified in the Commission's regulations in 10 CFR Chapter I and is subject to all applicable provisions of the Act and to the rules, regulations, and orders of the Commission, now or hereafter in effect; and is subject to the additional conditions specified or incorporated below:
- (1) Maximum Power Level
- The Operating Corporation is authorized to operate the facility at reactor core power levels not in excess of 3565 megawatts thermal (100% power) in accordance with the conditions specified herein.
- (2) Technical Specifications and Environmental Protection Plan
- The Technical Specifications contained in Appendix A, as revised through Amendment No. 195, and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated in the license. The Corporation shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.
- (3) Antitrust Conditions
- Kansas Gas & Electric Company and Kansas City Power & Light Company shall comply with the antitrust conditions delineated in Appendix C to this license.
- (4) Environmental Qualification (Section 3.11, SSER #4, Section 3.11, SSER #5)*
- Deleted per Amendment No. 141.

*The parenthetical notation following the title of many license conditions denotes the section of the supporting Safety Evaluation Report and/or its supplements wherein the license condition is discussed.

5.5 Programs and Manuals

5.5.9 Steam Generator (SG) Program (continued)

3. The operational LEAKAGE performance criterion is specified in LCO 3.4.13, "RCS Operational LEAKAGE."
- c. Provisions for SG tube repair criteria. Tubes found by inservice inspection to contain flaws with a depth equal to or exceeding 40% of the nominal tube wall thickness shall be plugged.

The following alternate tube repair criteria shall be applied as an alternative to the 40% depth-based criteria:

1. For Refueling Outage 18 and the subsequent operating cycle, tubes with service-induced flaws located greater than 15.2 inches below the top of the tubesheet do not require plugging. Tubes with service-induced flaws located in the portion of the tube from the top of the tubesheet to 15.2 inches below the top of the tubesheet shall be plugged upon detection.

(continued)

5.5 Programs and Manuals

5.5.9 Steam Generator (SG) Program (continued)

- d. Provisions for SG tube inspections. Periodic SG tube inspections shall be performed. The number and portions of the tubes inspected and methods of inspection shall be performed with the objective of detecting flaws of any type (e.g., volumetric flaws, axial and circumferential cracks) that may be present along the length of the tube, from the tube-to-tubesheet weld at the tube inlet to the tube-to-tubesheet weld at the tube outlet, and that may satisfy the applicable tube repair criteria. For Refueling Outage 18 and the subsequent operating cycle, the portion of the tube below 15.2 inches from the top of the tubesheet is excluded from this requirement. The tube-to-tubesheet weld is not part of the tube. In addition to meeting the requirements of d.1, d.2, and d.3 below, the inspection scope, inspection methods, and inspection intervals shall be such as to ensure that SG tube integrity is maintained until the next SG inspection. An assessment of degradation shall be performed to determine the type and location of flaws to which the tubes may be susceptible and, based on this assessment, to determine which inspection methods need to be employed and at what locations.
1. Inspect 100% of the tubes in each SG during the first refueling outage following SG replacement.
 2. Inspect 100% of the tubes at sequential periods of 120, 90, and, thereafter, 60 effective full power months. The first sequential period shall be considered to begin after the first inservice inspection of the SGs. In addition, inspect 50% of the tubes by the refueling outage nearest the midpoint of the period and the remaining 50% by the refueling outage nearest the end of the period. No SG shall operate for more than 48 effective full power months or two refueling outages (whichever is less) without being inspected.
 3. If crack indications are found in any portion of the SG tube not excluded above, then the next inspection for each SG for the degradation mechanism that caused the crack indication shall not exceed 24 effective full power months or one refueling outage (whichever is less). If definitive information, such as from examination of a pulled tube, diagnostic non-destructive testing, or engineering evaluation indicates that a crack-like indication is not associated with a crack(s), then the indication need not be treated as a crack.
- e. Provisions for monitoring operational primary to secondary LEAKAGE.

(continued)

5.6 Reporting Requirements

5.6.10 Steam Generator Tube Inspection Report

A report shall be submitted within 180 days after the initial entry into MODE 4 following completion of an inspection performed in accordance with the Specification 5.5.9, Steam Generator (SG) Program. The report shall include:

- a. The scope of inspections performed on each SG;
- b. Active degradation mechanisms found;
- c. Nondestructive examination techniques utilized for each degradation mechanism;
- d. Location, orientation (if linear), and measured sizes (if available) of service induced indications;
- e. Number of tubes plugged during the inspection outage for each active degradation mechanism;
- f. Total number and percentage of tubes plugged to date;
- g. The results of condition monitoring, including the results of tube pulls and in-situ testing;
- h. Following completion of an inspection performed in Refueling Outage 18 (and any inspections performed in the subsequent operating cycle) the primary to secondary LEAKAGE rate observed in each SG (if it is not practical to assign the LEAKAGE to an individual SG, the entire primary to secondary LEAKAGE should be conservatively assumed to be from one SG) during the cycle preceding the inspection which is the subject of the report;
- i. Following completion of an inspection performed in Refueling Outage 18 (and any inspections performed in the subsequent operating cycle) the calculated accident induced leakage rate from the portion of the tubes below 15.2 inches from the top of the tubesheet for the most limiting accident in the most limiting SG. In addition, if the calculated accident induced leakage rate from the most limiting accident is less than 2.50 times the maximum operational primary to secondary leak rate, the report should describe how it was determined; and
- j. Following completion of an inspection performed in Refueling Outage 18 (and any inspections performed in the subsequent operating cycle) the results of monitoring for the tube axial displacement (slippage). If slippage is discovered, the implications of discovery and corrective action shall be provided.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NO. 195 TO

RENEWED FACILITY OPERATING LICENSE NO. NPF-42

WOLF CREEK NUCLEAR OPERATING CORPORATION

WOLF CREEK GENERATING STATION

DOCKET NO. 50-482

1.0 INTRODUCTION

By letter dated November 30, 2010 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML103410455) (Reference 1), Wolf Creek Nuclear Operating Corporation (WCNOC, the licensee), submitted a license amendment request (LAR) to the U.S. Nuclear Regulatory Commission (NRC) to revise the Technical Specifications (TS) for Wolf Creek Generating Station (WCGS). The request proposed changes to the inspection scope and repair requirements of TS 5.5.9, "Steam Generator (SG) Program," and to the reporting requirements of TS 5.6.10, "Steam Generator Tube Inspection Report." The proposed changes would establish interim SG tube alternate criteria for tubing flaws located in the lower region of the tubesheet and would be applicable only to Refueling Outage 18 and the subsequent operating cycle. The proposed interim SG tube alternate criteria would replace similar, existing criteria that were applicable for Refueling Outage 17 and the subsequent operating cycle.

2.0 BACKGROUND

WCGS has four Model F SGs that were designed and fabricated by Westinghouse. There are 5,626 Alloy 600 tubes in each SG, each with an outside diameter of 0.688 inches and a nominal wall thickness of 0.040 inches. The thermally treated tubes are hydraulically expanded for the full depth of the 21-inch tubesheet and are welded to the tubesheet at each tube end. Until the fall of 2004, no instances of stress-corrosion cracking affecting the tubesheet region of thermally treated Alloy 600 tubing had been reported at any nuclear power plants in the United States.

In the fall of 2004, crack-like indications were found in tubes in the tubesheet region of Catawba Nuclear Station, Unit 2 (Catawba), which has Westinghouse Model D5 SGs. Like WCGS, the Catawba SGs use thermally treated Alloy 600 tubing that is hydraulically expanded against the tubesheet. The crack-like indications at Catawba were found in a tube overexpansion (OXP), in the tack expansion region, and near the tube-to-tubesheet (T/TS) weld. An OXP is created when the tube is expanded into a tubesheet bore hole that is not perfectly round. These

out-of-round conditions were created during the tubesheet drilling process by conditions such as drill bit wandering or chip gouging. The tack expansion is an approximately 1-inch long expansion at each tube end. The purpose of the tack expansion is to facilitate performing the T/TS weld, which is made prior to the hydraulic expansion of the tube over the full tubesheet depth.

Since the initial findings at Catawba in the fall of 2004, other nuclear plants have found crack-like indications in tubes within the tubesheet as well. These plants include Braidwood Station, Unit 2; Byron Station, Unit No. 2; Comanche Peak Nuclear Power Plant, Unit 2; Surry Power Station, Unit No. 2; Vogtle Electric Generating Plant, Unit 1; and WCGS. Most of the indications were found in the tack expansion region near the tube-end welds and were a mixture of axial and circumferential primary-water stress-corrosion cracking.

On February 21, 2006, the licensee for WCGS submitted an LAR that would permanently limit the scope of inspections required for tubes within the tubesheet (Reference 2). The LAR was based on an analysis performed by Westinghouse Electric Company LLC (Westinghouse) that provided a technical basis for permanently limiting the scope of inspections required for tubes within the tubesheet. After three requests for additional information (RAIs) and several meetings, the NRC staff informed the licensee during a phone call on January 3, 2008, that it had not provided sufficient information to allow the staff to review and approve the permanent LAR; therefore, the licensee withdrew the LAR (Reference 3). In a letter dated February 28, 2008 (Reference 4), the NRC staff identified the specific issues that needed to be addressed to support any future request for a permanent amendment, which included but were not limited to, thermal expansion coefficients, crevice pressure assumptions, uncertainty models, acceptance standards for probabilistic assessment, and leakage resistance.

After withdrawal of the first LAR requesting permanent changes in 2008, industry addressed many questions posed by the NRC in Reference 4 about the technical analysis (referred to as H*), and improved the finite element modeling used in the analysis. A second LAR for permanent changes that addressed the issues identified by the staff was submitted by the licensee on May 19, 2009 (Reference 5). Responses to NRC staff RAIs were supplied in References 6 and 7. During the RAI response review, the staff identified a new technical issue relating to tubesheet bore eccentricity that could not be resolved in time to support approval of the permanent LAR; consequently, the licensee modified its LAR in a letter dated September 15, 2009, such that the proposed changes would only be applicable for one inspection cycle (Reference 8). The revised LAR applied only to Refueling Outage 17 and the subsequent operating cycle for WCGS.

The NRC staff approved the revised amendment request in Reference 9. The accompanying safety evaluation concluded that the staff did not have sufficient information to determine whether the tubesheet bore displacement eccentricity had been addressed in a conservative fashion and, thus, the staff did not have an adequate basis to approve a permanent H* amendment at that time. The staff further concluded that notwithstanding any potential non-conservatism in the calculated H* distance which may be associated with the eccentricity issue, there is sufficient conservatism embodied in the proposed H* distances to ensure for at least one operating cycle (one fuel cycle) that tube structural and leakage integrity will be maintained with structural safety.

margins consistent with the design basis and with leakage integrity within assumptions employed in the licensing basis accident analyses, without undue risk to public health and safety.

Subsequent analyses by industry to address the NRC staff's concerns revealed that tubesheet bore eccentricity per se did not have a significant bearing on the outcome of the H* analyses. However, these analyses also revealed a significant shortcoming in how displacements from the three-dimensional (3-D) finite element model of the lower SG assembly were being applied to the T/TS interaction model which was based on thick-shell equations. The industry developed a new T/TS interaction model to address this shortcoming and the H* analyses were updated accordingly. This more recent background is discussed in more detail as part of the staff's technical evaluation in Section 4.0 of this safety evaluation. Details of these more recent analyses became available for NRC staff review too late to support applications for a permanent H* amendment in the spring or fall of 2011. For this reason, the subject amendment request is for an interim H* amendment, applicable to Refueling Outage 18 and the subsequent operating cycle at WCGS.

3.0 REGULATORY EVALUATION

The requirements related to the content of the TSs are established in Title 10 of the *Code of Federal Regulations* (10 CFR) 50.36 "Technical specifications." Pursuant to 10 CFR 50.36, TSs are required to include items in the following five categories related to station operation: (1) safety limits, limiting safety system settings, and limiting control settings; (2) limiting conditions for operation (LCOs); (3) surveillance requirements; (4) design features; and (5) administrative controls. The rule does not specify the particular requirements to be included in a plant's TSs. In 10 CFR 50.36(c)(5), administrative controls are stated to be, "the provisions relating to organization and management, procedures, recordkeeping, review and audit, and reporting necessary to assure the operation of the facility in a safe manner." This also includes the programs established by the licensee, and listed in the administrative controls section of the TSs, for the licensee to operate the facility in a safe manner. For WCGS, the requirements for performing SG tube inspections and repair are in TS 3.4.13, "RCS [Reactor Coolant System] Operational LEAKAGE," and TS 5.5.9, and the requirements for reporting the SG tube inspections and repair are in TS 5.6.10.

The TSs for all pressurized-water reactor (PWR) plants require that an SG program be established and implemented to ensure that SG tube integrity is maintained. For WCGS, SG tube integrity is maintained by meeting the performance criteria specified in TS 5.5.9.b for structural and leakage integrity, consistent with the plant design and licensing basis. TS 5.5.9.a requires that a condition monitoring assessment be performed during each outage in which the SG tubes are inspected, to confirm that the performance criteria are being met. TS 5.5.9.d includes provisions regarding the scope, frequency, and methods of SG tube inspections. These provisions require that the inspections be performed with the objective of detecting flaws of any type that may be present along the length of a tube, from the T/TS weld at the tube inlet to the T/TS weld at the tube outlet, and that may satisfy the applicable tube repair criteria. The applicable tube repair criteria, specified in TS 5.5.9.c., are that tubes found by inservice inspection to contain flaws with a depth equal to or exceeding 40 percent of the nominal wall

thickness shall be plugged, unless the tubes are permitted to remain in service through application of the alternate repair criteria provided in TS 5.5.9.c.

The SG tubes are part of the reactor coolant pressure boundary (RCPB) and isolate fission products in the primary coolant from the secondary coolant and the environment. For the purposes of this safety evaluation, SG tube integrity means that the tubes are capable of performing this safety function in accordance with the plant design and licensing basis. The WCGS Updated Safety Analysis Report states that the facility design complies with the requirements of the General Design Criteria (GDC) in Appendix A to 10 CFR Part 50. These requirements state that the RCPB shall have "an extremely low probability of abnormal leakage...and of gross rupture" (GDC 14), "shall be designed with sufficient margin" (GDCs 15 and 31), shall be of "the highest quality standards practical" (GDC 30), and shall be designed to permit "periodic inspection and testing...to assess...structural and leaktight integrity" (GDC 32). To this end, 10 CFR 50.55a, "Codes and standards," specifies that components which are part of the RCPB must meet the requirements for Class 1 components in Section III of the American Society of Mechanical Engineers Boiler and Pressure Vessel Code (ASME Code), except as provided in 10 CFR 50.55a(c)(2), (3), and (4). Section 50.55a further requires that throughout the service life of PWR facilities like WCGS, ASME Code Class 1 components meet the Section XI requirements of the ASME Code to the extent practical, except for design and access provisions, and pre-service examination requirements. This requirement includes the inspection and repair criteria of Section XI of the ASME Code. The Section XI requirements pertaining to inservice inspection of SG tubing are augmented by additional requirements in the TSs.

As part of the plant licensing process, applicants are required by 10 CFR 50.34 to analyze the consequences of postulated design-basis accidents (DBAs), which for PWR licensees, include an SG tube rupture and a main steam line break (MSLB). These analyses consider primary-to-secondary leakage that may occur during these events and must show that the offsite radiological consequences do not exceed the applicable limits of the 10 CFR 100.11, "Determination of exclusion area, low population zone, and population center distance," accident source term, GDC 19 for control room operator doses (or some fraction thereof as appropriate to the accident), or the NRC-approved licensing basis (e.g., a small fraction of these limits). No accident analyses for WCGS are being changed because of the proposed amendment and, thus, no radiological consequences of any accident analysis are being changed.

License Amendment No. 186 (Reference 9) for WCGS modified TS 5.5.9, "Steam Generator (SG) Program," and TS 5.6.10, "Steam Generator Inspection Report," incorporating interim alternate repair criteria and associated tube inspection and reporting requirements that were applicable during Refueling Outage 17 and the subsequent operating cycle. That amendment exempted the portion of tubing located more than 13.1 inches (the "H*" distance") below the top of the tubesheet (TTS) from the TS inspection and repair requirements. Tubes with service-induced flaws located in the portion of the tube from the TTS to 13.1 inches below the TTS shall be plugged upon detection. The proposed amendment is similar to the currently approved Amendment No. 186, with the exception that the H* distance would be 15.2 inches and would be applicable to Refueling Outage 18 (spring 2011) and the subsequent operating cycle. Similar amendments have been approved for several other plants in recent years, including Vogtle, Units 1 and 2, Seabrook Station, Unit No. 1, and Catawba, Unit 2.

4.0 TECHNICAL EVALUATION

4.1 Proposed Changes to the TSs

The references for the indicated changes below are the current WCGS TSs, including the currently approved interim alternate repair criteria and associated tube inspection and reporting requirements that were applicable during Refueling Outage 17 and the subsequent operating cycle. The proposed changes are shown in markup form for clarity.

TS 5.5.9.c. would be changed as follows:

- c. Provisions for SG tube repair criteria. Tubes found by inservice inspection to contain flaws with a depth equal to or exceeding 40% of the nominal tube wall thickness shall be plugged.

The following alternate tube repair criteria shall be applied as an alternative to the 40% depth-based criteria:

- 1. For Refueling Outage ~~17~~ **18** and the subsequent operating cycle, tubes with service-induced flaws located greater than ~~13.4~~ **15.2** inches below the top of the tubesheet do not require plugging. Tubes with service-induced flaws located in the portion of the tube from the top of the tubesheet to ~~13.4~~ **15.2** inches below the top of the tubesheet shall be plugged upon detection.

TS 5.5.9.d. would be revised as follows:

- d. Provisions for SG tube inspections. Periodic SG tube inspections shall be performed. The number and portions of the tubes inspected and methods of inspection shall be performed with the objective of detecting flaws of any type (e.g., volumetric flaws, axial and circumferential cracks) that may be present along the length of the tube, from the tube-to-tubesheet weld at the tube inlet to the tube-to-tubesheet weld at the tube outlet, and that may satisfy the applicable tube repair criteria. For Refueling Outage ~~17~~ **18** and the subsequent operating cycle, the portion of the tube below ~~13.4~~ **15.2** inches below the top of the tubesheet is excluded from this requirement. The tube-to-tubesheet weld is not part of the tube. In addition to meeting the requirements of d.1, d.2, and d.3 below, the inspection scope, inspection methods, and inspection intervals shall be such as to ensure that SG tube integrity is maintained until the next SG inspection. An assessment of degradation shall be performed to determine the type and location of flaws to which the tubes may be susceptible and, based on this assessment, to determine which inspection methods need to be employed and at what locations.

- 1.-3. [No change/Not shown]

TS 5.6.10 would be revised as follows:

A report shall be submitted within 180 days after the initial entry into MODE 4 following completion of an inspection performed in accordance with the Specification 5.5.9, Steam Generator (SG) Program. The report shall include:

- a.-g. [No change/Not shown]
- h. Following completion of an inspection performed in Refueling Outage 47 **18** (and any inspections performed in the subsequent operating cycle) the primary to secondary LEAKAGE rate observed in each SG (if it is not practical to assign LEAKAGE to an individual SG, the entire primary to secondary LEAKAGE should be conservatively assumed to be from one SG) during the cycle preceding the inspection which is the subject of the report;
- i. Following completion of an inspection performed in Refueling Outage 47 **18** (and any inspections performed in the subsequent operating cycle) the calculated accident induced leakage rate from the portion of the tubes below ~~13.4~~ **15.2** inches from the top of the tubesheet for the most limiting accident in the most limiting SG. In addition, if the calculated accident induced leakage rate from the most limiting accident is less than 2.50 times the maximum operational primary to secondary leak rate, the report should describe how it was determined; and
- j. Following completion of an inspection performed in Refueling Outage 47 **18** (and any inspections performed in the subsequent operating cycle) the results of monitoring for the tube axial displacement (slippage). If slippage is discovered, the implications of discovery and corrective action shall be provided.

4.2 Technical Evaluation

The T/TS joints are part of the pressure boundary between the primary and secondary systems. Each T/TS joint consists of the tube, which is hydraulically expanded against the bore of the tubesheet, the T/TS weld located at the tube end, and the tubesheet. The joints were designed in accordance with the ASME Code, Section III, as welded joints, not as friction joints. The T/TS welds were designed to transmit the tube end-cap pressure loads, during normal operating and DBA conditions, from the tubes to the tubesheet with no credit taken for the friction developed between the hydraulically-expanded tube and the tubesheet. In addition, the welds serve to make the joints leak tight.

This design basis is a conservative representation of how the T/TS joints actually work, since it conservatively ignores the role of friction between the tube and tubesheet in reacting the tube end-cap loads. The initial hydraulic expansion of the tubes against the tubesheet produces an "interference fit" between the tubes and the tubesheet; thus, producing a residual contact

pressure (RCP) between the tubes and tubesheet, which acts normally to the outer surface of the tubes and the inner surface of the tubesheet bore holes. Additional contact pressure between the tubes and tubesheet is induced by operational conditions as will be discussed in detail below. The amount of friction force that can be developed between the outer tube surface and the inner surface of the tubesheet bore is a direct function of the contact pressure between the tube and tubesheet times the applicable coefficient of friction.

To support the proposed TS changes, the licensee's contractor, Westinghouse, has defined a parameter called H* to be that distance below the TTS over which sufficient frictional force, with acceptable safety margins, can be developed between each tube and the tubesheet under tube end-cap pressure loads associated with normal operating and design basis accident conditions to prevent significant slippage or pullout of the tube from the tubesheet, assuming the tube is fully severed at the H* distance below the TTS. For WCGS, the proposed H* distance is 15.2 inches. Given that the frictional force developed in the T/TTS joint over the H* distance is sufficient to resist the tube end-cap pressure loads, it is the licensee's and Westinghouse's position that the length of tubing between the H* distance and the T/TTS weld is not needed to resist any portion of the tube end-cap pressure loads. Thus, the licensee is proposing to change the TSs to not require inspection of the tubes below the H* distance and to exclude tube flaws located below the H* distance (including flaws in the T/TTS weld) from the application of the TS tube repair criteria. Under these changes, the T/TTS joint would now be treated as a friction joint extending from the TTS to a distance below the TTS equal to H* for purposes of evaluating the structural and leakage integrity of the joint.

The regulatory standard by which the NRC staff has evaluated the subject license amendment is that the amended TSs should continue to ensure that tube integrity will be maintained, consistent with the current design and licensing basis. This includes maintaining structural safety margins consistent with the structural integrity performance criterion in TS 5.5.9.b.1 and the design basis, as is discussed in Section 4.2.1.1 below. In addition, this includes limiting the potential for accident-induced primary-to-secondary leakage to values not exceeding the accident-induced leakage performance criteria in TS 5.5.9.b.2, which are consistent with values assumed in the licensing basis accident analyses. Maintaining tube integrity in this manner ensures that the amended TSs are in compliance with all applicable regulations, including GDC 14 and 31. The NRC staff's evaluation of joint structural integrity and accident-induced leakage integrity is discussed in Sections 4.2.1 and 4.2.2 of this safety evaluation, respectively.

4.2.1 Joint Structural Integrity

4.2.1.1 Acceptance Criteria

Westinghouse has conducted extensive analyses to establish the necessary H* distance to resist pullout under normal operating and DBA conditions. The NRC staff agrees that pullout is the structural failure mode of interest since the tubes are radially constrained against axial fishmouth rupture by the presence of the tubesheet. The axial force which could produce pullout derives from the pressure end-cap loads due to the primary-to-secondary pressure differentials associated with normal operating and DBA conditions. Westinghouse determined the needed H* distance on the basis of maintaining a factor of three against pullout under normal operating conditions and a factor of 1.4 against pullout under DBA conditions. The NRC

staff agrees that these are the appropriate safety factors to apply to demonstrate structural integrity. These safety factors are consistent with the safety factors embodied in the structural integrity performance criteria in TS 5.5.9.b.1 and with the design basis; namely the stress limit criteria in the ASME Code, Section III.

4.2.1.2 3-D Finite Element Analysis

A detailed 3-D finite element analysis (FEA) of the lower SG assembly (consisting of the lower portion of the SG shell, the tubesheet, the channel head, and the divider plate separating the hot- and cold-leg inlet plenums inside the channel head) was performed to calculate tubesheet displacements due to primary pressure acting on the primary face of the tubesheet and SG channel head, secondary pressure acting on the secondary face of the tubesheet and SG shell, and the temperature distribution throughout the entire lower SG assembly. The calculated tubesheet displacements were used as input to the T/TS interaction analysis evaluated in Section 4.2.1.3 below.

The tubesheet bore holes were not explicitly modeled. Instead, the tubesheet was modeled as a solid structure with equivalent material property values selected such that the solid model exhibited the same stiffness properties as the actual perforated tubesheet.

A number of FEA mesh enhancements in the tubesheet region have been made since the reference analysis (Reference 5). The mesh near the plane of symmetry (perpendicular to the divider plate) was revised to permit obtaining displacements parallel to the direction of the divider directly from the 3-D FEA for application (as displacement boundary conditions) to the edges of the square-cell model discussed in Section 4.2.1.3.2. The mesh near the TTS was enhanced to accommodate high temperature gradients in this area during normal operating conditions.

This 3-D FEA replaces the 2-D axisymmetric FEA used to support H* amendment requests submitted prior to 2008. The NRC staff concludes that the 3-D analysis adequately addresses a concern cited by the staff in Reference 6 concerning the validity of the axisymmetric model to conservatively bound significant non-axisymmetric features of the actual tubesheets. These non-axisymmetric features include the solid (non-bored) portion of the tubesheet between the hot and cold leg sides, and the divider plate which acts to connect the solid part of the tubesheet to the channel head.

Some non-U.S. units have experienced cracks in the weld between the divider plate and the stub runner attachment on the bottom of the tubesheet. Should such cracks ultimately cause the divider plate to become disconnected from the tubesheet, tubesheet vertical and radial displacements under operational conditions could be significantly increased relative to those for an intact divider plate weld. Although the industry believes that there is little likelihood that cracks such as those seen abroad could cause a failure of the divider plate weld, the 3-D FEA conservatively considered both the case of an intact divider plate weld and a detached divider plate weld to ensure a conservative analysis. The case of a detached divider plate weld was found to produce the most limiting H* values. In the reference analyses (Reference 5), a factor was applied to the 3-D FEA results to account for a non-functional divider plate, based on earlier sensitivity studies performed with the 2-D axisymmetric FEA model of the lower SG assembly.

The 3-D FEA model now assumes the upper 5 inches of the divider plate to be non-existent. The NRC staff concludes that this further improves the accuracy of the 3-D FEA for the assumed condition of a non-functional divider plate.

Separate 3-D FEA analyses were conducted for each loading condition considered (i.e., normal operating conditions, MSLB, feedwater line break (FLB)), rather than scaling unit load analyses to prototypic conditions as was done in analyses prior to 2008. The NRC staff concludes that this corrects a significant source of error in analyses used by applicants to support permanent H* amendment requests submitted prior to 2008, which were subsequently withdrawn (Reference 6). In addition, the temperature distributions throughout the lower SG assembly, including the tubesheet region, were calculated directly in the 3-D FEA from the assumed plant temperature conditions (e.g., from the assumed primary and secondary water temperatures) for each operating condition. The NRC staff concludes that this is a more realistic approach relative to the reference analysis (Reference 5) where a linear distribution of temperature was assumed to exist through the thickness of the tubesheet in the 3-D FEA with an adjustment factor being applied to the H* calculations for the case of normal operating conditions to account for the actual temperature distribution in the tubesheet based on sensitivity analyses.

4.2.1.3 T/TS Interaction Model

4.2.1.3.1 Thick-shell Model

The resistance to tube pullout is the axial friction force developed between the expanded tube and the tubesheet over the H* distance. The friction force is a function of the radial contact pressure between the expanded tube and the tubesheet. In the reference analysis (Reference 5) for the interim H* amendment issued on October 19, 2009 for WCGS (Reference 9), Westinghouse used classical thick-shell equations to model the interaction effects between the tubes and tubesheet under various pressure and temperature conditions for purposes of calculating contact pressure (T/TS interaction model). Calculated displacements from the 3-D FEA of the lower tubesheet assembly were applied to the thick-shell model as input to account for the incremental tubesheet bore diameter change caused by the primary pressure acting on the primary face of the tubesheet and SG channel head, secondary pressure acting on the secondary face of the tubesheet and SG shell, and the temperature distribution throughout the entire lower SG assembly. However, the tubesheet bore diameter change from the 3-D FEA tended to be non-uniform (eccentric) around the bore circumference. The thick-shell equations used in the T/TS interaction model are axisymmetric. Thus, the non-uniform diameter change from the 3-D finite element analyses had to be adjusted to an equivalent uniform value before it could be used as input to the T/TS interaction analysis. A 2-D plane stress finite element model was used to define a relationship for determining a uniform diameter change that would produce the same change to average T/TS contact pressure as would the actual non-uniform diameter changes from the 3-D finite element analyses. In Reference 10, Westinghouse identified a difficulty in applying this relationship to Model D5 SGs under MSLB conditions. In reviewing the reasons for this difficulty, the NRC staff developed questions relating to the conservatism of the relationship and whether the tubesheet bore displacement eccentricities are sufficiently limited such as to ensure that T/TS contact is maintained around the entire tube circumference. This concern was applicable to all SG models with Alloy 600 thermally treated tubing. However, responses to NRC staff questions provided in References 6,

7, and 11 did not provide sufficient information to allow the staff to reach a conclusion on these matters and on the acceptability of a permanent H* amendment. However, for reasons discussed in the staff's safety evaluation in Reference 9, the staff concluded that there was an adequate technical basis to support issuance of an interim H* amendment.

In Reference 12, the NRC staff documented a list of questions that would need to be addressed satisfactorily before the staff would be able to approve a permanent H* amendment. These questions related to the technical justification for the eccentricity adjustment, the distribution of contact pressure around the tube circumference, and a new model under development by Westinghouse to address the aforementioned issue encountered with the Model D5 SGs.

On June 14 and 15, 2010, the NRC staff conducted an audit at the Westinghouse Waltz Mill Site (Reference 13). The purpose of the audit was to gain a better understanding of the H* analysis pertaining to eccentricity, to review draft responses to the staff's questions in Reference 12, and to determine which documents would need to be provided on the docket to support any future requests for a permanent H* amendment. Based on the audit, including a review of pertinent draft responses to Reference 12, the staff concluded that eccentricity does not appear to be a significant variable affecting either average T/TS contact pressure at a given elevation or calculated values of H*. The staff found that average contact pressure at a given elevation is primarily a function of average bore diameter change at that elevation associated with the pressure and temperature loading of the tubesheet. Accordingly, the staff concluded that no adjustment of computed average bore diameter change considered in the thick-shell model is needed to account for eccentricities computed by the 3-D FEA. The material reviewed during the audit revealed that computed H* values from the reference analyses continued to be conservative when the eccentricity adjustment factor is not applied.

During the audit, Westinghouse presented preliminary details of a new T/TS interaction model developed as an alternative to the thick-shell interaction model. This model is termed the square-cell model. This model was originally developed in response to the above-mentioned difficulty encountered when applying the eccentricity adjustment to Model D SGs T/TS interaction analysis under MSLB conditions using the thick-shell model. Early results with this model indicated significant differences compared to the thick-shell model, irrespective of whether the eccentricity adjustment was applied to the thick-shell model. The square-cell model revealed a fundamental problem with how the results of the 3-D FEA model of the lower SG assembly were being applied to the tubesheet bore surfaces in the thick-shell model. As discussed in Section 4.2.1.2 above, the perforated tubesheet is modeled in the 3-D FEA model as a solid plate whose material properties were selected such that the gross stiffness of the solid plate is equivalent to that of a perforated plate under the primary-to-secondary pressure acting across the thickness of the plate. This approach tends to smooth out the distribution of tubesheet displacements as a function of radial and circumferential location in the tubesheet, and ignores local variations of the displacements at the actual bore locations. These smoothed-out displacements from the 3-D FEA results were the displacements applied to the bore surface locations in the thick-shell model. The square-cell model provides a means for post-processing the 3-D FEA results such as to account for localized variations of tubesheet displacement at the bore locations as part of T/TS interaction analysis. The square-cell model was still under development at the time of the audit and no draft documentation of the model was available for NRC staff review. Although the NRC staff found that the objectives of the new model approach

appeared reasonable, the staff was unable to provide feedback on the details of the approach at that time. The staff also observed (Reference 13) that the square-cell model approach may also need to be applied to the Model F, 44F, and 51F SGs to confirm that the analyses for these plants are conservative.

4.2.1.3.2 Square-Cell Model

Documentation for the square-cell model is included with the subject amendment request for an interim H^* at WCGS (Reference 1). The square-cell model is a 2-D plane stress FEA model of a single square-cell of the tubesheet with a bore hole in the middle and each of the four sides of the cell measuring one tube pitch in length. Displacement boundary conditions are applied at the edges of the cell, based on the displacement data from the 3-D FEA model. The model also includes the tube cross-section inside the bore. Displacement compatibility between the tube outer surface and bore inner surface is enforced except at locations where a gap between the tube and bore tries to occur.

The square-cell model is applied to nine different elevations, from the top to the bottom of the tubesheet, for each tube and loading case analyzed. The square-cell slices at each elevation are assumed to act independently of one another. T/TS contact pressure results from each of the nine slices are used to define the contact pressure distribution from the top to the bottom of the tubesheet.

The resisting force to the applied end-cap load, which is developed over each incremental axial distance from the TTS, is the average contact pressure over that incremental distance times the tubesheet bore surface area (equal to the tube outer diameter surface area) over the incremental axial distance times the coefficient of friction. The NRC staff reviewed the coefficient of friction used in the analysis and judges it to be a reasonable lower bound (conservative) estimate. The H^* distance for each tube was determined by integrating the incremental friction forces from the TTS to the distance below the TTS where the friction force integral equaled the applied end-cap load times the appropriate safety factor as discussed in Section 4.2.1.1.

The square-cell model assumes as an initial condition that each tube is fully expanded against the tubesheet bore such that the outer tube surface is in contact with the inner surface of the tubesheet bore under room temperature, atmospheric pressure conditions, with zero residual contact pressure associated with the hydraulic expansion process. The NRC staff concludes that the assumption of zero residual contact pressure in all tubes is a conservative assumption.

The limiting tube locations in terms of H^* were determined during the reference analysis to lie along the plane of symmetry perpendicular to the divider plate. The outer edges of the square-cell model conform to the revised mesh pattern along this plane of symmetry in the 3-D FEA model of the lower SG assembly, as discussed in Section 4.2.1.2. Because the tubesheet bore holes were not explicitly modeled in the 3-D FEA, only the average displacements along each side of the square-cell are known from the 3-D FEA. Three different assumptions for applying displacement boundary conditions to the edges of the square-cell model were considered to allow for a range of possibilities about how local displacements might vary along the length of each side. The most conservative assumption, in terms of maximizing the calculated H^*

distance, was to apply the average transverse displacement uniformly over the length of each edge of the square-cell.

Primary pressure acting on the inside tube surface and crevice pressure¹ acting on both the tube outside surface and tubesheet bore surface are not modeled directly as in the case of the thick-shell model. Instead, the primary side (inside) of the tube is assumed to have a pressure equal to the primary pressure minus the crevice pressure. Note the crevice pressure varies as a function of the elevation being analyzed, as discussed in Section 4.2.1.4.

The NRC staff has not completed its review of the square-cell model. This review will need to be completed before the staff can approve any request for a permanent H* amendment. However, for reasons discussed in Section 4.2.4 of this safety evaluation, the staff concludes that the proposed H* distances will ensure for at least one operating cycle (one fuel cycle) that tube structural and leakage integrity will be maintained with structural safety margins consistent with the design basis and with leakage integrity within assumptions employed in the licensing basis accident analyses, without undue risk to public health and safety.

4.2.1.4 Crevice Pressure Evaluation

The H* analyses postulate that interstitial spaces exist between the hydraulically expanded tubes and tubesheet bore surfaces. These interstitial spaces are assumed to act as crevices between the tubes and the tubesheet bore surfaces. The NRC staff concludes that the assumption of crevices is conservative since the pressure inside the crevices acts to push against both the tube and the tubesheet bore surfaces, thus reducing contact pressure between the tubes and tubesheet.

For tubes which do not contain through-wall flaws within the thickness of the tubesheet, the pressure inside the crevice is assumed to be equal to the secondary system pressure. For tubes that contain through-wall flaws within the thickness of the tubesheet, a leak path is assumed to exist, from the primary coolant inside the tube, through the flaw, and up the crevice to the secondary system. Hydraulic tests were performed on several tube specimens that were hydraulically expanded against tubesheet collar specimens to evaluate the distribution of the crevice pressure from a location where through-wall holes had been drilled into the tubes to the top of the crevice location. The T/TS collar specimens were instrumented at several axial locations to permit direct measurement of the crevice pressures. Tests were run for both normal operating and MSLB pressure and temperature conditions.

The NRC staff concludes that the use of the drilled holes, rather than through-wall cracks, is conservative since it eliminates any pressure drop between the inside of the tube and the crevice at the hole location. This maximizes the pressure in the crevice at all elevations, thus reducing contact pressure between the tubes and tubesheet.

¹ Although the tubes are in tight contact with the tubesheet bore surfaces, interstitial spaces between these surfaces, which are effectively crevices, are conservatively assumed to be created. See Section 4.2.1.4 of this safety evaluation for more information

The crevice pressure data from these tests were used to develop a crevice pressure distribution as a function of normalized distance between the TTS and the H* distance below the TTS where the tube is assumed to be severed. These distributions were used to determine the appropriate crevice pressure at each axial location of the T/TTS interaction model. The NRC staff concludes that this approach acceptably addresses the staff's concerns cited in Reference 4 concerning the use of the limiting median crevice pressure value of the normal operating and MSLB data, respectively, for each axial slice in previous H* analyses in support of amendment applications submitted prior to 2008. The staff concludes that the crevice pressure distributions used to support the current amendment request are more realistic and more conservative than those used previously.

Because the crevice pressure distribution is assumed to extend from the H* location, where crevice pressure is assumed to equal primary pressure, to the TTS, where crevice pressure equals secondary pressure, an initial guess as to the H* location must be made before solving for H* using the T/TTS interaction model and 3-D finite element model. The resulting new H* estimate becomes the initial estimate for the next H* iteration.

4.2.1.5 H* Calculation Process

The calculation of H* consists of the following steps for each loading case considered:

1. Perform initial H* estimate (mean H* estimate) using the T/TTS interaction and 3-D FEA models, assuming nominal geometric and material properties, and assuming that the tube is severed at the bottom of the tubesheet for purposes of defining the contact pressure distribution over the length of the T/TTS crevice. This initial estimate also did not consider the effect of the Poisson's contraction of the tube radius associated with application of the axial end-cap load (see Step 6 below).
2. In the reference analysis (Reference 5), a 0.3-inch adjustment was added to the initial H* estimate to account for uncertainty in the bottom of the tube expansion transition (BET) location relative to the TTS, based on an uncertainty analysis on the BET for Model F SGs conducted by Westinghouse. This adjustment is not included in the revised H* analysis accompanying the subject amendment request, as discussed and evaluated in Section 4.2.1.5.1 of this safety evaluation.
3. In the reference analysis (Reference 5) for normal operating conditions only, an additional adjustment was added to the initial H* estimate to correct for the actual temperature distribution in the tubesheet compared to the linear distribution assumed in the finite element analysis. This adjustment is no longer necessary, as discussed in Section 4.2.1.2, since the temperature distributions throughout the tubesheet were calculated directly in the 3-D FEA supporting the current request for an interim H* amendment.
4. Steps 1 through 3 yield a so-called "mean" estimate of H*, which is deterministically based. Step 4 involves a probabilistic analysis of the potential

variability of H^* , relative to the mean estimate, associated with the potential variability of key input parameters for the H^* analyses. This leads to a "probabilistic" estimate of H^* , which includes the mean estimate. The NRC staff's evaluation of the probabilistic analysis is provided in Sections 4.2.1.6 and 4.2.1.7 of this safety evaluation.

5. Add a crevice pressure adjustment to the probabilistic estimate of H^* to account for the crevice pressure distribution which results from the tube being severed at the final H^* value, rather than at the bottom of the tubesheet. This step is discussed and evaluated in Section 4.2.1.5.2 of this safety evaluation.
6. A new step, Step 6, has been added to the H^* calculation process since the reference analysis was developed, to support the subject interim amendment request. This step involves adding an adjustment to the probabilistic estimate of H^* to account for the Poisson contraction of the tube radius due to the axial end-cap load acting on each tube. This step is discussed and evaluated in Section 4.2.1.5.3 of this safety evaluation.

4.2.1.5.1 BET Considerations

In the reference H^* analysis (Reference 5), a 0.3-inch adjustment was added to the initial H^* estimate to account for uncertainty in the BET location, relative to the TTS, based on a BET uncertainty analysis for Model F SGs conducted by Westinghouse. As discussed previously in Section 4.2.1.3.1, the reference analysis was based on the thick-shell model and the results of that analysis did not indicate a loss of contact pressure at the TTS during normal operating conditions or steam line break conditions; therefore, this adjustment for the BET location was necessary. In response to NRC staff questions regarding the BET uncertainty analysis, Westinghouse performed an analysis (Reference 1) that showed BET locations as great as 1 inch below the TTS could be tolerated at any tube location. Because the limiting calculated H^* value is in the most limiting tubesheet sector, that H^* value provides greater than 1 inch of margin for most other tubesheet sectors. For those few sectors in the tubesheet where the local H^* distance was within 1 inch of the maximum H^* distance, Westinghouse showed that the contact pressure gradient was positive with increasing depth into the tubesheet, and therefore, an H^* length reduced by 1 inch still met the pull out resistance requirements, including appropriate safety factors.

The new analysis performed in Reference 1 has made the need for this adjustment moot, as the square-cell model shows a loss of contact pressure at the TTS that is greater than the possible variation in the BET location. The loss of contact pressure at the TTS shown in the square-cell model (which is unrelated to BET location) is compensated for by a steeper contact pressure gradient than was shown previously in the thick-shell model H^* analysis.

4.2.1.5.2 Crevice Pressure Adjustment

As discussed in Section 4.2.1.5, Steps 1 through 4 of the H^* calculation process leading to a probabilistic H^* estimate are performed with the assumption that the tube is severed at the bottom of the tubesheet for purposes of calculating the distribution of crevice pressure as a

function of elevation. If the tube is assumed to be severed at the initially computed H^* distance and Steps 1 through 4 are repeated, a new H^* may be calculated which will be incrementally larger than the first estimate. This process may be repeated until the change in H^* becomes small (convergence). Sensitivity analyses conducted during the reference analysis with the thick-shell model showed that the delta between the initial H^* estimate and final (converged) estimate is a function of the initial estimate for the tube in question. This delta (i.e., the crevice pressure adjustment referred to in Step 5 of Section 4.2.1.5) was plotted as a function of the initial H^* estimate for the limiting loading case and tube radial location. The NRC staff concludes that this is an acceptable approach where the H^* estimates are based on the thick-shell model; however, the staff has not yet reached a conclusion regarding the applicability of this adjustment to H^* estimates that are based on the square-cell model. The staff will need to reach a conclusion on this point before the staff can approve any request for a permanent H^* amendment. However, for reasons discussed in Section 4.2.4 of this safety evaluation, the staff concludes that the proposed H^* distances will ensure for at least one operating cycle (one fuel cycle) that tube structural and leakage integrity will be maintained with structural safety margins consistent with the design basis and with leakage integrity within assumptions employed in the licensing basis accident analyses, without undue risk to public health and safety.

4.2.1.5.3 Poisson Contraction Effect

The axial end-cap load acting on each tube is equal to the primary-to-secondary pressure difference times the tube cross-sectional area. For purposes of resisting tube pullout under normal and accident conditions, the end-cap loads used in the H^* analyses are based on the tubesheet bore diameter, which the NRC staff concludes is a conservative assumption. The axial end-cap load tends to stretch the tube in the axial direction, but causes a slight contraction in the tube radius due to the Poisson's Ratio effect. This effect, by itself, tends to reduce the T/TS contact pressure and, thus, to increase the H^* distance. The axial end-cap force is resisted by the axial friction force developed at the T/TS joint. Thus, the axial end-cap force begins to decrease with increasing distance into the tubesheet, reaching zero at a location before the H^* distance is reached. This is because the H^* distances are intended to resist pullout under the end-cap loads with the appropriate factors of safety applied as discussed in Section 4.2.1.1.

This Poisson radial contraction effect was neglected in the reference analyses, but is accounted for in the analyses supporting the subject amendment request. A simplified approach was followed. First, thick-shell equations were used to estimate the reduction in contact pressure associated with application of the full end-cap load, assuming none of this end-cap load has been reacted by the tubesheet. The T/TS contact pressure distributions determined in Step 4 of the H^* calculation process in Section 4.2.1.5 were reduced by this amount. Second, the friction force associated with these reduced T/TS contact pressures were integrated with distance into the tubesheet, and the length of engagement necessary to react one times the end-cap loading (i.e., no safety factor applied) was determined. At this distance (termed attenuation distance by Westinghouse), the entire end-cap loading was assumed to have been reacted by the tubesheet, and the axial load in the tube below the attenuation distance was assumed to be zero. Thus, the T/TS contact pressures below the attenuation distance were assumed to be unaffected by the Poisson radial contraction effect. Finally, a revised H^* distance was calculated, where the T/TS contact pressures from Step 4 of Section 4.2.1.5 were reduced only over the attenuation distance. The NRC staff has not completed its review of the applied

adjustment to account for the Poisson radial contraction effect. However, for reasons discussed in Section 4.2.4 of this safety evaluation, the staff concludes that the proposed H* distances will ensure for at least one operating cycle (one fuel cycle) that tube structural and leakage integrity will be maintained with structural safety margins consistent with the design basis and with leakage integrity within assumptions employed in the licensing basis accident analyses, without undue risk to public health and safety.

4.2.1.6 Acceptance Standard - Probabilistic Analysis

The purpose of the probabilistic analysis is to develop an H* distance that ensures with a probability of 0.95 that the population of tubes will retain margins against pullout consistent with criteria evaluated in Section 4.2.1.1 of this safety evaluation, assuming all tubes to be completely severed at their H* distance. The NRC staff concludes this probabilistic acceptance standard is consistent with what the staff has approved previously and is acceptable. For example, the upper voltage limit for the voltage based tube repair criteria in NRC Generic Letter 95-05 (Reference 14) employs a consistent criterion. The staff also notes that use of the 0.95 probability criterion ensures that the probability of pullout of one or more tubes under normal operating conditions and conditional probability of pullout under accident conditions is well within tube rupture probabilities that have been considered in probabilistic risk assessments (References 15 and 16).

In terms of the confidence level that should be attached to the 0.95 probability acceptance standard, it is industry practice for SG tube integrity evaluations, as embodied in industry guidelines, to calculate such probabilities at a 50 percent confidence level. The NRC staff has been encouraging the industry to revise its guidelines to call for calculating such probabilities at a 95 percent confidence level when performing operational assessments and a 50 percent confidence level when performing condition monitoring (Reference 17). In the meantime, the calculated H* distances supporting this interim amendment request have been evaluated at the 95% confidence level, as recommended by the staff.

Another issue relating to the acceptance standard for the probabilistic analysis is determining what population of tubes needs to be analyzed. For accidents such as MSLB or FLB, the NRC staff and licensee agree that the tube population in the faulted SG is of interest, since it is the only SG that experiences a large increase in the primary-to-secondary pressure differential. However, normal operating conditions were found to be the most limiting in terms of meeting the tube pullout margins. For normal operating conditions, tubes in all SGs at the plant are subject to the same pressures and temperatures. Although there is not a consensus between the staff and industry on which population needs to be considered in the probabilistic analysis for normal operating conditions, the calculated H* distances for normal operating conditions supporting this interim amendment request are 95 percent probability/95 percent confidence estimates based on the entire tube population for the plant, consistent with the NRC staff's recommendation.

Based on the above, the NRC staff concludes that the proposed H* distance in the subject LAR is based on acceptable probabilistic acceptance standards evaluated at acceptable confidence levels.

4.2.1.7 Probabilistic Analyses

Sensitivity studies were conducted in the reference analyses (Reference 5) and demonstrated that H^* was highly sensitive to the potential variability of the coefficients of thermal expansion (CTE) for the Alloy 600 tubing material and the SA-508 Class 2a tubesheet material. Given that no credit was taken in the reference H^* analyses (Reference 5) for RCP associated with the tube hydraulic expansion process², the sensitivity of H^* to other geometry and material input parameters was judged by Westinghouse to be inconsequential and they were ignored, with the exception of Young's modulus of elasticity for the tube and tubesheet materials. Although the Young's modulus parameters were included in the reference H^* analyses sensitivity studies, these parameters were found to have a weak effect on the computed H^* . Based on its review of the analysis models and its engineering judgment, the NRC staff agrees that the sensitivity studies adequately capture the input parameters which may significantly affect the value of H^* . This conclusion is based, in part, on no credit being taken for RCP in the reference H^* analyses.

These sensitivity studies were used to develop influence curves describing the change in H^* , relative to the mean H^* value estimate (see Section 4.2.1.5), as a function of the variability of each CTE parameter and Young's modulus parameter, relative to the mean values of CTE and Young's Modulus. Separate influence curves were developed for each of the four input parameters. The sensitivity studies showed that of the four input parameters, only the CTE parameters for the tube and tubesheet material had any interaction with one another. A combined set of influence curves containing this interaction effect was also created.

Two types of probabilistic analyses were performed independently in the reference analyses. One was a simplified statistical approach utilizing a "square root of the sum of the squares" method and the other was a detailed Monte Carlo sampling approach. The NRC staff's review (Reference 9) of the reference analysis relied on the Monte Carlo analysis, which provides the most realistic treatment of uncertainties. The staff reviewed the implementation of probabilistic analyses in the reference analyses (Reference 5) and questioned whether the H^* influence curves had been conservatively treated. To address this concern, new H^* analyses were performed as documented in References 6 and 7. These analyses made direct use of the H^* influence curves in a manner that the NRC staff concludes is acceptable (Reference 9).

The revised reference analyses in References 6 and 7 divided the tubes by sector location within the tube bundle and all tubes were assumed to be at the location in their respective sectors where the initial value of H^* (based on nominal values of material and geometric input parameters) was at its maximum value for that sector. The H^* influence curves discussed above, developed for the most limiting tube location in the tube bundle, were conservatively used for all sectors. The revised reference analyses also addressed a question posed by the NRC staff in Reference 4 concerning the appropriate way to sample material properties for the tubesheet, whose properties are unknown but do not vary significantly for a given SG, in contrast to the tubes whose properties tend to vary much more randomly from tube to tube in a given SG. This issue was addressed by a staged sampling process where the tubesheet properties were sampled once and then held fixed, while the tube properties were sampled a number of times equal to the SG tube population. This process was repeated 10,000 times, and

² Residual contact pressures are sensitive to variability of other input parameters.

the maximum H* value from each repetition was rank ordered. The final H* value was selected from the rank ordering to reflect a 0.95 probability value at the desired level of confidence for a single SG tube population or all SG population, as appropriate. The staff concludes that this approach addresses the staff's question in a realistic fashion and is acceptable.

New Monte Carlo analyses using the square-cell model to evaluate the statistical variability of H* due to the CTE variability for the tube and tubesheet materials were not performed in support of the subject interim amendment request. Instead, the probabilistic analysis utilized the results of the Monte Carlo from the reference analysis, which are based on the thick-shell T/T/S interaction model, to identify CTE values for the tube and tubesheet associated with the probabilistic H* values near the desired rank ordering. Tube CTE values associated with the high ranking order estimates are generally negative variations from the mean value whereas tubesheet CTE values associated with the higher ranking order estimates are generally positive variations from the mean value. For the upper 10 percent of the Monte Carlo results ranking order, a combined uncertainty parameter, "alpha," was defined as the square root of the sum of the squares of the associated tube and tubesheet CTE values for each Monte Carlo sample. Alpha was plotted as a function of the corresponding H* estimate and separately as a function of rank order. Each of these plots exhibited well defined "break lines," representing the locus of maximum H* estimates and maximum rank orders associated with given values of alpha. From these plots, paired sets of tube and tubesheet CTE values were selected such as to maximize the H* estimate and to establish upper and lower bounds on the rank orders corresponding to the appropriate probabilistic acceptance criteria described and evaluated in Section 4.2.1.6 of this safety evaluation. These CTE values were then input to the lower SG assembly 3-D FEA model and the square-cell model to yield probabilistic H* estimates. These H* estimates were then plotted as a function of rank ordering, allowing the interpolation of H* values at the desired rank orders.

The limiting probabilistic H* value, evaluated at the appropriate acceptance standard as discussed in Section 4.2.1.6 and with the adjustments for crevice pressure and Poisson radial contraction effect discussed in Section 4.2.1.5, is bounded by the proposed H* value of 15.2 inches in the subject interim amendment request.

The NRC staff has not completed its evaluation of the above probabilistic analysis, which must be done before the staff can approve any request for a permanent H* amendment. However, for reasons discussed in Section 4.2.4 of this safety evaluation, the staff concludes that the proposed H* distances will ensure for at least one operating cycle (one fuel cycle) that tube structural and leakage integrity will be maintained with structural safety margins consistent with the design basis and with leakage integrity within assumptions employed in the licensing basis accident analyses, without undue risk to public health and safety.

4.2.1.8 Coefficient of Thermal Expansion

During operation, a large part of contact pressure in an SG T/T/S joint is derived from the difference in CTE between the tube and tubesheet. As discussed in Section 4.2.1.7, the calculated value of H* is highly sensitive to the assumed values of these CTE parameters. However, CTE test data acquired by an NRC contractor, Argonne National Laboratory (ANL), suggested that CTE values may vary substantially from values listed in the ASME Code for

design purposes. In Reference 4, the NRC staff highlighted the need to develop a rigorous technical basis for the CTE values, and their potential variability, to be employed in future H* analyses.

In response, Westinghouse had a subcontractor review the CTE data in question, determine the cause of the variance from the ASME Code CTE values, and provide a summary report (Reference 18). Analysis of the CTE data in question revealed that the CTE variation with temperature had been developed using a polynomial fit to the raw data, over the full temperature range from 75 degrees Fahrenheit (°F) to 1300 °F. The polynomial fit chosen resulted in mean CTE values that were significantly different from the ASME Code values from 75 °F to about 300 °F. When the raw data was reanalyzed using the locally weighted least squares regression (LOWESS) method, the mean CTE values determined were in good agreement with the established ASME Code values.

Westinghouse also formed a panel of licensee experts to review the available CTE data in open literature, review the ANL-provided CTE data, and perform an extensive CTE testing program on Alloy 600 and SA-508 steel material to supplement the existing data base. Two additional sets of CTE test data (different from those addressed in the previous paragraph) had CTE offsets at a low temperature that were not expected. Review of the test data showed that the first test, conducted in a vacuum, had proceeded to a maximum temperature of 700 degrees Celsius (°C), which changed the microstructure and the CTE of the steel during decreasing temperature conditions. As a result of the altered microstructure, the CTE test data generated in the second test, conducted in air, was also invalidated. As a result of the large "dead band" region and the altered microstructure, both data sets were excluded from the final CTE values obtained from the CTE testing program. The test program included multiple material heats to analyze chemistry influence on CTE values and repeat tests on the same samples were performed to analyze for test apparatus influence. Because the tubes are strain hardened when they are expanded into the tubesheet, strain hardened samples were also measured to check for strain hardening influence on CTE values.

The data from the test program was combined with the ANL data that was found to be acceptable, and the data obtained from the open literature search. A statistical analysis of the data uncertainties was performed by comparing deviations to the mean values obtained at the applicable temperatures. The correlation coefficients obtained indicated a good fit to a normal distribution, as expected. Finally, an evaluation of within-heat variability was performed due to increased data scatter at low temperatures. The within-heat variability assessment determined that the increase in data scatter was a testing accuracy limitation that was only present at low temperature. The CTE report is included as Appendix A to References 5.

The testing showed that the nominal ASME Code values for Alloy 600 and SA-508 steel were both conservative relative to the mean values from all the available data. Specifically, the CTE mean value for Alloy 600 was greater than the ASME Code value and the CTE mean value for SA-508 steel was smaller than the ASME Code value. Thus, the H* analyses utilized the ASME Code values as mean values in the H* analyses. The NRC staff concludes that this is conservative because it tends to lead to an over-prediction of the expansion of the tubesheet bore and an under-prediction of the expansion of the tube, thereby resulting in an increase in

the calculated H* distance. The statistical variances of the CTE parameters from the combined data base were utilized in the H* probabilistic analysis.

Based on its review of the Westinghouse CTE program, the NRC staff concludes that the CTE values used in the H* analyses are fully responsive to the concerns stated in Reference 4 and are acceptable.

4.2.2 Accident-Induced Leakage Considerations

Operational leakage integrity is assured by monitoring primary-to-secondary leakage relative to the applicable WCGS TS LCO limits in TS 3.4.13, "RCS Operational LEAKAGE." However, it must also be demonstrated that the proposed TS changes do not create the potential for leakage during DBA to exceed the accident leakage performance criteria in TS 5.5.9.b.2, including the leakage values assumed in the plant licensing basis accident analyses.

If a tube is assumed to contain a 100 percent through-wall flaw some distance into the tubesheet, a potential leak path between the primary and secondary systems is introduced between the hydraulically expanded tubing and the tubesheet. The leakage path between the tube and tubesheet has been modeled by the licensee's contractor, Westinghouse, as a crevice consisting of a porous media. Using Darcy's model for flow through a porous media, leak rate is proportional to differential pressure and inversely proportional to flow resistance. Flow resistance is a direct function of viscosity, loss coefficient, and crevice length.

Westinghouse performed leak tests of T/TS joint mockups to establish loss coefficient as a function of contact pressure. A large amount of data scatter, however, precluded quantification of such a correlation. In the absence of such a correlation, Westinghouse has developed a leakage factor relationship between accident-induced leak rate and operational leakage rate, where the source of leakage is from flaws located at or below the H* distance. Using the Darcy model, the leakage factor for a given type of accident is the product of four quantities. The first quantity is ratio of the maximum primary-to-secondary pressure difference during the accident divided by that for normal operating conditions. The second quantity is the ratio of viscosity under normal operating primary-water temperature divided by viscosity under the accident condition primary-water temperature. The third quantity is the ratio of crevice length under normal operating conditions to crevice length under accident conditions. This ratio equals 1, provided it can be shown that positive contact pressure is maintained along the entire H* distance for both conditions. The fourth quantity is the ratio of loss coefficient under normal operating conditions to loss coefficient under the accident conditions. Although the absolute value of these loss coefficients is not known, Westinghouse has assumed that the loss coefficient is constant with contact pressure such that the ratio is equal to 1. The NRC staff agrees that this is a conservative assumption, provided there is a positive contact pressure for both conditions along the entire H* distance and provided that contact pressure increases at each axial location along the H* distance when going from normal operating to accident conditions. Both assumptions were confirmed to be valid in the H* analyses.

Leakage factors were calculated for DBAs exhibiting a significant increase in primary-to-secondary pressure differential, including MSLB, FLB, locked rotor, and control rod ejection. The design basis FLB heat-up transient was found to exhibit the highest leakage factor, 2.50,

meaning that it is the transient expected to result in the largest increase in leakage relative to normal operating conditions.

As a condition of NRC approval of Amendment No. 186 for WCGS (Reference 9; i.e., the currently approved interim repair criteria), the licensee provided a commitment in Reference 10 that described how the leakage factor would be used to satisfy TS 5.5.9.a for condition monitoring and TS 5.5.9.b.2 regarding performance criteria for accident-induced leakage:

For the condition monitoring (CM) assessment, the component of operational leakage from the prior cycle from below the H* distance will be multiplied by a factor of 2.50 and added to the total accident leakage from any other source and compared to the allowable accident induced leakage limit. For the operational assessment (OA), the difference in the leakage between the allowable accident induced leakage and the accident induced leakage from sources other than the tubesheet expansion region will be divided by 2.50 and compared to the observed operational leakage. An administrative limit will be established to not exceed the calculated value.

In the subject amendment request (Reference 1), the licensee stated the program/procedure changes needed to meet these commitments were completed in accordance with the Amendment No. 186 and that these changes remain in place and will also apply to the subject license amendment. The NRC staff concludes that these previously implemented program/procedural changes will provide further assurance, in addition to the licensee's operational leakage monitoring processes, that accident-induced SG tube leakage will not exceed values assumed in the licensing bases accident analyses.

4.2.3 Proposed Change to TS 5.6.10, "Steam Generator Tube Inspection Report"

The NRC staff has reviewed the proposed conforming changes to the reporting requirements and concludes that they are sufficient to allow the staff to monitor the implementation of the proposed amendment. Therefore, the staff concludes that the proposed changes to the reporting requirements are acceptable.

4.2.4 Technical Bases for Interim H* Amendment

The proposed H* value is based on the conservative assumption that all tubes in all steam generators are severed at the H* location. This is a bounding, but necessary assumption for purposes of supporting a permanent H* amendment because the tubes will not be inspected below the H* distance for the remaining life of the steam generators, which may range up to 30 years from now depending on the plant, and because the tubes are susceptible to stress corrosion cracking below the H* distance. In addition, the proposed H* distance conservatively takes no credit for RCP associated with the tube hydraulic expansion process.

As discussed in Sections 4.2.1.3.2, 4.2.1.5.2, 4.2.1.5.3, and 4.2.1.7 of this safety evaluation, the staff has not completed its review of certain elements of the technical basis for the proposed H* distance. Thus, in spite of the significant conservatism embodied in the proposed H* distance, the NRC staff is unable to conclude at this time that the proposed H* distance is sufficiently

conservative from the standpoint of ensuring that all tubes will retain acceptable margins against pullout (i.e., structural integrity) and acceptable accident leakage integrity for the remaining lifetime of the steam generators, assuming all tubes to be severed at the H* location. The staff will need to complete its review of these certain elements before it can approve any request for a permanent H* amendment. However, for the reasons below, the staff concludes that the proposed H* distances will ensure for at least one operating cycle (one fuel cycle) that tube structural and leakage integrity will be maintained with structural safety margins consistent with the design basis and with leakage integrity within assumptions employed in the licensing basis accident analyses, without undue risk to public health and safety.

From a fleet-wide perspective (for all Westinghouse plants with tubes fabricated from thermally treated Alloy 600), the NRC staff has observed from operating experience that the extent of cracking is at an early stage in terms of the number of tubes affected by cracking below the H* distance and the severity of cracks, compared to the idealized assumption that all tubes are severed at the H* distance. Most of these cracks occur in the lower-most 1 inch of tubing, which is a region of relatively high residual stress associated with the 1-inch tack roll expansion in that region. Although the extent of cracking can be expected to increase with time, it is the staff's judgment based on experience that cracking will continue to be limited to a small percentage of tubes, mostly near the tube ends, over the next operating cycle (approximately 18 months for WCGS). The staff's observations are based on the review of SG tube inspection reports from throughout the PWR fleet. These reports are reviewed and the staff's conclusions are documented within a year of each SG tube inspection.

The most recent inspection of the tubing below the proposed 15.2 inch H* distance was performed in spring 2008 at WCGS. The licensee states that during the spring 2008 inspection, 76 tubes with flaw indications in the lower-most 1-inch of tubing were found, out of 18,414 tubes inspected (Reference 5). No indications of a complete 360-degree tube severance were found. No inspections below the H* distance were performed during the fall 2009 inspection; however, inspections above the H* distance continued to show no evidence of corrosion related indications (Reference 19). The NRC staff concludes that the extent and severity of cracking at WCGS is limited and within the envelope of industry experience with similar units.

Whereas the proposed H* distance of 15.2 inches was developed on the assumption that all tubes are severed at the H* location, the NRC staff concludes that few if any tubes are likely to be severed at the H* distance over the next operating cycle, based on the recent experience at WCGS and other similar units. For this reason, the staff concludes that there is sufficient conservatism embodied in the proposed H* distances to ensure acceptable margins against tube pullout during the next operating cycle for the reasons discussed above. The staff also concludes there is reasonable assurance during the next inspection cycle that any potential accident-induced leakage will not exceed the TS performance criteria for accident-induced leakage. This reflects current operating experience trends that cracking below the H* distance is occurring predominantly in the tack roll region near the bottom of the tube. At this location, it is the staff's judgment that the total resistance to primary-to-secondary leakage will be dominated by the resistance of any "crevice" in the roll expansion region (due to very high T/TS contact pressures in this region), such that the leakage factors discussed in Section 4.2.2 will remain conservative.

5.0 SUMMARY

The proposed license amendment for WCGS applies only to Refueling Outage 18 and the subsequent operating cycle. The NRC staff concludes that there is sufficient conservatism embodied in the proposed H* distances to ensure for at least one operating cycle (one fuel cycle) that tube structural and leakage integrity will be maintained with structural safety margins consistent with the design basis and with leakage integrity within assumptions employed in the licensing basis accident analyses, without undue risk to public health and safety. The proposed changes to TS 5.5.9 meet the requirements of GDC 14, 15, 30, 31 and 32 for the SG tubes and maintain the accident analyses and dose consequences previously reviewed and approved by the NRC staff for the applicable DBAs. Based on the above, the staff concludes that the proposed amendment is acceptable.

6.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Kansas State official was notified of the proposed issuance of the amendment. The State official had no comments.

7.0 ENVIRONMENTAL CONSIDERATION

The amendment changes a requirement with respect to the installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The NRC staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendment involves no significant hazards consideration and there has been no public comment on such finding published in the *Federal Register* on February 1, 2011 (76 FR 5623). Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

8.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

9.0 REFERENCES

1. Garrett, T. J. , Wolf Creek Nuclear Operating Corporation, letter to U.S. Nuclear Regulatory Commission, "Docket No. 50-482: Revision to Technical Specifications 5.5.9, 'Steam Generator (SG) Program,' and TS 5.6.10, 'Steam Generator Tube Inspection Report,' for a Temporary Alternate Repair Criterion," dated November 30, 2010 (ADAMS Accession No. ML103410455). This letter also transmitted Westinghouse

Electric Company report, WCAP-17330-P (Proprietary) and WCAP 17330-NP (Non-Proprietary), Revision 0, "H*: Resolution of NRC Technical Issue Regarding Tubesheet Bore Eccentricity (Model F/Model D5)," November 2010 (ADAMS Accession No. ML103410453 (Non-Proprietary)).

2. Garrett, T. J., Wolf Creek Nuclear Operating Corporation, letter to U.S. Nuclear Regulatory Commission, "Docket No. 50-482: Revision to Technical Specification 5.5.9, 'Steam Generator Tube Surveillance Program'," dated February 21, 2006 (ADAMS Accession No. ML060600456).
3. Garrett, T. J., Wolf Creek Nuclear Operating Corporation, letter to U.S. Nuclear Regulatory Commission, "Docket No. 50-482: Withdrawal of License Amendment Request for a Permanent Alternate Repair Criteria in Technical Specification (TS) 5.5.9, 'Steam Generator (SG) Program'," dated February 14, 2008 (ADAMS Accession No. ML080580201).
4. Singal, B. K., U.S. Nuclear Regulatory Commission, letter to Rick A. Muench, Wolf Creek Nuclear Operating Corporation, "Wolf Creek Generating Station – Withdrawal of License Amendment Request on Steam Generator tube Inspections," dated February 28, 2008 (ADAMS Accession No. ML080450185).
5. Garrett, T. J., Wolf Creek Nuclear Operating Corporation, letter to U.S. Nuclear Regulatory Commission, "Docket No. 50-482: Revision to Technical Specifications 5.5.9, 'Steam Generator (SG) Program,' and TS 5.6.10, 'Steam Generator Tube Inspection Report,' for Permanent Alternate Repair Criterion," dated June 2, 2009 (ADAMS Accession No. ML091590170). This letter also transmitted Westinghouse Electric Company Report, WCAP-17071-P (Proprietary) and WCAP-17071-NP (Non-Proprietary), Revision 0, "H*: Alternate Repair Criteria for the Tubesheet Expansion Region in Steam Generators with Hydraulically Expanded Tubes (Model F)," dated April 2009 (ADAMS Accession No. ML091590167 (Non-Proprietary)).
6. Garrett, T. J., Wolf Creek Nuclear Operating Corporation, letter to U.S. Nuclear Regulatory Commission, "Docket No. 50-482, Response to Request for Additional Information Related to License Amendment Request for a Permanent Alternate Repair Criterion to Technical Specification 5.5.9, 'Steam Generator (SG) Program'," dated August 25, 2009 (ADAMS Accession No. ML092450095). This letter also transmitted Westinghouse Electric Corporation LLC letter LTR-SGMP-09-100-P (Proprietary) and LTR-SGMP-09100-NP (Non-Proprietary), "Response to NRC Request for Additional Information on H*; Model F and D5 Steam Generators," dated August 12, 2009 (ADAMS Accession No. ML092450095 (Non-Proprietary)).
7. Garrett, T. J., Wolf Creek Nuclear Operating Corporation, letter to U.S. Nuclear Regulatory Commission, "Docket No. 50-482: Response to Request for Additional Information Related to License Amendment Request for a Permanent Alternate Repair Criterion to Technical Specification 5.5.9, 'Steam Generator (SG) Program'," dated September 3, 2009 (ADAMS Accession No. ML092590299). This letter also transmitted Westinghouse Electric Corporation LLC letter, LTR-SGMP-09-109-P (Proprietary) and

- LTR-SGMP-09109-NP (Non-Proprietary) "Response to NRC Request for Additional Information on H*; RAI #4; Model F and D5 Steam Generators," dated August 25, 2009 (ADAMS Accession No. ML092590299 (Non-Proprietary)).
8. Garrett, T. J., Wolf Creek Nuclear Operating Corporation, letter to U.S. Nuclear Regulatory Commission, "Docket No. 50-482, Revision to Technical Specifications (TS) 5.5.9, 'Steam Generator (SG) Program,' and TS 5.6.10, 'Steam Generator Tube Inspection Report'," dated September 15, 2009 (ADAMS Accession No. ML092730340).
 9. Singal, B. K., U.S. Nuclear Regulatory Commission, letter to Rick A. Muench, Wolf Creek Nuclear Operating Corporation, "Wolf Creek Generating Station - Issuance of Amendment Re. Revision to Technical Specification (TS) Section 5.5.9, "Steam Generator (SG) Program," and TS 5.6.10, "Steam Generator Tube Inspection Report," for Alternate Repair Criteria (TAC No. ME1393)," dated October 19, 2009 (ADAMS Accession No. ML092750606).
 10. Westinghouse Electric Company LLC, report, WCAP-17072-P (Proprietary) and WCAP 17072-NP (Non-Proprietary), Revision 0, "H*: Alternate Repair Criteria for the Tubesheet Expansion Region in Steam Generators with Hydraulically Expanded Tubes (Model D5)," May 2009 (ADAMS Accession No. ML091670172 (Non-Proprietary)).
 11. Ajluni, M. J., Southern Nuclear Company, letter to U.S. Nuclear Regulatory Commission, NL-09-1317, "Vogtle Electric Generating Plant, Supplemental Information for License Amendment Request to Revise Technical Specification (TS) Sections 5.5.9, "Steam Generator (SG) Program" and TS 5.6.10, "Steam Generator Tube Inspection Report" for Permanent Alternate Repair Criteria," dated August 28, 2009, transmitting Westinghouse Electric Company LLC letter LTR-SGMP-09-104-P Attachment "White Paper on Probabilistic Assessment of H*" dated August 13, 2009 (ADAMS Accession No. ML092450029 (Non-Proprietary)).
 12. Wright, D., U.S. Nuclear Regulatory Commission, letter to M. J. Ajluni, Southern Nuclear Operating Company, "Vogtle Electric Generating Plant, Units 1 and 2, Transmittal of Unresolved Issues Regarding Permanent Alternate Repair Criteria for Steam Generators," dated November 23, 2009 (ADAMS Accession No. ML093030490).
 13. U.S. Nuclear Regulatory Commission, memorandum from R. Taylor to G. Kulesa, "Vogtle Electric Generating Plant – Audit of Steam Generator H* Amendment Reference Documents," dated July 9, 2010 (ADAMS Accession No. ML101900227).
 14. U.S. Nuclear Regulatory Commission, Generic Letter 95-05, "Voltage-Based Repair Criteria for Westinghouse Steam Generator Tubes Affected by Outside Diameter Stress Corrosion Cracking," dated August 3, 1995 (ADAMS Accession No. ML031070113).
 15. NUREG-0844, "NRC Integrated Program for the Resolution of Unresolved Safety Issues A-3, A-4, and A-5 Regarding Steam Generator Tube Integrity," September 1988.

16. NUREG-1570, "Risk Assessment of Severe Accident-Induced Steam Generator Tube Rupture," March 1998.
17. Johnson, A. B., U.S. Nuclear Regulatory Commission, "Summary of the January 8, 2009 Category 2 Public Meeting with the Nuclear Energy Institute (NEI) and Industry to Discuss Steam Generator Issues," dated February 6, 2009 (ADAMS Accession No. ML090370782).
18. Riley, J. H., Nuclear Energy Institute, letter to C. Haney, U.S. Nuclear Regulatory Commission, dated July 7, 2008 (ADAMS Accession No. ML082100086), transmitting King, P. J., Babcock and Wilcox Canada LTD letter 2008-06-PK-001, "Re-assessment of PMIC measurements for the determination of CTE of SA 508 steel," dated June 6, 2008 (ADAMS Accession No. ML082100097).
19. Garrett, T. J., Wolf Creek Nuclear Operating Corporation, letter to U.S. Nuclear Regulatory Commission, "Docket No. 50-482, Results of the Sixteenth Steam Generator Tube Inservice Inspection' dated April 8, 2010 (ADAMS Accession No. ML101100676).

Principal Contributor: E. Murphy

Date: April 6, 2011

April 6, 2011

Mr. Matthew W. Sunseri
President and Chief Executive Officer
Wolf Creek Nuclear Operating Corporation
Post Office Box 411
Burlington, KS 66839

SUBJECT: WOLF CREEK GENERATING STATION - ISSUANCE OF AMENDMENT RE:
CHANGES TO TECHNICAL SPECIFICATION (TS) 5.5.9, "STEAM GENERATOR
(SG) PROGRAM," AND TS 5.6.10, "STEAM GENERATOR TUBE INSPECTION
REPORT" (TAC NO. ME5121)

Dear Mr. Sunseri:

The U.S. Nuclear Regulatory Commission (the Commission) has issued the enclosed Amendment No. 195 to Renewed Facility Operating License No. NPF-42 for the Wolf Creek Generating Station (WCGS). The amendment consists of changes to the Technical Specifications (TSs) in response to your application dated November 30, 2010.

The amendment revises TS 5.5.9, "Steam Generator (SG) Program," to exclude portions of the tube below the top of the steam generator tubesheet from periodic steam generator tube inspections during Refueling Outage 18 and the subsequent operating cycle. In addition, the amendment revises TS 5.6.10, "Steam Generator Tube Inspection Report," to remove a reference to the previous interim alternate repair criteria and to provide reporting requirements specific to the temporary alternate repair criteria.

A copy of our related Safety Evaluation is enclosed. The Notice of Issuance will be included in the Commission's next biweekly *Federal Register* notice.

Sincerely,

/RA/

James R. Hall, Senior Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-482

Enclosures:

- 1. Amendment No. 195 to NPF-42
- 2. Safety Evaluation

cc w/encls: Distribution via Listserv

DISTRIBUTION:

PUBLIC	RidsNrrDirItsB Resource	RidsNrrLJJBurkhardt Resource
LPLIV r/f	RidsNrrDorIDpr Resource	RidsOgcRp Resource
RidsAcrsAcnw_MailCTR Resource	RidsNrrDorLpl4 Resource	RidsRgn4MailCenter Resource
RidsNrrDciCsgb Resource	RidsNrrPMWolfCreek Resource	EMurphy, NRR/DCI/CSGB

ADAMS Accession No. ML110840590

*by SE dated 3/14/2011

OFFICE	NRR/LPL4/PM	NRR/LPL4/LA	DIRS/ITSB/BC	DCI/CSGB/BC	OGC	NRR/LPL4/BC	NRR/LPLR/PM
NAME	JRHall	JBurkhardt	RElliott (MHamm for)	RTaylor*	DRoth	MMarkley (BSingal for)	JRHall
DATE	3/30/11	3/28/11	3/31/11	3/14/11	4/1/11	4/6/11	4/6/11

OFFICIAL RECORD COPY