

APPENDIX A

NOTICE OF VIOLATION

Tennessee Valley Authority  
Bellefonte Units 1 and 2

License Nos. CPPR-122  
CPPR-123

Based on the NRC inspection March 27-30, 1979, certain of your activities were apparently not conducted in full compliance with NRC requirements as indicated below. These items have been categorized as described in correspondence to you dated December 31, 1974.

- A. As required by Criterion XVII of Appendix B to 10 CFR 50, and implemented by the FSAR, paragraph 17.1A.17, Sufficient records must be maintained to furnish evidence of activities affecting quality and these records shall include materials analyses and qualifications of personnel.

Contrary to the above, on March 29, 1979 the only certifications available for five heats of filler material were "typical" chemistries signed by the filler metal supplier and one heat of filler metal did not have any certification available. Also on this date the latest eye test record for the inspector of record on welds 2NX 694, 2NX 893 and 2NX 925 was missing; the qualification record for visual test for the inspector of record on welds 1NX569 1NX640, 1NX746 and 1NX1060 was missing; and the qualification record for vacuum box test for the inspector of record on welds 1NX640, 1NX746, 1NX877, 1NX877, 1NX892 and 2NX648 was missing.

This is a deficiency.

7906220238