

---

---

# Seismic Review Table

---

---

Prepared by M. Subudhi, M. Reich, B. Koplik, J. Lane

**Department of Nuclear Energy  
Brookhaven National Laboratory**

**Prepared for  
U. S. Nuclear Regulatory  
Commission**

## NOTICE

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, or any of their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for any third party's use, or the results of such use, of any information, apparatus product or process disclosed in this report, or represents that its use by such third party would not infringe privately owned rights.

Available from

GPO Sales Program  
Division of Technical Information and Document Control  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

and

National Technical Information Service  
Springfield, Virginia 22161

---

---

# Seismic Review Table

---

---

Manuscript Completed: April 1980  
Date Published: May 1980

Prepared by  
M. Subudhi, M. Reich, B. Koplik, J. Lane\*

Structural Analysis Group  
Department of Nuclear Energy  
Brookhaven National Laboratory  
Upton, NY 11973

\*Staff, U.S. Nuclear Regulatory Commission

Prepared for  
Division of Operating Reactors  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555  
NRC FIN No. A 3326



## ABSTRACT

The Seismic Review Table is a summary of Engineering Design parameters that were employed in the seismic analysis and design of nuclear power plants. The table covers 71 reactors licensed to operate by the U.S.N.R.C. The information contained is listed plant by plant and consists of OBE and SSE "g" Level and Modified Mercalli Intensity; Earthquake Time History used to develop the ground response spectra or as input in the dynamic analysis; Number of Earthquake Components used and Method of Combining Them; Method of Modal Combination; Type of Ground Design Spectra; Method of Generation of Floor Response Spectra; Type of Foundation and Depth; Type, Thickness, Shear Wave Velocity and Shear Modulus Profile of the Surrounding Subgrade Soil and Bedrock; Ground Water Table Depth; nearby Dams; Modelling Method used for soil-structure interaction; Material Damping of Soil; Limitation on Modal Damping . Damping Values; and Loading Combinations, and Acceptance Criteria for Category I Structures, Mechanical Equipment, Piping, and Electrical systems. The goal of the Seismic Review Table is to provide a reference of the available information relevant to the seismic design of currently licensed nuclear power plants.



TABLE OF CONTENTS

	<u>Page</u>
Abstract.....	iii
Acknowledgements.....	vii
Introduction.....	1
Program Tasks and Accomplishments.....	2
Table I - Contents of Seismic Review Table (Currently Licensed in the United States).....	I-1

## ACKNOWLEDGEMENTS

The authors wish to acknowledge their indebtedness and gratitude to various people consulted during the preparation of the Seismic Review Tables. Particular thanks are due to our Department Librarians, Mrs. Helen Todosow and Mrs. Catherine Green for their help in gathering and obtaining the various FSAR's, amendments, etc. and to Dr. C. P. Tan of the Structural Engineering Branch, NRC, for the Containment Vessel data shown in Table I of this report. Grateful acknowledgement is also due to Larry Shao, Acting Assistant Director of Engineering Programs, Division of Operating Reactors and Assistant Director for General Reactor Safety Research, NRC, and Dr. P. T. Kuo, Section Leader, Seismic Review Group, NRC, for their constructive criticism and advice regarding the contents of the review tables. Finally to Miss Joan Murray who with patience typed and retyped the corrected drafts, our sincerest gratitude is due.

## INTRODUCTION

The intent of this report is to enable a quick reference of the major seismic design parameters inherent in the 71 currently licensed nuclear power plants. All of the presented data was obtained from the existing Final Safety Analysis Reports (FSAR) and their associated amendments. The results are tabulated for each plant in a five page "Seismic Review Table." The major headings in the table are:

- A) Earthquake data
- B) Method of combination (e.g., modes and earthquakes directional components)
- C) Design spectra
- D) Foundation and liquefaction assessment
- E) Soil-structure interaction
- F) Damping, load combination and acceptance criteria and allowable stresses for:
  - 1) Category I structures
  - 2) Mechanical Equipment and piping
  - 3) Electrical equipment

Table I lists all of the plants together with the names of the owners, the location, the principal reactor contractor, the plant architectural engineers, the type of plant (PWR, BWR, HTGR), the type of containment vessel, and the electrical and thermal power output. FSAR's for all the plants listed in the table have been reviewed and the tabulated results are given in this report. For completeness Figure 1 depicting the geographical locations of the operational plants is also included.

## PROGRAM TASKS AND ACCOMPLISHMENTS

Efforts under this program can be subdivided into three distinct stages: Stage 1 involved the determination and collection of all available plant FSAR's and related questions, answers, and amendments. Next, under Stage 2, the collected information was reviewed in detail for relevance to the information needed for the Seismic Review Table. Finally, under Stage 3, the pertinent parameters were assembled and summarized in tabular form.

With reference to the work carried out under Stage 1, it should be realized that the documented information contains numerous sections, subsections, and amendments per plant which were compiled over a span of many years. This information had to be reviewed to ascertain which documents were available and which had to be ordered. This was accomplished by carrying out a careful review of the documents and comparing the information contained within the documents against the information compiled in the following reference reports:

Title Listing of Civilian Power Reactor Docket Literature in Nuclear Science Abstracts, volumes 21-26 (1967-1972), TID-3354 R1. U.S. Atomic Energy Commission, Technical Information Center, April 1973.

Title Listing of Civilian Power Reactor Docket Literature in Nuclear Science Abstracts, volumes 27 (Jan.-June 1973), TID-3324-R1-S1. U.S. Atomic Energy Commission, Technical Information Center, September 1973.

Title Listing of Power Reactor Docket Information, PRDI-74-12. U.S. Atomic Energy Commission, Technical Information Center, December 1974.

Power Reactor Docket Information, Annual Cumulation, NUREG/PRDI-75/12. U.S. Energy Research and Development Administration, Technical Information Center, December 1975.

Power Reactor Docket Information, Annual Cumulation, NUREG/PRDI-76/12/P1. U.S. Energy Research and Development Administration, Technical Information Center, December 1976.

Power Reactor Docket Information, Annual Cumulation, NUREG/PRDI-77/12/P1. U.S. Dept. of Energy, Technical Information Center, December 1977.

Power Reactor Docket Information, Annual Cumulation, NUREG/PRDI-78/12/P1. U.S. Dept. of Energy, Technical Information Center, December 1978.

Since there was no specific standardized FSAR format until 1975-76, each FSAR had to be examined on an individual basis. In a number of cases the FSAR was actually defined as an amendment to the PSAR. Once it was determined what information was missing and what part of the missing information involved seismic design criteria, the necessary steps were taken to obtain the required documents.

Once the material needed for the review was compiled, Stage 2 efforts were initiated. For each plant assembled FSAR's were first reviewed for the pertinent seismic information. These were available either in "hard cover" or in "microfiche" form. Next, the amendments which include various questions and answers about the plant raised over a period of many years were reviewed and the gathered information was then compiled and referenced for section and page number.

Under Stage 3, the compiled reference material of Stage 2 was prepared and extracted for insertion into the Seismic Review Tables. The information given in the table thus reflects the data up to and including the latest amendments available at time of publication. The tables are numbered according to the numbering scheme shown in the first column of Table I. For each number, a set of five pages comprising the Seismic Review Table is presented with the page number appearing in the lower right hand corner in sequence. As an example, page 8-2 would indicate the eighth entry on Table I, with the number 2 representing the second page of the five-page review table.

Referring to the Seismic Review Tables, the first item assembled is on page 1 of the five-page table. The name of the plant with reactor unit numbers (if more than one), the type of reactors, and containment, Nuclear Steam System Supplier (NSSS), the architect engineer, and the CP/OL issue dates. Next, under the heading of earthquake data, information pertaining to OBE, SSE, and earthquake time-history was assembled. The OBE and SSE information was further broken down into horizontal and vertical "g" values and Modified Mercalli Intensity values. Reference pages, sections, and amendment numbers are listed in the tables for all assembled information. Under the time history column, names of the earthquake records used are given. These records in turn are

used either for the development of the ground design spectra or are modified so that their response spectra envelopes the specified ground design spectra. Generally speaking, this information was available for most of the plants. However, some of the early plants, such as Yankee Rowe, did not have this information in the reviewed docket, and thus the term "not available" is written in the table. For those cases where the available information was unclear, the term "unclear information" appears in the table, together with the pertinent page numbers where the unclear information is given so that the reader can look up the information for further insight.

Returning to headings OBE and SSE, in many plants the vertical components were equal to two-thirds of the horizontal, with OBE values typically one-half of the SSE. For the earthquake time-history, the older plants usually used El Centro or Taft, while the newer plants used synthetic time-histories.

Methods of combinations were assembled under the subheadings "Number of Earthquake Components Used and Its Combination" and "Modal Combination." The information under these headings includes such items as the the number of horizontal and vertical components used for the analysis, the number of modes considered, and how they were combined, e.g., absolute sum, SRSS, or algebraic sum. It is to be noted that the term "modal combination used" in the table refers to the response spectrum analysis.

The final item on page 1 involves the design spectra with the two subheadings entitled "Type of Ground Design Spectra" and "Method of Generation of Floor Response Spectra." Ground design spectra includes the Housner, Newmark, and Regulatory Guide 1.60 response spectra or any other method specified in the FSAR's. The most commonly used method for generating the floor response spectra was the time-history method. When information regarding the input

time-history was available, it was also included under this heading. For some of the older plants, the ground design spectra was directly used with some amplification factor.

Turning to page 2 of 5 of the table, the major headings are "Foundation and Liquefaction Assessment" and "Soil-Structure Interaction." The first item contains four subtopics: "Type of Foundation," "Bearing Information" (including information related to the type, thickness, and shear velocity profile), "Groundwater Table," and "Dams." Foundation description and bedrock characteristics are listed for the containment building. Information regarding structures on pile foundations is also given under this heading. Bearing Information lists such items as type of rock (dolomite, glacial fill, sandstone, etc.), the thickness of the various soil deposits, and shear wave velocities. Groundwater Table information and the existence of nearby dam locations were obtained from the site geological survey.

"Soil Structure Interaction" consists of four subtopics. "Method of Modelling" lists the mathematical model chosen for generating the floor response spectra of the reactor building and the soil beneath it. Usually the structure is modeled as a conventional stick model while the soil is represented as either a lumped spring or finite element model. It is to be noted that a number of plants have their foundation on bedrock. When reviewing the soil structure interaction modelling method, it was found that for some plants a fixed base method was employed. For these cases, the notation fixed base method appears. For cases where no statement was found as to the type of modelling used, the term "not available" was entered in the table. The term "not available" should only be interpreted as a statement of fact with reference to the material presented in the FSAR; it only means that no information about the particular item was found. Other subtopics include the "Soil Shear Strength Modulus Profile," "Material Damping of Soil," and the "Limitation on Modal Damping."

Pages 3, 4, and 5 of the Seismic Review Table are devoted respectively to Category I--structure, mechanical, piping and electrical equipment. Each of these pages have common headings that include "Damping Values" (OBE/SSE) and "Design Criteria," with the latter heading containing subheadings for load

combination and acceptance criteria/allowable stresses. "Method of Qualification" (testing or analytical) was included for the mechanical equipment, piping and electrical equipment given on pages 4 and 5. Generally, very little information was available for electrical equipment.

The information listed for the 11 SEP plants (Big Rock Point, Dresden 1 and 2, Ginna, Haddam Neck, LaCrosse, Millstone 1, Oyster Creek, Palisades, San Onofre 1, and Yankee Rowe) was partly obtained through the use of unpublished docket search reports supplied to us by the Systematic Evaluation Program Branch, DOR. This information supplements what was obtained by Brookhaven staff members in their docket search.

In conclusion, this report contains much information covering a wide range of seismic topics. It is possible that some relevant information has been inadvertently overlooked. The Structural Engineering Branch of the Division of Engineering has the responsibility for maintaining these tables and would appreciate any contribution from interested parties as to additions or modifications which might be made to improve it.

The information contained here comprises a data base which will be used to evaluate conformance of the operating reactors with current seismic design guidelines.





CONTENTS

Seismic Review Table No.	Name and/or owner	Location	NSSS Manufacturer **	Architect Engineer **	Reactor Type	Containment Type *	Power	
							Unit Size Net MW(e)	Reactor MW (t)
1-1	Arkansas Nuclear One, Unit 1 (Arkansas Power & Light Co.)	Russellville, Ark.	B&W	Bechtel	PWR	(11)	850	2,568
2-1	Arkansas Nuclear One, Unit 2 (Arkansas Power & Light Co.)	Russellville, Ark.	Comb.	Bechtel	PWR	(11)	912	2,815
3-1	Beaver Valley Power Station, Unit 1 (Duquesne Light Co., Ohio Edison Co., and Pennsylvania Power Co.)	Shippingport, Pa.	West.	S&W	PWR	(7)	852	2,652
4-1	Big Rock Point Plant Nuclear (Consumer Power Co.)	Big Rock Point, Mich.	GE	Bechtel	BWR	(1)	72	240
5-1	Browns Ferry Nuclear Power Station, Unit 1 (Tennessee Valley Authority)	Decatur, Ala.	GE	TVA	BWR	(2)	1,065	3,293
5-1	Browns Ferry Nuclear Power Station, Unit 2 (Tennessee Valley Authority)	Decatur, Ala.	GE	TVA	BWR	(2)	1,065	3,293
5-1	Browns Ferry Nuclear Power Station, Unit 3 (Tennessee Valley Authority)	Decatur, Ala.	GE	TVA	BWR	(2)	1,065	3,293
6-1	Brunswick Steam Electric Plant, Unit 1 (Carolina Power & Light Co.)	Southport, N.C.	GE	UE&C	BWR	(5)	821	2,436
6-1	Brunswick Steam Electric Plant, Unit 2 (Carolina Power & Light Co.)	Southport N.C.	GE	UE&C	BWR	(5)	821	2,436
7-1	Calvert Cliffs Nuclear Power Plant, Unit 1 (Baltimore Gas & Electric Co.)	Lusby, Md.	Comb.	Bechtel	PWR	(10)	845	2,700
7-1	Calvert Cliffs Nuclear Power Plant, Unit 2 (Baltimore Gas & Electric Co.)	Lusby, Md.	Comb.	Bechtel	PWR	(10)	845	2,700
8-1	Cooper Nuclear Station (Nebraska Public Power District and Iowa Power and Light Co.)	Brownville, Nebr.	GE	B&R	BWR	(2)	778	2,381
9-1	Crystal River Nuclear Plant, Unit 3 (Florida Power Corp.)	Red Level, Fla.	B&W	Gilbert	PWR	(10)	825	2,452

TABLE I: CURRENTLY LICENSED REACTORS IN UNITED STATES

Seismic Review Table No.	Name and/or owner	Location	NSSS Manufacturer **	Architect Engineer **	Reactor Type	Containment Type *	Power	
							Unit Size Net MW(e)	Reactor MW (t)
10-1	Davis-Besse Nuclear Power Station, Unit 1 (Cleveland Electric Illuminating Co.)	Oak Harbor, Ohio	B&W	Bechtel	PWR	(4)	906	2,772
11-1	Donald C. Cook Nuclear Power Plant, Unit 1 (Indiana and Michigan Electric Co.)	Bridgman, Mich.	West.	AEP	PWR	(6)	1,054	3,250
11-1	Donald C. Cook Nuclear Power Plant, Unit 2 (Indiana and Michigan Electric Co.)	Bridgman, Mich.	West.	AEP	PWR	(6)	1,100	3,391
12-1	Dresden Nuclear Power Station, Unit 1 (Commonwealth Edison Co.)	Morris, Ill.	GE	Bechtel	BWR	(1)	200	700
13-1	Dresden Nuclear Power Station, Unit 2 (Commonwealth Edison Co.)	Morris, Ill.	GE	S&L	BWR	(2)	794	2,527
13-1	Dresden Nuclear Power Station, Unit 3 (Commonwealth Edison Co.)	Morris, Ill.	GE	S&L	BWR	(2)	794	2,527
14-1	Duane Arnold Energy Center, Unit 1 (Iowa Electric Light & Power Co., Central Iowa Power Cooperative, and Corn Belt Power Cooperative)	Palo, Iowa	GE	Bechtel	BWR	(2)	538	1,593
15-1	Edwin I. Hatch Nuclear Plant, Unit 1 (Georgia Power Co.)	Baxley, Ga.	GE	Bechtel	BWR	(2)	786	2,436
16-1	Edwin I. Hatch Nuclear Plant, Unit 2 (Georgia Power Co.)	Baxley, Ga.	GE	Bechtel	BWR	(2)	795	2,436
17-1	Fort Calhoun Station, Unit 1 (Omaha Public Power District)	Fort Calhoun, Nebr.	Comb.	G&H	PWR	(9)	457	1,420
18-1	Fort St. Vrain Nuclear Generating Station (Public Service Co. of Colorado)	Platteville, Colo.	GA	S&L	HTGR	(9)	330	842
19-1	Haddam Neck Plant (Connecticut Yankee Atomic Power Co.)	Haddam Neck, Conn.	West.	S&W	PWR	(8)	575	1,825
20-1	H. B. Robinson Plant, Unit 2 (Carolina Power & Light Co.)	Hartsville, S. C.	West.	Ebasco	PWR	(9)	700	2,200

CURRENTLY LICENSED REACTORS IN UNITED STATES (continued)

Seismic Review Table No.	Name and/or owner	Location	NSSS Manufacturer **	Architect Engineer **	Reactor Type	Containment Type *	Power	
							Unit Size Net MW(e)	Reactor MW (t)
21 -1	Humboldt Bay Power Plant, Unit 3 (Pacific Gas & Electric Co.)	Eureka, Calif.	GE	Bechtel	BWR	(1)	63	242
22 -1	Indian Point Station, Unit 1 (Consolidated Edison Co. of New York, Inc.)	Buchanan, N.Y.	B&W	UE&C	PWR	(3)	265	615
23 -1	Indian Point Station, Unit 2 (Consolidated Edison Co. of New York, Inc.)	Buchanan, N.Y.	West.	UE&C	PWR	(8)	873	2,758
24 -1	Indian Point Station, Unit 3 (Power Authority of New York)	Buchanan, N.Y.	West.	UE&C	PWR	(8)	965	2,760
25 -1	James A. FitzPatrick Nuclear Power Plant (Power Authority of the State of New York)	Scriba, N.Y.	GE	S&W	BWR	(2)	821	2,436
26 -1	Joseph M. Farley Nuclear Plant, Unit 1,2 (Alabama Power Co.)	Dothan, Ala.	West.	Bechtel	PWR	(11)	821	2,652
27 -1	Kewaunee Nuclear Power (Wisconsin Power & Light Co., Wisconsin Public Service Co., and Madison Gas & Electric Co.)	Carlton, Wis.	West.	Pioneer	PWR	(4)	535	1,650
28 -1	La Crosse (Genoa) Nuclear Generating Station (Dairyland Power Cooperative)	La Crosse, Wis.	AC	S&L	BWR	(1)	50	165
29 -1	Maine Yankee Atomic Power Plant (Maine Yankee Atomic Power Co.)	Wiscasset, Maine	Comb.	S&W	PWR	(7)	790	2,500
30 -1	Millstone Nuclear Power Station, Unit 1 (Northeast Nuclear Energy Co.)	Waterford, Conn.	GE	Ebasco	BWR	(2)	660	2,011
31 -1	Millstone Nuclear Power Station, Unit 2 (Northeast Nuclear Energy Co.)	Waterford, Conn.	Comb.	Bechtel	PWR	(11)	830	2,560
32 -1	Monticello Nuclear Generating Plant (Northern States Power Co.)	Monticello, Minn.	GE	Bechtel	BWR	(2)	545	1,670
33 -1	Nine Mile Point Nuclear Station, Unit 1 (Niagara Mohawk Power Corp.)	Scriba, N.Y.	GE	S&W	BWR	(2)	610	1,850

Seismic Review Table No.	Name and/or owner	Location	NSSS Manufacturer **	Architect Engineer **	Reactor Type	Containment Type *	Power	
							Unit Size Net MW(e)	Reactor MW (t)
34-1	North Anna Power Station, Unit 1 (Virginia Electric & Power Co.)	Mineral, Va.	West.	S&W	PWR	(7)	907	2,775
35-1	Oconee Nuclear Station, Unit 1 (Duke Power Co.)	Seneca, S. C.	B&W	Utility & Bechtel	PWR	(10)	887	2,568
35-1	Oconee Nuclear Station, Unit 2 (Duke Power Co.)	Seneca, S. C.	B&W	Utility & Bechtel	PWR	(10)	887	2,568
35-1	Oconee Nuclear Station, Unit 3 (Duke Power Co.)	Seneca, S. C.	B&W	Utility & Bechtel	PWR	(10)	887	2,568
36-1	Oyster Creek Nuclear Power Plant, Unit 1 (Jersey Central Power & Light Co.)	Toms River, N.J.	GE	B&R	BWR	(2)	650	1,930
37-1	Palisades Nuclear Plant, Unit 1 (Consumers Power Co. of Michigan)	South Haven, Mich.	Comb.	Bechtel	PWR	(10)	805	2,530
38-1	Peach Bottom Atomic Power Station, Unit 2 (Philadelphia Electric Co., Public Service Electric & Gas Co., Atlantic City Electric Co., and Delmarva Power & Light Co.)	Peach Bottom, Pa.	GE	Bechtel	BWR	(2)	1,065	3,293
38-1	Peach Bottom Atomic Power Station, Unit 3 (Philadelphia Electric Co., Public Service Electric & Gas Co., Atlantic City Electric Co., and Delmarva Power & Light Co.)	Peach Bottom, Pa.	GE	Bechtel	BWR	(2)	1,065	3,293
39-1	Pilgrim Nuclear Power Station, Unit 1 (Boston Edison Co.)	Plymouth, Mass.	GE	Bechtel	BWR	(7)	655	1,998
40-1	Point Beach Nuclear Plant, Unit 1 (Wisconsin Electric Power Co. and Wisconsin Michigan Power Co.)	Two Creeks, Wis.	West.	Bechtel	PWR	(10)	497	1,518
40-1	Point Beach Nuclear Plant, Unit 2 (Wisconsin Electric Power Co. and Wisconsin Michigan Power Co.)	Two Creeks, Wis.	West.	Bechtel	PWR	(10)	497	1,518

Seismic Review Table No.	Name and/or owner	Location	NSSS Manufacturer **	Architect Engineer **	Reactor Type	Containment Type *	Power	
							Unit Size Net MW(e)	Reactor MW (t)
41-1	Prairie Island Nuclear Generating Plant, Unit 1 (Northern States Power Co.)	Red Wing, Minn.	West.	Pioneer	PWR	(4)	530	1,650
41-1	Prairie Island Nuclear Generating Plant, Unit 2 (Northern States Power Co.)	Red Wing, Minn.	West.	Pioneer	PWR	(4)	530	1,650
42-1	Quad-Cities Station, Unit 1 (Commonwealth Edison Co. and Iowa-Illinois Gas & Electric Co.)	Cordova, Ill.	GE	S&L	BWR	(2)	789	2,511
42-1	Quad-Cities Station, Unit 2 (Commonwealth Edison Co. and Iowa -Illinois Gas & Electric Co.)	Cordova, Ill.	GE	S&L	BWR	(2)	789	2,511
43-1	Rancho Seco Nuclear Generating Station, Unit 1 (Sacramento Municipal Utility District)	Clay Station, Calif.	B&W	Bechtel	PWR	(11)	918	2,772
44-1	Robert Emmett Ginna Nuclear Power Plant, Unit 1 (Rochester Gas & Electric Co.)	Ontario, N.Y.	West.	Gilbert	PWR	(9)	490	1,520
45-1	Salem Nuclear Generating Station, Unit 1,2 (Public Service Electric & Gas Co., Philadelphia Electric Co., Atlantic City Electric Co., and Delmarva Power & Light Co.)	Salem, N.J.	West.	UE&C	PWR	(8)	1,090	3,338
46-1	San Onofre Nuclear Generating Station, Unit 1 (Southern California Edison and San Diego Gas & Electric Co.)	San Clemente, Calif.	West.	Bechtel	PWR	(3)	436	1,347
47-1	Shippingport Atomic Power Station (DOE and Duquesne Light Co.)	Shippingport, Pa.	West.	B&R,S&W	PWR	(3)	60	236
48-1	St. Lucie Plant, Unit 1 (Florida Power & Light Co.)	Fort Pierce, Fla.	Comb.	Ebasco	PWR	(4)	802	2,560
49-1	Surry Power Station, Unit 1 (Virginia Electric & Power Co.)	Gravel Neck, Va.	West.	S&W	PWR	(7)	822	2,441

CURRENTLY LICENSED REACTORS IN UNITED STATES (continued)

Seismic Review Table No.	Name and/or owner	Location	NSSS Manufacturer **	Architect Engineer **	Reactor Type	Containment Type *	Power	
							Unit Size Net MW(e)	Reactor MW (t)
49 -1	Surry Power Station, Unit 2 (Virginia Electric & Power Co.)	Gravel Neck, Va.	West.	S&W	PWR	(7)	822	2,441
50 -1	Three Mile Island Nuclear Station, Unit 1 (Metropolitan Edison Co.)	Middletown, Pa.	B&W	Gilbert	PWR	(10)	819	2,535
51 -1	Three Mile Island Nuclear Station, Unit 2 (Metropolitan Edison Co.)	Middletown, Pa.	B&W	B&R	PWR	(10)	906	2,772
52 -1	Trojan Nuclear Plant, Unit 1 (Portland General Electric Co., Eugene Water & Electric Board, and Pacific Power & Light Co.)	Prescott, Oreg.	West.	Bechtel	PWR	(12)	1,130	3,411
53-1	Turkey Point Plant, Unit 3 (Florida Power & Power Co.)	Florida City, Fla.	West.	Bechtel	PWR	(10)	693	2,200
53 -1	Turkey Point Plant, Unit 4 (Florida Power & Power Co.)	Florida City, Fla.	West.	Bechtel	PWR	(10)	693	2,200
54 -1	Vermont Yankee Nuclear Power Station (Vermont Yankee Nuclear Power Corp.)	Vernon, Vt.	GE	Ebasco	BWR	(2)	514	1,593
55 -1	Yankee-Rowe Nuclear Power Station (Yankee Atomic Electric Co.)	Rowe, Mass.	West.	S&W	PWR	(3)	175	600
56 -1	Zion Nuclear Plant, Unit 1 (Commonwealth Edison Co.)	Zion, Ill.	West.	S&L	PWR	(10)	1,040	3,250
56 -1	Zion Nuclear Plant, Unit 2 (Commonwealth Edison Co.)	Zion, Ill.	West.	S&L	PWR	(10)	1,040	3,250

\* Containment types:

- (1) Pre-Mark (Steel)
- (2) Mark I (Steel)
- (3) Dry Containment-Spherical (Steel)
- (4) Dry Containment-Cylindrical (Steel)
- (5) Mark I (Reinforced Concrete)
- (6) Ice Condenser (Reinforced Concrete)
- (7) Sub-Atmospheric (Reinforced Concrete)
- (8) Atmospheric (Reinforced Concrete)
- (9) Without Buttresses (Pre-Stressed Concrete)

- (10) 6 Buttresses With Shallow Dome (Pre-Stressed Concrete)
- (11) 3 Buttresses With Shallow Dome (Pre-Stressed Concrete)
- (12) 3 Buttresses With Hemispherical Dome (Pre-Stressed Concrete)

\*\* Manufacturers and Engineers  
AC = Allis-Chalmer Mfg. Co.  
AEP = American Electric Power Service Corp.

B&R = Burns & Roe, Inc.  
B&W = Babcock & Wilcox Co.  
Comb. = Combustion Eng., Inc.  
GA = General Atomic  
GE = General Electric Co.  
G&H = Gibbs & Hills, Inc.  
S&W = Stone & Webster Eng. Corp.  
S&L = Sargent & Lundy Engineers  
TVA = Tennessee Valley Authority

UE&C = United Engineers & Constructors  
West. = Westinghouse Electric Corp.

I-6

SEISMIC REVIEW TABLE

Docket Number

50-313

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					EARTHQUAKE TIME HISTORY	METHOD OF COMBINATION		DESIGN SPECTRA	
	OBE		INTENSITY MM	SSE			NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g		HOR. g	VERT. g					
<p>ARKANSAS NUCLEAR UNIT No. 1</p> <p>Reactor type: PWR Containment type: 3 buttresses with shallow dome (prestressed con- crete)</p> <p>NSSS Manufacturer: Babcock &amp; Wilcox Arcitect Engineer: Bechtel</p> <p>12-68/5-74</p>	0.10	0.067	VII	0.20	0.133	<p>A synthetic time history is generated so that its response spectra envelops the ground design spectrum.</p>	<p>Three components: 2 horizontal &amp; 1 vertical. Each horizontal was combined with the ver- tical, assuming simultaneous occurrences.</p>	<p>SRSS (No closely spaced modes).</p>	Housner	<p>Time-history method . Vertical ground response spec- trum was used for equipment design (no ver- tical floor response spec- tra generated).</p>
	Sec. 5.1.1.2.5 p. 5-28a		p. 2-19	Sec. 5.1.1.2.5 p. 5-28a		p. 5.A-6 Amend. 28	Sec. 5.A.4.1 p.5.A-5 Amend. 28	Sec. 5.A.4.2 p. 5.A-7	Sec. 5.A 4.1 p. 5.A-5 Figs. 5.A-1 and 5.A-2	Sec. 5.A, 4.2 p. 5.A-6 p. 5-28c Amend. 23

8/18/72

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
Flat Slab 9 feet  "All Class I structures utilize the shale bedrock as a foundation"	Bedrock which consists of Pennsylvanian McAlester formation shale.	13 ft to 24 ft.	Properties of shale, 10,000 to 14,500 fps.	Most wells drilled into bedrock are less than 150 ft.	Not available.	Stick model with soil springs, as indicated in Fig. 5A-3 Fig. 5A-4 Fig. 5A-5	Not available	Unclear information	Not available
Sec. 5.1.1.1 p. 5.1 Sec. 2.7.2 p. 2-16		p. 2-24	p. 2-16	Table 2-5 p. 2-28	Sec. 2.5.3 p. 2-7a				Sec. 5.1.1.5.6 p. 2-28a

SEISMIC REVIEW TABLE

STRUCTURES			
DAMPING OBE/SSE	DESIGN CRITERIA		
	LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES	
(% critical damping)			
Welded steel plate assemblies	1.0/1.0	Y = 1/φ (1.25 D + 1.0 R + 1.25 E) Y = 1/φ (1.25 D + 1.25 H + 1.25 E) Y = 1/φ (1.25 D + 1.25 H + 1.25 W)	ACI-318-63 Code AWS D12.1-61
Welded steel framed structures	2.0/2.0	Y = 1/φ (1.0 D + 1.8 E) (For structural element carrying mainly earthquake forces.)	
Bolted or riveted steel framed structure	2.5/2.5	Y = 1/φ (1.0 D + 1.0 R + 1.0 E') Y = 1/φ (1.0 D + 1.0 H + 1.0 E') (0.9 D is used where dead load subtracts for critical stress in the first three equations.)	Ultimate strength design "Design of Protective Structures", Dept. of Navy, NP-3726, August 1950.
Reinforced concrete equipment supports	2.0/3.0	Y = yield strength. D = dead load.	
Reinforced concrete frames and buildings	3.0/5.0	R = force or pressure on structure due to rupture of any pipe. H = force on structure due to thermal expansion. E = design earthquake load. E' = maximum earthquake load.	
Prestressed concrete structure	2.0/5.0	W = tornado load φ = 0.9 for reinforced concrete, 0.85 for shear, bond. Anchorage in reinforced concrete. 0.75 for spirally reinforced concrete component members. 0.70 for tied component members. 0.90 for fabricated structural steel, and 0.90 for reinforced steel (not prestressed) in direction of tension.	
Sec. 5.A.4 p. 5.A-6		Sec. 5.A.3 p. 5.A-3 p. 5.A-4	Sec. 5.A.3 p. 5-38a p. 5.A-3 Amend. 28

SEISMIC REVIEW TABLE

MECHANICAL & PIPING			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
(% critical damping) Steel piping 0.5/0.5	Analytical and/or testing	L. C. for Internals, vessels, integral support attachments and piping:  <u>L.C.</u> Design loads + design earthquake loads  Design loads + SSE  Design loads + pipe rupture  Design loads + SSE	ASME BPVC, Section III  ANSI B31.7 Nuclear Power piping code -
Sec. 5A.4 p. 5A-6	Sec. 5.A,4,2 p. 5A-6 p. 5A-8	Sec. 4.1,2 p. 4-4	Sec. A-3 p. A-2

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	Not available.	Not available.	<p>Class I electrical equipment is seismic qualified in accordance with the IEEE Guide for seismic qualification of Class I electrical equipment for nuclear power generating stations, JeNPS/Sec. 5 (to be designated IEEE 344).</p> <p>Sec. 8.1 p. 8-1, Amendment No. 22, December 14, 1971</p>



SEISMIC REVIEW TABLE

Docket Number  
50-368

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					EARTHQUAKE TIME HISTORY	METHOD OF COMBINATION		DESIGN SPECTRA	
	OBE		INTENSITY MM	SSE			NO. OF EARTH. COMP. USED AND ITS COMP.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g		HOR. g	VERT. g					
CP/OL ISSUE DATE										
Arkansas Nuclear One Unit No. 2  Reactor type: PWR Containment type: 3 buttresses with shallow dome (prestressed con- crete)  NSSS Manufacturer: Combustion Engin- eering  Architect Engineer: Bechtel	0.10	0.067	VII	0.20	0.133	Synthetic time history	Three components: two horizontal and one vertical. Each horizontal was combined with the vertical, assuming simultaneous occurrence.	SRSS	Design response spectra generated from time-histories  as per AEC Reg. Guide 1.60  (BC-TOP-4)	Time-history method using synthetic earthquake accelera- tion time history
12-72/9-78	p. 2.5-25	p. 3.7-7		p. 2.5-25	p. 3.7-7	pg. 3.7-1	p. 3B-1	p. 3.7-9	p. 3.7-1	p. 3.7-3

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
Reinforced concrete flat circular slab.  Depth not available.  p. 3.8-46	Moderate to stiff, plastic, red and tan clay with occasional zone of silty clay, which overlies black, dense, horizontally bedded shale and interbedded shale and sandstone of the McAlester formation.  p. 2.5-9	70 ft to 90 ft.  p. 2.5-8	Not available.	About 10 ft below ground surface.  p. 2.5-11	Ozark Dam Dardanelle Dam Robert S. Kerr Dam  p. 2.4-6 to 2.4-8	Stick model with fixed base  p. 3.7-3	Not available.	No soil damping  p. 3.7-2	Not available.

SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING OBE/SSE	DESIGN CRITERIA	
	LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Welded steel frame structures (% critical damping) 2.0/5.0	A. Design loading case: 1) $D+L+F+T_o$ 2) $D+L+F+P+T_A$	ACI 318-63 AISC 1969 Supplement 1, 2, November 1970 and December 1971.
Bolted and riveted steel 3.0/5.0	B. Factored loading case: 1. $C = 1/\phi ((1.0+0.05) D + 1.5 P + 1.0 T_A + 1.0 F)$ 2. $C = 1/\phi ((1.0+0.05) D + 1.25 P + 1.0 T_A + 1.25 H + 1.25 E + 1.0 F)$	
Reinforced concrete structure and equipment supports 3.0/5.0	3. $C = 1/\phi ((1.0+0.05) D + 1.25 H + 1.0 R + 1.0 F + 1.25 E + 1.0 T_o)$ 4. $C = 1/\phi ((1.0+0.05) D + 1.0 F + 1.25 H + 1.0 W' + 1.0 T_o)$ 5. $C = 1/\phi ((1.0+0.05) D + 1.0 P + 1.0 T_A + 1.0 H + 1.0 E' + 1.0 F)$	
Prestressed concrete structures 2.0/5.0	6. $C = 1/\phi ((1.0+0.05) D + 1.0 H + 1.0 R + 1.0 E' + 1.0 F + 1.0 T_o)$	
Bolted or riveted steel frame structures 2.5/2.5	C = Required capacity of the containment D = Dead loads. E = Operating basis earthquake loads. E' = Design basis earthquake loads. F = Prestress loads. H = Pipe expansion loads. L = Live loads. P = LOCA pressure loads. R = Pipe rupture loads T = LOCA thermal loads. T <sub>o</sub> = Operating thermal loads. W' = Tornado wind and tornado missile loads. φ = Capacity reduction factors.	

p. 3.7-15

p. 3.8-7 to 3.8-8

p. 3.8-3

SEISMIC REVIEW TABLE

MECHANICAL & PIPING			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Steel piping Vital piping Welded steel plate assemblies	Analytical	Loading combination 1: normal operating loads + OBE loads. Loading combination 2: normal operating loads + DBE loads. Loading combination 3: normal operating loads + DBE loads + pipe rupture loads.	ASME BPVC Section III
(% critical damping) 0.5/0.5 0.5/1.0 1.0/1.0			
p. 3.7-15	p. 3.6-6	p. 3.6-4	p. 3.6-4

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	Not available.	Not available.	<p>Equipment supplied by NSSS vendor:</p> <p>Combustion Engineering Topical Report CENPD-61</p> <p>Equipment supplied by other than NSSS vendor:</p> <p>IEEE Standard 344-1971</p> <p>p. 3-10.2</p>



SEISMIC REVIEW TABLE

Docket Number  
50-334

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					EARTHQUAKE TIME HISTORY	METHOD OF COMBINATION		DESIGN SPECTRA	
	OBE		INTENSITY MM	SSE			NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g		HOR. g	VERT. g					
CP/OL ISSUE DATE										
Beaver Valley Power Station Unit No. 1  Reactor type: PWR Containment type: Sub-atmospheric (Reinforced con- crete)  NSSS Manufacturer: Westinghouse  Architect Engineer: Stone & Webster	0.06	0.04	IV	0.125	0.085	Compared with El Centro 1940 and Taft 1952, Golden Gate 1957.	Three components. Combination is simultaneous.	SRSS	Housner response spectra was generated which enveloped El Centro, Taft and Golden Gate time histories. Performed by Dr. R. V. Whitman	Time-history method.
6-70/7-76	Sec. 2.5.3 p. 2.5-4	Sec. 2.5.3 p. 2.5-4	Sec. 2.5.3 p. 2.5-3	Sec. 2.5.3 p. 2.5-4	Sec. 2.5.3 p. 2.5-4	Sec. 2.6.4.2 p. 2.6-11	Q. 3.15-5 Amend. 5 10/10/73	Q. 3.15-1 Amend. 1 4/23/73	Figs. 2.5-1 and 2.5-2 Pg. 2.5-3	

App. B.1-3

App. 2D

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>g</sub> PROFILE						
Reinforced concrete mat 10 ft thick	Gravel terrace	100 ft	Varying from 800 to 1250 psf	10 ft to 50 ft average 30 ft below surface.	3.1 miles downstream from Montgomery Lock and Dam  19.6 miles upstream from New Cumberland Rock and Dam.	Stick model with soil springs.	(1) Containment structure G = 22,000 psi  (2) Fuel building, auxiliary building and other near surface building G = 17,000 psi  (3) Intake structure G = 17,000 psi	Not available.	5% OBE  7% DBE
Sec. 2.6.3.1 p. 2.6-3	Sec. 2.4 p. 2.4-2	Sec. 2.4 p. 2.4-2	Sec. 2.6.2.3 p. 2.6-3	Sec. 2.3.2.1.1 p. 2.3-3	Sec. 2.3.1 p. 2.3-1	Sec. 2.6.4.4 p. 2.6-15	Sec. 2.5.3 p. 2.5-5		App. B pg. B.1-3

SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING OBE/SSE	(% critical damping)	DESIGN CRITERIA
		LOAD COMBINATION
		ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Containment structure	5.0/7.0	Concrete structure D.L. + L.L. D.L. + L.L. + OBE D.L. + L.L. DBE D.L. + L.L. + TOR D.L. + L.L. + F
Steel reinforced concrete (no cracking)	0.5 to 1.0	
Welded steel, well reinforced concrete (with slight cracking)	2.0	
Reinforced concrete (with consider- able cracking)	2.0	Steel structure D.L. + L.L. D.L. + L.L. + OBE D.L. + L.L. + DBE D.L. + L.L. + TOR D.L. + L.L. + F
Bolt steel	5.0	
Welded steel	5.0	
Reinforced concrete	5.0	
Bolted steel	7.0	
Amendment I, Sec. B.1.2, Table B.1-3, p. B.1-3 4/23/73		Amendment VII, p. B.1-6 (3/29/74)
		Using working stress design ACI 318-63
		Steel structure, AISC-63, Part I Specified minimum yield strength for structural steel.
		Amendment VII, P. B.1-7 3/29/74



SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available	Testing for mounted components	<p>"Class I instrumentation and electrical equipment are designed to maintain their capability to:</p> <ol style="list-style-type: none"> <li>1. Initiate a protective action during DBE and OBE</li> <li>2. Withstand seismic disturbances during post accident operation</li> </ol>	<p>maintain their</p> <p>IEEE STD 344-1971 "Seismic Qualification of Class I Electric Equipment for NPP Generating Station".</p> <p>p. B. 2-14</p>



## SEISMIC REVIEW TABLE\*

Docket Number  
50-155

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
Big Rock Point Nuclear Plant  Reactor type: BWR  Containment type: Pre-Mark (steel)  NSSS Manufacturer: General Electric  Architect Engineer: Bechtel   5-60/8-62	Not used	Not used	Not avail- able	.05 and 0.025 (see last column of this page) 0.12 for RDS only.	not used	not used	one horizon- tal component  3 direc- tions with SRSS for reactor depressurization system only	SRSS for RDS only	Not used	The lateral concrete loads for design of internal concrete structures were determined from U.B.C. requirements. A seismic factor of 0.025 was used for the equivalent lateral coefficient for these structures as well as other major structures, e.g. turbine building, 240 ft. high stack, control room and waste storage building. RDS re-analyzed in 1974 using R.G. 1.60, floor response spectra by Kapur method.
				Sec. 2-11			Sec. 2-11			

\*Information obtained from BNL Docket search and SEP8 Report prepared by LLL; EDAC Report #175-130.04, January 1979.

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
The lower segment of the spherical steel vessel is embedded in concrete and the structure extends 27 ft. below grade. The foundation consists of a combination of a 3-foot thick concrete mat and reinforced concrete footings from 38 ft. to 8 ft. below grade.	Rock	Not available	Not available	Not available	Not available	Not used	Not available	Not used	Not available

SEISMIC REVIEW TABLE


STRUCTURES			
DAMPING OBE/SSE	(% Critical damping)	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
<p>Containment: used in 1974 reanalysis of reactor depressurization system to acceleration equal to 0.12g.</p> <p>RDS components assumed to have damping values of R.G. 1.61.</p>	4.0	<p><u>Containment</u>: Seismic (0.05g) + DL + snow <u>Internal Concrete Structure</u>: Seismic (0.05g) + DL + equipment <u>NSSS</u>: Seismic (0.05g) + DL + pressure <u>NSSS Piping</u>: Seismic (0.025g) + pressure + equipments <u>Turbine Building</u>: Seismic (0.025g) + DL + equipment</p> <p>Sec. 3-3</p>	<p>Containment: ASME B and PV Sec. VI, VIII, IX UBC - 1958 ACI - 318-56</p> <p>Sec. 2-11</p>

SEISMIC REVIEW TABLE

MECHANICAL & PIPING			
DAMPING OBE/SSE (% Critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available	Not available	Not available	<u>Containment/Reactor Vessel:</u> ASME BPVC  Sec. II, VI, VIII, IX, 1958  <u>Piping and Supports:</u> ASA B 31.1 1955

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE  (% Critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
	Test		<p>MIL-STD-167, Mechanical vibration of shipboard equipment</p> <p>MIL-STD-901C, Requirements for shock test.</p> <p>"Seismic qualification of RDS for BRP plant".</p> <p>Amend. 8, Docket 50155-50</p>



SEISMIC REVIEW TABLE

Docket Number  
50-259, 260, 348

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION	DESIGN SPECTRA			
	OBE		SSE		EARTHQUAKE TIME HISTORY		NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g						
Browns Ferry Nuclear Plant Unit Nos. 1, 2, & 3 Reactor type: BWR  Containment type: Mark I (steel)  NSSS Manufacturer: General Electric  Architect Engineer: Tennessee Valley Authority          Unit 1: 5-67/6-73 Unit 2: 5-67/6-74 Unit 3: 7-68/8-76	0.10	0.067	VII	0.20	0.13	Design spectra compared with the El Centro, May 1940, N-S component, normalized to maximum acceleration. El Centro time history enveloped ground spectrum and was used in time-history analyses	Three components: Each horizontal component combined with vertical component simultaneously. "A vertical acceleration is considered to act simultaneously (with horizontal) and to increase or decrease the vertical load, whichever is most conservative.	SRSS	Housner design spectra	Time-history method.
	Sec. 2.5.4 p. 2.5-6	p.12.2-2	p. 2.5-6	Sec. 2.5.4 p. 2.5-6	p.12.2-2	Sec. 2.5-4 pp. 2.5-7, 2.5-8, 2.5-12	P. 12.2-32 Sec. C.3-2 p. C.0-3	Sec. C.3-2 p. C.0-3	Figs. 2.5-15 and 2.5-16 , 2.5-17 p. 2.5-7	Sec. 12.2.2.8 p. 12.2-12

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT				SOIL - STRUCTURE INTERACTION					
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
Base slab with a circular mass of concrete at the center supporting the drywell.	Bedrock	Average depth 54 ft (41 to 69 ft)	Not available.	Ground water is derived from precipitation.	Wheeler Dam Wilson Dam	Lumped mass model with soil springs	2,300,000 psi bedrock	Not available	5% for all modes
	Tuscombia formation	50 ft below bedrock							
	Fort Payne formation	145 ft below Tuscombia							
Sec. 12.2.2.1 p. 12.2-1	Sec. 2.5.2.3.2 pp. 2.5-1&2.5-2			Sec. 2.4.2.1 p. 2.4.1	p. 2.4-3	Sec. 12.2.2.8 p. 12.2-11	Sec. 2.5.2.4.2 p. 2.5-5	p. 12.2-69	Sec.12.2.2.8 p. 12.2-31

p. 12.2-69  
Fig. 12.2-78

SEISMIC REVIEW TABLE

STRUCTURES			
DAMPING OBE/SSE	(% critical damping)	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Steel structure	1.0	<p>These loads are considered in the following combinations:                      Reactor building                      Case 1. Prestartup - DL+LL+P                      Case 2. Operating - DL+LL+P+THERM+RESTR                      Case 3. Operating + Earthquake                      -A. DL+LL+P+THERM+RESTR+OBE                      -B. DL+LL+P+THERM+RESTR+DBE</p> <p>where</p> <p>DL = dead load                      LL = live load                      P = pressure transmitted through polyurethane foam at operating temperature                      OBE = Operating Basis Earthquake (0.1 g)                      DBE = Design Basis Earthquake (0.2 g)                      THERM = thermal load at operating temperatures                      RESTR = restraint to thermal growth of shield by pools</p> <p>For more details: refer to Tables 12.2-1 through 12.2-43</p>	<p>ACI-318-63</p> <p>N.O. + OBE <math>\leq 0.5 f_y</math></p> <p>N.O. + DBE <math>\leq 0.85 f'_c</math> or <math>0.9 f_y</math></p> <p>Ultimate strength method</p>
Concrete	5.0		<p>Sec. 12.2.2.2.3 p. 12.2-4</p>

SEISMIC REVIEW TABLE

MECHANICAL & PIPING					
DAMPING OBE/SSE	(% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA		
			LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES	
Piping	0.5	Analytical	Deformation limit	Table C.0-1	Piping ANSI B31.1.0 ANSI B31.7  Vessel ASME BPVC, Section III
Equipment	1.0		Primary stress limit	Table C.0-2	
			Buckling stability limit	Table C.0-3	
			Fatigue limit	Table C.0-4	
			For details refer to Tables C.0-1 to C.0-7.		
Sec. C.3-2 p. C.0-3		Appendix C Section C.3	Section C.2-6 p. C.0-2		Appendix C Section C.4-1

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	Not available.	Not available.	Not available.



SEISMIC REVIEW TABLE

Docket Number  
50-324, 325

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION	DESIGN SPECTRA				
	OBE		SSE				EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g						
<p>CP/OL ISSUE DATE</p> <p>Brunswick Steam Electric Plant Units 1 &amp; 2</p> <p>Reactor type: BWR</p> <p>Containment type: Mark I (Reinforced concrete)</p> <p>NSSS Manufacturer: General Electric</p> <p>Architect Engineer: United Engineers &amp; Constructors</p>	0.08	0.053	VII (SSE)	0.16	0.107	1940 N-S El Centro spectrum normalized by a factor was used for developing the design spectra.	<p>Three components, each horizontal was combined with the vertical, resulting in two distinct load cases.</p>	<p>For piping equipment by SRSS C.4.3.2</p> <p>For structure absolute sum.</p>	<p>The envelope of the Housner spectra and the El Centro spectra was termed as the smoothed 1940 N-S El Centro normalized spectrum.</p> <p>Fig. 2.6-7 Fig. 2.6-9</p>	Time-history method	
<p>Unit 1: 2-70/10-76</p> <p>Unit 2: 2-70/12-74</p>	<p>Sec. 2.6 p. 2.6-6</p>	<p>Sec. 2.6 p. 2.6-10</p>	<p>Sec. 2.6 p. 2.6-11</p>	<p>Sec. 2.6 p. 2.6-7</p>	<p>Sec. 2.6 p. 2.6-11</p>	<p>Sec. 2.6.6.1 p. 2.6-10</p>	<p>C4.3.2 p. C-56</p>	<p>Comment C-10 MC.10-1 Amend. 14 1972</p>	<p>Sec. 2.6 p. 2.6-9 Fig. 2.6-7</p>	<p>Comment C.3, P.MC.3-1 Amend. 13 (Sept. 72)</p>	

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
Reinforced concrete mat foundation, founded on a strata of very dense-fine to medium-coarse sand.  Depth not available.	Sand and clay.	115 ft	Thick. (ft)      V <sub>s</sub> (ft/sec)	Table M.2.17-1 gives ground water details.	Not available.	Lumped mass with soil springs.  See design reports 4, 9, and 10.	Not available	Soil structure interaction damping .04/.07 critical damping for OBE/DBE.	Not available.
	Limestone	115 ft	35      750 30      1400						
	Hard calcareous clay and cretaceous rock.	down to 1500 ft	43      5500 127      4500 1290      3000						
	Crystalline								
Sec. 12.2.1 p. 12.2-1	Sec. 1.5 p. 1.5-2	Sec. 1.5 p. 1.5-2	Fig. 2.6-7	Comment 2.17 EM2.17-1 Amend. 14, 11/72		C.57, p. MC.57-1		Table C-1	



SEISMIC REVIEW TABLE

MECHANICAL & PIPING						
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA				ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
		LOAD COMBINATION				
(% critical damping)						
Equipment	1.0/2.0	Analytical and testing	<u>Piping Design condition</u>	<u>Load combination</u>	<u>Stress limits</u>	ANSI B31.1 - 1967 Power piping ASME BPVC, Sec. III  <u>Valves</u> ANSI-B31.1-67 ANSI-B16.5  <u>Pumps</u> ANSI-B31.1-67 ASME Sec. III. Class C
Piping	0.5/2.0		Design, normal and upset	Pressure	$S_h$	
			Pressure; dead weight	$S_h$		
			Pressure, dead weight, OBE	$1.25 S_h$		
			Pressure, dead weight, thermal	$S_n + S_h$		
			Emergency	Pressure, dead weight, DBE	$1.8 S_h$	
Table C-1		Sec. 2.2 C-4	Table C-7 through C-29 Amendment 13, Comment 4.3, p. M4.3-1			Amendment 13 (Sept. 1972) p. M4.1-1 Sec. A.1.1, p. 2  p. MC.18-3





SEISMIC REVIEW TABLE

Docket Number  
50-317, 318

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					EARTHQUAKE TIME HISTORY	METHOD OF COMBINATION		DESIGN SPECTRA	
	OBE		INTENSITY MM	SSE			NO. OF EARTH. COMP. USED AND ITS COMP.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g		HOR. g	VERT. g					
<p>Calvert Cliffs Nuclear Power Plant Units No. 1 &amp; 2</p> <p>Reactor type: PWR</p> <p>Containment type: 6 Buttresses with shallow dome (prestressed con- crete)</p> <p>NSSS Manufacturer: Combustion Engineer- ing</p> <p>Architect Engineer: Bechtel</p> <p>Unit 1:7-69/7-74 Unit 2:7-69/11-76</p>	0.08	0.053	VII	0.15	0.10	<p>Compared with digit- alized El Centro earthquake 1940 (E-W) normalized to: 0.08 g horizontal 0.053 g vertical</p>	<p>Horizontal and vertical components combined simultaneously.</p>	<p>SRSS in- cluding closely spaced modes.</p>	<p>1. Housner spectra for frequency &gt;0.33 cps. 2. Newmark spectra for frequency &lt;0.33 cps  (Figs. 2.6-4, and 2.6-5)</p>	<p>"Digitize" El Centro was used in the analysis of Class I equipment.  Class 2 struc- tures use UBC Zone 3.  AEC TID 7024 "Nuclear Reactors and Earthquakes".</p>
<p>Sec. 2.6.5.2 p. 2.6-9</p>	<p>Sec. 2.6.5.2 p. 2.6-9</p>	<p>← Sec. 2.6.5.3 p. 2.6-9 →</p>	<p>Sec. 2.6.5.4 p. 2.6-10</p>	<p>Sec. 5A.3.1.4 p. 5A-5</p>	<p>Sec. 5.1.3.2(h) p. 5-22</p>	<p>Sec. 2.6.5.4 p. 2.6-10</p>				

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
Foundation for containment: 10 ft thick reinforced concrete slab.  Sec. 5.1.2.1 p. 5.2	Major structure: Miocene sandy and clay silts of Chesapeake group. Appurtenant structure: surficial pleistocene silt which overlies the miocene sediments.  Sec. 2.6.5.1 p. 2.6-9	200 ft  Sec. 2.4.1 p. 2.4-1	1600 fps  Sec. 2.6.4.4 p. 2.6-7	Varies from 8 ft to 82 ft.  Sec. 2.5.3.3 p. 2.5-9	Not available.	Stick model with soil springs.  Sec. 5.1.3.2 p. 5-21	Not available.	Soil: % critical damping OBE: 2% SSE: 3%  E' 7%  Rocking Motion Prestressed concrete Rocking Motion Reinforce concrete  7%	Not available
								Sec. 5A.3.1.4 p. 5A-5, p. 5A-6	

SEISMIC REVIEW TABLE

STRUCTURES			
DAMPING OBE/SSE		DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
	(% critical damping)		
	(translational)		
1. Welded steel framed structure	1.0/1.0	$Y \geq 1/\phi (1.05 D + 1.5 P + 1.0 T_A + 1.0 F)$	ACI-318-63, when $\phi$ is taken as 1.
2. Bolted or riveted steel framed structure	2.5/2.5	$Y \geq 1/\phi (1.05 D + 1.25 P + 1.0 T_A + 1.25 H + 1.25 E + 1.0 F)$	
3. Reinforced concrete frames and buildings	3.0/5.0	$Y \geq 1/\phi (1.05 D + 1.25 H + 1.0 R + 1.0 F + 1.25 E + 1.0 T_o)$	
4. Prestressed concrete structures	2.0/5.0	$Y \geq 1/\phi (1.05 D + 1.25 H + 1.0 F + 1.25 W + 1.0 T_o)$	
		$Y \geq 1/\phi (1.0 D + 1.0 P + 1.0 T_A + 1.0 H + 1.0 E' + 1.0 F)$	
		$Y \geq 1/\phi (1.0 D + 1.0 H + 1.0 R + 1.0 E' + 1.0 F + 1.0 T_o)$	
		Y = Yield strength.	
		D = Dead load.	
		E = OBE	
		E' = SSE	
	(rotational)		
1. Rocking motion for prestressed concrete structures	5.0/7.0	W = Tornado wind load.	Sec. 5A.3.1.2 p. 5A-3
2. Rocking motion for reinforced concrete structures	5.0/7.0	P = LOCI pressure load.	
		F = Final prestress load.	
		T <sub>A</sub> = Thermal load incident temperature gradient through walls and expansion liner	
		R = Force or pressure on structure due to rupture of one pipe.	
		H = Thermal expansion force.	
		T <sub>o</sub> = Thermal load due to normal operating temperature gradient through walls.	
		$\phi$ = Reduction factor.	
Sec. 5A.3.1.4 pp. 5A-5 and 5A-6		Sec. 5A.3.1.2 pp. 5A-3 and 5A-4	

SEISMIC REVIEW TABLE

MECHANICAL & PIPING			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
(% critical damping) (Translational) Steel piping 0.5/0.5 Welded steel plate assemblies 1.0/1.0	Analytical	Vessels 1. Design loading + OBE: $P_m \leq S_m$ $P_B + P_L \leq 1.5 S_m$ 2. Normal operating + SSE: $P_m \leq S_D$ $P_B \leq 1.5 \left[ 1 - \left( \frac{P_m}{S_D} \right)^2 \right] S_D$ 3. Normal operating + SSE + pipe rupture: $P_m \leq S_L$ $P_B \leq 1.5 \left[ 1 - \left( \frac{P_m}{S_L} \right)^2 \right] S_L$	Piping $P_m \leq S_m$ $P_B + P_L \leq 1.5 S_m$ $P_m \leq S_D$ $P_B \leq \frac{4}{\pi} S_D \cos\left(\frac{\pi}{2} \cdot \frac{P_m}{S_D}\right)$ $P_m \leq S_L$ $P_B \leq \frac{4}{\pi} S_L \cos\left(\frac{\pi}{2} \cdot \frac{P_m}{S_D}\right)$
Sec. 5A.3.1.4 p. 5A-5	p. 5A-5	Sec. 4.2.1, Table 4-2 pp. 4-5 to 4-7	Reactor vessel: ASME BPVC III Piping: ASME BPVC III (1967) USAS B 31.7, Class I (Code cases 83, 1477 are included).  Sec. 4.2.1, Table 4-2 p. 4-7

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT

DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available	Not available	<p>"All electrical-systems and components vital to plant safety, including the emergency diesel generators, are designed as Class I so their integrity is not impaired by the design basis earthquake, high winds, or disturbances on the external electrical system".</p> <p>pg. 8.1</p>	Not available



SEISMIC REVIEW TABLE

Docket Number  
50-298

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION	DESIGN SPECTRA				
	OBE		SSE				EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g						
Cooper Nuclear Station  Reactor type: BWR  Containment type: Mark I (steel)  NSSS Manufacturer: General Electric  Architect Engineer: Burns & Roe, Inc.	0.10	0.05	VII	0.20	0.10	The accelerogram of the N69W component of the July 21, 1952 Kern County earth- quake recorded at Taft, California was used to develop re- sponse spectra	Three components: two horizontal and one vertical. Each horizontal was combined with the vertical simultaneously.	Reactor vessel in- ternals: SRSS for re- sponse spec- trum method; algebraic sum for time- history method	Design spectrum re- sponse curves gen- erated from 1952 Taft earthquake	Time-history method.	
6-68/1-74	Vol. 1 Sec. 5.2.3 p.II-5-4	Vol. 1 Sec. 5.2.3 p.II-5-4	Vol. 1 Sec. 5.2.1 p. II 5-3	Vol. 1 Sec. 5.2.3 p.II-5-4	Vol. 1 Sec. 5.2.3 p.II-5-4	Vol. 1 Sec. 5.2.4 p. II-5-4	App. C Sec. 3.3.3 p. C-3-12	Vol. 1 Sec.3.5.3 p.III-3-12	Vol. 1, Sec. 5.2.4 p. II-5-4, Figs. II-5-7 to II-5-10	Vol. VII Amend 9 Q.12.35	



SEISMIC REVIEW TABLE

STRUCTURES			
DAMPING OBE/SSE  (% critical damping)		DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Reinforced concrete structures.	5.0/7.0	D+E D+R D+R+E D+E+Flood D+T D+R+E'	ACI-318-63 for reinforced concrete.
Steel frame structures.	2.0		AISC Manual of Steel Construction (Sixth Edition)
Welded assemblies.	1.0		
Bolted and riveted assemblies	2.0		
<p>Vol. IV, p. XII-2-16 Table XII-2-5</p>		<p>D = Dead load of structure and equipment. R = Loads resulting from jet forces and pressure and temperature due to rupture of a single pipe. E = OBE E' = SSE Flood = Loads due to flooding. W = Wind loads. T = Tornado loads.</p> <p>Appendix C Sec. 2.2 p. C-2-1</p>	<p>Vol. V Sec. 2,4 p. C-2-3</p>



SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	Not available.	Not available.	Not available.



SEISMIC REVIEW TABLE

Docket Number

50-302

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					EARTHQUAKE TIME HISTORY	METHOD OF COMBINATION		DESIGN SPECTRA	
	OBE		SSE		NO. OF EARTH. COMP. USED AND ITS COMB.		MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA	
	HOR. g	VERT. g	INTENSITY MM	HOR. g						VERT. g
Crystal River Nuclear Generating Plant, Unit 3  Reactor type: PWR  Containment type: Mark I (steel)  NSSS Manufacturer: Babcock & Wilcox  Architect Engineer: Gilbert Associates          9-68/12-76	0.05	0.033	V	0.10	0.067	Response spectrum method was used in design. Floor response spec- tra generated with either 1940 N-S El Centro, 1952 M2IE Taft or other time-history.  Ref. Sec. 5.4.5 p.5-65A Amend. 26 (5-25-73) and Sec. 2.5.4.1 p. 2-31	Three components: Each horizontal combined with the vertical by absolute sum, although "struc- tural response due to vertical <del>input was assumed to be</del> insignificant".  Sec. 5.4.5 p.5-65 Amend. 26 (5-25-73)	SRSS          Sec. 5.4.5.2 p.5-66 D Amend. 32 (10-1-73)	Spectra developed were estimated by two methods: Housner and Estere and Rosenblueth   p. 2-32	Approximate method not based on time-history          GAI Topical 1729  Sec. 5.4.5 p. 5-65A Amend. 26 (5-25-73)

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
<p>For reactor building</p> <p>Mat foundation thickness 12.5 ft.</p> <p>Sec. 2.5.7 p. 2-36 and Sec. 5.2, p.5-7 Amend.26, (5-25-73)</p>	<p>Natural soil: Laminated organic sandy silts and clays interspersed with a pleistocene marine deposits.</p> <p>Underlying limestone</p> <p>Sec. 2, p.2.1</p> <p>Bedrock: biogenic carbonates of tertiary age.</p>	<p>Average of thickness of approximately 4 ft.</p> <p>Approximately 20 ft. beneath the present ground surface.</p>	<p>Not available</p>	<p>Depth of approximately 10 ft. below ground surface. Based on a ground datum of 100 ft. groundwater levels were recorded to rise approximately 1.5 ft. at peaks of high tides.</p> <p>Sec. 2.5 p. 2-20 and Sec. 2.5.3.5 p. 2-29 and p.2-30</p>	<p>Not available.</p>	<p>Stick model with fixed base. Soil spring model was used to check accuracy of fixed base model.</p> <p>Sec. 5.4.5.2 p. 5-66 and Sec. 5.4.5 p. 5-65 and p. 5-65a Amend. 32 (10-1-73)</p>	<p>Not available.</p>	<p>"Sum of material and radiation damping was assumed as small as 5%."</p> <p>p. 5-65a</p>	<p>Not available.</p>

Sec. 2.5.3  
p 2-22

SEISMIC REVIEW TABLE

STRUCTURES

DESIGN CRITERIA

DAMPING  
OBE/SSE

(% criti-  
cal damping)

LOAD COMBINATION

ACCEPTANCE CRITERIA  
& ALLOWABLE STRESSES

Reactor building shell

2.0

Concrete support: Structure  
(Inside reactor building)

2.0

Steel assemblies and structure  
a) bolted  
b) welded

2.5

1.0

Other concrete structure  
(Above ground)

5.0

- a)  $c = (1.0 \pm .05) D + 1.5P + 1.0T$   
 b)  $c = (1.0 \pm .05) D + 1.25P + 1.0T' + 1.25 (E \text{ or } W)$   
 c)  $c = (1.0 \pm .05) D + 1.0P + 1.0 \frac{T}{t} + 1.0E'$   
 d)  $c = (1.0 \pm .05) D + 1.0 W_T + 1.0 P_t$

D= Dead load  
 P= Design accident pressure load  
 E= Seismic load based on 0.05g.  
 E'= Seismic load based on 0.10g.  
 W<sub>T</sub>= Wind load based on Tornado  
 P<sub>t</sub>= Pressure load based on external pressure drop of  
 3 psig between inside and outside of reactor  
 building.

Sec. 5.2.3.2.1  
 p. 5-32

Reactor building:

R. C. ACI 318-63

Structure concrete ACI 301-66

Structure steel AISC. 1963.

Sec. 5.2.3.1  
 p. 5-31

SEISMIC REVIEW TABLE

MECHANICAL & PIPING																
DAMPING OBE/SSE  (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA														
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES													
Vital piping systems. 0.5	Analyses and test.  Details. Ref. Table 5-5 p.5-86 AMEND. 17 (4-10-72)  Sec. 5.4.5 p. 5-65 AMEND. 40 (7-3-74) p.5-64b AMEND. 45, (7-14-75)	For piping:  primary stress + OBE $\leq 1.2 \times S_h$ thermal stress $\leq S_A$ where $S_A = t (1.25 S_c + 0.25 S_h)$ $S_A$ = allowable stress $S_A$ = basic material allowable stress at max. (hot) temp. $S_h$ = basic material allowable stress at min. (cold) temp. c p. 5-641 Amend. 45(7-11-75) and p. 5-63	Reactor coolant system: ASME, boiler and pressurizer Vessel code, Sec. III, Art. 9 Summer, 1967 For piping (belongs to reactor coolant) USAS Sec. B31.7													
		<table border="1"> <thead> <tr> <th>Case</th> <th>Load Combination</th> <th>Stress Limits</th> </tr> </thead> <tbody> <tr> <td>I)</td> <td>Design loads + design earthquake loads</td> <td><math>P_m \leq 1.0 S_m</math> <math>P_L + P_b \leq 1.5 S_m</math></td> </tr> <tr> <td>II)</td> <td>Design loads + maximum hypothetical earthquake loads</td> <td><math>P_m \leq 1.2 S_m</math> <math>P_L + P_b \leq 1.2 (1.5 S_m)</math></td> </tr> <tr> <td>III)</td> <td>Design loads + pipe rupture loads</td> <td><math>P_m \leq 1.2 S_m</math> <math>P_L + P_b \leq 1.2 (1.5 S_m)</math></td> </tr> <tr> <td>IV)</td> <td>Design loads + maximum hypothetical earthquake loads</td> <td><math>P_m \leq 2/3 S_y</math> <math>P_L + P_b \leq 2/3 S_y</math></td> </tr> </tbody> </table>	Case	Load Combination	Stress Limits	I)	Design loads + design earthquake loads	$P_m \leq 1.0 S_m$ $P_L + P_b \leq 1.5 S_m$	II)	Design loads + maximum hypothetical earthquake loads	$P_m \leq 1.2 S_m$ $P_L + P_b \leq 1.2 (1.5 S_m)$	III)	Design loads + pipe rupture loads	$P_m \leq 1.2 S_m$ $P_L + P_b \leq 1.2 (1.5 S_m)$	IV)	Design loads + maximum hypothetical earthquake loads
Case	Load Combination	Stress Limits														
I)	Design loads + design earthquake loads	$P_m \leq 1.0 S_m$ $P_L + P_b \leq 1.5 S_m$														
II)	Design loads + maximum hypothetical earthquake loads	$P_m \leq 1.2 S_m$ $P_L + P_b \leq 1.2 (1.5 S_m)$														
III)	Design loads + pipe rupture loads	$P_m \leq 1.2 S_m$ $P_L + P_b \leq 1.2 (1.5 S_m)$														
IV)	Design loads + maximum hypothetical earthquake loads	$P_m \leq 2/3 S_y$ $P_L + P_b \leq 2/3 S_y$														

p. 5-42

$P_L$  = Primary local membrane stress intensity  
 $P_m$  = Primary general membrane stress intensity  
 $P_b$  = Primary bending stress intensity  
 $S_m$  = Allowable membrane stress intensity  
 $S_u$  = Ultimate stress for unirradiated material at operating temperature

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	<p>Test or prototype test or calcula- tion.</p> <p>Ref. Sec. 7.1.3.1.4 p. 7-9b Amend. 32 (10-1-73)</p>	Not available.	<p>IEEE Standard. 314-1971</p> <p>Sec. 7.1.1.8 p. 7-2b and p. 7-26 Amend. 45 (7-11-75)</p>



SEISMIC REVIEW TABLE

Docket Number

50-346

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION	DESIGN SPECTRA				
	OBE		SSE				EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g						
<p>Davis-Besse Nuclear Power Station, Unit 1</p> <p>Reactor type: PWR</p> <p>Containment type: Dry containment -cylindrical (steel)</p> <p>NSSS Manufacturer: Babcock &amp; Wilcox</p> <p>Architect Engineer: Bechtel</p>	0.08	.053	VII	0.15	0.10	E-W component of Helena Earthquake of October 31, 1935 was used as the basis for developing accelerograms of the OBE & DBE.	3 com- ponents: each hor- izontal combined with the vertical resulting two seis- mic load cases.	SRSS	Design spectrum re- sponse curves were developed by Newmark's method modifying the spec- tral amplification factors.	Time-history method.	
	Vol. 1, Append. 2C Sec.D p. 2C-36	Vol. 1 Append.2C Sec. D p. 2C-36	Vol. 1, Append. 2C, p. 2C-31	Vol. 1, Append. 2C, p. 2C-31	Vol. 1, Append. 2C, p. 2C-39	Vol. 1, Append. 2C, p. 2C-39	Vol. 2C, Sec. 3.7.1.6 p. 3-51	Vol. 2 Sec. 3.7.3.3 p. 3-63 Fig. 3-24	Vol. 1, Append. 2C, p. 2C-41 to 45	Vol. 2 Sec. 3.7.2 p. 3-54	

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
Main structure: Mat footings & Auxiliary building: Pier footings bearing on bedrock.  Depth not available.	Soil: Glaciola-gustrine and a till deposit.		For bedrock 5,700 fps to 7,500 fps	Prior to construction  571 ft. to 572 ft. (I.G. L.D.)	Not available.	Stick model with fixed base for the containment and the auxiliary building	Soil: For OBE: 10 KIPS/ft <sup>2</sup>	Soil: For OBE: 0.04	Not available.
	Bedrock: Tymochtee formation which consists of argillaceous dolomite with interbedded gypsum, anhydrite and shale strata.	8 ft. to 10 ft.		During construction  525 ft. (I.G. L.D.)			Soil: For SSE: 12 KIPS/ft <sup>2</sup>	For SSE: 0.05	
Vol. 1 Sec. 2.5.1.10.2 p. 2-126 to 128			Vol. 1 Sec. 2.5.1.7 p. 2-123	Vol. 1 Sec. 2.5.1.5 p. 2-122		Vol. 2 Sec. 3.7.2 p. 3-52 to 55	Bedrock: For OBE: 150 KIPS/ft <sup>2</sup>  For SSE: 180 KIPS/ft <sup>2</sup>	Bedrock: For OBE:0.01  For SSE:0.02	

Vol. 1,  
Sec. 2.5.1.8,  
p. 2-123 and p. 2-124

**SEISMIC REVIEW TABLE**

<b>STRUCTURES</b>																				
<b>DAMPING OBE/SSE</b>		(% critical damping)			<b>DESIGN CRITERIA</b>															
					<b>LOAD COMBINATION</b>	<b>ACCEPTANCE CRITERIA &amp; ALLOWABLE STRESSES</b>														
<p><b>Welded steel</b></p> <p><b>Bolted and Riveted steel</b></p> <p><b>Reinforced concrete</b></p>	<table border="1"> <tr> <td style="text-align: center;"><math>&lt; 1/4 \sigma_y</math></td> <td style="text-align: center;"><math>1/2 \sigma_y</math></td> <td style="text-align: center;"><math>\sigma_y</math></td> <td style="text-align: center;"><math>&gt; \sigma_y</math></td> </tr> <tr> <td style="text-align: center;">1.0</td> <td style="text-align: center;">2.0</td> <td style="text-align: center;">5.0</td> <td style="text-align: center;">7.0</td> </tr> <tr> <td style="text-align: center;">1.0</td> <td style="text-align: center;">5.0</td> <td style="text-align: center;">10.0</td> <td style="text-align: center;">20.0</td> </tr> <tr> <td style="text-align: center;">1.0</td> <td style="text-align: center;">2.0</td> <td style="text-align: center;">7.0</td> <td style="text-align: center;">10.0</td> </tr> </table>	$< 1/4 \sigma_y$	$1/2 \sigma_y$	$\sigma_y$	$> \sigma_y$	1.0	2.0	5.0	7.0	1.0	5.0	10.0	20.0	1.0	2.0	7.0	10.0	<p><b>Class I Structures: Operation during normal and OBE conditions</b></p> <p><u>Concrete</u></p> <p>U=1.5D + 1.8L            U=1.25(D + L + H + E) + 1.0 T            U=1.25(D + L + H<sup>o</sup> + W) + 1.0 T<sup>o</sup>            U=0.9D + 1.25(H<sup>o</sup> + E) + 1.0 T<sup>o</sup>            U=0.9D + 1.25(H<sup>o</sup> + W) + 1.0 T<sup>o</sup></p> <p><u>Structural steel</u></p> <p>D + L            D + L + T + H + E            D + L + T<sup>o</sup> + H<sup>o</sup> + W</p> <p><u>During accident and SSE conditions:</u></p> <p><u>Concrete:</u></p> <p>U=1.0D + 1.0L + 1.25E + 1.0T<sub>a</sub> + 1.0H<sub>a</sub> + 1.0R            U=1.0D + 1.25E + 1.0T<sub>a</sub> + 1.0H<sub>a</sub> + 1.0R            U=1.0D + 1.0L + 1.0E' + 1.0T<sub>o</sub> + 1.25H<sub>o</sub> + 1.0R            U=1.0D + 1.0L + 1.0E' + 1.0T<sub>a</sub> + 1.0H<sub>a</sub> + 1.0R            U=1.0D + 1.0L + 1.0W' + 1.0T<sub>o</sub> + 1.25 H<sub>o</sub></p> <p><u>Structural Steel</u></p> <p>D + L + R + T<sub>o</sub> + H<sub>o</sub> + E'            D + L + R + T<sub>a</sub> + H<sub>a</sub> + E'</p>		<p><u>Concrete</u></p> <p>A.C.I. Code. 318-63            Ultimate strength method</p> <p><u>Structural steel</u></p> <p>f<sub>s</sub>            1.25f<sub>s</sub>            1.33f<sub>s</sub></p> <p>1.5f<sub>s</sub>            1.5f<sub>s</sub></p>
$< 1/4 \sigma_y$	$1/2 \sigma_y$	$\sigma_y$	$> \sigma_y$																	
1.0	2.0	5.0	7.0																	
1.0	5.0	10.0	20.0																	
1.0	2.0	7.0	10.0																	
<p>Vol. 2, Table 3-7, pg. 3-50</p>																				
<p>D= Dead load of structure and equipment plus other permanent loads, e.g., soil or hydrostatic loads            L=Live load and piping loads            R=Force or pressure on structure due to pipe rupture            T<sub>o</sub>=Thermal loads due to temp. gradient, operating            H<sub>o</sub>=Force due to thermal expansion of pipes, operating            T<sub>a</sub>=Thermal loads due to temp. gradient, accident            H<sub>a</sub>=Force on structure due to thermal exp., accident            E=force due to OBE            E'=force due to SSE            W=Wind load=wind velocity 90 mph at 30 ft. above gr.            W'=Tornado loads including differential pressure</p>																				

Vol. 2, Sec. 3.1.1.3, pg. 3-76

Vol. 2, Sec. 3.8.1.1.6, pg. 3-72







SEISMIC REVIEW TABLE

Docket Number

50-315, 316

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION	DESIGN SPECTRA			
	OBE		SSE		EARTHQUAKE TIME HISTORY		NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. S	VERT. S	INTENSITY MM	HOR. S						
<p>Donald C. Cook Nuclear Plant Units No. 1 &amp; 2</p> <p>Reactor type: PWR</p> <p>Containment type: <del>Pre-Condenser</del> (Reinforced concrete)</p> <p>NSSS Manufacturer: Westinghouse</p> <p>Architect Engineer: American Electric Power Service Corporation</p>	0.10	0.067	VII	0.20	0.133	<p>El Centro (as presented in TID 7024) Normalized to the recommended ground acceleration was used to develop response spectra.</p>	<p>Two-thirds of horizontal taken as vertical and combined with the full horizontal response. No further details available.</p>	SRSS	<p>Response spectra as shown in Figs. 2.5-2 and 2.5-3 were generated from El Centro earthquake.</p>	<p>Time-history method.</p>
<p>3-69/10-74</p>	<p>Vol. I Sec. 2.8.6 p. 2.8-2</p>	<p>Vol. I Sec. 2.8.6 p. 2.8-2</p>		<p>Vol. I Sec. 2.8.6 p. 2.8-2</p>	<p>Vol. I Sec. 2.8.6 p. 2.8-2</p>	<p>Vol. I Sec. 2.5.2 p. 2.5-5</p>				

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT				SOIL - STRUCTURE INTERACTION					
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
Mat foundation  Depth not available.	Compact sand, re-compact sand or stiff clay deposits on shale bedrock.	120 to 200 ft	900 fps	ground water elevation 593 ft	Not available.	Stick model with soil springs.	Not available.	Not available.	Not available.
Sec. 2.5.2 p. 2.5.2	Sec.2.3.2 p. 2.3-4	Sec. 2.3 Fig.2.3-2	Vol. IX, Amend. 19, p. 5.85-2	Vol. I, Sec. 2.4.2 p. 2.4-4		Amend. 16. Question 5.71 Fig. 5.71-1			

SEISMIC REVIEW TABLE

STRUCTURES

DESIGN CRITERIA

DAMPING  
OBE/SSE

(% criti-  
cal damping)

LOAD COMBINATION

ACCEPTANCE CRITERIA  
& ALLOWABLE STRESSES

Containment structure: (with DBA) 4.0/7.0  
(without DBA) 2.0/5.0

Welded steel structure 1.0/1.0

Bolted or rivited steel assemblies 2.0/2.0

For containment:

$$C = (1.0+0.05)D + 1.5 P = 1.0 (T+TL) + 1.0 B$$

$$C = (1.0+0.05)D + 1.25 P + 1.0 (T'+TL') + 1.25 E + 1.0 B$$

$$C = (1.0+0.05)D + 1.0 P + 1.0 (T''+TL'') + 1.0 E' + 1.0 B$$

$$C = (1.0+0.05)D + 1.0 (T''' + TL''') + 1.0 B + 1.0 W' + 1.0 P$$

$$C = (1.0+0.05)D + 1.0 (T'''' + TL''') + 1.0 B$$

$$C = (1.0+0.05)D + 1.15 P$$

ACI-318-63, Ultimate strength design.

Amend. 9  
Question 5.85, p. 5.85-2

Sec. 5.2.2.3  
p. 5.2-18

Amendment .9, Question 5.1-1  
Appendix B-9

SEISMIC REVIEW TABLE

MECHANICAL & PIPING			
DAMPING OBE/SSE  (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Piping	0.5/0.5	Analytical and Testing	<p>For pressure vessels:</p> <p>1. (a) <math>P_m \leq S_m</math>            (b) <math>P_m</math> (or <math>P_L</math>) + <math>P_B \leq 1.5 S_m</math>            (c) <math>P_m</math> (or <math>P_L</math>) + <math>P_B + Q \leq 3.0 S_m</math> } Normal condition</p> <p>2. (a) <math>P_m \leq S_m</math>            (b) <math>P_m + P_B \leq 1.5 S_m</math>            (c) <math>P_m + P_B + Q \leq 3.0 S_m</math> } Upset condition</p> <p>For pressure piping:</p> <p>1. (a) <math>P_m \leq S</math>            (b) <math>P_m + P_B \leq S</math> } Normal condition</p> <p>2. (a) <math>P_m \leq 1.2 S</math>            (b) <math>P_m + P_B \leq 1.2 S</math> } Upset condition</p>
Amendment 19, Q. 5.85 p. 5.85-2	Amendment 25 Q. 4.31-1		Tables 1 and 2, p. B-18 and p. B-19.

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	Not available.	Not available.	Not available.



## SEISMIC REVIEW TABLE \*

Docket Number

50-010

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION	DESIGN SPECTRA				
	OBE		INTENSITY MM	SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g		HOR. g	VERT. g						
Dresden Nuclear Power Station Unit 1  Reactor type: BWR  Containment type: Pre-Mark (steel)  NSSS Manufacturer: General Electric  Architect Engineer: Bechtel          5-56/9-59	None used (0.10)**	None used (0.067)**	None used	None used (0.20)**	None used (0.13)**	None used	None used Two SRSS ** comps., ** vertical + worst case horizontal	None used	No floor response spectra generated UBC, 1955 used for containment (Zone 2) and internal con- crete structure (Zone 1) Housner spectra Times 2 used for ECCS and Core Spray System.		

\* Data are obtained from FHSR Docket 50-010 and SEPB Report "Seismic Design Bases and Criteria for Dresden Unit 1 Nuclear Generating Station," EDAC 175-130.03, January 1979.

\*\* Used for ECCS and Core Spray System only.

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT				SOIL - STRUCTURE INTERACTION					
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
Circular concrete foundation 37 ft. below grade.	Limestone Shale Dolomited Limestone	20-45 ft. 70 ft. 100-400ft.	Not used, bed-rock site	"Groundwater found @ various levels beneath the site".	Dresden Dam	No SSI model used	Not used	Not used	Not used

SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING OBE/SSE (% Critical damping)	DESIGN CRITERIA	
	LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available	<u>Internal Concrete Structures:</u> E + pressure + equipment (E = 0.025g)	UBC, 1955 ACI, 318-55 AISC, 1955

SEISMIC REVIEW TABLE

MECHANICAL & PIPING				
DAMPING OBE/SSE (% Critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA		
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES	
Vital piping Welded assembly Bolted assembly	0.5 1.0 1.0	None	<p><u>Containment:</u> 1.) 0.033g 2.) pressure + snow + wind</p> <hr/> <p><u>NSSS:</u> 1.) 0.025g 2.) operational transients</p> <hr/> <p><u>ECCS:</u> 1.) earthquake + operational + blowdown</p>	<p><u>Steel Containment Sphere and NSSS:</u> ASME Section VIII (1955 ed.) and UBC, 1955</p> <hr/> <p><u>Piping and ECCS, Core Spray:</u> ANSI B31.7, and ASME Sec. III, (1974 ed.)</p>

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available	Not available	Not available	Not available



SEISMIC REVIEW TABLE\*

Docket Number  
50-237,249

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					EARTHQUAKE TIME HISTORY	METHOD OF COMBINATION		DESIGN SPECTRA	
	OBE		SSE				NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
<p>Dresden Nuclear Power Station Unit 2 and 3</p> <p>Reactor type: BWR</p> <p>Containment type: Mark-I (steel)</p> <p>NSSS Manufacturer: General Electric</p> <p>Architect Engineer: Sargent and Lundy Engineers.</p> <p>Unit 2: 1-66/12-69 Unit 3: 10-66/1-71</p>	0.10	0.067	VII	0.20	0.133	<p>N-S component of the El Centro Earthquake (May, 1940) normalized to a maximum ground acceleration of 0.1g was used for time history analysis.</p> <p>Question II.A.1 Docket 50237-16 (microfiche)</p>	2 comp., greater horizontal + vertical, absolute method	SRSS (reactor, turbine bldg., and drywell analyzed by time history method)	Housner-(El Centro T-H envelops the Housner spectra except for high frequency end.)	<p>Equipment and piping analyzed by either response spectrum or equivalent static method. Floor response spectra for pressure vessel, isolation condenser, turbine building, control room, etc. are derived by factoring up the Housner Ground Response Spectra to account for the maximum floor acceleration determined from the time history analysis. Static coefficients were also used for APCI and Core Spray Equipment. Floor response spectra from Brown's Ferry used for recirculating loop piping, feed-water and mainsteam lines.</p>

\*Information was obtained from BNL Docket Search and SEPB Report "Seismic Review of Dresden Unit 2 for the Systematic Evaluation Program", NUREG/CR-0891, July 1979.

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE (calculated)	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE (calculated)						
p. 12.1-10 Reinforced concrete mat founded on competent rock	p. III-1-3 The site consists of an upper layer of Pennsylvanian Pottsville sandstone of variable thickness which is 40-50 ft. Next below is a layer of about 15 to 35 ft. of Ordovician Maquoketa limestone based on a 65 ft. layer of Maquoketa dolomitic shale. The Ordovician system has a total thickness approaching 1000 ft. with the Cambrian system next below. Brecciated rock is found on same cross sections and is indicative of ancient faulting.		p. III-2-21 Sandstone = 2,600 fps Limestone = 8,600 fps Argillaceous Dolomite = 4,700 fps Shale = 3,900 fps Dolomite Shale = 4,700 fps	Not available	p. 2.5-1 Dresden Dam	Fig. 12.1.8 and Fig. 12.1.9 indicate stick model with fixed base. <u>p. 12.1-12</u> Lumped mass and stick model (torsional effects not considered.)	Sandstone = $18.7 \times 10^4$ psi Limestone = $250 \times 10^4$ psi Argillaceous = $68 \times 10^4$ psi Dolomite = $68 \times 10^4$ psi Shale = $44 \times 10^4$ psi Dolomite = $74 \times 10^4$ psi Shale	Not available	Not available

SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING OBE/SSE (% critical damping)	DESIGN CRITERIA	
	LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Reinforced concrete structures	5.0	a) Normal allowable code stresses, AISC for structural steel, ACI-318-63 without increase for seismic as a general case. In this approach, is made to determine such that it exceeds the Reactor and Earthquake" Sec.
Steel frame structures	2.0	
Welded assemblies	1.0	b) D + R + E' Stresses are limited to the minimum yield pt. case an analysis, using the limit-design approach the energy absorption capacity which should be energy input. AEC publication TID-7024 "Nuclear 5.7.
Bolted and Riveted assemblies	2.0	
Reactor and turbine building	5.0	Primary containment (including penetrations) a) D + P + H + T + E
Ventilation stack	5.0	
Drywell	5.0	b) D + P + R + H + T + E  Same as (a), above except local yielding is permitted in the area of jet force where the shell is backed up by concrete. In areas not backed up by concrete, primary local membrane stresses at the jet force <0.9 x yield pt. of material at 300°F.
Control room	5.0	
Amend 13 - Unit 2-SAR Amend 14 - Unit 3-SAR		c) D + P + R + H + T + E' Primary membrane stresses, in general, do not exceed the yield pt. of the material. If the total stresses exceeded yield pt. an analysis was made to determine that the energy absorption capacity exceeded the energy input from the earthquake. The same criteria as in (b), above, is applied to the effect of jet force for this

D = Dead load of structure and equipment plus any other permanent loads contributing stress.  
 P = Pressure due to loss-of-coolant accident, R = Jet force on pressure on structure due to rupture of any one pipe,  
 H = Force on structure due to thermal expansion of pipes under operation conditions, T = Thermal loads on containment  
 due to loss-of-coolant accident, E = Design earthquake load.

loading condition.

SEISMIC REVIEW TABLE

MECHANICAL & PIPING				
DAMPING OBE/SSE  (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA		
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES	
Suppression chamber	2.0	Analytical model	<u>Reactor Primary Vessel Internals</u> a) D + E	a) ASME, Sec. III Class A vessel
Feedwater lines	0.5		b) D + E' b) The secondary and primary plus secondary stresses are examined on a rational basis taking into account elastic and plastic strains. These strains are limit to preclude failure by deformation which would compromised any of the engineered safeguards or prevent safe shut-down of the reactor.	
Vital piping systems	0.5			
Reactor pressure vessel	2.0			
Recirculation loop piping	0.5		c) P + D	c) ASME, Sec. III, Class A
Main steam lines	0.5		<u>Reactor Primary Vessel Supports</u> a) D + H + E	a) AISC for structural steel ACI for reinforced concrete
Suppression chamber ring header	0.5	b) D + H + R + E	b) Stresses do not exceed: - 150% of AISC allowable for structural steel - 90% of yield stress for reinforcing bars - 85% of ultimate stress for concrete	
		c) D + H + E'	c) The design is such that energy absorption capacity exceeds energy input.	

ECCS: a.) D + T + H + E

a.) Piping - ASA B 31.1 (1955 ed.) and code cases  
Pumps - ASME Sec. III, Class C  
Shellside - ASME Sec. III, Class C and TEMA C  
Tubeside - ASME Sec. VIII, TEMA C

13-4

b.) D + T + H + E'

b.) Same as P + D above

p. 12. 1-6

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available	Analysis and Generic Testing	Battery racks - No structural design calculations Instrumentation and control room panels - GE generic tests* Motor Control Center - Cutler Hammer Co. Generic Tests ** - Vibration test and analysis of 7700 Line Motor Control Center, # 70ICS100, 8-70  Transformers - No tests or calculations Cable trays - S. and L. Engrs., Specs, for Cable Pans and Hangers, Spec. K-2197	Not available

\* GE - "Seismic Testing of Instrumentation" Dresden 2, 1-71  
 \*\* Wyle Labs - "Seismic Simulation Test Report for Modified Unitrol  
 Motor Control Center, Report 43746-1, 10-77



SEISMIC REVIEW TABLE

Docket Number  
50-331

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					EARTHQUAKE TIME HISTORY	METHOD OF COMBINATION		DESIGN SPECTRA	
	OBE		INTENSITY MM	SSE			NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g		HOR. g	VERT. g					
Duane Arnold Energy Center  Reactor type: BWR  Containment type: Mark I (steel)  NSSS Manufacturer: General Electric  Architect Engineer: Bechtel          6-70/2-74	For struc- tures on bedrock or loft fill: 0.06  For struc- ture on 30-50 ft. of soil: 0.09.  Sec. 2.6.2.1.1 p. 2.6-24 Table 2.6-2	For struc- ture on bedrock: 0.05  For struc- ture on soil: 0.06  Sec. 2.6.2.1.1 p. 2.6-24 Table 2.6-2	Not avail- able.	For struc- tures on bedrock or 10 ft. of fill: 0.12  For struc- ture on 30-50 ft. of soil: 0.18  Sec. 2.6.2.1.1 p. 2.6-40 Table 2.6-3	Struc- ture on rock: 0.10  Struc- ture on 30-50 ft. of soil: 0.12  Sec. 2.6.2.5.3 p. 2.6-40	1. 1935 Helena, Montana earthquake.  2. 1952 Taft, California earth- quake.          Sec. 2.6.2.5.3 p. 2.6-40	The earth- quake con- ditions were applied to the struc- ture in the direc- tion of each of their principal axes.          Sec. C.5.2.3.1 p. C.5-5	Direct addition (Time history)  SRSS (Spectrum analysis)          p. C.5-5 p. C.5-13	Response spectra developed for struc- tures on: (1) Bedrock: 1935 Helena, Montana earthquake, (2) Compact fill and/or soil over- lying bedrock: 1952 Taft, Cali- fornia earthquake.          Sec. 2.6.2.5.3 p. 2.6-40	Time history method using developed earth- quake time history.          Sec. C.5.2.3.1 p. C.5-6

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT				SOIL - STRUCTURE INTERACTION					
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
<p>Reactor building: mat foundation on bedrock.</p> <p>Depth: not available.</p> <p>Sec. 2.6.3.1.1 p. 2.6-46</p>	<p>Surficial deposits of clayey silt, sand, and gravel.</p> <p>Glacial till.</p> <p>Wapsipinicon formation (limestone and dolomite).</p> <p>Sec. 2.6.1.1.1 p. 2.6-1 Fig. 2.6-9</p>	<p>25 feet to more than 100 feet thick.</p> <p>About 67 feet thick.</p> <p>Sec. 2.6.1.1.1 p. 2.6-1 Fig. 2.6-9</p>	<p>V<sub>s</sub> value computed:</p> <p>Surficial deposit: 500 fps</p> <p>Glacial till: 1800 fps.</p> <p>Limestone: 8600 fps.</p> <p>Fig. 2.6-9</p>	<p>About 8 feet below the existing ground surface.</p> <p>Fig. 2.6-12</p>	<p>"There are 12 low head dams."</p> <p>Sec. 2.5.1 p. 2.5-1,2</p>	<p>Figure C.5-5 indicates stick model with soil springs.</p> <p>Sec. C.5, 2.3.1 p. C.5-5</p>	<p>Alluvial sand: 0.5x10<sup>6</sup> psf</p> <p>Glacial till: 0.7x10<sup>6</sup> psf</p> <p>Rock: 200x10<sup>6</sup> psf</p> <p>Table 2.6-4 p. 2.6-80</p>	<p>Foundations, rock, soil: OBE and DBE: 5.0% of critical damping.</p> <p>Table C.5-1</p>	<p>Not available.</p>

**SEISMIC REVIEW TABLE**

<b>STRUCTURES</b>		
<b>DAMPING OBE/SSE</b>	<b>(% criti- cal damping)</b>	<b>DESIGN CRITERIA</b>
		<b>LOAD COMBINATION</b>
		<b>ACCEPTANCE CRITERIA &amp; ALLOWABLE STRESSES</b>
<p><b>Containment structure and all internal concrete structures:</b></p>	<p>2.0/5.0</p>	<p>(1) Normal loads + operating basis earthquake                      (2) Normal loads + maximum probable flood                      (3) Normal loads + design basis earthquake                      (4) Normal loads + tornado loads                      (5) Normal loads + design basis loss-of-coolant accident reference</p> <p>For further information refer to Sec. 12.4.2, p. 12.4-1.</p>
<p><b>Other conventionally reinforced concrete structures, such as shear walls or rigid frames:</b></p>	<p>5.0/5.0</p>	
<p>Table C.5-1</p>		<p>p. 12.4-3</p>
		<p>p. 12.4-7</p>







SEISMIC REVIEW TABLE

Docket Number  
50-321

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					EARTHQUAKE TIME HISTORY	METHOD OF COMBINATION		DESIGN SPECTRA	
	OBE		INTENSITY MM	SSE			NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. S	VERT. S		HOR. S	VERT. S					
CP/OL ISSUE DATE										
Edwin I. Hatch Nuclear Power Plant Unit No. 1  Reactor type: BWR  Containment type: Mark I (steel)  NSSS Manufacturer: General Electric  Architect Engineer: Bechtel	0.08	0.053	VII	0.15	0.10	N-S component of 1940 El-Centro earthquake.	2 com- ponents: Worst horizontal component plus vertical combined simultan- eously	SRSS including closely spaced modes.	Conform to the aver- age spectra by G.W. Housner for $T \leq 4$ s.  Normalized to the peaks (horizontal) of OBE and SSE.	Time-history method  Class II UBC
9-69/8-74	Sec. 12.3.3.2 p. 12-8		Sec. 2.5.9 p. 2-33	Sec. 12.3.3.2 p. 12-8	Sec. 12.3.3.2 p. 12-8	Sec. 12.6.2.1 p. 12-21	p. C-13	Sec. 12.6.2.1 p. 12-20	Sec. 2.5.9 p. 2-33 Fig. 2.5-5 and 6	Sec. 12.6.2.1 p. 12-21

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
Reinforced concrete mat foundations for the following buildings: reactor, turbine, control, diesel generator, and radwaste. The foundation for the main stack is a reinforced concrete mat on steel H-piles.	Duplin: (cemented clay-sand grading to sandy clay). Beneath: (sand, sandy-clay) Clay, sand, gravel, etc. Crystal-line basement rock.	135 ft  10 to 70 ft  65 ft  4000 ft	2450 fps	Summary of domestic well study is given in Table 2.4-3, pp. 2-18 and 2-19 of Section 2.4.6.2.  Summary of Piezometer Installation Data is given in Table 2.4-4, pp. 2-20 and 2-21 of Section 2.4.6.2  No liquefaction potential has been found.	Not available.	Stick model with soil springs.	23,300 ksf   Amendment 14, 4/72 Vol. VIII of FSAR Table Q 12.3.3.2.4-1 of Question 12.3.3.2.4	Translation and rotation of foundation soil - 4.5%DBE - 5.5%DBE	Unclear information Ref: PSAR Sec. XII-3.1
Sec. 12.5 p. 12-18	Sec. 2.7.4 p. 2-41		Amend. 14 (4/72) p. 12.3.3.2.4-2	Sec. 2.7.7 p. 2-45		Amendment 12 12/72 Sec. 12.6.2.1 p. 12-20 Fig. 12.6-1		Table 12.3-2 p. 12-10	

SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING OBE/SSE	(% critical damping)	DESIGN CRITERIA
		LOAD COMBINATION
<p>Reinforced concrete structures:</p> <p>Steel frame structures:</p> <p>Bolted and riveted assemblies:</p> <p>Welded assemblies:</p> <p>Vital piping:</p> <p>Translation and rotation of foundation soil:</p>	<p>3.0/5.0</p> <p>3.0/5.0</p> <p>3.0/5.0</p> <p>2.0/3.0</p> <p>0.5/1.0</p> <p>4.5/5.5</p>	<p>Class I structures</p> <p>1. Primary containment.</p> <p style="padding-left: 20px;">(a) D+L+H+T+E                      (b) D+L+H+P+R+T+E</p> <p style="padding-left: 20px;">(c) D+L+H+P+R+T+E'              (d) D+E+F</p> <p>2. Reactor pressure vessel support.</p> <p style="padding-left: 20px;">(a) D+L+H+E                      (b) D+L+H+R+P+T</p> <p style="padding-left: 20px;">(c) D+L+H+T+P+T+E              (c) D+L+H+R+P+T+E'</p> <p>3. Reactor building and all other Class I structures.</p> <p style="padding-left: 20px;">(a) D+L+H+E                      (b) D+L+H+W</p> <p style="padding-left: 20px;">(c) D+L+H+E'                      (d) D+L+H+W'</p> <p>4. Reactor building crane structure.</p> <p style="padding-left: 20px;">(a) D+L+C+I                      (b) D+L+C+E</p> <p style="padding-left: 20px;">(c) D+L+C+E'                      (d) D+L+C+W</p> <p style="padding-left: 20px;">(d) D+L+C+W'</p> <p>Class II structures: designed according to applicable codes and standards.</p> <p>NOTE: D = dead load, L = live load, C = crane load, I = impact load, P = pressure due to LOCA, R = jet force, T = thermal load, E = OBE, E' = SSE, W = wind, W' = tornado wind, and F = hydrostatic.</p>
<p>Amendment 12, 2/72, Vol. III Sec. 12, Table 12.3-2 p. 12-10</p>		<p>ACCEPTANCE CRITERIA &amp; ALLOWABLE STRESSES</p> <p>They are classified according to the load combination case. For details, see Sec. 12.4, pp. 12-15 and 12-16.</p> <p>Generally used: ASME, Sec. III, Class B. For steel structures, AISC. For concrete structure: ACI 318-63 and 307-69</p> <p>Sec. 12.4, p. 12-15</p>



SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	Not available.	Not available.	Not available.



SEISMIC REVIEW TABLE

Docket Number

50-366

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					EARTHQUAKE TIME HISTORY	METHOD OF COMBINATION		DESIGN SPECTRA	
	OBE		INTENSITY MM	SSE			NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g		HOR. g	VERT. g					
Edwin I. Hatch Nuclear Power Plant Unit No. 2  Reactor type: BWR  Containment type: Mark I (steel)  NSSS Manufacturer: General Electric  Architect Engineer: Bechtel          9-69/8-74	0.08	0.053	VII	0.15	0.10	Modified Taft 1952 horizontal component was used for develop- ing synthetic accel- eration time history.	3 compo- nents: Each hori- zontal combined with the vertical simulta- neously, re- sulting in two separ- ate seis- mic cases.	SRSS with close modes summed absolute- ly.	Modified Newmark design spectra.	Time-history method.
	Sec. 2.5.2.11 p. 25-26	Sec. 2.5.2.11 p. 25-26	Sec. 2.5.2.10 p. 25	Sec. 2.5.2.10 p. 25	Sec. 2.5.2.10 p. 25	Sec. 3.7A.1.2 p. 3.7A-1	Sec. 3.7A.3.7 Sec. 3.7B.3.7 p.9	Sec. 3.7A.2.1.1 Sec. 3.7A.2.2 Sec. 3.7A.3.7	Sec. 3.7A.1.1 Figs. 3.7A1-3.7A6	Sec. 3.7B.2.6 Sec. 3.7B.2.3 Sec. 3.7B.2.8

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT				SOIL - STRUCTURE INTERACTION					
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
Reinforced concrete mat 27'2" thick at middle dry well and 12'4" thick at other sections.  Sec. 3.8.5.1b p. 3.8-76 Fig. 3.8-31 & 32	Major and minor struct: Upper Miocene Dublin locally cemented sand to sandy clay Upon Hawthorne sandy clay.  Sec. 2.5.2.1 p. 23 Sec. 2A. p. 4 Figures 2A-2 thru 2A-3EE	To a depth of 135' (ft).  Below Dublin down 10'-70' (ft).  Sec. 2.5.2.1 p. 23 Sec.2A.2 p. 4 Figures 2A-2 thru 2A-3EE	2450 ± 200 fps  Sec. 2A.1.4 p. 2A.1-3 Fig. 2A-5 and 2A-6	e1.70 to e1.75 ft.  Sec. 2.5.4.6 p. 2.5-30	2 upstream of plant, Caltamaha River Basin 1) Sinclair Dam on Oconee Riv. 2) Lloyd Shoals Dam, Ocmulgee River.	Stickmodel with soil springs  Sec. 3.7A.2.4 Sec. 3.7A.2.5 p. 5	Not available.	Not available.	Not available.

SEISMIC REVIEW TABLE

		STRUCTURES	
DAMPING OBE/SSE	(% critical damping)	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Reinforced concrete structure:	3.0/5.0	Steel containment	ASME, BPVC, Sec. III
Steel frame structures:	3.0/5.0	(a) Initial and final testings	AISC 1969 Ed.
Bolted and riveted assemblies:	3.0/5.0	(1) $D+L+P_t+T_t+E$	ACI 318-63
Welded assemblies:	2.0/3.0	(2) $D+L+P_t+T_t+E'$	
Translation and rotation of soil: (NSSS)-	4.0/5.0	(b) Normal operating	
Drywell-building (coupled):	3.0/5.0	(1) $D+L+T_o+R_o+E$	
Suppression chamber:	2.0/3.0	(2) $D+L+T_o+R_o+E'$	
Reactor pressure vessel, support skirt, shroud head, separator and guide tubes:	2.0/3.0	(3) $D+L+T_e+R_e+P_e+E$	
Fuel:	7.0/7.0	(4) $D+L+T_e+R_e+P_e+E'$	
Table 3.7A-1 and 3.7B-1		(c) Refueling	
		(1) $D+L+E$	
		(2) $D+L+E'$	
		(d) Accident	
		(1) $D+L+T_a+R_a+P_a+E$	Sec. 3.8.2.3 p. 7
		(2) $D+L+T_a+R_a+P_a+E'$	Sec. 3.8.3.3 p. 47
		(3) $D+L+T_a+R_a+P_a+Y_r+Y_j+Y_m+E'$	Sec. 3.8.4.3 p. 58
		(e) Flood	Sec. 3.8.5.3 p. 78
		(1) $D+L+E+F$	Sec. 3.8.2.2 p. 4 Sec. 3.8.3.2 p. 45 Sec. 3.8.4.2 p. 57 Sec. 3.8.5.2 p. 78







SEISMIC REVIEW TABLE

Docket Number

50-285

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					EARTHQUAKE TIME HISTORY	METHOD OF COMBINATION		DESIGN SPECTRA	
	OBE		INTENSITY MM.	SSE			NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g		HOR. g	VERT. g					
CP/OL ISSUE DATE										
Fort Calhoun Station Unit #1  Reactor type: PWR  Containment type: Without Buttresses (Prestressed Con- crete)  NSSS Manufacturer: Combustion Engi- neering  Architect Engineer: Gibbs & Hill, Inc.	0.08	.053	Unclear information	0.17	.0113	Time history—1940 El Centro and 1952 Taft normalized to the ground acceler- ation of the maximum hypothetical earth- quake are used for developing floor response spectra.	3 compo- nents. Combina- tion not available.	SRSS	Response spectra conform to the average spectra developed by Housner for fre- quency > 0.33 HZ and Newmark for frequency < 0.33 HZ.	Time history method.
6-68/5-73	Sec. 2.4 p. 2.4-3	Sec. 2.4 p. 2.4-3	Sec. 2.4 p. 2.4.1	Sec. 2.4 p. 2.4.3	Sec. 2.4 p. 2.4.3	Sec. F.2.2.4 p. F-10	App. F Sec. F.2.5 p. F-12	App. F Sec. F.2.2.3 p. F-9	App. F Sec. F.2.1.4 p. F-6	App. F Sec. F.2 p. F.10 & F.14

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT				SOIL - STRUCTURE INTERACTION					
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
High strength concrete mat supported by pile foundation resting on bedrock (containment, auxiliary bldg.)	Compact granular.	60 ft	Not available.	Missouri River Valley.	Gavin Point	Stick model with soil springs.	Not available.	Not available.	0.05 SSE 0.02 OBE
	Fluvial deposits on limestone.	4-8 ft		Domestic wells depth 20 ft to 35 ft.	Fort Randall				
	Bedrock underlain by rock strata.	19-21 ft		Commercial wells depth 50 ft to 75 ft.	Big Bend Oahe Garrison Fort Peck				
Sec. 5.1 p. 5.1.1 Covering letter "Dames & Moore" App. C p. 10	Sec. 5.1 p. 5.1.1 App. C p. 6	Sec. 5.1 p. 5.1.1 App. C p. 6		Sec. 2.7.2 p. 2.7-6	Sec. 2.7 p. 2.7-1	Sec. F.2.2.3 p. F-8			Sec. F.2.2.3 p. F.9

SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING OBE/SSE	(% critical damping)	DESIGN CRITERIA
		LOAD COMBINATION
		ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
<p>Containment structure: 2.0/2.0</p> <p>Concrete support structures for reactor vessel and steam generators: 2.0/2.0</p> <p>Steel Assemblies: Bolted or riveted 2.0/2.0 Welded 1.0/1.0</p> <p>Vital piping systems: 0.5/0.5</p> <p>Rigid vault type concrete structures: 2.0/5.0</p> <p>Framed concrete structures: 5.0/7.0</p> <p>Sec. F-2.1.3 p. F-6</p>	<p>1. D+L+S+T'''</p> <p>2. D+L+S+T'''+W or E</p> <p>3. D+L+P+S+T+W or E</p> <p>where:</p> <p>D = Dead load including equipment weights and hydrostatic loading</p> <p>L = Live load</p> <p>S = Post-tensioning load (which varies with time)</p> <p>P = Accident design pressure</p> <p>T = Thermal loads based on a temperature corresponding to pressure P</p> <p>W = Wind load</p> <p>E = Design earthquake</p> <p>T''' = Thermal loads based on normal operating temperature</p> <p>For further details refer to section 5.5.</p> <p>Sec. 5.5 p. 5.5-1 to 5.5-5a</p>	<p>Ultimate strength method ACI 318-63</p> <p>Modified ultimate strength design</p> <p>No loss of function design for extreme environmental loading</p> <p>Sec. F.2.1.1 p. 5.5-1 Sec. 5.5 p. F.3</p>



SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT

DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	<p>Shop test, prototype test, field test or seismic analysis to meet Class I seismic criteria.</p> <p>Appendix F Sec. 6.14 Sec. F.2.2.2 p. 6.1-4 p. F.7.C, 7d</p>	<p>"Special seismic restraints will be installed at the electrical cable trays. The cable will be supported vertically and horizontally so as to meet the stress criteria under all conditions including postulated earthquakes."</p> <p>Sec. F.2.2.2 p. F.7.C</p>	<p>According to IEEE 344 "Guide for Seismic Qualification of Class I Equipment for Nuclear Power Generating Station"</p> <p>Sec. F.2.2.2 and Sec. 7.2.2 p. F.7.C and p. 7.2.1</p>



SEISMIC REVIEW TABLE

Docket Number

50-267

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					EARTHQUAKE TIME HISTORY	METHOD OF COMBINATION		DESIGN SPECTRA	
	OBE		INTENSITY MM	SSE			NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g		HOR. g	VERT. g					
CP/OL ISSUE DATE										
Fort St. Vrain Nuclear Generating Station (Unit 1)  Reactor type: HTGR  Containment type: Prestressed Concrete  NSSS Manufacturer: Gulf General Atomic  Architect Engineer: Sargent and Lundy Engineers	0.05	0.033	VII	0.10	0.067	TID-7024, "Nuclear Reactors and Earthquakes", AEC, 8/63	The hori- zontal re- sults from spec- tral anal- ysis were combined simulta- neously with the vertical	PCRV: "Linear super- position of all modal contribu- tions". All other Cat. I struct: SRSS	Response spectra were developed as recommended in AEC TID-7024.  Housner	TID-7024
9-68/12-73	Amend. 14 Sec. 5.2.1.1 p. 5.2-4	Amend. 14 Sec. 5.2.1. p. 5.2-4		Amend. 14 Sec. 5.2.1.1 p. 5.2-4	Amend. 14 Sec. 5.2.1.1 p. 5.2-4	p. 14.1-1, App. E.13	p. 5.3-33	p. 14.1-4	Fig. 14.1-1 Sec. 14.1 p. 14.1-1, 14.1-3	p. 14.1-1 App. E.13

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
<p>1. Reactor, turbine buildings and heavy equipment, as well as the main and service water cooling towers.</p> <p>Straight shaft piers. drilled into the claystone bedrocks.</p>	<p>The major plant facilities will be founded on Pierre Shale bedrock (dark gray, silty shale). 44 to 54 ft.</p> <p>p 1.2-2</p>		<p>Not available</p>	<p>Ground water level was well below proposed foundation level, except reactor building which extends below the water level.</p>	<p>V<sub>S</sub> = 1200 fps @ 20 ft. V<sub>S</sub> = 2400 fps @ 65 ft.</p> <p>Boring UH1</p>	<p>Lumped mass model with soil springs</p>	<p>G<sub>S</sub> = 850 psi @ 20 ft. G<sub>S</sub> = 104,000 psi @ 65 ft.</p> <p>Boring UH1</p>	<p>Not available</p>	<p>Not available</p>
<p>2. Miscellaneous light equipment.</p> <p>Spread footings.</p>	<p>Above it lies St. Vrain Platte River alluvia sands and gravel</p> <p>p. 1.2-2</p>			<p>Sec. 2.6 p. 2.6-21</p>	<p>Table 3-1</p>	<p>p. E. 37-12 Fig. E.13-1</p>	<p>Table 3-1 p. 3-8</p>		

SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING OBE/SSE (X Critical damping)	DESIGN CRITERIA	
	LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Reinforced concrete: 2.0/5.0  PCR.V. (prestressed concrete reactor vessel) 2.0/5.0  Welded steel 2.0/5.0  Bolted steel 2.0/10.0	PCR.V:  DL + 1.23 NWP + E' + TL DL + 1.23 NWP + 1.5 TL  NWP = Normal working pressure DL = Dead load E' = SSE earthquake loads TL = Temperature loads	For reactor core support structure:  Concrete. ACI 318-63 Metal. ASME B and PV Code Sec. III. Class A  <u>Stress Criteria: Operating</u> Principal Comp. $0.45 C_f f'_c$ Principal tension $3\sqrt{f'_c}$  Bearing tendon area $0.6f'_c \sqrt{3ab'/ab'} < f'_c$ Bearing: Shear Anchors $0.6f'_c$ average
Amend. 16, p. 14.1-3	Table E.1-1	Table E.1-1 Sec. 3.2, p. 3.2-2









SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
<p>Containment- 9 ft. mat. Spent fuel pit founded on bedrock with lowerside walls embedded in rock and earth.</p> <p>Major structures are founded directly on the granitic gneiss bedrock. Minor structures are founded either on rock on piles driven to rock or on spread footings in compacted granular fill.</p> <p>2.4-2</p>	<p>SAMPLE:</p> <p>Boring L-11</p> <p>Loose loam EL+7.0 to + 5.0</p> <p>Firm fine sand and gravel + 5.0 to -2.0</p> <p>boulder -2.0 to -8.0</p> <p>schist -8.0 to -30.0</p> <p>Fig. 2.4-4</p>	<p>Not available</p> <p>+ 5.0</p> <p>-2.0</p> <p>-8.0</p> <p>-30.0</p>	<p>21 ft. MSL is yard grade. Calculated site flood stage is 15.1 MSL</p> <p>GWL: - 8 ft. MSL</p> <p>2.3-3</p>	<p>Not available</p>	<p>Fixed base with single degree of freedom (containment).</p>	<p>Not available</p>	<p>Not used</p>	<p>Not used ..</p>	

SEISMIC REVIEW TABLE

STRUCTURES			
DAMPING OBE/SSE (% critical damping)	DESIGN CRITERIA		
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
R/C containment: Include mat	7.0	<u>Reinforcing steel - primary plus secondary</u> operating + incident - 33.3 ksi operating + .03g hor. - 26.7 ksi operating + .03g hor. + incident - 33.3 ksi operating + incident + 0.17g hor. - 40.0 ksi	ACI and ASME Codes plus Rayleigh method and equivalent static loads for seismic
R/C framed structure	5.0		
Steel framed structures, include support. structure and foundation			
bolted	2.5		
welded	1.0	- wind loads up to 150 mph - 30 psf snow and ice (not included in combination)  p. 3.2-2	
		<u>Non-safety related systems:</u> E (=0.03g): No loss of function	

Table 2.5-2

p. 3.2-2

SEISMIC REVIEW TABLE

MECHANICAL & PIPING													
DAMPING OBE/SSE (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA											
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES										
Piping:  Carbon steel 0.5  Stainless steel 1.0  Reactor internals and CRD  welded 1.0  bolted 2.0  Mechanical equipment includes pumps and fans 2.0	Analytical	Reactor coolant Safety Injection System:  Operating loads + E < working Stress (E = 0.17g)  <hr/> Main Steam Piping:  Operating loads + E < Working Stress (E= 0.03g)	<table border="0"> <thead> <tr> <th style="text-align: center;"><u>Component</u></th> <th style="text-align: center;"><u>Design Code</u></th> </tr> </thead> <tbody> <tr> <td>Steam generator- Reactor Coolant Pumps- Reactor Coolant Piping - Pressurizer</td> <td>ASME Section VIII (1956 ed.) ASME Section VIII (1956 ed.) ASA B31.1 (1955 ed.) ASME Section VIII (1956 ed.) and Code Case Nos. 1224 and 1234 ASME Section I (1956 ed.) and Code Case Nos. 1224 and 1234</td> </tr> <tr> <td>Safety and Relief Valves</td> <td>ASA B16.5 (1957 ed.) ASA B16.5 (1957 ed.) ASA B31.1 (1955 ed.)</td> </tr> <tr> <td>Loop Stop Valves Loop Check Valves Pressure Control and Relief System Piping</td> <td></td> </tr> <tr> <td>Low Pressure Surge Tank</td> <td>ASME Section VIII (1956 ed.)</td> </tr> </tbody> </table>	<u>Component</u>	<u>Design Code</u>	Steam generator- Reactor Coolant Pumps- Reactor Coolant Piping - Pressurizer	ASME Section VIII (1956 ed.) ASME Section VIII (1956 ed.) ASA B31.1 (1955 ed.) ASME Section VIII (1956 ed.) and Code Case Nos. 1224 and 1234 ASME Section I (1956 ed.) and Code Case Nos. 1224 and 1234	Safety and Relief Valves	ASA B16.5 (1957 ed.) ASA B16.5 (1957 ed.) ASA B31.1 (1955 ed.)	Loop Stop Valves Loop Check Valves Pressure Control and Relief System Piping		Low Pressure Surge Tank	ASME Section VIII (1956 ed.)
<u>Component</u>	<u>Design Code</u>												
Steam generator- Reactor Coolant Pumps- Reactor Coolant Piping - Pressurizer	ASME Section VIII (1956 ed.) ASME Section VIII (1956 ed.) ASA B31.1 (1955 ed.) ASME Section VIII (1956 ed.) and Code Case Nos. 1224 and 1234 ASME Section I (1956 ed.) and Code Case Nos. 1224 and 1234												
Safety and Relief Valves	ASA B16.5 (1957 ed.) ASA B16.5 (1957 ed.) ASA B31.1 (1955 ed.)												
Loop Stop Valves Loop Check Valves Pressure Control and Relief System Piping													
Low Pressure Surge Tank	ASME Section VIII (1956 ed.)												

Table 2.5.2

**SEISMIC REVIEW TABLE**

**ELECTRICAL EQUIPMENT**

DAMPING OBE/SSE  (% Critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available	No testing	Not available	Not available



SEISMIC REVIEW TABLE

Docket Number  
50-261

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					EARTHQUAKE TIME HISTORY	METHOD OF COMBINATION		DESIGN SPECTRA	
	OBE		INTENSITY MM	SSE			NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. S	VERT. S		HOR. S	VERT. S					
CP/OL ISSUE DATE										
H. B. Robinson Nuclear Steam Electric Plant Unit No. 2  Reactor type: PWR  Containment type: without buttresses (prestressed con- crete)  NSSS Manufactuer: Westinghouse  Architect Engineer: Ebasco	0.10	0.067	VII	0.20	0.133	Not used.	X and Y (vertical) or Z and Y (vertical) applied together. Combina- tion not available.	Absolute sum.	Housner spectra.	No floor re- sponse spectra generated.  Housner spectra used for components.
4-67/8-70	p. 5.1.2 -6	p. 5.1.2 -6		p. 5.1.2 -6	p. 5.1. 2-6	p. 5A-4	Question III A 11	Question IIA	Figures 2.9-2 9.9-3 p. 2.9-9	p. 5A-4

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
<p>A 144 ft. diameter circular reinforced concrete slab 10 ft. in thickness supported by 923 steel pile.</p> <p>p. 5.1.2-20</p>	<p>The piedmont crystal-line basement rock at the site is overlaid with 460 ft. of unconsolidated plain sediment. These sediments are comprised of surface alluvium *</p> <p>(cont.)</p>	<p>The middendorf is made up of silty and sandy clay, sandstone and mudstone. Fig. 2.8-2</p> <p>Basement Rock Middendorf 430ft. Alluvium 30ft.</p>	<p>Not available.</p>	<p>Not available.</p>	<p>Earth dam at the site has a central vertical clay core and supporting shells of compacted sand. The crest of the dam is at El. 230, the normal pool is at El. 220 and the dam has a maximum height of 50 ft. The crown width of dam is 15 ft. and side slopes are 1(vertical): **</p>	<p>Not available.</p> <p>**DAM (cont.) 3(horizontal) on upstream side and 1 (vertical): 2.5(Horizontal) on downstream with 15 ft. berm at El. 200. Sec. 2.9.8 p. 2.9-10 Dock. 50261-104</p>	<p>Not available.</p>	<p>Not available.</p>	<p>The modal analysis was performed utilizing the same damping factor for each mode.</p> <p>Question III A4</p>
<p>TYPE (cont.)</p> <p>* over 430 ft. middendorf formations.</p> <p>Sec. 2.8.3 p. 2.8-6 Dock. 50261-104</p>									

SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING OBE/SSE	(% critical damping)	DESIGN CRITERIA
		LOAD COMBINATION
		ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Containment structure:  Concrete support structure of reactor vessel:  Concrete structures above ground: (a) Shear wall (b) Rigid frame	2.0  2.0  5.0 5.0	For containment structure: (a) $C=1.0D+0.05D+1.5P+1.0(T+TL)+1.0B$ (b) $C=1.0D+0.05D+1.25P+1.0(T'+TL')+1.25E+1.0B$ (c) $C=1.0D+0.05D+1.0P+1.0(T'+TL')+1.0E'+1.0B$ (d) $C=1.0D+0.05D+1.0P_T+1.0(T_T+TL_o)+1.25WT+1.0B$ (e) $C=1.0D+0.05D+1.15P_D$  Symbols used in these formulas are defined on p. 5.1.2-9.
Table 5A.1-1 p. 5A-5		p. 5.1.2-8

SEISMIC REVIEW TABLE

MECHANICAL & PIPING					
DAMPING OBE/SSE (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA			
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES		
Vital pipe systems: 0.5	Analytical	<u>Vessels</u>	<u>Piping</u>		
Steel assemblies:		1. Normal loads	$P_m \leq S_m$	$P_m \leq S$	
(a) Bolted or riveted 2.5		$P_L + P_B \leq 1.5S_m$	$P_L + P_B \leq S$	Pressure piping: USAS B31.1  Pressure vessel: ASME, BPVC	
(b) Welded 1.0		2. Normal + design earthquake loads	$P_m \leq S_m$		$P_m \leq 1.2S$
		$P_L + P_B \leq 1.5S_m$	$P_L + P_B \leq 1.2S$		
	3. Normal + assumed hypothetical earth- quake loads	$P_m \leq 1.2S_m$	$P_m \leq 1.2S$		
	$P_L + P_B \leq 1.2(1.5S_m)$	$P_L + P_B \leq 1.2(1.5S)$			
	4. Normal + pipe rupture loads	$P_m \leq 1.2S_m$	$P_m \leq 1.2S$		
		$P_L + P_B \leq 1.2(1.5S_m)$	$P_L + P_B \leq 1.2(1.5S)$		
		$P_m$ = primary general membrane stress; or stress intensity. $P_L$ = primary local membrane stress; or stress intensity. $P_B$ = primary bending stress; or stress intensity. $S_m$ = stress intensity value from ASME, BPVC Code, Section III $S$ = allowable stress from USAS B31.1 Code for pressure piping.			
Table 5A.1-1 p. 5A-5		Table 5A.3-1	p. 5A-3		

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	Circuits and equipment were subjected to vibration tests which simulated the seismic conditions for the "low seismic" class of plants.  p. 7.5-13	Not available.	Electrical equipment: WCAP 7397-L  p. 7.5-14 Amendment 10





SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING.	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
Not available	Sand and alluvium overlying strata of Hookton and Carlotta formation which are more or less consolidated sands. Gravels and clays and conglomerates with good structural properties.	Not available	Not available	Not available	Not available	2 dimensional finite element model which includes embedded reactor caissons  p. 5-1		BC -	TOP 4A

FHSR, Amend 11,  
Sec. I, p. 155

SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING OBE/SSE	DESIGN CRITERIA	
	LOAD COMBINATION	ACCEPTANCE CRITERIA & 'ALLOWABLE' STRESSES
R. G. 1.61 (BC-TOP-4A)	<p><u>Accident Condition</u> Concrete structures:</p> $U = D + L + T_A + H_A + R + 1.5 P$ $U = D + L + T_A + H_A + R + 1.25 P + 1.25 E$ $U = D + L + T_A + H_A + R + P + E'$ $U = D + L + T_O + H_O + E'$ <p>Steel Structures <u>Elastic working stress</u></p> $1.6S = D + L + T_A + H_A + R + P$ $1.6S = D + L + T_A + H_A + R + P + E$ $1.6S = D + L + T_A + H_A + R + P + E'$ <p><u>Plastic</u></p> $0.9 Y = D + L + T_A + H_A + R + 1.5 P$ $0.9 Y = D + L + T_A + H_A + R + 1.25 P + 1.25 E$ $0.9 Y = D + L + T_A + H_A + R + P + E'$ <p>App. B-3</p>	<p>AWS D1.1-74 welded steel tanks for oil storage, API 650, 1973 BC-TOP-9A, Design of structures for missile impact, Rev. 2, 1974</p> <p>UBC - 1973 ACI -214 - 65 ACI -318 - 71 AISC - 1969</p> <p>p. C-1 p. C-2</p>

SEISMIC REVIEW TABLE

MECHANICAL & PIPING							
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA			ACCEPTANCE CRITERIA & ALLOWABLE STRESSES		
		LOAD COMBINATION					
Reg. Guide 1.61 (BC-TOP-4A)	Test or Analysis	<u>Piping System</u>			BN-TOP-2, Design for pipe break effects		
		<u>Plant Operating Condition</u>	<u>Loading Condition</u>	<u>ASME SEC.III Ref.</u>		<u>Allowable Stress</u>	
		Normal	P + W	Eq.(8) of NC-3652.1		$S_H$	
		Upset	P + W + OBE P + W + FV*	Eq.(9) of NC-3652.2		$1.2 S_H$	
		Faulted	P + W + SSE	Eq.(9) of Code Case 1606 NC-3652.2		$2.4 S_H$	
		Normal & Upset	TH	Eq.(10) of NC-3652.3(a)		$S_A$	
			P + W + TH	Eq.(11) of NC-3652.3(b)		$S_A + S_H$	
		<u>Vessel Loading Conditions</u>					
		Upset	P + W + OBE	NC-3300 Sec. VIII Code Case 1607		$P_M \leq 1.10 S$ $(P_M \text{ or } P_L) + P_B \leq$	1.65 S
		Faulted	P + W + SSE	NC-3300 Sect. VIII, Div. 1		$P_M \leq 2.0 S$ $(P_M \text{ or } P_L) + P_B \leq$	2.4 S
	Table 6.1	p. B-5,6					

\*Applies to main steam line





## SEISMIC REVIEW TABLE

Docket Number

50-3

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					EARTHQUAKE TIME HISTORY	METHOD OF COMBINATION		DESIGN SPECTRA	
	OBE		SSE	EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.		MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA	
	HOR. g	VERT. g								INTENSITY MM
Indian Point Nuclear Generating Station, Unit No. 1  Reactor type: BWR  Containment type: Dry containment- spherical (steel)  NSSS Manufacturer: Babcock and Wilcox  Architect Engineer: United Engineers and Constructors   5-56/3-62	None	None	Not avail- able	0.10g for containment structure (including steel sphere and interior structure), nu- clear service bldg., chemical systems bldg., fuel handling bldg., stack  .090g for screenwell house 0.03g for superheater bldg. 0.05g for vertical analysis	Synthetic Time History          "Earthquake Analysis of Piping Systems." 9-12-69 J. Blume Report, p. 1-2	Each hori- zontal combined with vertical simul- taneously	SRSS	Synthetic design spectra  TID-7024  Housner	Time-history method          J. Blume Report on Piping Systems, p. 1-2 Class I structure Sheet 10.1, p. 1-4, 5 Piping Sheet 11.1, p. 1-2, 5 Reanalyzed, Sheet 4.30, p. 1,2,3	

\* "Sheet" refers to microfiche Sheet #

22-1

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT				SOIL - STRUCTURE INTERACTION					
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
Reinforced concrete mat.  Sheet 10.1 p. 2-1	Hard, well-bedded dolomitic limestone, bedrock is extremely jointed and fractured joint systems extended at near right angles to bedding, other systems are irregular. The intensity is almost brecciation.	Foundation sits on bedrock  Sheet 10.1 p. 2-1	Not available	Not available	Not available	Stick model with foundation rigidly fixed to bedrock.  Sheet 10.1 p. 2-1	Not available	No damping assumed  Sheet 10.1 p. 2-1	Not available


SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING OBE/SSE (% critical damping)	DESIGN CRITERIA	
	LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
<p>Reinforced concrete                      5.0/5.0</p> <p>Structural steel - bolted                2.0/2.5</p> <p>   - welded                      1.0/1.0</p>	<p>First analysis-</p> <p><math>C = (1.0 \pm 0.05) D + (E \text{ or } W)</math></p> <p>C = Required load capacity; E = earthquake loads</p> <p>D = Normal loads (dead load of structure, plus any normal Sheet 10.1, p. 1-3 operating live loads)</p> <hr/> <p>Reanalysis-</p> <p><math>U = D + L + F_{eqs} + T_a = P_A</math> - steel containment</p> <p><math>U = D + L + T_a + F_{eqs}</math> - Biological shield</p> <p><math>U = D + L + F_{eqs}</math> - other Class I structures</p> <p>D = Dead loads; L = live loads</p> <p><math>T_a</math> = Thermal loads; <math>P_A</math> = pressure loads</p> <p><math>F_{eqs}</math> = SSE loads</p>	<p>ACI Standard- ACI 318-63</p> <p>"Ultimate Strength Design"</p> <p>ASME BPVC, Sec. VIII</p>
<p>Sheet 10.1, p. 1-2</p> <p>Sheet 430, p. 1</p>	<p>Sheet 4.30, p. 1 and 2</p> <p>Sheet 114.2, Question 7</p>	<p>Sheet 4.1, p. 1-4</p> <p>Sheet 10.1, p. 1-3</p> <p>and Sheet 10.2</p>



SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available	Not available	Not available	Not available



SEISMIC REVIEW TABLE

Docket Number  
50-247

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					EARTHQUAKE TIME HISTORY	METHOD OF COMBINATION		DESIGN SPECTRA	
	OBE		SSE	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.		TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA		
	HOR. g	VERT. g							INTENSITY MM	HOR. g
CP/OL ISSUE DATE										
Indian Point Nuclear Generating Station, Unit No. 2  Reactor type: PWR  Containment type: Atmospheric (Reinforced Concrete)  NSSS Manufacturer: Westinghouse  Architect Engineer: United Engineers & Constructors	0.10	0.05	VI	0.15	0.10	None used	Horizontal and verti- cal.  acting simultan- eously	SRSS	Housner	No floor re- sponse spectra generated; ground response spectra used for piping and com- ponents.
10-66/10-71	Sec. 1.2.2 P. 1.2-9		Sec. 2.8 p. 2.8-1	Sec. 1.2.2 P. 1.2-9		App. A	p. A-3	Q. 1.3-2 Suppl. 9 (5/70)	Fig. A.1-2	Sec. 3.1.5 p. 3.0-9 Supp. 6 (2/70)

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
<p>Mat foundation 9ft. thick.</p> <p>Sec. 1.3.0 p. 1.0-4 Supp. 6 (2/70)</p>	<p>Hard, wellbedded dolomitic limestone. This bedrock is extremely jointed and fractured. Joint systems extended at near right angles to bedding, other systems are irregular. The intensity may be described almost as brecciation.</p>	<p>Not available.</p>	<p>Not available.</p>	<p>Stony Point: about 35ft. depth</p> <p>Rockland County 100ft. to 300ft. depth</p> <p>At the fringe of Westchester County depth less than 50ft.</p> <p>Vol. 1, Sec. 2.5, p. 5-10</p>	<p>Not available.</p>	<p>Structure; Stick Model</p> <p>Fixed base</p> <p>Sec. 3.1.5, p. 3.0-9, Suppl. 9</p>	<p>Not available.</p>	<p>Not available.</p>	<p>Not available.</p>

Sec. 2.7  
p. 4-4



SEISMIC REVIEW TABLE

MECHANICAL & PIPING						
DAMPING OBE/SSE (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA				ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
		LOAD COMBINATION				
		L. C.	Vessel	Piping	Supports	
Vital Piping Systems 0.5 * One damping value is given. But not clear whether for O.B.E. or D.B.E.	Analytical and Testing          Sec. 5.1.3.8 p.5.1.3-6 and Q.4.5, Q.4.5-1 Supp. 6	1. Normal loads  2. Normal + Design E.Q.  3. Normal + SSE  4. Normal + pipe rupture	$P_M \leq S_M$ $P_L + P_B \leq 1.5 S_M$  Same as above  $P_M \leq 1.2 S_M$ $P_L + P_B \leq 1.2 (1.5 S_M)$  Same as above	$P_M \leq S$ $P_L + P_B \leq S$  $P_M \leq 1.2 S$ $P_L + P_B \leq 1.2 S$  $P_M \leq 1.2 S$ $P_L + P_B \leq 1.2(1.5 S)$  Same as above	Working stress or applicable factored load value  1 1/3 working stress  Maintain equip. within stress limits  Same as above	For mechanical: ASME , BPVC, Section III  For piping: USAS B31.1 (1955)  For further details refer to Q. 4.10      Sec. 3.2.3, p. 3.2.3-3 Sec. Q. 4.5, p. Q. 4.5-1 Supp. 6
Sec. 5.1.3.8, p. 5.1.3-7		Table A.3-1				

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	Not available.	Not available.	Not available.



SEISMIC REVIEW TABLE

Docket Number  
50-286

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION	DESIGN SPECTRA			
	OBE		SSE		EARTHQUAKE TIME HISTORY		NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g						
Indian Point Nuclear Generating Station, Unit No. 3  Reactor type: PWR  Containment type: Atmospheric (reinforced con- crete)  NSSS Manufacturer: Westinghouse  Architect Engineer: United Engineer and Contractors          8-69/5-76	.10	.05	VII	.15	.10	Compared with (1) El Centro 12/30/34 and 5/18/40 (2) Olympia 4/13/49 (3) Taft 7/21/52.          p. A1-9, Appendix A1 Curves-Fig. A1-1&2	3 compo- nents: Each hori- zontal combined with vertical component by abso- lute sum.          Question 5.22	SRSS, closely spaced (10%) modes combined by abso- lute sum.          p. Q5.28 -1 p. Q5.37 -1	Containment response: Housner spectra          Sec. 5.1.3.5 p. 5.1.3-3	Time history.          p. Q4.32-1 Vol. VI

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT				SOIL - STRUCTURE INTERACTION					
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
Concrete base mat--9 feet thick.	Fine-grained phyllite, a schist, and limestone with bedrock lying close to the surface. Bedrock is jointed and fractured.	Not available.	Not available.	Fluctuates between El. 35 to El. 55 (MSL)	Three reservoirs are within five mile radius. No information on dams is available.	Structure: stick model  Soil: cantilever beam assumption indicates fixed base modeling.	Not available.	Not available.	Not available.
Sec. 5.1.2.1 p. 5.1.2-1	Sec. 2.7 p. 2.7-1			See Fig. 2.7-3	Sec. 2.5 p. 2.5-2	Appendix 5A Sec. 3.1.5 p. 5A-26→28			









SEISMIC REVIEW TABLE

Docket Number  
50-333

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					EARTHQUAKE TIME HISTORY	METHOD OF COMBINATION		DESIGN SPECTRA	
	OBE		INTENSITY MM	SSE			NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g		HOR. g	VERT. g					
CP/OL ISSUE DATE										
James A. Fitzpatrick Nuclear Power Plant	0.08	.053	VIII	0.15	0.10	Artificial time- history used	SRSS	Housner	Time-history method.	
Reactor type: BWR										
Containment type: Mark I (steel)										
NSSS Manufacturer: General Electric										
Architect Engineer: Stone and Webster Engineering Corp.										
5-70/10-74	p. 2.6-1	p. 2.6-1		p. 2.6-1	p.2.6-1	Sec. 2.6 , p. 2.6-1	App. C 3.3 p. C.3-4	Sec. 12.5.1 p. 12.5-1	Sec. 2.6, p. 2.6-2  See Fig. 2.6-1 and Fig. 2.6-2	Sec. 12.5.4, p. 12.5-13

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
Reinforced concrete mat.  5'-9" thick  embedded 45 ft. below top of bedrock in the surrounding area          Sec. 12.3.1, p. 12.3-1	10-12ft. of glacial till which lies directly on top of the Oswego sandstone with laminations and lenticular beds of dark gray shale. At 130 ft. below surface it makes contact with Lorraine Group   Sec. 2.5 p. 2.5-1	150 ft. of Oswego sandstone	Not available.	Water table at the site slopes toward Lake Ontario at an average gradient of 37 ft. per mile and the direction of ground water is toward the lake.          Sec. 2.4.1 p. 2.4-1	Not available.	Stick model with springs to model the rock.          Sec. 12.5.1.1 p. 12.5-1	Not available.	Not available.	Not available.

**SEISMIC REVIEW TABLE**

<b>STRUCTURES</b>					
<b>DAMPING</b> <b>OBE/SSE</b>  (% critical damping)		<b>DESIGN CRITERIA</b>			
		<b>LOAD COMBINATION</b>			<b>ACCEPTANCE CRITERIA &amp; ALLOWABLE STRESSES</b>
<b>Concrete structures</b>	2.0/5.0	<u>L. C.</u> 1. Normal dead + live load	<u>Structural steel</u> AISC Code	<u>Concrete</u> ACI 318 working stress	Building code requirements ACI-318 (working stress design)
<b>Steel frame structures,                      Bolted and riveted assemblies</b>	2.0/3.0	2. "1" + wind	1/3 increase of AISC	1/3 increase per ACI Code	Specific for structural concrete ACI-301
<b>Welded assemblies</b>	1.0/1.0	3. "1" + OBE	Same as above	Same as above	Concrete chimneys ACI-307
<b>Fluid containers</b>	0.5/0.5	4. "1" + DBE	90% of yield	75% of ultimate	AISC
		5. Normal dead + tornado load	Same as above	Same as above	NY State Building Construction Code
		6. Normal dead + max. possible flood	Same as above	Same as above	
Sec. 12, Table 12.4-2		Table 12.4.3			Sec. 12.4.8 to 12.4-5

SEISMIC REVIEW TABLE

MECHANICAL & PIPING			
DAMPING OBE/SSE (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Vital piping systems 0.5/1.0	Analytical	<p><u>Piping:</u></p> <p>1. General membrane primary stress: <math>S_{LP} + S_{DL} \leq S_m</math></p> <p>2. Operating basis earthquake: <math>M_R</math> <math>S_{LP} + S_{DL} + S_{OBEQ} = S_{LP} + \frac{M_R}{SM} i \leq 1.8 S_m</math></p> <p>where <math>M_R = \sqrt{(M_{x1} \pm M_{x2})^2 + (M_{y1} \pm M_{y2})^2 + (M_{z1} \pm M_{z2})^2}</math></p> <p>3. Design basis earthquake <math>S_{LP} + (S_{DL} + S_{TH} + S_{DBEQ}) = S_{LP} + \frac{M_R}{SM} i \leq 3 S_m</math></p> <p>where <math>M_R = \sqrt{(M_{x1} + M_{x2} \pm M_{x3})^2 + (M_{y1} + M_{y2} \pm M_{y3})^2 + (M_{z1} + M_{z2} \pm M_{z3})^2}</math></p> <hr/> <p><math>S_{LP}</math> = Longitudinal Pressure Stress  <math>S_{DL}</math> = Dead Load Stress  <math>S_{TH}</math> = Thermal Stress  <math>S_{OBEQ}</math> = Operating Earthquake Stress  <math>S_{DBEQ}</math> = Design Earthquake Stress  <math>S_m</math> = Allowable Stress at operating temperature</p> <p><math>i</math> = Appropriate stress intensification factor  <math>SM</math> = Section modulus</p>	<p>For piping: ANSI B31.1.0 App. C.3.3, p. c.3-3</p> <p>Mechanical: ASME BPVC Section III Subsection B, 1968 Edition and Addenda published to June 30, 1968.</p> <p>App. I.3.2.2, p. I.3-2</p>

Sec. 12, Table 12.4-2

Sec. 12.5.4,  
p. 12.5-11

Section 12.5.4, p. 12.5-10 to p. 12.5-11

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available	Not available	Not available	Not available



SEISMIC REVIEW TABLE

Docket Number

50-348

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION	DESIGN SPECTRA			
	OBE		SSE		EARTHQUAKE TIME HISTORY		NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g						
<p>CP/OL ISSUE DATE</p> <p>Joseph M. Farley Nuclear Power Plant Units I and II</p> <p>Reactor type: PWR</p> <p>Containment type: 3 buttresses with shallow dome (prestressed con- crete)</p> <p>NSSS Manufacturer: Westinghouse</p> <p>Architect Engineer: Bechtel</p> <p>Unit I: 8-72/6-77 Unit II: 8-72/6-77</p>	0.05	0.033	VI	0.10	0.067	Synthesized time history.	3 compo- nents: Each horizontal combined with vertical component.	SRSS Closely spaced modes are combined absolutely	Modified Newmark curves.	Time history method.
	Sec. 2.5.2.11	Sec. 2.5.2.11	Sec. 2.5.2.10 p. 2.5-33	Sec. 2.5.2.10 p.2.5-33	Sec. 2.5.2.10 p.2.5-33	Sec. 3.7.1.2 p. 3.7-2	Sec. 3.7.3.7 p. 3.7-14	Sec. 3.7.3.3,4 p. 3.7-13	Sec. 3.7.1.1 p. 3.7-1	Sec. 3.7.2.1 p. 3.7-6



SEISMIC REVIEW TABLE

STRUCTURES			
DAMPING OBE/SSE	(% critical damping)	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Welded steel frame structures:	2.0/5.0	<p>Design loading case:</p> <ol style="list-style-type: none"> <li>1. D+F+L (construction case)</li> <li>2. D+F+L+T<sub>o</sub>+E (or W) (operating case)</li> <li>3. D+F+L+P+T<sub>e</sub> (design accident case)</li> <li>4. D+F+L+T<sub>s</sub>+E (or W) (prolonged shutdown case)</li> <li>5. D+F+L+1.15P (test case)</li> </ol> <p>Factored loading case:</p> <ol style="list-style-type: none"> <li>1. <math>C=1/\phi(1.0D+1.5P+1.0T_a+1.0F)</math></li> <li>2. <math>C=1/\phi(1.0D+1.25P+1.0T_a+1.25H+1.25E \text{ (or } 1.25W) +1.0F)</math></li> <li>3. <math>C=1/\phi(1.0D+1.25H+1.0R+1.0F+1.25E \text{ (or } 1.25W) +1.0T_o)</math></li> <li>4. <math>C=1/\phi(1.0D+1.25H+1.0F+1.25W_t+1.0T_o)</math></li> <li>5. <math>C=1/\phi(1.0D+1.0P+1.0T_a+1.0H+1.0E'+1.0F)</math></li> <li>6. <math>C=1/\phi(1.0D+1.0H+1.0R+1.0E'+1.0F+1.0T_o)</math></li> </ol> <p>Sec. 3.8.1.3 p. 3.8-13</p>	<p>ACI 318-63 AISC 1969 AEC Reg. Guides</p> <p>For further details refer to Section 3.8.1.2.</p> <p>Sec. 3.8.1.2 p. 3.8-3</p>
Reinforced concrete structures plus equipment supports:	2.0/5.0		
Prestressed concrete structures:	2.0/5.0		

Table 3.7-1

SEISMIC REVIEW TABLE

MECHANICAL & PIPING					
DAMPING OBE/SSE  (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA			
		LOAD COMBINATION		ACCEPTANCE CRITERIA & ALLOWABLE STRESSES	
Vital piping:	0.5/1.0	Analytical and Testing	<u>L. C. -Class 1 Components</u>	ASME, BPVC, Section III, Table 3.9-3 "Design Criteria for Components not covered by ASME Code."  Ex. Heat exchangers - ARI 410-64 Fan AMCA Test Code 300-67, 211 A-67	
Welded steel plate assemblies:	1.0/2.0		Normal		<u>Stress Limits</u> $P_M \leq S_M$ $P_L \leq 1.5 S_M$ $P_M \text{ (or } P_L) + P_B \leq 1.5 S_M$ $P_M \text{ (or } P_L) + P_B + Q \leq 3.0 S_M$
Bolted and riveted steel:	3.0/5.0		Upset		Same as normal
			Faulted	Table 5.2-6	
Table 3.7-1		Sec. 3.7.2.1 p. 3.7-5 3.9-1, 3.9-24 3.9-3	p. 3.9-1, Table 3.9-1, Table 5.2-4, -5, -6, -7		
				Table 3-9-3 Section 3.9.2, 3.9.2	

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	Testing and analysis.  Sec. 3.10.1 p. 3.10-2	For electrical cable tunnels: (Dead load + live load + E.Q.) $0.75 \leq$ maximum allowable stress  Table 3.8-14	IEEE 344-1971  Sec. 3.10.1,2 p. 3.10-2,3



SEISMIC REVIEW TABLE

Docket Number  
50-305

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					EARTHQUAKE TIME HISTORY	METHOD OF COMBINATION		DESIGN SPECTRA	
	OBE		SSE	HOR. g	VERT. g		NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g								
<p>Kewaunee Nuclear Power Plant</p> <p>Reactor type: PWR</p> <p>Containment type: Dry containment- cylindrical (steel)</p> <p>NSSS Manufacturer: Westinghouse</p> <p>Architect Engineer: Pioneer</p> <p>8-68/12-73</p>	0.06	0.04	<p>V normal fo- cus shock within 7 miles of plant site.</p> <p>VII normal fo- cus shock</p>	0.12	0.08	Synthetic time history	<p>Horizontal and vertical components</p> <p>Combina- tion not known</p>	SRSS	Newmark method	<p>Spectral method</p> <p>Blume report #JAB-PS-01, JAB-PS-03</p>
	App. B Sec. B.4.5 p. B.4-2	App. B Sec. B.6.3 p. B.6-5	App. A p. 31-32	App. B Sec. B.4.5 p. B.4-3	App. B Sec. B.6.3 p. B.6-6		App. B p. B.6-5	App. B p. B.6-5	Plate 8-A and Plate 8-B App. A p. 33	App. B p. B.6-5

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
Soil-bearing type (Raft-type formation)	Glacial till	60-150 ft	Shear wave velocity soil =2500 fps	Varies from 10-30 ft below ground surface	Not avail-able.	Stick model with soil springs.	Glacial till G=1x10 <sup>7</sup> lbs/sq ft	5% critical damping OBE,SSE	Not avail-able.
Concrete base slab	Glacial lacustrine deposits	350-600 ft	Shear wave velocity rock =11,500 fps				Glacial lacustrine deposits G=5x10 <sup>5</sup> lbs/sq ft		
35 ft. depth of slab	Bedrock (Niagra dolomite)						Bedrock G=7.5x10 <sup>8</sup> lbs/sq ft		
App. E Sec. E.1-E.3 Fig. E.2-5	App. A p. 16	App. A p. 16	App. A p. 16	App. A p. 11		App. B Sec. B.6.3 p. B.6-5	App. A p. 26 - Table 7	App. B Table B.6-5	

**SEISMIC REVIEW TABLE**

<b>STRUCTURES</b>			
<b>DAMPING OBE/SSE</b>	<b>(% criti- cal damping)</b>	<b>DESIGN CRITERIA</b>	
		<b>LOAD COMBINATION</b>	<b>ACCEPTANCE CRITERIA &amp; ALLOWABLE STRESSES</b>
Reactor Containment vessel	1.0/1.0		
Shield building	2.0/2.0	Normal operating	Dead+live+wind+snow
Reactor containment vessel internal concrete	5.0/5.0	OBE	Dead+live+DBA+snow+greater of the OBE or wind
Steel frame structures	2.0/2.0	DBE	Dead+live+snow+DBA+DBE
Reinforced concrete construction	2.0/2.0	Tornado	Dead+live+300 mph design tornado+tornado missile, if any
App. B Table B.6-5		Table B.6-1	App. B Table B.6-2

SEISMIC REVIEW TABLE

MECHANICAL & PIPING																										
DAMPING OBE/SSE  (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA																								
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES																							
Piping systems Mechanical Equipment	0.5/0.5 2.0/2.0	Analytical or Tests.	<table border="0"> <tr> <td></td> <td style="text-align: center;"><u>Pressure Vessels</u></td> <td style="text-align: center;"><u>Piping</u></td> <td></td> </tr> <tr> <td>Normal condition:</td> <td>(a) <math>P_m \leq S_m</math> (b) <math>P_m \text{ (or } P_L) + P_b \leq 1.5S_m</math> (c) <math>P_m \text{ (or } P_L) + P_b + Q \leq 3.0S_m</math></td> <td><math>P \leq S</math></td> <td rowspan="6">ASME, BPVC, Sec. III, 1968  ANSI B31.1 code for power piping 1967.</td> </tr> <tr> <td>Upset condition:</td> <td>(a) <math>P_m \leq S_m</math> (b) <math>P_m \text{ (or } P_L) + P_b \leq 1.5S_m</math> (c) <math>P_m \text{ (or } P_L) + P_b + Q \leq 3.0S_m</math></td> <td><math>P \leq 1.2S</math></td> </tr> <tr> <td>Emergency condition:</td> <td>(a) <math>P \leq 1.2S_m</math> or <math>S_y</math> (b) <math>P_m \text{ (or } P_L) + P_b \leq 1.8S_m</math> or <math>1.5S_y</math></td> <td><math>P \leq 1.5(1.2S)</math></td> </tr> <tr> <td>Faulted condition:</td> <td>(a) Stainless steel: design limit curve (b) Carbon steel: (i) <math>P_m = 1.5S_m</math> or <math>1.2S_y</math> (ii) <math>P_m \text{ (or } P_L) + P_b \leq 2.25S_m</math> or <math>1.875S_y</math></td> <td>(a) Stainless steel design limit curve (b) Carbon steel <math>P \leq S_y</math> or <math>1.8S</math></td> </tr> <tr> <td></td> <td></td> <td></td> </tr> <tr> <td></td> <td></td> <td></td> </tr> </table>		<u>Pressure Vessels</u>	<u>Piping</u>		Normal condition:	(a) $P_m \leq S_m$ (b) $P_m \text{ (or } P_L) + P_b \leq 1.5S_m$ (c) $P_m \text{ (or } P_L) + P_b + Q \leq 3.0S_m$	$P \leq S$	ASME, BPVC, Sec. III, 1968  ANSI B31.1 code for power piping 1967.	Upset condition:	(a) $P_m \leq S_m$ (b) $P_m \text{ (or } P_L) + P_b \leq 1.5S_m$ (c) $P_m \text{ (or } P_L) + P_b + Q \leq 3.0S_m$	$P \leq 1.2S$	Emergency condition:	(a) $P \leq 1.2S_m$ or $S_y$ (b) $P_m \text{ (or } P_L) + P_b \leq 1.8S_m$ or $1.5S_y$	$P \leq 1.5(1.2S)$	Faulted condition:	(a) Stainless steel: design limit curve (b) Carbon steel: (i) $P_m = 1.5S_m$ or $1.2S_y$ (ii) $P_m \text{ (or } P_L) + P_b \leq 2.25S_m$ or $1.875S_y$	(a) Stainless steel design limit curve (b) Carbon steel $P \leq S_y$ or $1.8S$						
	<u>Pressure Vessels</u>	<u>Piping</u>																								
Normal condition:	(a) $P_m \leq S_m$ (b) $P_m \text{ (or } P_L) + P_b \leq 1.5S_m$ (c) $P_m \text{ (or } P_L) + P_b + Q \leq 3.0S_m$	$P \leq S$	ASME, BPVC, Sec. III, 1968  ANSI B31.1 code for power piping 1967.																							
Upset condition:	(a) $P_m \leq S_m$ (b) $P_m \text{ (or } P_L) + P_b \leq 1.5S_m$ (c) $P_m \text{ (or } P_L) + P_b + Q \leq 3.0S_m$	$P \leq 1.2S$																								
Emergency condition:	(a) $P \leq 1.2S_m$ or $S_y$ (b) $P_m \text{ (or } P_L) + P_b \leq 1.8S_m$ or $1.5S_y$	$P \leq 1.5(1.2S)$																								
Faulted condition:	(a) Stainless steel: design limit curve (b) Carbon steel: (i) $P_m = 1.5S_m$ or $1.2S_y$ (ii) $P_m \text{ (or } P_L) + P_b \leq 2.25S_m$ or $1.875S_y$	(a) Stainless steel design limit curve (b) Carbon steel $P \leq S_y$ or $1.8S$																								
App. B Table B.6-5	App. B p. B.7-10d,e	Table B.7-2 Table B.7-3 For further details refer to App. B	App. B p. B.7-6																							

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available	Analysis	<p>"Electrical equipment and its supports were designed to be sufficiently rigid so that its natural frequency will be out of the range of resonance with the building structure".</p> <p style="text-align: center;">B.7-10C</p>	Not available



## SEISMIC REVIEW TABLE \*

Docket Number

50-409

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION	DESIGN SPECTRA			
	OBE		SSE		EARTHQUAKE TIME HISTORY		NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g						
La Crosse (Genoa) Nuclear Generating Station  Reactor type: BWR  Containment type: Pre-Mark (steel)  NSSS Manufacturer: Allis Chalmers, Manufacturing Co.  Architect Engineer: Sargent and Lundy Engineers   3-63/7-67	.06	.04	VI	.12	.08	Taft 1952 record chosen as initial accelerogram. A ground time-history which envelops the 2% damping curve of R.G. 1.60 was gene- rated for analysis of major structures such as the containment.	Horizontal only for RCB Maximum horizontal spectra (x or z direction) are added simultan- eously with the vertical for major piping and equipment.	SRSS for equipment and piping (R.S.)  Algebraic sum for reactor bldg. (time his- tory method.)	R.G. 1.60 used as basis to develop response spectra from Taft earth- quake. (not specifi- cally stated as such but curves are those of R.G. 1.60)	No vertical response spectra generated, instead use 2/3 of horizontal ground response spectra. Horizontal re- sponse spectra derived from time history analysis.  Reanalysis of Mechanical and Piping, 1975-77, No amplification of vertical response.
	Sec. 2.4	Sec. 2.4	Sec. 2.4	Sec. 2.4	Sec. 2.4					

\*Information was obtained from BNL Docket search and SEPB Report "Seismic Review of La Crosse BWR Phase I Report"

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
Pile foundation 232 piles will support 50 tons each	15 ft. of hydraulic fill overlies about 100-130 ft. of glacial outwash and fluvial deposits at the site. Bedrock of flat-lying sandstone and shale of the	Dresbach group extends below these deposits about 650 ft. where it makes contact with the crystalline basement.	Not available	Not available	Not available	Lumped-mass for structure soil-spring and dashpot  deconvolution process used; soil layers modeled as shear beam (2% damping used)	Not available	Not available	Not available

SEISMIC REVIEW TABLE

STRUCTURES														
DAMPING OBE/SSE	(% Critical damping)	DESIGN CRITERIA												
		LOAD COMBINATION												
		ACCEPTANCE CRITERIA & ALLOWABLE STRESSES												
Reactor Containment	$\frac{1}{2}$ SSE 3.0 up	SSE 7.0 up												
Turbine building		7.0												
Stacks		7.0 up												
New diesel generator building	4.0	7.0												
		<p><u>Structural Steel - Elastic:</u>            Construction: <math>1.0 D + 1.0 L + 1.0 T + W &lt; 1.33</math> AISC (1969)            Test: <math>1.0 D + 1.0 L + 1.0 T_o + 1.0 R_o &lt; 1.33</math> AISC (1969)            Normal: <math>1.0 D + 1.0 L + 1.0 T_o + 1.0 R_o &lt; \text{AISC}</math></p> <p>Severe Environmental: <math>1.0 D + 1.0 L + 1.0 T + 1.0 R + E &lt; \text{AISC}</math>            Extreme Environmental: <math>1.0 D + 1.0 L + 1.0 T_o + 1.0 R_o + E' &lt; 1.6</math> AISC</p> <p><u>R/C - strength design:</u>            Construction: <math>1.1 D + 1.3 L + 1.3 T_o + 1.3 W</math>            Test: <math>1.1 D + 1.3 L + 1.3 T_o + 1.3 R_o</math>            Normal: <math>1.4 D + 1.7 L + 1.3 T_o + 1.3 R_o</math></p> <p>Severe Environmental: <math>1.4 D + 1.7 L + 1.3 T_o + 1.3 R_o + 1.3 W</math>  <math>0.9 D + 1.3 T_o + 1.3 R_o + 1.3 W</math>  <math>1.4 D + 1.7 L + 1.3 T_o + 1.3 R_o + 1.4 E</math>  <math>0.9 D + 1.3 T_o + 1.3 R_o + 1.4 E</math></p> <p>Extreme Environmental: <math>1.0 D + 1.0 L + 1.0 T_o + 1.0 K_o + 1.0 E'</math></p> <p>Section 3.7.1; Table 4.5-1 and 4.5-2</p>												
		<p>Allowable structural Capacities for RCB, Two stacks, turbine building waste disposal building:</p> <p><u>Concrete:</u></p> <table> <tr> <td>Moment</td> <td><math>\frac{1}{2}</math> SSE <math>M_u</math></td> <td>SSE <math>0.63 M_u</math></td> </tr> <tr> <td>Shear</td> <td><math>V_u</math></td> <td><math>0.60 V_u</math></td> </tr> </table> <p><u>Steel</u></p> <table> <tr> <td>Moment</td> <td><math>0.66 M_y</math></td> <td><math>M_y</math></td> </tr> <tr> <td>Shear</td> <td><math>0.40 V</math></td> <td><math>0.53 V</math></td> </tr> </table>	Moment	$\frac{1}{2}$ SSE $M_u$	SSE $0.63 M_u$	Shear	$V_u$	$0.60 V_u$	Moment	$0.66 M_y$	$M_y$	Shear	$0.40 V$	$0.53 V$
Moment	$\frac{1}{2}$ SSE $M_u$	SSE $0.63 M_u$												
Shear	$V_u$	$0.60 V_u$												
Moment	$0.66 M_y$	$M_y$												
Shear	$0.40 V$	$0.53 V$												

SEISMIC REVIEW TABLE

MECHANICAL & PIPING			
DAMPING OBE/SSE  (% Critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Piping  $\frac{1/2 \text{ SSE}}{1.0}$ $\frac{\text{SSE}}{2.0}$	Not available	<p><u>M.S. Piping:</u> Load conditions from NB-3110, 3620</p> <p><u>Design:</u> (Primary) <math>P_o + DL + E &lt; 1.5 S_M</math></p> <p><u>Normal:</u> (Primary and secondary) <math>T + P + SA + TA + E &lt; 3 S_M</math></p> <p><u>Upset:</u> Same as for <u>normal</u> condition</p> <p><u>Emergency:</u> (Primary stress) <math>&lt; 2.25 S_M</math></p> <p><u>Faulted:</u> <math>P_o + DL + E &lt; 3.0 S_M</math> (Main steam piping and feedwater piping designed as Class 2 since fatigue loads not considered). Follows R.G. 1.48, EQ 8,9,10,11 of ASME Code</p>	<p>Piping:</p> <p>AEC Reg. Position 1 and Subsection NB-3600 of Section III of ASME B&amp;PV Code</p>

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available	Not available	Not available	Not available



SEISMIC REVIEW TABLE

Docket Number

50-309

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					EARTHQUAKE TIME HISTORY	METHOD OF COMBINATION		DESIGN SPECTRA	
	OBE		INTENSITY MM	SSE			NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g		HOR. g	VERT. g					
<p>CP/OL ISSUE DATE</p> <p>Maine Yankee Atomic Power Company</p> <p>Reactor type: PWR</p> <p>Containment type: Sub-atmospheric (Reinforced concrete)</p> <p>NSSS Manufacturer: Combustion Engineer- ing</p> <p>Architect Engineer: Stone &amp; Webster Engineering Corp.</p>	0.05	0.033	VI	0.10	.067	No earthquake time- history used.	Each hori- zontal combined with the vertical resulting in two load cases. The method of com- bination is un- clear.	No combin- ation used flexural mode used only.	Housner spectra	<p>Empirical procedure used for piping to provide amplified response spectra. For equipment and anchors used equi- valent static load method or Housner response spectra.</p> <p>Amendment 22 (4-71) Q. 4.4 Q. 4.5</p> <p>Method used de- scribed in Section 5.1.1.2.2 p. 5-6</p>
10-68/9-72	Sec. 1.3.2 p. 1-6	Sec. 1.3.2 p. 1-6		Sec. 1.3.2 p. 1-6	p. 1-6	Amendment 20 (3-71) Q. 4.5	p.5-3	p. 5-6	Sec. 2.5.4 p. 2-27 Figs. 2.5.6 and 2.5.7	

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT				SOIL - STRUCTURE INTERACTION					
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
Flat reinforced concrete slab bearing on bedrock with a central reactor vessel pit.  10 ft. thick	Major structure  Hard crystalline bedrock  Minor structure  on rock or compacted granular fill above the rock.	Joints in bedrock are medium spaced, ranging from 1 to 5 ft intervals or and less.	7,000 fps	Dug wells: less than 25 ft deep.  Drilled wells: depth of 100 ft or more.	Not available.	Translational & Rocking modes were not incorporated in the dynamic model.	1.80x10 <sup>6</sup> -2.06x10 <sup>6</sup> psi	Not available.	Not available.
Sec. 5.1 p. 5-1	Sec. 2.4 p. 2-23	Sec. 2.4 p. 2-23	Sec. 2.4 p. 2-23	Sec. 2.3.3 p. 2-22		Sec. 5.1.1.2.2 p. 5-6	Sec. 2.4 p. 2-23		

SEISMIC REVIEW TABLE

STRUCTURES			
DAMPING OBE/SSE	(% critical damping)	DESIGN CRITERIA	
		LOAD COMBINATION	
		ACCEPTANCE CRITERIA & ALLOWABLE STRESSES	
1. Reactor containment.	5.0/7.0	1. $(1.0+0.05) D + 1.5 P + 1.0 (T+TL)$ 2. $(1.0+0.05) D + 1.25 P + 1.0 (T+TL) + 1.25 E$ 3. $(1.0+0.05) D + 1.0 T + 1.0 C$ 4. $(1.0+0.05) D + 1.0 P + 1.0 (T+TL) + 1.0 E'$  D = dead load P = design pressure load TL = load by exposed liner T = temperature gradient load E = OBE E' = SSE	Containment: Ultimate strength methods ACI 318-63, Sec. 1504, Part IV B or the Ultimate Strength Design Handbook ACI Special Publication No. 17.
2. Reinforced concrete structure, other than containment (on rock or soil).	5.0/7.0		
3. Reinforced concrete structure (not on soil or rock).	2.0/5.0		
4. Steel framed structure Bolted or riveted	3.0/5.0		
Welded	1.0/2.0		
5. Reactor vessel Welded assemblies	1.0/1.0		
Bolted assemblies	3.0/3.0		
Table 2.5-1		Section 5.1.1.2, p. 5-2	Section 5.1.1.2, p. 5-2

SEISMIC REVIEW TABLE

MECHANICAL & PIPING				
DAMPING OBE/SSE  (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA		
		LOAD COMBINATION *		ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
1. Mechanical equipment.	2.0/2.0	Analytical	Reactor vessel internal structure	ASME BPVC, Section III
2. Piping.	1.0/2.0		1. Design loading + OBE $P_m \leq S_m$ $P_B + P_L \leq 1.5 S_m$ 2. Normal Operating + SSE $P_m \leq S_D$ $P_B \leq 1.5 [1 - (\frac{P_m}{S_D})^2] S_D$ 3. Normal Operating + SSE + pipe rupture $P_m \leq S_L$ $P_m \leq 1.5 [1 - (\frac{P_m}{S_L})^2] S_L$ Where: $S_L = S_y + (1/3)(S_u - S_y)$ $S_D = 1.2 S_m$	
Amendment 20 (3-71) Q. 4.9, Table 2.5-1		Amendment 22 (4-71) Q. 4.8	Piping 1. Design load + OBE Applicable code allowables 2. N.O. + SSE $P_m \leq S_D$ $P_B \leq \frac{4}{\pi} S_D \cos(\frac{\pi}{2} \cdot \frac{P_m}{S_D})$ 3. N.O. + SSE + pipe rupture $P_m \leq S_L$ $P_B \leq \frac{4}{\pi} S_L \cos(\frac{\pi}{2} \cdot \frac{P_m}{S_L})$	p. 3-4, 4.2-4

\*For reactor internals: Table 3.2-1, p. 3-4  
 Vessels and piping: Table 4.2-3, p. 4.2-4

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	Not available.	Not available.	Not available.



SEISMIC REVIEW TABLE \*

Docket Number

50-245

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					EARTHQUAKE TIME HISTORY	METHOD OF COMBINATION		DESIGN SPECTRA	
	OBE		INTENSITY MM	SSE			NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g		HOR. g	VERT. g					
Millstone Point Nuclear Power Station Unit 1 Reactor type: BWR Containment type: Mark I (steel) NSSS Manufacturer: General Electric Architect Engineer: Ebasco CP/OL ISSUE DATE: 5-66/10-70	0.07	0.05	VII	0.17	0.113	Taft 69° west earthquake record (Blume response spectrum is more conservative than Taft response spectrum)	Horizontal and vertical (X+Y,Z+Y) The resulting seismic stress for the two motions were combined linearly.	No modal combination needed for time history. Unclear information for response spectrum method.	Housner	Equivalent Static Method - for intake structure, turbine bldg., main steam lines, Class I piping in reactor and turbine bldg., batteries and battery racks. Time History Method: Reactor bldg., ventilation stack, radwaste/control room, condensate storage tank Response Spectrum Gas turbine bldg., recirculation loop piping, torus, RPV, isolation condenser, fuel racks
	Sec. XII p. XII-1.7	Sec. XII p. XII-1.7		Sec. XII p. XII-1.7	p. XII-1.7	Q VII - A.9 and Q VII - A.10 Amend. 17	Sec. XII p. XII-1.7		Fig. XII-1.2 Fig. XII-1.3 Sec. XII p. XII-1.7	p. XII-1.12

Information obtained from BNL Docket Search and SEP8 Report, "Seismic Review of Millstone Nuclear Power Station, Unit 1"

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>B</sub> PROFILE						
<p>Reinforced concrete square mat (42'-6") and six feet of thickness at elevation of 32'-0". The foundation is supported directly on the bedrock.</p> <p>Gas turbine building founded on piles. Turbine build mat foundation on piles.</p>	not applicable	not applicable	14,000 fps	Not available	None	<p>Lumped mass with soil springs (for reactor bldg. only). Rocking mode was considered for reactor bldg. Fixed base without rocking for other major structures.</p>	Not available	Not available	Not available
			Sec. XII-p. XII-1.13			Sec. XII p. XII-1.2.1			





SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE TRESSES
Not available	Not available	Battery racks and batteries were designed to withstand lateral and vertical seismic loads of 0.12g horizontal and 0.046g vertical	Not available





SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
<p>Reactor building mat rests on unweathered rock.</p> <p>Depth: 8½ feet</p> <p>Sec. 2.7.5 p. 2.7-3 Sec. 5.2.1 p. 5.2-1</p>	<p>Glacial deposits: Ablation till and a dense basal till which lies above the bedrock. Bedrock consist of Monson gneiss intruded by westerly granite.</p> <p>Sec. 2.4 p. 2.4-4 p. 2.4-5</p>	<p>Glacial deposits: 0 to 30 ft</p> <p>Bedrock: 11 to 54 ft below ground.</p> <p>Sec. 2.4 p. 2.4-4 p. 2.4-5</p>	<p>5500-7500 fps in bedrock.</p> <p>Sec. 2.4.4 p. 2.4-9</p>	<p>Little or no ground water is present in bedrock. So virtually all ground water is restricted to the soil overburden. Water level is subjected to considerable seasonal fluctuations.</p> <p>Sec. 2.5.2 p. 2.5-2 Fig. 2.4-2c, 2d</p>	<p>Not available.</p>	<p>Backfill: Stick model with soil springs.</p> <p>Bedrock: Stick model with fixed base.</p> <p>Sec. 5.8.2 p. 5.8-3,4</p>	<p>Not available.</p>	<p>2%/5%</p> <p>Table 5.8-1 p. 5.8-9</p>	<p>2%</p> <p>Sec. 5.8.3.3 p. 5.8-10</p>

SEISMIC REVIEW TABLE

STRUCTURES			
DAMPING OBE/SSE	(% criti- cal damping)	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Welded steel plate assemblies:	1.0/1.0	a. D+F+L	Construction case
Welded steel framed structures:	2.0/2.0	b. D+F+L+T <sub>o</sub> +E	Operating case
Bolted or riveted steel framed structures:	2.5/2.5	c. D+F+L+P+T <sub>i</sub>	Design incident case
Reinforced concrete equipment supports:	2.0/3.0	d. D+F+L+T <sub>s</sub> +E	Prolonged shutdown case
Reinforced concrete frames and buildings:	3.0/5.0	e. D+F+L+1.15P	Test case
Prestressed concrete structures:	2.0/5.0	D = dead loads L = live loads F = prestressing loads P = design pressure T <sub>i</sub> = thermal loads due to the loss of coolant incident T <sub>o</sub> = thermal loads due to operating temperature T <sub>s</sub> = thermal loads due to transient wall temperature over a prolonged shutdown (20 F at exterior face, 70 F at center, 50 F at interior face) E = operating basis earthquake loads (0.09 g) For further details refer to Section 5.2.3.2.5. Sec. 5.2.3.2.4 p. 5.2.8	

Table 5.8-1, p. 5.8-9

Sec. 5.1.2  
p. 5.1-2



SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	Analytical and testing.  Sec. 5.8.6 p. 5.8-13	Not available.	Instrumentation designed as per Reg. guide 1.12.  Sec. 5.8.6 p. 5.8-13



SEISMIC REVIEW TABLE

Docket Number  
50-263

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION	DESIGN SPECTRA			
	OBE		SSE		EARTHQUAKE TIME HISTORY		NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g						
Monticello Nuclear Generating Plant, Unit 1  Reactor type: BWR  Containment type: Mark I (steel)  NSSS Manufacturer: General Electric  Architect Engineer: Bechtel          6-67/9-70	Class I 0.06  Class II 0.05	0:004  0.0033	VIII	0.12	0.08	Taft Earthquake of July 21, 1952, North 69 West component	Horizontal and vertical component combined linearly.	SRSS          Sec. 2.1.9 p. 12-2.9c and Vol. VI Append. A Reactor Building Seismic	Response spectra from Taft earth- quake          Fig. 2-6-5 p. 2-6.1 Sec. 2.1.9, p. 12 -2.8a and p. 12- 2.9	Time-history analysis for Class 1 struc- tures, UBC for Class 2          Sec. 2.1.9 p. 12-2.9

Analysis  
p-6

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT				SOIL - STRUCTURE INTERACTION					
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE *	THICKNESS	V <sub>s</sub> PROFILE						
Reinforced concrete mat founded on medium sand with some gravel.  Sec. 2.2.1.1 p. 12-2.13	Decomposed granitic and basic rocks of precambrian age comprise the formation.	75 to 122 ft.	Not available.	The water table beneath the low terraces which border the Mississippi River usually lies at about river elevation and slopes very slightly toward the river during periods of normal stream flow.  Groundwater at shallow depths moves toward the Mississippi River or its tributaries at variable gradients depending on local conditions.  Sec. 5.4, p. 2-5.3 and Fig. 2-5-3	Not available.	Stick model with soil springs.	Not available.	Not available.	10.0% of critical damping.
	Weathered precambrian crystalline rocks are directly below the above strata.	10 to 15 ft.							
	Above the sandstone is a series of alluvial strata consists predominantly of clean sands with gravel, as well as a few layers of clay and glacial till.	50 ft.							

Sec. 5.3, p. 1-5.2, \*Because of space Type and Thickness columns are combined together.  
p. 2-5.3









SEISMIC REVIEW TABLE

Docket Number  
50-220

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					EARTHQUAKE TIME HISTORY	METHOD OF COMBINATION		DESIGN SPECTRA	
	OBE		SSE				NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
CP/OL ISSUE DATE  Nine Mile Point Nuclear Station Unit No. 1  Reactor type: BWR  Containment type: Mark I (steel)  NSSS Manufacturer: General Electric  Architect Engineer: Stone & Webster Engineering Corp.  4-65/8-69	Not used	Not used	IX	0.11	0.055	Not used	Not avail- able.	SRSS	Houner	Analysis by Reserve Energy- Technique, by John Blume
			PHSR III-1	PHSR III-1	Amend- ment 6, Supp. 2, Ques- tion I-11		Amend. 6, Supp. 2, Question I-2.	PHSR VI-22 App. e	PHSR III-1	

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
<p>All major structures founded on Oswego sandstone. Reactor bldg. is founded in rock to a depth of 60 ft.</p> <p>PHSR III-3</p>	<p>10-12 ft. of glacial till was removed. Bedrock is Oswego sandstone. It makes contact with Lorraine Shale at a depth of 185 ft.</p> <p>Amend. 2, Vol. 2, FSAR 6/1/67</p>	<p>185 ft.</p>	<p>14,000 fps</p> <p>Amend. 6, Supp. 2, FSAR, Oct. 1968, Question IV 12, p IV-24</p>	<p>195 ft. below ground surface</p> <p>App. C "Earth Science"</p>	<p>Not available.</p>	<p>Stick model with soil springs.</p> <p>Amend. 6, Supp.2, Question I-2</p>	<p>Not available.</p>	<p>2 to 3% critical damping.</p> <p>Amend. 6, Supp. 2, FSAR Oct. 1968, Question IV 12, p IV-25</p>	<p>Not available.</p>

SEISMIC REVIEW TABLE

STRUCTURES			
DAMPING OBE/SSE	(Z criti- cal damping)	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
critical damping for integral reinforced- concrete structures.....	5.0	Reactor bldg. Waste disposal bldg. screen and pump house drywell radial steel framing:	<ol style="list-style-type: none"> <li>1. ACI-318-63</li> <li>2. For proportioning of concrete members: Part IV-A "Working stress design" of Code 318-63.</li> <li>3. Reinforced-concrete ventilation stack: ACI 505-54</li> <li>4. AISC specifications for the design, fabrication and erection of structural steel for building.</li> <li>5. New York State Building Code</li> <li>6. UBC</li> </ol>
critical damping for ventilation stack...	7.5	DL + LL + OL + Design Earthquake  Reactor vessel concrete pedestal  DL + Equipment Load + Temp. (operating) DL + Equipment Load + Jet Load + Temp. + Design Earthquake  See Table I-4 for 10 load combinations for the drywell	
Amendment 6, Supp. 2, Question I-5		Supplement 2, question I-4, question I-9	Amend. 6, Supp. 2, Question I-2

SEISMIC REVIEW TABLE

MECHANICAL & PIPING			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	Not available.	<p>Core spray piping and sparger ring located in the reactor vessel:</p> <p>Equations given in ASME Section III.</p> <p><u>Drywell</u> - ASME Sect. VIII plus Code Case 1270N-5, 1271N, 1272N-5</p> <p>Amend. 5-Supp 1 (5/20/68) Question II-12.</p>	<p>1. "Method of Differences"</p> <p>2. Reactor internals: ASME Code Class A</p> <p>1. Amend. 6, Supp. 2, Question I-10</p> <p>2. Amend. 5, Supp. 1 FSAR Question I-5</p>

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	Not available.	Not available.	Not available.



SEISMIC REVIEW TABLE

Docket Number

50-338

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION	DESIGN SPECTRA				
	OBE		INTENSITY MM	SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g		HOR. g	VERT. g						
CP/OL ISSUE DATE											
North Anna Power Station Unit 1  Reactor type: PWR  Containment type: Sub-atmospheric (reinforced con- crete)  NSSS Manufacturer: Westinghouse  Architect Engineer: Stone and Webster	0.06g for struc- tures on rock  0.09g for struc- tures on soil	0.04g for struc- tures on rock  0.06g for struc- tures on soil	VII	0.12g for struc- tures on rock  0.18g for struc- tures on soil	0.08g for struc- tures on rock  0.12g for struc- tures on soil	E-W and N-S compo- nents of Helena, Montana 1935 earth- quake, and the S-E component of the San Francisco 1957 earthquake.	2 components: Horizontal plus ver- tical added simultan- eously	SRSS	Developed from Helena 1935 and San Francisco 1957 by enveloping the response spectra shown in Fig. 2.5-9 thru Fig. 2.5-12.	Time history method.	
2-71/11-77	p. 1.2-2 1.2-3	p. 1.2-2 p. 1.2-3		p. 1.2-2 1.2-3	p.1.2-2 1.2-3	p. 2.5-9	p. 3.7-10	Sec. 3.7	p. 2.5-9	Sec. 3.7	

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
Flat reinforced concrete mat 10 ft. thick.  Founded on concrete backfill.          p. 1.2-2 p. 2.5-17	Saprolite soil  weathered rock          p. 2.5-12	Not available.	Not available.	Not available.	North Anna Reservoir          Sec. 2.4.1.1	Stick model with soil springs.          Sec. 3.7 p. 2.5-9	Fresh and slightly weathered rock G=1.0x10 <sup>6</sup> psi  Soils @ 10 ft. depth 14,000 psi @ 20 ft. depth 19,800 psi          p. 2.5-24	Not available.	Not available.

SEISMIC REVIEW TABLE

STRUCTURES				
DAMPING OBE/SSE			DESIGN CRITERIA	
			LOAD COMBINATION Containment Structural Loading Criteria:	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Stress Level	Type & Condition of Struct, Syst. or Component	Percentage Critical Damping	(1.0 ± 0.05) D + 1.0 P + 1.0 (T + TL) + 1.5 E (1.0 ± 0.05) D + 1.0 P + 1.0 (T + TL) + 1.0 (DBE) (1.0 ± 0.05) D + 1.25 P + (T' + TL') + 1.25 E	AISC Manual ACI 301-66 ACI 318-63
1. Low Stress, well below proportional limit. Stresses below 0.25 yield point.	a. Steel, reinforced concrete; no cracking and no slipping at joints.	0.5 to 1.0		
2. Working stress limited to 0.5 yield point stress	a. Welded steel, well reinforced concrete (with only slight cracking) b. Bolted steel	2.0 5.0		
3. At or just below yield point	a. Welded steel b. Reinforced concrete c. Bolted steel	5.0 5.0 7.0		
Table 3.7.2-1			p. 3.8-87, Table 3.8.2.2-1	p. 3.7-49 3.8-17

SEISMIC REVIEW TABLE

MECHANICAL & PIPING			
DAMPING OBE/SSE  (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Piping  0.5/1.0	Analysis and Testing	<p>ASME Class 1 Piping: based on Subarticle NB-3650</p> <p><u>Class A Components</u></p> <p>1) Normal    a) <math>P_m \leq S_m</math>,    b) <math>P \leq 1.5 S_m</math>,                              c) <math>P_m</math> (or <math>P_L</math>) + <math>P_B \leq 1.5 S_m</math>                              d) <math>P_m</math> (or <math>P_L</math>) + <math>P_B</math> + <math>Q \leq 3.0 S_m</math></p> <p>2) Upset        a) <math>P_m &lt; S_m</math>,    b) <math>P_L \leq 1.5 S_m</math> (SIC)                              c) <math>P_m</math> (or <math>P_L</math>) + <math>P_B</math> + <math>P_{B-} \leq 1.5 S_m</math>                              d) <math>P_m</math> (or <math>P_L</math>) + <math>P_B</math> + <math>Q \leq 3.0 S_m</math></p> <p>3) Faulted    i) <math>P_m \leq 1.2 S_m</math> or <math>S_y</math> whichever is larger,                              AND <math>P_m</math> (or <math>P_L</math>) + <math>P_B \leq 1.5</math> (1.2) <math>S_m</math> or <math>1.5 S_y</math> whichever is                              larger                              ii) Table 5.2-15</p>	<p>ANSI B31.7-1969            ASME BPVC Sec. III</p>
p. 3.7-23	p. 3.7-46,47 p. 3.7-22	p. 3.7-30, p. 5.2-46, T 5.2-15	p. 3.1-101 p. 3.7-49





SEISMIC REVIEW TABLE

Docket Number  
50-269, 270, 287

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
<p>Oconee Nuclear Station Unit Nos. 1,2,3</p> <p>Reactor type: PWR</p> <p>Containment type: 6 buttresses with shallow dome (pre-stressed concrete)</p> <p>NSSS Manufacturer: Babcock &amp; Wilcox</p> <p>Architect Engineer: Utility &amp; Bechtel</p> <p>Unit #1: 11-67/2-73 Unit #2: 11-67/10-73 Unit #3: 11-67/7-74</p>	0.05 for rock foundation	0.03	VI	0.10 for rock foun- dation. 0.15 for over- burden foun- dation.	0.07	Time history record of the N-S, May 1940 El Centro Earthquake was used (vertical and N-S horizontal components) at 0.01 sec intervals for the first 30 sec of duration.	3 com- ponents: Each hori- zontal combined with the vertical simultane- ously.	Absolute sum	R-S smooth curve with max. accelera- tion of .15g @ 2% damping. Housner.	Time-history method.
	Sec. 2.6 p. 2-9			Sec. 2.6 p. 2-9		Sec. 1C.3.4.2.1 p. 1C-4d	Sec. 5A. 2.2 p. 5A-3	p.5-19	Plate II-4 App. 2B	Sec. 1C.3.4.2.1 p. 1C-4d Sec. 1C.3.4.2.2(b) p. 1C-4e-4f

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT				SOIL - STRUCTURE INTERACTION					
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
Reinforced concrete foundation slab. Depth = 8½ feet thick. Founded on bedrock.  Sec. 5.1.2.1 p. 5-2	Banded biotite hornblende gneiss and granite gneiss. The surface has weathered unevenly and the residual soils grade down irregularly.	Sound Rock is found at depths of 5-40 feet	Not available in FSAR	Not available in FSAR.	"Design of Keowee and Jocassee Dam" Refer to PSAR p. 2.4.3 and Question 8.6-PSAR Supp. 1, Question 12.1-PSAR Supp. 4, Question 12.2-PSAR Supp. 4, Item 11-PSAR Supp. 5, Item 1-PSAR Supp. 6.	Stick model with soil springs.	Not available	in FSAR.	2% OBE 5% SSE
			Refer to Sec. 2.5 and Sec. 2.6 p. 2-8 in PSAR	Refer to PSAR 2.4.4 Sec. 2.4.5 p. 2-8	Sec. 2.4.4 p. 2-8	Sec. 5.1.3.2 p. 5-18	Refer to Sec. 2.5, p. 2-8, in PSAR	and Sec. 2.6 2-9	p. 5-12 Fig. 5-10

SEISMIC REVIEW TABLE

STRUCTURES

DESIGN CRITERIA

DAMPING  
OBE/SSE

(% criti-  
cal damping)

LOAD COMBINATION

ACCEPTANCE CRITERIA  
& ALLOWABLE STRESSES

Welded carbon and stainless steel  
assemblies:

1.0

$$\underline{Y} = 1/\phi(1.0D+1.0P+1.0T+E')$$

ACI 318-63

Steel framed structures:

2.0

$$\underline{Y} = 1/\phi(1.05D+1.25P+1.0T+1.25E \text{ or } W)$$

ACI 301

Reinforced concrete equipment  
supports:

2.0

$$\underline{Y} = 1/\phi(1.05D+1.5P+1.0T)$$

ASME, PVBC, Sec. III, VIII, IX

Reinforced concrete frames and  
buildings:

5.0

$$\underline{Y} = 1/\phi(1.0D+1.0W_t+1.0P_1) \text{ for tornado forces}$$

Y=required yield strength of structure

D=dead loads

P=design accident pressure

T=thermal load

E=seismic load based on design earthquake

E'=seismic load based on maximum hypothetical earthquake

W=wind load

P<sub>1</sub>=stress due to differential pressure

φ=capacity reduction factor

Prestressed concrete structures  
(i) under design earthquake forces  
(ii) under maximum hypothetical  
earthquake

2.0

5.0

Sec. 5A.2.2  
p. 5A-3

For further details refer to  
Sec. 5A.2.2, p. 5A-2

Sec. 5.1.2.1  
p. 5-4

SEISMIC REVIEW TABLE

MECHANICAL & PIPING			
DAMPING OBE/SSE  (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Vital piping:          Sec. 5A.2.2 p. 5A-3	0.5          Analytical       Sec. 1C.3.4.1 p. 1C-4ai	<p>(A) piping:</p> <p>I. Design loads + design earthquake loads  <math>P_m &lt; 1.0S_m</math>  <math>P_L + P_b &lt; 1.5S_m</math></p> <p>II. Design loads + maximum hypothetical earthquake loads  <math>P_m &lt; 1.2S_m</math>  <math>P_L + P_b &lt; 1.2(1.5S_m)</math></p> <p>III. Design loads + pipe rupture loads  <math>P_m &lt; 1.2S_m</math>  <math>P_L + P_b &lt; 1.2(1.5S_m)</math></p> <p>IV. Design loads + maximum hypothetical earthquake loads + pipe rupture loads  <math>P_m &lt; 2/3S_u</math>  <math>P_L + P_b &lt; 2/3S_u</math></p> <p><math>P_m</math> = Primary local membrane stress intensity  <math>P_L</math> = Primary bending stress intensity  <math>P_b</math> = Primary general membrane stress intensity  <math>S_m</math> = Allowable membrane stress intensity  <math>S_u</math> = Ultimate stress</p> <p>p. 4-4</p>	<p><u>For piping:</u>                      Nuclear power piping code                      USAS B31.7, Sec. 1C.3,                      p. 1C-3</p> <p><u>Mechanical components:</u>                      -ASME, Sec. III for nuclear vessels.                      -<math>S_m</math> values Table N-421 of ASME code.</p> <p>Sec. 4.1.2.5.1                      Sec. 4.1.2.5.2                      p. 4-3</p>







SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT				SOIL - STRUCTURE INTERACTION					
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
Mat foundation Grade: + 23 ft MSL Foundation: -11 ft MSL  Sec. II.5.2	Fine to medium texture sand of med. density alternating layers of clay, silt and fine sand dense sand, med. to coarse texture layers of clay, silt and fine sand dense fine to coarse sand  Sec. II.5.2	17 ft. 17 ft. 65 ft. 8 ft. below	Not available	Wells are 60 to 70 ft. or more in depth.  Sec. II.4, p. II-4-1	Not available	Rocking mode analyzed separately in seismic analysis of reactor and control room/turbine building. Using a torsional spring to represent the foundation flexibility.	Not available	Not available	Not available

SEISMIC REVIEW TABLE

STRUCTURES				
DAMPING OBE/SSE (% critical damping)	DESIGN CRITERIA			
	LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES		
Reinforced concrete structures (reactor building)	10.0	Reactor building., Control Room., Battery Room., Intake Structure.* 1. DL + LL + OL + E (0.11g) 2. DL + LL + OL + W 3. DL + LL + OL + E (0.22g)	Reinforcing Steel Max. Tension 1. 0.5 F <sub>y</sub> 2. 0.667 F <sub>y</sub> 3. 0.90 F <sub>y</sub>	Concrete Max. Allowable Compression 0.45 f <sub>c</sub> 0.60 f <sub>c</sub> 0.90 f <sub>c</sub>
steel frame structures	2.0			
welded assemblies	1.0			
bolted and riveted assemblies	2.0	Reactor Concrete Pedestal** 1. DL + equipment + jet load + temperature + OBE 2. DL + equipment + jet load + temperature + SSE	1. 0.25 F <sub>y</sub> 2. 0.25 F <sub>y</sub>	0.133 f <sub>c</sub> (bending) 0.267 f <sub>c</sub> (bending)
reinforced concrete stack	5.0	Drywell Concrete Shield*** 1. DL + LL + over pressure + max. temp. + OBE 2. DL + LL + over pressure + max. temp. + SSE 3. DL + LL + max. temp. + OBE + jet force	1. 0.50 F <sub>y</sub> 2. 0.50 F <sub>y</sub> 3. 0.667 F <sub>y</sub>	0.45 f <sub>c</sub> 0.45 f <sub>c</sub> 0.60 f <sub>c</sub>

Sec. V.3, p.  
Table V-3-1

\*Table V-3-3, Table 1-A-4, Amend. 22

\*\*Table 1-A-2, Amend. 22

\*\*\*Table 1-A-1, Amend. 22

SEISMIC REVIEW TABLE

MECHANICAL & PIPING				
DAMPING OBE/SSE (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA		
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES	
1. Bolted and riveted assemblies	Not available	<u>Class I piping*</u> Thermal MOL + SL MOL + 2(SL)  MOL = Max. operating loads SL = Seismic loads due to OBE $S_A = f(1.25 S_C + 0.25 S_H)$ f = stress range reduction factor $S_C, S_H$ = allowable stress, ASA B31.1	<u>Allowable stress</u> $S_A$ $S_H$ Safe shutdown can be achieved	See load combinations and Supplement 6, Amend. 68, Appendix 6.
2. Welded assemblies		<u>Reactor vessel supports*</u> Seismic - Seismic + jet - 2(seismic) -	Normal AISC allowables 150% of normal AISC allowables 150% of normal AISC allowables	
3. Vital piping		<u>Primary containment **</u> DL + operating + LOCA + E DL + operating + LOCA + E'	ASME Sec. VIII Code case 1272N-5	
Table V-3-1 Sec. V.3 p. V-3-2		* Ques. IV. 1, Amend. 11 ** Table V-3-2, Sec. 3.8.1		

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE (% Critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available	Not available	<p>Quoted from answer to Question IV.1, Amend 11</p> <p>"The control room panels and auxiliary racks are usually shipped assembled and therefore these units must be designed for normal shipping shock which is in the order of several g's acceleration. Certain components are removed and padded to reduce vibration effect and excessive acceleration. In all cases, however, the design analysis is made of the panels and instruments. All relays in safety circuits are energized; and since they are capable of closing against 1.0g, they can certainly maintain contact during an acceleration of 0.22g."</p> <p>Question IV.1, Amend. 11</p>	



SEISMIC REVIEW TABLE\*

Docket Number  
50-255

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					EARTHQUAKE TIME HISTORY	METHOD OF COMBINATION		DESIGN SPECTRA	
	OBE		INTENSITY MM	SSE			NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g		HOR. g	VERT. g					
CP/OL ISSUE DATE										
Palisades Nuclear Generating Plant Unit 1  Reactor type: PWR  Containment type: 6 buttresses with shallow dome (prestressed con- crete)  NSSS Manufacturer: Combustion Engineering  Architect Engineer: Bechtel   3-67/3-71	0.10	0.067	VII	0.20	0.13	Containment design Housner spectra. For floor response spec- tra generation and for equipment and piping the 1952 TAFT earthquake was used, whose R-S envelops the Housner spectra.	Maximum horizontal component with ver- tical com- ponent simul- taneously.	SRSS - response spectra method for structural modes and piping.	Housner design spectrum	Not clear - it appears that TAFT 1952 earthquake was used to generate floor response spectra. Then from lumped-mass model, the accelerations at each floor level were obtained and the TAFT response spectra were scaled to those valves. Static method used for piping with frequency > 20 Hz. For vertical R-S, 2/3 of horizontal ground spectrum Ref. 3.Q.5.8 and Q.5.6.
	p. 2-16	Sec. A.2 p. A-7		p. 2-16	Sec. A.2 p. A-7		Sec. A.2 p. A-7		Question 5.13 p. 5.13-1	

\*Information obtained from BNL Docket search and SEP8 Report, "Seismic Review of Palisades NPP Unit No. 1".

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
Reinforced concrete slab 8 1/2 to 13 ft. thick  Sec. 5.1.2 p. 5-2	Loose dune sand overlies about 30 ft. of well-compacted, gray silty sand. Below this is about 90 ft. of compact till. Bedrock, Mississippian Coldwater Shale, is reached at a depth of about 150 ft. below lake level. It is composed of blue, gray or red shale. **		5400 fps for lake deposits	10 ft. from ground surface  Sec. 2.4.1, p. 2-14, p. 5.10-21	Not available	Containment: Lumped mass, spring model. Deterministic horizontal spring constant and 2 vertical springs which provide rotational restraint. "Building FNDT. interaction effects". 10-66, ASCE Engr. Mech.	Not available	Not available	Not available
			6700 fps for glacial till						
			10,000 fps for bedrock						

Sec. 2.3.1

p. 2-10 to p. 2-11

\*\* Type and thickness of bearing information are presented together.

SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING OBE/SSE (% critical damping)	DESIGN CRITERIA	
	LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
1. Welded steel framed structures 2.0/2.0	Final design (SSE) for Class I structures except the containment shell 1. $Y = 1/\phi (1.25D + 1.0R + 1.25E)$ 2. $Y = 1/\phi (1.25D + 1.25H + 1.25E)$ 3. $Y = 1/\phi (1.25D + 1.25H + 1.25E)$ (0.9 D is used where dead load subtracts from critical stress in the above two equations) 4. $Y = 1/\phi (1.0D + 1.0R + 1.0E')$ 5. $Y = 1/\phi (1.0D + 1.0H + 1.0E')$	ACI 318-63 Code Ultimate strength design  Sec. A.2, p. A-3, Appendix A
2. Bolted steel framed structures 2.0/2.0		
3. Reinforced concrete: structures on soil including structural damping 5.0/7.5		
4. Prestressed concrete: containment structure on soil including structural damping 4.0/7.5	Final design (SSE) of the containment structure ( $.7 < \phi < .9$ ) a) $Y = 1/\phi (1.05D + 1.5P + 1.0T + 1.0F)$ b) $Y = 1/\phi (1.05D + 1.25P + 1.0T^A + 1.25H + 1.25E + 1.0F)$ c) $Y = 1/\phi (1.05D + 1.25H + 1.0R^A + 1.0F + 1.25E + 1.0T_o)$ d) $Y = 1/\phi (1.05D + 1.0F + 1.25H + 1.25W + 1.0T)$ e) $Y = 1/\phi (1.0D + 1.0P + 1.0T^A + 1.0H + 1.0E' + 1.0T_o)$ f) $Y = 1/\phi (1.0D + 1.0H + 1.0R^A + 1.0E' + 1.0F + 1.0T_o)$	Sec. B.1.6 p. B-5, Appendix B  <u>Containment Working Stress:</u> a. $D + L + F + T_o$ b. $D + L + F + T_A + E$ (or W) c. $P' = 1.15P$ FSAR App. B.1
	Y = Required yield strength of the structures D = Dead load of structure and equipment + any other permanent loads contributing stress, such as soil or hydrostatic loads R = Force or pressure on structure due to rupture of any one pipe H = Force on structure due to thermal expansion of pipes under operating conditions. E = Design seismic load for Class I structures E' = Maximum seismic load for Class I structures W = Wind load for Class I structures, tornado load for containment $\phi$ = Capacity reduction factor (Defined in B.1.7) P = Design accident pressure loads	
Sec. A.2, p. A-8, Appendix A		

F = Effective prestress loads  
 T = Thermal loads due to temperature gradient through wall during operating conditions  
 $T_o$  = Thermal loads due to temperature gradient through the wall and expansion  
 $T_A$

SEISMIC REVIEW TABLE

MECHANICAL & PIPING			
DAMPING OBE/SSE (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
1) Welded steel plate assemblies 1.0/1.0 2) Concrete equipment supports on another structures 2.0/2.0 3) Steel piping 0.5/0.5	Analytical method  DC control centers 250V-test	Critical reactor vessel internal structural 1. Design loading + design earthquake forces $P_m \leq S_m$ $P_B + P_L \leq 1.5 S_m$	$P_L, P_m, S_m, S_y$ are defined in the ASME Boiler and Pressure Vessel Codes, Section III, Article 4.  ASA B31.1 "USA Standard Code for pressure piping power piping." Piping: FSAR App. A Q.5.12, Q.5.7
		2. Normal operating loadings + hypothetical earthquake forces $P_m \leq S_D$ $P_B \leq 1.5 [1 - (\frac{P_m}{S_D})^2] S_D$	
		3. Normal operating loadings + hypothetical earthquake forces + pipe rupture loadings $P_m \leq S_L$ $P_B \leq 1.5 [1 - (\frac{P_m}{S_L})^2] S_L$	
		$S_u$ = Minimum tensile strength of material at temperature $S_L = S_y + (1/3) (S_u - S_y)$ $S_D = \text{Design stress}^u = 1.2 S_m$	
	Question 5.8 p. 5.8-3	Class 1 systems and equipment design (including piping) 1. MOL + PTT + SL 1. Applicable code allowable stress 2. MOL + MTT + SL 2. Minimum yield stress at temperature 3. MOL + MTT + 2SL 3. Minimum yield stress at temperature may be exceed but limited to no more than + 10%	MOL = Maximum normal operating load including design pressure, design temperature + piping and support reactions PTT = Normal planned thermal transients associated with expected plant normal operating transients such as start-up, shutdown and load swings

Sec. A.2  
Appendix A

MTT = Maximum thermal transients in the systems functioning during plant emergency conditions such as full power reactor trip turbine generator trip, loss of auxiliary power and the DBA

SL = Design seismic load resulting from a seismic ground surface acceleration of 0.1g

2SL = Hypothetical seismic load resulting from a seismic ground surface acceleration of 0.2g

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available	Not available	Not available	Not available





SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT				SOIL - STRUCTURE INTERACTION					
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
Class I structures: Spread or mat Foundation on fresh rock Peters Creek Schist. Depth: Not avail- able Auxiliary building: Steel H bearing pile foundation.	Residual soils. Weathered Peters Creek Schist. Fresh Peters Creek Schist.	0 to 40 ft. be- low sur- face. 25 to 65 ft. in thick- ness. 15 to 80 ft. be- low sur- face.	Not available	Varies from 12 to 15 ft. near and upstream. Reaches 100 ft. one mile down- stream.	Site is 9 miles above Conowingo Dam; 6 miles below Holt- wood Dam	Fig. C.3.3 indicates fixed base stick model.	Not available	Not available	Not avail- able
p. 2.7-3, p. 2.7.4	p. 2.5- 14	p.2.5- 14		p. 2.5-10	p. 2.5-10	p. C.3.3			

SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING OBE/SSE (% critical damping)	DESIGN CRITERIA	
	LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Reinforced concrete structures	2.0/5.0	1. D + E 2. D + E' 3. D + W 4. D + W' 5. D + E + T 6. D + E' + T 7. D + F  where D = Dead load                      E' = DBE W = Wind load                                T = Thermal W' = Tornado load                        F = Flood E = OBE
Steel framed structures	2.0/5.0	
Weld steel assemblies	1.0/2.0	
Bolted and riveted assemblies	2.0/5.0	
p. C.2-2	p. C.2-6 p. C.2-7 For further reference, refer Appendix C	AISC for structural steel ACI 318-63 for reinforced concrete  <u>Maximum allowable stresses</u> Steel - .9 yield strength Concrete - .85 compressive strength Reinforcement - .9 yield strength  See Codes on p. C.2-8.  p. C.2-6

SEISMIC REVIEW TABLE

MECHANICAL & PIPING			
DAMPING OBE/SSE (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Welded steel assemblies 1.0/2.0 Bolted and riveted assemblies 2.0/5.0 Seismic Class I Piping System 0.5/0.5	Analysis and tests	Normal and upset: 1. D. W. + pressure 2. D. W. + pressure + OBE 3. D. W. + pressure + thermal 4. D. W. + pressure + OBE + thermal  Emergency: 1. D. W. + DBE  Faulted: 1. D. W. + DBE + Jet reaction forces	<u>Reactor Vessel</u> ASME BPVC III  <u>Piping</u> USAS B 31.1.0
p. C.2-2	p. C.5-1	For further details refer to Table C.5.6, Table C.5.7	Table C.5.6 Table C.5.7







SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
<p>Heavily reinforced concrete mat 8 ft. depth</p> <p>Sec. 12.2.2.1, p. 12.2-2</p>	<p>Layers of glacial and recent deposits. Upper layer sandy silts (about 20 ft.) lower layer (glacial zone) poorly graded to well graded sands with varying amount of gravel. Boulders are scattered thru-out the soils. Bedrock is Dedham Granodiorite Group with a depth of six feet.</p>		<p>Not available.</p>	<p>Ground water table generally follows the site topography. i.e., moderately steep ground water gradients are present with flow toward Cape Cod Bay.</p> <p>Water level is about 2 1/2 to 5 ft. from surface (gathered from boring logs).</p> <p>Sec. 2.4.1.3.2, p. 2.4-1</p>	<p>Not available.</p>	<p>Stick model with soil springs.</p> <p>Sec. 12.2.3.5.2 p. 12.2-5</p>	<p>Not available.</p>	<p>Not available.</p>	<p>Not available.</p>

Sec. 2.5.2.4.2  
and Sec. 2.5.2.4.3  
p. 2.5-4

SEISMIC REVIEW TABLE

STRUCTURES			
DAMPING OBE/SSE	(% critical damping)	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Reinforced concrete building	5.0/7.5	1. Dead load + OBE.	1. Stresses according AISC. and ACI Codes.
Internal concrete structures and equipment supports	2.0/3.0	2. Dead load + wind loading.	2. Maximum allowable stress increased 1/3 above normal code-allowable stress.
Steel frame structures	2.0/5.0	3. Dead load + jet forces and pressure and temperature transient with rupture of single pipe + OBE.	3. Normal code-allowable stress.
Bolted steel assemblies	2.0/5.0	4. Dead load + R + SSE	4. Steel - 15% of AISC Code allowable stress concrete -0.75 f'c where "working stress design" method is used. Reinforcement = 0.9 f <sub>y</sub> when "ultimate strength design" method is used. Load factor of 9.0 is used with appropriate reduction factor as in ACI-318-63.
Welded assemblies	1.0/2.0	R= Jet forces and pressure and temperature transient with rupture of single pipe.	Details: See C.2.3, App. C, p. C.0-2
Table 12.2.3, p. 12.2-6		Details: See C.2.3, App. C, p. C.0-2	Details: See C.2.3, App. C, p. C.0-2



SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available	Not available	Not available	Not available



SEISMIC REVIEW TABLE

Docket Number  
50-266, 301

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION	DESIGN SPECTRA				
	OBE		SSE				EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY mm	HOR. g	VERT. g						
Point Beach Nuclear Plant Unit No. 1 & 2  Reactor type: PWR  Containment type: 6 buttresses with shallow dome (prestressed con- crete)  NSSS Manufacturer: Westinghouse  Architect Engineer: Bechtel          Unit 1: 7-67/10-70 Unit 2: 7-68/11-71	0.06	0.04	NOT AVAILABLE	0.18	0.08	NOT AVAILABLE	Horizontal & Vertical Components Combined Simultan- eously	SRSS	Housner Spectra	Olympia, Washing- ton N80E on April 13, 1949 Earthquake normalized to .06g was used for this analysis.	
	Sec. 5.1 p. 5.1-41			Sec. 5.1 p. 5.1-41		Append. A p. A-3	Sec. 5.1.2.4 p. 5.1-52	Q. 5.2 p. 5.2-2 Fig. A-1 & A-2	Append. A. p. A-18		

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
<p>For containment building:</p> <p>Reinforced concrete foundation slab which is supported by steel H-piles</p> <p>Depth is not available</p> <p>Sec. 1.2 p. 1.2-2 Sec. 2.11.4 p. 2.11-3</p>	<p>Overburden soils: silty clay, to silty sand, sand, gravel, cobbles and boulders</p> <p>Bedrock: Niagara dolomite the bedrock as a whole consists of dolomites limestones and sandstones.</p>	<p>70 ft. 100 ft.</p> <p>NOT AVAILABLE</p>	<p>NOT AVAILABLE</p>	<p>"The potable water for use at the Point Beach Plant is drawn from a 257 ft. deep well."</p> <p>Sec. 2.6 p. 2.6-10</p>	<p>NOT AVAILABLE</p>	<p>Structure: Stick Model Soil: Cantilever Beam assumption indicates fixed base modelling</p> <p>Q.5.15 p.Q5.15-6</p>	<p>NOT AVAILABLE</p>	<p>OBE/SSE: 5.0/5.0 % of damping factors.</p> <p>Append. A p. A-5</p>	<p>NOT AVAILABLE</p>

SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING OBE/SSE (% critical damping)	DESIGN CRITERIA	
	LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Welded Steel Framed Structures 2.0/2.0 Bolted Steel Framed Structures 2.5/5.0 Reinforced Concrete Structures on Soils 5.0/7.5 Prestressed Concrete Containment Structures on Piles 2.0/5.0	For Containment Structures: a) $Y = 1/\phi (1.05D + 1.5p + 1.0TA + 1.0F)$ b) $Y = 1/\phi (1.05D + 1.25p + 1.0TA + 1.25H + 1.25E + 1.0F)$ c) $Y = 1/\phi (1.05D + 1.25H + 1.0R + 1.0F + 1.25E + 1.0To)$ d) $Y = 1/\phi (1.05D + 1.0F + 1.25H + 1.0W + 1.0To)$ e) $Y = 1/\phi (1.0D + 1.0p + 1.0TA + 1.0H + 1.0E' + 1.0F)$ f) $Y = 1/\phi (1.0D + 1.0H + 1.0R + 1.0E' + 1.0F + 1.0To)$  Note: 0.95D is used instead of 1.05D where dead load subtracts critical stress.	For Concrete Structures of the Reactor Containment: ACI-318-63.  For further details refer to Sec. 5.1 p. 5.1-8
Append. A p. A-5 Table A.1-1	Sec. 5.1 p. 5.1-26	Sec. 5.1 p. 5.1-2







SEISMIC REVIEW TABLE

Docket Number  
50-282,306

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION	DESIGN SPECTRA				
	OBE		INTENSITY MM	SSF			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g		HOR. g	VERT. g						
<p>CP/OL ISSUE DATE</p> <p>Prairie Island Nuclear Generating Plant Unit 1 and 2</p> <p>Reactor Type: PWR</p> <p>Containment Type: Dry Containment- Cylindrical (Steel)</p> <p>NSSS Manufacturer: Westinghouse</p> <p>Architect Engineer: Pioneer</p> <p>Unit #1: 6-68/8-73 Unit #2: 6-68/10-74</p>	0.06	0.04	VI	0.12	0.08	Synthetic time- history	2 com- ponents combined linearly JAB-PS-02 App. B, John Blume	SRSS	Housner	Time history method.  For details refer to John A. Blume report, JAB-PS-04.	
	Sec. 2.10.2 p. 2.10-2	Sec. 5.2.1 p. 5.2-6		Sec. 2.10.2 p. 2.10 -2	Sec. 5.2.1 p. 5.2 -6	B. 6-7 App. A-1 p. 4.11	B. 6-9 B. 6-6	App. B Sec. B.6. 3(i) p. B.6-10	App. A. Plate 4.5,4.6	App. B Sec. B6.3 p. B.6-6 to B.6-7	

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
<p>Plant grade is at Elv. 693.5</p> <p>1. Mat foundation at Elv. 674</p> <p>App. A-1, p. 5.12</p> <p>Because of problem with liquefaction of soils above Elv. 645 due to ground acceleration, the soil above Elv. 645 is densified to a minimum relative density of 85%.</p> <p>For further details refer to App. A1, Sec. 5</p>	<p>Overburden materials are permeable sandy Alluvial soils from glacial outwash and recent river deposits. The bedrock is sandstone of Franconia Formation of &lt;180 feet in thickness.</p>	<p>Structures are founded on densified sandy Alluvial soils of 158 to 185 feet</p>	<p>Elv. 470 0-20 ft/sec loose sand</p> <p>Elv. 2150 20-50 ft/sec med dense</p> <p>Elv. 2860 50-180 ft/sec very dense</p> <p>Elv. 5020 180-4100 ft/sec Sandstone</p>	<p>Ground water table is 5 ft to 20 ft of the ground surface of the site and slope southwest from the Mississippi River toward Vermillion River.</p>	<p>Lock and dam number 2 is 17 miles upstream of plant site. It is 3250 ft long dike, 2 single-lift locks with chambers 110'x600' and 110'x500'; and a spillway section of 20-30 ft.</p>	<p>Stick model with soil springs.</p>	<p>Not available.</p>	<p>5% of critical damping.</p>	<p>Not available.</p>
	<p>Sec. 2.9.4 p. 2.9-4</p>	<p>2.9-5</p>	<p>App. A Sec. 4 Plate 4.1</p>	<p>Sec. 2.7.1 p. 2.7-1</p>	<p>Amend. 22 Sec. 2.7.3 p. 2.7-8C</p>	<p>App. B Sec. B6.3 p. 3.6-6</p>		<p>Amend. 12 App. B Table B.6-5</p>	

SEISMIC REVIEW TABLE

STRUCTURES																				
DAMPING OBE/SSE	(% critical damping)	DESIGN CRITERIA																		
		LOAD COMBINATION																		
		ACCEPTANCE CRITERIA & ALLOWABLE STRESSES																		
		<table border="0"> <tr> <td></td> <td style="text-align: center;"><u>R/C</u></td> <td style="text-align: center;"><u>Steel</u></td> </tr> <tr> <td></td> <td style="text-align: center;">ACI 318-63</td> <td style="text-align: center;">AISC</td> </tr> <tr> <td></td> <td style="text-align: center;">"</td> <td style="text-align: center;">"</td> </tr> </table>		<u>R/C</u>	<u>Steel</u>		ACI 318-63	AISC		"	"									
	<u>R/C</u>	<u>Steel</u>																		
	ACI 318-63	AISC																		
	"	"																		
Reactor building containment vessel:	1.0/1.0	<table border="0"> <tr> <td><u>L. C.</u></td> <td style="text-align: center;"><u>Class 1</u></td> <td></td> </tr> <tr> <td>Normal operating</td> <td>D + L + (W or S)</td> <td></td> </tr> <tr> <td>OBE</td> <td>D + L + DBA + greater of the OBE + (W or S)</td> <td></td> </tr> <tr> <td>DBE</td> <td>D + L + S + DBA + DBE</td> <td>1 1/2 times ACI 318-63 1 1/2 AISC</td> </tr> <tr> <td>Tornado</td> <td>D + L + tornado + tornado missiles</td> <td><math>f_c = 0.85 f_c'</math>      <math>f_s = 0.9 F_y</math></td> </tr> <tr> <td>Other</td> <td>Jet forces, rupture loads, flood wherever applicable</td> <td><math>f_s = 0.9 F_y</math></td> </tr> </table>	<u>L. C.</u>	<u>Class 1</u>		Normal operating	D + L + (W or S)		OBE	D + L + DBA + greater of the OBE + (W or S)		DBE	D + L + S + DBA + DBE	1 1/2 times ACI 318-63 1 1/2 AISC	Tornado	D + L + tornado + tornado missiles	$f_c = 0.85 f_c'$ $f_s = 0.9 F_y$	Other	Jet forces, rupture loads, flood wherever applicable	$f_s = 0.9 F_y$
<u>L. C.</u>	<u>Class 1</u>																			
Normal operating	D + L + (W or S)																			
OBE	D + L + DBA + greater of the OBE + (W or S)																			
DBE	D + L + S + DBA + DBE	1 1/2 times ACI 318-63 1 1/2 AISC																		
Tornado	D + L + tornado + tornado missiles	$f_c = 0.85 f_c'$ $f_s = 0.9 F_y$																		
Other	Jet forces, rupture loads, flood wherever applicable	$f_s = 0.9 F_y$																		
Reactor building shield structure:	2.0/2.0																			
Reactor building internal concrete construction:	5.0/5.0																			
Steel framed structures:	2.0/2.0																			
Reinforced concrete construction:	2.0/2.0																			
Amend. 12 (11-15-71) App. B Table B.6-5		<p>For details refer to App. B, Sec. B.6.1, p. B.6-1 and Table B.6-1.</p> <p>App. B Sec. B.3 p. B.3-1</p>																		

SEISMIC REVIEW TABLE

MECHANICAL & PIPING					
DAMPING OBE/SSE  (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA			
		LOAD COMBINATION		ACCEPTANCE CRITERIA & ALLOWABLE STRESSES	
Piping systems: 0.5/0.5 Mechanical equipment: 2.0/2.0	Analytical and testing.	1. Normal condition (D.L. thermal and pressure)	<u>Vessel</u> (a) $P_m \leq S_m$ (b) $P_m \text{ (or } P_L) + P_B \leq 1.5S_m$ (c) $P_m \text{ (or } P_L) + P_B + Q \leq 3.0S_m$	<u>Piping</u> $P \leq S$	ASME, BPVC, Section III ANSI B31.1, 1967 (App. B., Table B.7-3)  p. 5.2-11 App. B Table B.7-3
		2. Upset condition (normal and OBE)	(a) $P_m \leq S_m$ (b) $P_m \text{ (or } P_L) + P_B \leq 1.5S_m$ (c) $P_m \text{ (or } P_L) + P_B + Q \leq 3.0S_m$	$P \leq 1.2S$	
		3. Emergency condition	(a) $P_m \leq 1.2S_m$ or $S_y$ whichever is larger (b) $P_m \text{ (or } P_L) + P_B \leq 1.5(1.2S_m)$ or $1.5S_y$ whichever is larger	$P \leq 1.5(1.2S)$	LOAD COMBINATION(cont.) $P_m$ =Primary general membrane stress intensity $P_L$ =Primary local membrane stress intensity $P_B$ =Primary bending stress intensity $Q$ =Secondary stress intensity $S$ =Allowable stress intensity value from ASME, BPVC $S_y$ =Maximum specified material yield strength Amend. 24 (10-6-72) Table 5.2-1
		4. Faulted condition (Normal+DBE+pipe rupture)	(a) $P_m \leq 1.5S_m$ or $1.2S_y$ whichever is larger (b) $P_m \text{ (or } P_L) + P_B \leq 2.25S_m$ or $1.8S_y$ whichever is larger	$P \leq S_y$ or $1.8S$	$S_y$ =Minimum specified yield strength (ASME, BPVC Code, Sec. III) Amend. 11, App. B., Table B.7-2 and Table B.7-3
Amend. 12 (11-15-71) App. B Table B.6-5	App. B Sec. B.7(i) p. B.7-9 p. B.7-14				$P$ =Stress $S$ =Allowable stress from ANSI B31.1 code for power piping

App. B, Table B.7-3.  
p. 5.2-11

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	Not available.	Not available.	Not available.



SEISMIC REVIEW TABLE

Docket Number  
50-254, 265

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION	DESIGN SPECTRA			
	OBE		SSE		EARTHQUAKE TIME HISTORY		NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g						
CP/OL ISSUE DATE										
Quad - Cities Station Unit 1 and 2  Reactor type: BWR Containment type: Mark I(Steel) NSSS Manufacturer: General Electric Architect Engineer: Sargent & Lundy, Engineers	0.12	0.08	VII	0.24	0.16	South-East component of San Francisco Golden Gate 1952 earthquake normalized to a maximum ground acceleration.	Horizontal and vertical components combined simulta- neously.	SRSS	Ground response spectra for the Golden Gate Park earthquake as well as the Housner spectra.	Normalized Golden Gate 1952 earthquake was used for the Time History Method.
Unit 1: 2-67/9-71  Unit 2: 2-67/3-72	Sec. 2.6 p. 2.6-1	Sec. 12.1.1.3 p. 12.1-6	Sec. 12.1.1.3 p. 2.6-1	Sec. 2.6 p. 2.6-1	Sec. 12.1.1.3 p.12.1-6	Append. C p. E-1	Sec. 12.1.2 p.12.1-9	Sec. 12.1.2 p.12.1-9	Amend. 13, Sec. 12, p. 12.1-1, Fig. 12.1-1	Sec. 12, Amend.13 p. 12.3-8

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
Reactor building: Reinforced concrete foundation.  297 ft.-0 by 150 ft. -0   Sec. 12.1.2.1 p. 12.1-7	Zone 1: (above El 530) contains both good & poor zones much of bad rock has been excavated  Zone 2: (El 530-500) primarily good rock  Zone 3: (El 500-475) both good & poor zones.  Zone 4: (Below El 475) primarily good rock  Amend. 15 p. 13 Table 4	0 to 20 ft.  30 ft.  25 ft.  50 ft.	Turbine Room No. 1. Middle Grout Zone  8,000 to 9,000 fps. above Upper Soft Zone 5,500 to 7,500 fps. Upper Soft Zone 3,900 to 5,100 fps. Good Rock Zone 8,000 fps. Lower Soft Zone 4,700 to 6,200 fps. below Deep Soft Zone 6,000 fps.  Amend. 15, p.6	Not available.	This site is about midway between Lock and Dam No. 14 and 13 on Mississippi River.  Sec. 2.4, p. 2.4-1	Structure: Stick Model  Soil: Fig. 12.1.6 shows fixed base assumption.	300,000 psi to 1,500,000 psi          Amend. 15, 1 of 2	Not available.	Not available.




SEISMIC REVIEW TABLE

MECHANICAL & PIPING			
DAMPING OBE/SSE (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
<p>Vital Piping Systems                      0.5</p> <p>(For both O.B.E. and D.B.E. except for the standby gas treatment system, where 1% of critical damping was used).</p> <p>Sec. 12.1.1.3, Table 12.1.1 p. 12.1-6</p>	<p>Analytical</p> <p>Amend. Sec. 12 p. 12.2-14</p>	<p>Reactor primary vessel supports =</p> <p>a) D + H + E b) D + H + R + E c) D + H + E'</p> <p>Reactor primary vessel internals =</p> <p>a) D + E b) D + E' c) P + D + T</p> <p>Other major Class I equipment =</p> <p>a) D + T + M + E b) D + T + M + E'</p> <p>For designations refer to previous page.</p> <p>Amend. 13, Sec. 12, p. 12.3-10</p>	<p>For reactor pressure vessel: ASME Boil and Pressure Code, Sec. III, 1963 and Summer 1964, Append. A.</p> <p>Class I piping: USAS B31.1</p> <p>Append. C p. ii, Amend. Sec. 12, p. 12.1-4</p>

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	Not available.	Not available.	Not available.



SEISMIC REVIEW TABLE

Docket Number  
50-312

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION	DESIGN SPECTRA				
	OBE		SSE				EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g						
Rancho Seco Nuclear Generating Station Unit No. 1  Reactor type: PWR  Containment type: 3 buttresses with shallow dome (pre- stressed concrete)  NSSS Manufacturer: Babcock and Wilcox  Architect Engineer: Bechtel   10-68/8-74	0.13	0.09	VI	0.25	0.17	1952 Taft Earthquake	Three earthquake components: two horizontal and one vertical. Results for each horizontal earthquake were added separately on absolute basis to those from vertical earthquake; yielding two distinct seismic loading cases.	SRSS both for structures and piping.	Accelerogram of Taft Earthquake 1952. The response spectra are broadened in their range of peak responses.	Time-history acceleration method	
	p. 5.1-2	p. 5.1-2		p. 5.1-2	p. 5.1-2	Appendix 5B p. 5B-4  Question AEC 5.51 p. 5A-51					Question AEC 5-51 p. 5A-51

SK6292-S-62

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
<p>Circular reinforced concrete mat 8 ft thickness</p> <p>Foundation is found about 35 ft below grade surface.</p> <p>Sec. 5.2.1 p. 5.2-1 Appendix 2E p. 2E-1</p>	<p>The granite &amp; metamorphic basement is overlain in the site by 1500 to 2000 ft tertiary or older sediments. The surface unit is pliocene laguna formation of firm siltstone, sand, gravel</p> <p>The surface unit of pliocene laguna formation is about 126 ft.</p> <p>Appendix 2C, Table 2C-7, Table 2C-1.2 Sec. 2.5</p>	<p>Not available.</p>	<p>150 ft below original ground surface.</p> <p>p. 2.4-1</p>	<p>1. Data on reservoirs and lakes within 50-mile radius are given in Table 2.4-1. 2. Plot of on-site dam, Question AEC No. 2.14.</p> <p>Appendix 2A p. 2A-132</p>	<p>Stick model with soil springs.</p> <p>Sec. 5.2.1.3.6 p. 5.2-18</p>	<p>Not available</p>	<p>10% for design basis earthquake.</p> <p>Appendix 5B p. 5B-6</p>	<p>Not available</p>	

SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING OBE/SSE	(% critical damping)	DESIGN CRITERIA
		LOAD COMBINATION
<p>Stress level:*</p> <p>1. a) Welded structural steel, reinforced or prestressed concrete, no cracking, no joint slip.      0.5/1.0</p> <p>2. a) Welded structural steel, reinforced and prestressed concrete (only slight cracking).      2.0</p> <p>b) Reinforced concrete with considerable cracking.      3.0/5.0</p> <p>c) Bolted and/or riveted steel.      5.0/7.0</p> <p>3. a) Welded structural steel, prestressed concrete (without complete loss in prestress).      5.0</p> <p>b) Prestressed concrete with no prestress left.      7.0</p> <p>c) Reinforced concrete.      7.0/10.0</p> <p>d) Bolted and/or riveted steel.      10.0/15.0</p> <p>4. Rocking of entire structure      5.0/9.0</p> <p>Translation of entire structure      30 (OBE, SSE)</p>	<p>A) <math>\phi C = (1+0.05) D + 1.5 P + 1.0 T_A + 1.0 F</math></p> <p>B) <math>\phi C = (1+0.05) D + 1.25 P + 1.0 T_A + 1.25 H + 1.25 E + 1.0 F</math></p> <p>C) <math>\phi C = (1+0.05) D + 1.25 H + 1.0 R + 1.0 F + 1.25 E + 1.0 T_c</math></p> <p>D) <math>\phi C = 1.0 D + 1.0 P + 1.0 T_A + 1.0 E' + 1.0 F + 1.0 H</math></p> <p>E) <math>\phi C = 1.0 D + 1.0 H + 1.0 R + 1.0 E' + 1.0 F + 1.0 T_o</math></p> <p><math>\phi</math> = Capacity reduction factor.</p> <p>D = Dead loads of structures and equipment plus any other permanent loading contribution stress, such as hydrostatic or soil.</p> <p>P = Design accident pressure load,</p> <p>F = Effective prestress loads,</p> <p>R = Force or pressure on structure due to rupture of any one pipe.</p> <p>H = Force on structure due to thermal expansion or contraction of pipes due to design conditions.</p> <p>T<sub>o</sub> = Thermal loads due to the temperature gradient during operating conditions.</p> <p>T<sub>A</sub> = Thermal loads due to the temperature gradient.</p> <p>E = OBE</p> <p>C = Required capacity to resist factored loads.</p> <p>E' = DBE</p>	<p style="text-align: center;">ACCEPTANCE CRITERIA &amp; ALLOWABLE STRESSES</p> <p>1. ACI-318-63 Ultimate strength method Question AEC 5.23, p. 5A-25</p> <p>2. AISC (Sixth Edition) Sec. 5.1.3, p. 5.1-4</p> <p>NOTE:</p> <p>1. Normal working stress. Design methods are used for design load case.</p> <p>2. Factored load case--to check the capacity to withstand accident conditions.</p> <p>Sec. 5.1.4, p. 5.1-4a For details see: Sec. 5.2.1.3 p. 5.2-11</p>
<p>*NOTE. Stress level 1 = low, well below proportional limit. Stress below 1/4 yield point. Stress level 2 = Working stress Stress level 3 = At or just below yield point Stress level 4 = Varies</p>		<p>p. 5.1-6 and p. 5.2-7</p>

Appendix 5B  
p. 5B-7

SEISMIC REVIEW TABLE

MECHANICAL & PIPING			
DAMPING OBE/SSE  (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Vital piping systems or equipment.	Dynamic analysis	I. Design loads + OBE loads	Nuclear vessels: ASME BPVC 1967, Section III Piping: USAS I, B31.7
Low, well below proportional limit, stress below 1/4 yield point.	0.5	Testing	
Working stress, no more than point.	0.5/1.0	IV. Design loads + DBE + pipe + rupture loads	
At or just below point.	0.5/2.0		
		P <sub>m</sub> ≤ 1.0 S <sub>m</sub> P <sub>L</sub> + P <sub>B</sub> ≤ 1.5 S <sub>m</sub> P <sub>m</sub> ≤ 1.2 S <sub>m</sub> P <sub>L</sub> + P <sub>B</sub> ≤ 1.2 (1.5 S <sub>m</sub> ) S <sub>m</sub> ≤ 2/3 S <sub>U</sub> P <sub>L</sub> + P <sub>B</sub> ≤ 2/3 S <sub>U</sub> P <sub>m</sub> ≤ 2/3 S <sub>U</sub> P <sub>L</sub> + P <sub>B</sub> ≤ 2/3 S <sub>U</sub>	
		P <sub>L</sub> = Primary local membrane stress intensity. P <sub>m</sub> = Primary general membrane stress intensity. P <sub>B</sub> = Primary bending stress intensity. S <sub>m</sub> = Allowable membrane stress intensity. S <sub>U</sub> = Ultimate stress for unirradiated material at operating temperature.	
p. 5B-7	Question AEC 5.49 p. 5A-49	p. 4.1-4	p. 4.1-5

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	Test data/or calculations of equipment to with-stand OBE and DBE are provided by vendors.  Question AEC 5.67 p. 5A-62	Not available.	Not available.



SEISMIC REVIEW TABLE \*

Docket Number  
50-244

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					EARTHQUAKE TIME HISTORY	METHOD OF COMBINATION		DESIGN SPECTRA	
	OBE		INTENSITY MM	SSE			NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. S	VERT. S		HOR. S	VERT. S					
Robert Emmett Ginna Nuclear Power Plant, Unit No. 1  Reactor type: PWR Containment type: cylindrical without buttresses (prestressed concrete)  NSSS Manufacturer: Westinghouse  Architect Engineer: Gilbert          4-66/9-69	0.08	0.08	V	0.20	0.20	None used	Two comp., larger horizontal plus ver- tical, com- bined via "direct addition" vertical component is assumed unampli- fied due to high axial stiffness of the con- tainment.	None (Contain- ment analyzed as single degree of freedom).	Housner	Equivalent static approach based on Housner ground spectra.  Multimode response spectrum analysis used to check con- tainment vessel and RHRS pipeline from RCS loop to con- tainment.
	Sec. 5.1.2.4 p. 5.1.2-15	Sec. 5.1.2.4 p. 5.1.2-15	Sec. 2.9 p. 2.9-1	Sec. 5.1.2.4 p. 5.1.2-15	Sec. 5.1.2.4 p. 5.1.2-15					

\*Information was obtained from BNL Docket Search and SEPB Report  
"Seismic Review of Ginna Nuclear Power Station Unit No. 1 for SEP, Phase 1 Report".

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT				SOIL - STRUCTURE INTERACTION					
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
Foundations for major structures will be installed at depths of 25 or more feet below original ground level. Foundations are spread or mat foundations on natural compact granular soil, compacted granular backfill or sound bedrock. The containment cylinder is founded on rock (sandstone) by means of post-tensioned rock anchors. The base slab is 2' thick.	Major structures are founded on Queenston formation atop a thin layer of natural or compacted granular soils immediately above the bed rock. The Queenston is roughly 1000 ft. thick and overlies 80 ft. of	Oswego sandstone, approximately 600 ft. of Lorraine shales. About 30 ft. of overburden was removed prior construction of foundation.	Not available	Not available	Not available	SDOF stick model with fixed base (checked with MDOF model and rock foundation modeled as elastic media with rotation and translation.	Not used	Not used	Not used

App. 2B, p. 2B-4  
 Sec. 5.1.2.1  
 p. 5.1.2-1

Sec. 2.8.2  
 2.8.3  
 p. 2.8-1  
 p. 2.8-2

SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING OBE/SSE (% critical damping)	DESIGN CRITERIA	
	LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
1. Containment structure (prestressed cylindrical wall) 2.0	<p><u>Containment Structure Loading Combinations:</u>  <u>Normal</u>- 12 load combinations, example  <math>1.0 DL + 1.17 VP + 1.0 OT_S + 2.0 E</math></p> <p><u>Test</u>- 4 load combinations, example  <math>1.0 DL + 1.17 VP + 1.0 OT_W + 1.15 IP</math></p> <p><u>Accident Pressure</u>-            Cond. "d" - 12 load combinations, example  <math>1.0 DL + 1.17 VP + 1.0 OT_W + 1.0 IP + 1.0 AT_{60} + 0.8 E</math>            (a=0.1g)</p> <p>Cond. "a" - 4 load combinations, example  <math>1.0 DL + 1.17 VP + 1.0 OT_W + 1.5 IP + 1.0 AT_{90}</math></p> <p>Cond. "b" - 8 load combinations, example  <math>1.0 DL + 1.17 VP + 1.0 OT_W + 1.25 IP + 1.0 AT_{90} + E</math></p> <p>Cond. "c" - 8 load combinations, example  <math>1.0 DL + 1.17 VP + 1.0 OT_S + 1.0 IP + 1.0 AT_{60} + 2.0 E</math></p> <p>DL = Dead load            VP = Vertical prestress  <math>OT_{W,S}</math> = Operating temp. winter, summer            App. 5D, Table 5.1.2-4I FSAR</p> <p>IP = Internal pressure (p=60 psig)  <math>AT_{60}</math> = Accident pressure + temperature (p = 60 psig, T = 286°F)            E = Design earthquake (a=0.1g)</p>	<p>ACT-318            AISC - 63            State of New York            Building Construction Code,            1961 (Class III structures)</p> <p>5.1.2.3            FSAR 5.1.2.4, 7.2</p>
2. Concrete support structure for reactor vessel and steam generator 2.0		
3. Steel assemblies a) Bolted or riveted 2.5 b) Welded 1.0		
4. Other concrete above ground 5.0		

Table 5.1.2-1

SEISMIC REVIEW TABLE

MECHANICAL & PIPING			
DAMPING OBE/SSE (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
1. Vital Piping System      0.5	Analytical and Testing	<u>Loading Combination</u>	<u>Vessels and Reactor Internals</u>
		<u>Piping</u>	
		1. Normal + OBE $P_m \leq S_m$ $P_L + P_B \leq 1.5 S_m$	$P_m \leq 1.2 S$ $P_L + P_B \leq 1.2 S$
		2. Normal + SSE $P_m \leq 1.2 S_m$ $P_L + P_B \leq 1.2(1.5 S_m)$	$P_m \leq 1.2 S$ $P_L + P_B \leq 1.2(1.5 S)$
		3. Normal + Pipe rupture loads $P_m \leq 1.2 S_m$ $P_L + P_B \leq 1.2 (1.5 S_m)$	$P_m \leq 1.2 S$ $P_L + P_B \leq 1.2(1.5 S)$
		P <sub>m</sub> = Primary general membrane stress; or stress intensity P <sub>L</sub> = Primary local membrane stress; or stress intensity P <sub>B</sub> = Primary bending stress; or stress intensity S <sub>m</sub> = Stress intensity value from ASME B and PV Code Sec. III S = Allowable stress from USAS B31.1 Code for pressure piping	ASME BPVC Sec. III, USAS B31.1 <u>Supports</u> Working stress within yield after load redistribution within yield after load redistribution Fuel Pool Racks: Reg. guides 1.13, 26, 28, 38, 60, 61 ANSI N 18.2 - 1973 ANSI N 45.2.2 - 1972 ANSI N 45.2.13 - 1974 Structural Welding Code AWS Spec. D1.1 Rev. 2-74 ASME BPV Code, Sec. III, Sec. VIII, and IX, 1974 AISC - 1974 FSAR 9.5, App. 14A
Table 5.1.2-1	Amend. 2, Question 5	FSAR 5.1.2, FSAR App. 4-A, Table 1	

Equipment: FSAR Table 3.2.3-2 through 3.2.3-7





SEISMIC REVIEW TABLE

Docket Number

50-272, 311

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION	DESIGN SPECTRA				
	OBE		SSE				EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g						
CP/OL ISSUE DATE											
<p>Salem Nuclear Generating Station Units 1 and 2 New Jersey</p> <p>Reactor type: PWR</p> <p>Containment type: Atmospheric (reinforced concrete)</p> <p>NSSS Manufacturer: Westinghouse</p> <p>Architect Engineer: United Engineers and Constructors</p> <p>Unit #1: 12-66/8-71 Unit #2: 10-67/8-71</p>	0.10	0.067	VII	0.20	.133	<p>El Centro (N-S) May 18, 1940 normalized to 0.10g to 0.20g for OBE and DBE respectively was used for containment structure analysis by step by step integration method.</p> <p>Sec. 5.2.4.2 p. 5.2-17</p>	<p>The vertical component was considered to be acting simultane- ously with the hori- zontal motion.</p> <p>Sec. 5.2. 4.2 p. 5.2-17</p>	<p>1. Response spectra analysis: Sq root of sum of squares but if &lt; 3 modes → absolute sum of maximum values. 2. Time history analysis (finite element method): summing of signif- icant modes.</p> <p>App. C Sec. C.3.3 p. C.3-2</p>	<p>1. For freq &gt; 0.33 cps: Aug spectra developed by Housner.</p> <p>2. For freq &lt; 0.33 cps: Utilized data suggested by Newmark.</p> <p>Fig. IIC-3a Fig. IIC-3b</p> <p>App. B p. IIC-10</p>	<p>Time history method.</p> <p>App. C Sec. C.3.3 p. C.3-2</p>	
	Sec. 2.9 p. 2.9-1										

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
Circular concrete mat Depth 16 ft  Sec. 5.6.2 See Table 5.6-1	1800 feet of sediments Upper 35 feet includes hydraulic fill and Quaternary alluvium of clay silt and some sand and gravel. Vincen-town formation is encountered at about 70 feet. App. B p. IIC-9	Foundations are established directly in Paleocene silty sands of Vincen-town formation or upon compacted fill extended to Vincen-town. Depth of Vincen-town is 90 feet. App. B p. IIC-9	3500 ft./sec  App. B. p. IIC-9	Water level is about 20' from surface, but ground water movement thru aquifers is quite low due to low permeability. The direction is going into Delaware River.  App. B p. IIB-14 Table IIB-2	Not avail-able.	Two methods were used: 1. Lumped mass model analysis using aug resp. spectra 2. Finite element modal analysis, for structure and soil. The most conservative results are used.  Sec. 5.2.4.2 p. 5.2-17	Not available.	2%--OBE 5%--DBE  Sec. 5.2.4.2 p. 5.2-17	Not avail-able.

See Plate IIC-1, App. B

SEISMIC REVIEW TABLE

STRUCTURES			
DAMPING OBE/SSE	(% critical damping)	DESIGN CRITERIA	
		LOAD COMBINATION	
		ACCEPTANCE CRITERIA & ALLOWABLE STRESSES	
Concrete structures:	2.0/5.0	1. Operating + DBA + OBE $C=1.0D+0.05D+1.25P+1.0(T'+TL')+1.25E+1.0B$	ACI 318-63
Structural steel:		2. Operating + DBA + DBE $C=1.0D+0.05D+1.0P+1.0(T''+TL'')+1.0E'+1.0B$	AISC Manual, 6th edition
Bolted or riveted	2.5	3. Operating + DBE $C=1.0D+0.05D+1.0T'''+1.0E'+1.0B$	Note:
Welded	1.0	C = Required load capacity of section D = Dead load P = Accident pressure load T' = Load due to maximum temperature gradient based upon temperature associated with 1.25 times accident pressure T'' = Load due to maximum temperature gradient based upon temperature associated with accident pressure T''' = Load due to operating temperature gradient thru the steel liner, concrete shell and mat E = Load from OBE E' = Load from DBE TL' = Load exerted by liner based upon temperature with 1.25 times accident pressure TL'' = Load exerted by liner based upon temperature associated with accident pressure.	(a) For normal operating + OBE" "Working Stress Design" ACI 318-63 and the allowable stresses are 1/3 above the normal applicable code working stresses.  (b) For normal load + DBE: "Ultimate Strength Design" ACI 318-63
App. C		Sec. 5.2.3	Sec. 5.6.3
Sec. C.3.2		p. 5.2-7 to 5.2-8	p. 5.6-2
p. C.3-1			

SEISMIC REVIEW TABLE

MECHANICAL & PIPING			
DAMPING OBE/SSE  (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Vital piping system: 0.5	Not available.	<p>1. Normal condition:</p> <p style="margin-left: 40px;">(a) <math>P_m \leq S_m</math></p> <p style="margin-left: 40px;">(b) <math>P_m \text{ or } (P_L) + P_b \leq 1.5S_m</math></p> <p style="margin-left: 40px;">(c) <math>P_m (P_L) + P_b + Q \leq 3.0S_m</math></p> <p>2. Upset condition:</p> <p style="margin-left: 40px;">(a) <math>P_m \leq S_m</math></p> <p style="margin-left: 40px;">(b) <math>P_m (P_L) + P_b \leq 1.5S_m</math></p> <p style="margin-left: 40px;">(c) <math>P_m (P_L) + P_b + Q \leq 3.0S_m</math></p> <p>3. Emergency condition:</p> <p style="margin-left: 40px;">(a) <math>P_m \leq 1.2S_m \text{ or } S_y</math> whichever is larger</p> <p style="margin-left: 40px;">(b) <math>P_m (P_L) + P_b \leq 1.5(1.2S_m)</math> or <math>1.5S_y</math> whichever is larger</p> <p>4. Faulted condition: Design limit curves*</p>	<p>ASME Nuclear Vessel Code Section III</p> <p>ANSI B31.1 for piping</p>
App. C Sec. C.3.2 p. C.3-1		<p>NOTE: <math>P_m</math> = primary general membrane stress, <math>P_L</math> = primary local membrane stress, <math>P_b</math> = primary bending stress, <math>S_m</math> = stress value for ASME, BPVC code, Section III, nuclear vessels, <math>S_y</math> = minimum specified material yield, <math>S</math> = allowable stress from USASI, B31.1 code for press piping. App. C, Table C.4-2</p>	<p>Sec. 5.2.8.3 p. 5.2-53</p>

\*Design limit curves developed using 50% of ultimate strain as maximum allowable membrane strain.

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	Not available.	Not available.	Not available.



SEISMIC REVIEW TABLE \*

Docket Number  
50-206

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					EARTHQUAKE TIME HISTORY	METHOD OF COMBINATION		DESIGN SPECTRA	
	OBE		SSE				NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
San Onofre Nuclear Generating Station Unit 1  Reactor type: PWR  Containment type: Dry containment- spherical (steel)  NSSS Manufacturer: Westinghouse  Architect Engineer: Bechtel  3-64/3-67	0.25g for Cat. A, 0.20g for Cat. B, UBC for Cat. C.	0.167	Not avail- able	0.50	0.33	A synthetic time history was generated so that it's response spectra envelop the Housner spectra at 2% damping.  3.7.1.1-1 Model System Analysis E.Q.Comp.&Comb. Reactor bldg. Res. Spec. 3comp. R.G. 1.92 R.G. 1.92 D.G. Bldg. Res. Spec. 3comp. R.G. 1.92 R.G. 1.92 Steel Con- Res. Spec. 3comp. SRSS tainment SRSS sphere RCL piping Time his- 3comp. algebraic Direct and equipment tory integration RCL supports Time his- 3comp. algebraic Direct Concrete sphere tory integration enclosure Res. Spec. 3comp. SRSS Diesel Gen. Res. Spec. 3comp. R.G. 1.92 R.G. 1.92 Bldg. Absolute Main bldg. Res. Spec. 3comp. Absolute Intake struct., Res. Spec. 2comp. Absolute Aux. bldg., battery rm. Housner spectra used in original design and 1972-75 re-evaluation except that a site specific spectra was used for the concrete sphere enclosure and the deisel generator bldg.	Absolute N/A	3.7.1.1.1	Floor response spectra by time history method for re-evaluation of RCL piping, equipment, and NSSS supports. All other Category "A" piping and equipment (ECCS, ACS, SIS, feedwater lines, CVC) - 1.0g and 0.67g for horizontal and vertical, 0.5g, Housner spectra for equipment.	

\*Information from BNL Docket search and SEPB Report No. EDAC-175-166, 01,  
August '79, "Seismic Design Bases and Criteria for San Onofre Nuclear  
Generating Station, Unit 1".

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
<p>p. The foundation of the containment-reactor building is in the shape of a spherical segment extending from the ground surface to a depth of 40 ft. The supporting medium is San Mateo sand. Bedrock is at a depth of 1000 ft.</p> <p>3.7.1-6</p>	<p>1. Quarternary terrance deposits: Consist of clayey or silty, fine to coarse sand with some cobbles. Average thickness is 40 ft.</p> <p>2. San Mateo formation: Massive, well-graded, fine to coarse sand with gravel and occasional lenses of thin beded gray shale or siltstone. Approx. 1000 ft. thick.</p>	<p>Surface terrace deposit San Mateo sand Capistrano siltstones Monterey shale San Onofre Breccia undifferentiated sediments</p>	<p>400 and 1250 fps 765 fps 2000 fps 2160 fps 5000 fps 3,900 fps</p>	<p>Average level of ground water is 15 ft. below original grade (El + 5ft. MLLW Datum), and the gradient is 17 ft. per mile toward the ocean.</p>	<p>Not avail- able</p>	<p>Soil-structure interaction is represented by a set of six frequency-independent interaction springs attached to the reactor building structure at the center of gravity of the base mat. "SHAKE" program used.</p>	<p>Not available</p>	<p>Soil horizontal translation - 12% Soil vertical translation - 18% Soil rocking - 10%</p> <p>These values include radiation and material damping.</p>	<p>Not avail- able</p>

Sec. 1.3.2  
p. 1-56

p. 3.7.2-4

Table 3.7.1-3

SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING OBE/SSE	(% critical damping)	DESIGN CRITERIA
		LOAD COMBINATION
		ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
1. Reactor vessel internals ( stainless steel core support structure) (a) welded assemblies (b) bolted assemblies	1.0 2.0	<u>Concrete structures</u> (concrete sphere enclosure) $u = 1.4 D + 1.7 L$ $u = 1.4 D + 1.7 L + 1.9 E$ $u = D + L + T_o + R_o + E'$
2. Reinforced concrete reactor support	4.0	$u = D + L + T_A + R_A + 1.0 P_A + (Y_R + Y_J + Y_M) + E'$ (9 additional L.C.)
3. Steel containment vessel and foundation	4.0	<u>Steel structures</u> $S = D + L$
4. Framed steel structures	2.5	$1.6S = D + L + T_o + R_o + E'$ $1.6S = D + L + T_A + R_A + P_A + 1.0 (Y_R + Y_J + Y_M) + E$
5. Concrete structures above ground (a) shear wall type (b) rigid frame type	7.0 5.0	(8 additional L.C.)  <u>Reactor building and foundation and cradle support</u> $u = 1.0 D + 1.0 L + 1.0 (DBE)$ $0.9Y = 1.0 D + 1.0 L + 1.0 (DBE)$ $Y = \text{ultimate strength of section}$
		Concrete sphere enclosure, Reactor bldg. (concrete in- ternals), foundation and cradle, diesel generation bldg. - ACI 318 - 71, AISC 1971
		Main building, intake structures, auxiliary bldg., battery rm., turbine pedestal - ACI 318 - 63 - AISC 1963 - UBC 1964
		Refueling Water Stg. Tank-API publication for storage tank.

Sec. 9.2.2  
 Table 9.1  
 p. 9-10



SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available	<p>Tested or evaluated to determine that the instruments would withstand 1.0g without mis-operation.</p> <p>Amend. 10, Suppl. 1, Quest. 14</p>	Not available	Not available



SEISMIC REVIEW TABLE

Docket Number

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
CP/OL ISSUE DATE										
Shippingport Project 129  Reactor type: PWR  Containment type: Dry containment- spherical (steel)  NSSS Manufacturer: Westinghouse  Architect Engineer: Burns and Roe, Inc. also Stone and Webster Engineering Corp.				Not available						

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT				SOIL - STRUCTURE INTERACTION					
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
				← Not Available →					

SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING OBE/SSE	DESIGN CRITERIA	
	LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available	Not available	ASME Code Sec. VIII 1952 Ed.  P.A. Regulations for pressure vessels 1954 ed.

SEISMIC REVIEW TABLE

MECHANICAL & PIPING			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
		Not Available	

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
		Not Available	



SEISMIC REVIEW TABLE

Docket Number  
50-335

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION	DESIGN SPECTRA				
	OBE		SSE				EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g						
St. Lucie Plant, Unit No. 1.  Reactor type: PWR  Containment type: Dry containment- cylindrical (steel)  NSSS Manufacturer: Combustion Engineering  Architect Engineer: Ebasco   7-70/3-76	0.05	0.033 for shield building	VI	0.10	0.067 for shield building	Synthetic time- history	Each horizontal combined with the vertical on an absolute sum basis. Resulting two load cases.	SRSS	Housner spectra	Time-history method using synthetic time history	
	Sec. 2.5 p. 2.5- 25a	Sec. 3.8. 2.2, p. 3.8-67, Amend. 32	Sec. 2.5 p. 2.5-27		Sec. 3.8 2.2, p. 3.8-67, Amend. 32	Sec. 2.5.3 p. 2.5-28	Sec. 3.7. 3.2.4, p. 3.7-43a	Sec. 3.7. 2, p. 3.7- 19	Fig. 2.5-23 and 24 Fig. 3.7-1 and 2	Sec. 3.7 p. 3.7-36 Sec. 3.7 p. 3.7-3 Rev. 16	

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT				SOIL - STRUCTURE INTERACTION					
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
For reactor building: Rigid foundation mat.  p. 2.5-1	More dense contains a greater percentage of fines (material finer than the no. 200 sieve) and has very few pockets of limestone nodules and *	50' to 60'	Not available	Shallow non-artesian aquifer extends to a depth of about 150 ft. below land surface	"No dams are located within the hydrological influence of Hutchinson Island."	Stick model with soil springs.	Generally utilize shear shear moduli ranging from ranging from 16,700 psi to 14,000 psi.	Not available	Not available
		60' to 150'	Sec. 2.5-36 p. 2.5-38	Vol. 1, Sec. 2.4 p. 2.4-20	Sec. 2.4, p. 2.4-7a	Sec. 3.7.2.1.1 p. 3.7-6	Sec. 2.5, p. 2.5-38	p. 2.5-19	

(Note: Due to space the columns for Type and Depth had to be continued here...)

\* shell fragments more clayey than the material above, does not contain pockets of shells and limestone, and is dense in consistency. Vol. 1, Sec. 2.5, p. 2.5-8

SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING OBE/SSE (% critical damping)	DESIGN CRITERIA	
	LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Welded steel framed structure	2.0/2.0	Shield Building $(1.0 \pm 0.05)(D + T) + 1.25 \text{ LOCA} + 1.25 \text{ OBE}$ $(1.0 \pm 0.05)(D + T) + 1.25 \text{ OBE}$ $(1.0 \pm 0.05)(D + T) + 1.0 \text{ LOCA} + 1.0 \text{ DBE}$ $(1.0 \pm 0.05)(D + T) + 1.0 \text{ DBE}$  For further details refer to Sec. 3.8.2.2 p. 3.8-68 of Amend. 32-9/6/74.
Bolted or riveted steel framed structure	2.5/2.5	
Reinforced concrete frames and buildings	2.0/5.0	
Steel containment vessel	2.0/2.0	
Sec. 3.7 p. 3.7-3a		AIC 318-63 $\phi$ Yield capacity reduction factors are used. Sec. 3.8.2.2.8 p. 3.8-71 <hr/> AISC -1969 Sec. 3.8 p. 3.8-2,3

SEISMIC REVIEW TABLE

MECHANICAL & PIPING				
DAMPING OBE/SSE (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA		
		LOAD COMBINATION		ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
<p>Welded steel plate assemblies 1.0/1.0</p> <p>Reinforced concrete equipment supports 2.0/5.0</p> <p>Steel piping 0.5/0.5</p>	<p>Analytical and Testing</p> <p>Sec. 3.7, p. 3.7-36, 43a</p> <p>Sec. 3.9 p. 3.9-1</p>	<p><u>Containment Vessel</u></p> <p>LOCA + OBE:  <math>P_M \leq 1.0 S_m</math>  <math>P_L + P_B \leq 1.5 S_m</math>  <math>P_L + P_B + Q \leq 3.0 S_m</math></p> <p>LOCA + DBE:  <math>P_M \leq 0.9 S_y</math>  <math>P_L + P_B \leq 0.9 S_u</math></p> <p>OBE + Pipe rupture:  <math>P_M \leq 1.0 S_m</math>  <math>P_L + P_B \leq 1.5 S_m</math>  <math>P_L + P_B + Q \leq 3.0 S_m</math></p> <p>DBE + Pipe rupture:  <math>P_M \leq 0.9 S_y</math>  <math>P_L + P_B \leq 0.9 S_u</math></p> <p>OBE + Thermal + Seismic loads on piping:  <math>P_M \leq 1.0 S_m</math>  <math>P_L + P_B \leq 1.5 S_m</math>  <math>P_L + P_B + Q \leq 3.0 S_m</math></p> <p>LOCA + DBE with pressure &amp; thermal + seismic loads on piping:  <math>P_M \leq 0.9 S_y</math>  <math>P_L + P_B \leq 0.9 S_u</math></p>	<p><u>Piping</u></p> <p>Design: <math>P_m \leq S_m</math>  <math>P_L + P_b \leq 1.5 S_m</math>  <math>P_L + P_b + P_e + Q \leq 3.0 S_m</math></p> <p>Normal: <math>P_L + P_b + P_e + Q + F = S_p</math> (use fatigue curve)</p> <p>Upset: <math>P_L + P_b + P_e + Q \leq 3.0 S_m</math></p> <p>(Press + Wt. + OBE + VT) <math>P_L + P_b + P_e + Q + F = S_p</math> (use fatigue curve)</p> <p>Emergency: Max press <math>\leq 1.5</math> design press</p> <p>(Press + Wt. + DBE) <math>P_L + P_b \leq 2.25 S_m</math></p> <p>Faulted: Max press <math>\leq 2.0</math> design press.</p> <p>(Press + Wt. + DBE + rupture) <math>P_L + P_b \leq 3.0 S_m</math></p> <p>Table 3.9-3 p. 3.9-18 Amend. 38</p>	<p>ASME BPVC Sec. III</p> <p>Sec. 3.8 p. 3.8-14 Rev. 13, 7-15-73</p> <p>ANSIB31.7 Sec. 3.9 Table 3.9-3 p. 3.9-18</p>





SEISMIC REVIEW TABLE

Docket Number

50-280, 281

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION	DESIGN SPECTRA				
	OBE		SSE				EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY mm	HOR. g	VERT. g						
<p>Surry Power Station Unit 1 &amp; 2</p> <p>Reactor type: PWR</p> <p>Containment type: sub-atmospheric (reinforced concrete)</p> <p>NSSS Manufacturer: Westinghouse</p> <p>Architect Engineer: Stone and Webster</p> <p>Unit 1: 6-68/5-72</p> <p>Unit 2: 6-68/1-73</p>	0.07	0.046	VII	0.15	0.10	<p>Synthetic time- history</p> <p>Q4.23, Supp. 1</p>	<p>For Class 1 Structures</p> <p>Hor. &amp; Vert.</p> <p>Combined  simultan- eously</p> <p>p. 15.2-16 B.1-1</p>	<p>SRSS</p> <p>Sup. Vol. 1 2.4.10 p. S4.10-2 10-15-70 &amp; Sup. Vol. 1 Q.4.12 p. S4.12-2 10-15-70</p>	<p>1) For frequencies higher than 2 cycles/ sec.</p> <p>Housner Spectra</p> <p>2) Frequency range between 0.3 cycles/ sec.</p> <p>Housner Average Spec- tra have been nor- malized to a max. ground velocity of about 4"/sec for O.B.E. and 9"/sec for P.B.E.</p> <p>3) For frequencies lower than about 0.3 cycles/sec. using data sugges- ted by Dr. Newmark &amp; Hall.</p> <p>Sec. 2.5.5 p. 2.5.5-9 Fig. 2.5-4, 2.5-5</p>	<p>The floor response spectra are encom- passed by the umbrel- la spectrum used in the dynamic analyses if Westinghouse sup- plied equipment.</p> <p>RCL analysis done with floor re- sponse spectra</p> <p>App. B, p. B.3-I</p> <p>Supp. Vol. 1 Q.4.10, Q 5.10, 4.12</p>	

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
<p>For Major Class I Struct. (except for the fuel building and main steam valve enclosure struct.); MAT Foundation. 10 ft. thick</p> <p>Pile foundation: turbine foundation spent fuel pit, mainsteam shielding, RWST</p> <p>Sec. 15.4 p. 15.4-8 Sec. 15.5 p. 15.5.1-1 p. 2.4.6-1</p>	<p>Surface Deposits of sand, silty sand thin layers of iron oxide-cement sands and clays of Norfolk Estuarine Formation</p> <p>Below this lies clays, compact sand and silt members, and shell fragments of the Chesapeake Formation</p>	<p>50'</p> <p>80'</p> <p>240'</p> <p>thickness varying from -16 msl to -47 msl</p> <p>*</p>	<p>Not available</p> <p>Sec. 2.5 p. 2.5.5-2</p> <p>TYPE - THICKNESS (cont.)</p> <p>* Below this thickness formations of Eocene 45' Paleocene 55' Cretaceous 800'</p> <p>Crystal-line Bedrock. Estimated at a depth of about 1300'</p> <p>Sec. 2.4 p. 2.4.2-2</p>	<p>18 wells within a five mile radius of the site. Depth from 280'~799'</p> <p>4 operating water wells on the site obtain water from the Eocene sediments at depth about 400'</p> <p>Part B Vol. 1 Sec. 2.3</p>	<p>NOT AVAILABLE</p>	<p>STICK MODEL</p> <p>with soil springs</p> <p>p. 15.5.1.4-2</p> <p>Append. B Sec. B.2 p. B.3-1</p>	<p>NOT AVAILABLE</p>	<p>O.B.E/S.S.E. 0.05/0.10</p> <p>This is an overall value which includes the damping in both the reinforced concrete structure and the damping.</p> <p>Sec. 15.5 p. 15.5.1.4-2 &amp; p. 15.5.1.4-3</p>	<p>O.B.E/S.S.E. 0.02/0.05</p> <p>Supp. Vol.1 Q. 5.22 p. S5.22-1</p>

SEISMIC REVIEW TABLE

STRUCTURES				
DAMPING OBE/SSE  (% of Crit. Damping)	DESIGN CRITERIA			
	LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES		
1) Containment Struct. & Foundation	5.0/10.0	1. Operating + DBA = $(1.0+0.05) D+1.5P+1.0 (T+TL)$	For Containment Struct. ACI 318-63 Part IV-B	
2) Steel Framed Struct. Including Supporting Struct. and Foundations		2. Operating + DBA + OBE = $(1.0+0.05) D+1.0P+1.0(T+TL) +1.5E$		
a) Bolted	2.5	3. Operating + DBA + DBE = $(1.0+0.05) D+1.0P+1.0(T+TL) +1.0E$		
b) Welded	1.0	4. Operating + 1.25DBA + 1.25OBE = $(1.0+0.05) D + (1.25p)+(T'+TL) +1.25E$		
3) Concrete Struct. Aboveground		5. Operating + Tornado Loading = $(1.0+0.05) D + 1.0T' + 1.0C$		
a) Shear-wall type	5.0			
b) Rigid-frame type	5.0			
Sec. 15.3 & Supp. Vol. 1		Sec. 15.5		Sec. 15.5 p. 15.5.1.2-2
p. 15.5.1.4-3	Q. 5.12	Table 15.5.1.2-1		
Sec. 15.2	P. S5.12-1	p. 15.5.1.2-4		
Table 15.2.4-1 p. 15.2-19		4-15-70		



SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
NOT AVAILABLE	<p>Tests Method. (This tests data is con- tained in WCAP- 7397-L Seismic Testing of Electrical and Control Systems Equipment)</p> <p>Supp. Vol. 1 Q.4.11 p. S4.11-1 B-15-71</p>	NOT AVAILABLE	NOT AVAILABLE



SEISMIC REVIEW TABLE

Docket Number  
50-289

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION	DESIGN SPECTRA			
	OBE		SSE		EARTHQUAKE TIME HISTORY		NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g						
CP/OL ISSUE DATE										
Three Mile Island Unit 1  Reactor type: PWR  Containment type: 6 buttresses with shallow dome (pre- stressed concrete)  NSSS Manufacturer: Babcock and Wilcox  Architect Engineer: Gilbert	0.06	0.04	VI	0.12	0.08	1957 Golden Gate Park - Average smooth revised with 1940 El Centro - nor- malized to ground acceleration of 0.06g.  Synthetic time- history for floor response spectra	Horizontal and vertical combined by abso- lute sum.	Piping: SRSS and modes 10% within each other are added absolutely.	Actual spectra en- velops Golden Gate and El Centro earthquake time histories.	Time-history method.  Gilbert Topical Report # 1729 "Dynamic Analysis of Vital Piping Systems Sub- jected to Seismic Motion."
5-68/4-74	Sec. 5.1.2.1.1 p. 5-10	Sec. 5.1.2.1.1 p. 5-10	Sec. 2.8.1 p. 2-41	Sec. 5.1.2.1.1 p. 5-10	Sec. 5.1.2.1. 1 p. 5-10	Sec. 2.7.1, p. 2-31 Sec. 2.8.2, p. 2-42	Sec. 5.2.4.1.2 p. 5-52	Sec. 5.4.5.1 p. 5-76a p. 5-52	Sec. 2-7, p. 2-31 Fig. 2-24 Fig 5-48	Sec. 5.4.5.1 p. 5-76a Fig. 5-49 through 5.54

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
Reinforced concrete mat foundation bearing on rock.  9 ft. thick with a 2 ft. thick concrete slab. Above the bottom liner plate.	sand and gravel  bedrock	14-19 ft.	Bedrock 8,500 to 11,500 fps.	Depth: between 14 and 19 ft.	Not available.	Stick model with fixed base	Not available.	Not available.	Not available.
Sec. 5.2, p. 5-11	Sec. 2.7.1 p. 2-30 Sec. 2.7.4.3 p. 2-37	Sec. 2.7.1 p. 2-30 Sec. 2.7.4.3 p. 2-37	Sec. 2.7.3.4 p. 2-34	Sec. 2.7.4.3 p. 2-37		Fig. 5-47			

SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING OBE/SSE (% critical damping)	DESIGN CRITERIA	
	LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Reactor Building: 2.0/2.0	a) $C = (1.0 \pm 0.05) D + 1.5P + 1.0T$ b) $C = (1.0 \pm 0.05) D + 1.25P + 1.0T + 1.25E$ c) $C = (1.0 \pm 0.05) D + 1.0P + 1.0T + 1.0E$ d) $C = (1.0 \pm 0.05) D + 1.0W_t + 1.0 P_t$	Reactor Building:
Concrete Equipment Supports: 2.0/3.0		ACI 318-63
Steel Framed Structure:		ACI 301-66 (modified)
a) Bolted or riveted 2.5/2.5		AISC Manual of Steel Construction
b) Welded 1.0/1.0		ASME BPVC Sect. III, VIII and IX
Prestressed concrete structures 2.0/5.0		ASA N 6.2-1965
Sec. 5.2.1.2.11 p. 5-18a	Sec. 5.2.3.2 p. 5-40	Sec. 5.2.3.1, p. 5-39 Sec. 5.2.2.4.1, p. 5-31


SEISMIC REVIEW TABLE

MECHANICAL & PIPING

DAMPING OBE/SSE (% critical damping)		METHOD OF QUALIFICATION	DESIGN CRITERIA	
			LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Vital Piping	0.5/0.5	Analytical and Testing	Design loads + DBE loads	ASME BPVC Sec. III USAS B31.1.0 USAS B31.7
Welded Steel Plate Assemblies	1.0/1.0		Design loads + SSE loads	
			Design loads + SSE loads + Pipe rupture	
			$P_m \leq S_m$ $P_L + P_b \leq 1.5 S_m$ $P_m + P_b \leq 1.2(1.5 S_m)$	
			$P_m \leq 2/3 S_u$ $P_L + P_b \leq 2/3 S_u$	
Sec. 5.2.1.2.11, p. 5-18a		p. 5-10 p. 5-76b	Sec. 4.1.2.5, p. 4-3	Table 4-2, p. 4-38; and Sec. 4.1.3, p.4-5

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	Not available.	Not available.	Not available.



SEISMIC REVIEW TABLE

Docket Number

50-320

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					EARTHQUAKE TIME HISTORY	METHOD OF COMBINATION		DESIGN SPECTRA	
	OBE		INTENSITY mm	SSE			NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g		HOR. g	VERT. g					
Three Mile Island Nuclear Station Unit 2 Reactor type: PWR Containment type: 6 buttresses with shallow dome (pre- stressed concrete) NSSS manufacturer: Babcock and Wilcox Architect Engineer: Burns and Roe  Unit 2: 11-69/5-78	0.06	0.04	VII	0.12	0.08	Golden Gate, 1957 El Centro, 1940 Synthetic time- history for floor response spectra  Sec 3.7.1.2 p. 3.7-1	Vertical & Horizontal Components were con- sidered to act simultan- eously	SRSS. Closely spaced modes com- bined di- rectly	Acceleration response Spectra for 1/2 SSE were partially devel- oped from "Golden Gate Park S.F. March 1957" Earthqk. Then it is modified in the low frequency region by the 1940 El Centro Earth- quake - normalized to basic ground mo- tion of 0.06g (OBE)  p. 2.5-11 Fig. 2.5-8	Time-History Method Using simulated ground motion.  Sec. 3.7.2.6 p. 3.7-5
	Sec 3.7.1.1 p. 3.7-1	Sec 3.7.2.8 p. 3.7-5		Sec 3.7.1.1 p. 3.7-1	Sec 3.7.2.9 p. 3.7-5		Sec 3.7.2.9 p. 3.7-5	Sec 3.7.3.4 p. 3.7-8	Sec. 3.7.1.2 p. 3.7-1	

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
The foundation slab is mild-steel reinforced circular mat Depth: 11 feet	The station is founded on un-weathered shales and sandstones of Gettysburg Formation.	NOT AVAILABLE	NOT AVAILABLE	Water levels occurred generally at a depth in excess of 15 ft & ranged from 14 to ft. The ground water level occurred at a max. 6.2 ft above the top of rock with less than one ft of head above the soil-rock interface at one pt. of observation.	No large dams exist immediately upstream of the site.	Stick model with rock springs	NOT AVAILABLE	NOT AVAILABLE	NOT AVAILABLE
Sec. 1.2.3.1.1 p. 1.2-3	Sec 2.5.1 p. 2.5-7	2.9		Sec 2.4.13.2 p. 2.4-26	Sec 2.4.4 p. 2.4-12	Sec 3.7.1.6 p. 3.7-3,4			


SEISMIC REVIEW TABLE

STRUCTURES								
DAMPING OBE/SSE  (% of critical damping)	DESIGN CRITERIA							ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
	LOAD COMBINATION							
Welded steel plate assemblies	1.0/1.0							1. ACI 318-63 ACI 318-71  2. AISC-1965
Welded steel framed structures	2.0/2.0							
Bolted steel framed structures(riveted)	2.5/2.5							
Reinforced concrete equipment supports	2.0/3.0							
Reinforced concrete frames & buildings	3.0/5.0							
Prestressed concrete structures	2.0/5.0							
Cable Tray Hangers (lateral direction)	5.0/10.0							Sec. 3.8.1.2 p. 3.8-2
<u>Unit Load</u>	<u>A</u>	<u>B</u>	<u>C</u>	<u>D</u>	<u>E</u>	<u>F</u>	<u>G</u>	
Dead load	0.95	0.90	0.95	0.87	0.95	0.95	0.90	
Int. pres.	1.50	1.25	1.25	1.00	-	1.00	1.00	
Prestress	1.0	1.0	1.0	1.0	1.0	1.0	1.0	
Wind load	-	-	1.25	-	-	-	-	
Tornado load	-	-	-	-	1.25	-	-	
Earthquake	-	0.81	-	1.0	-	-	0.81	
Thermal norm	1.25	1.25	1.25	1.25	1.25	1.25	1.25	
Accident	1.00	1.00	1.00	1.00	-	1.00	1.00	
Thermal incr.								
Table 3.7-1 p. 3.7-13	Table 3.8.-1,-2							

SEISMIC REVIEW TABLE

MECHANICAL & PIPING																	
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA															
		LOAD COMBINATION		ACCEPTANCE CRITERIA & ALLOWABLE STRESSES													
(% of critical damping)																	
Steel Piping	0.5/0.5	Analytical procedure 1. Equivalent Static Load Method 2. Dynamic Analysis Method	<table border="0" style="width: 100%;"> <tr> <td style="width: 30%;"></td> <td style="text-align: center;"><u>Components</u></td> <td style="text-align: center;"><u>Piping</u></td> <td></td> </tr> <tr> <td>I. Max Operating Loads + 1/2 SSE (upset)</td> <td style="text-align: center;"><math>P_m \leq 1.0S_m</math> <math>P_L + P_b \leq 1.5S_m</math></td> <td style="text-align: center;"><math>P_m \leq S_m</math> <math>P_L + P_b \leq 1.5S_m</math></td> <td rowspan="3" style="vertical-align: top;">1. ASME, B&amp;PV Code Section III 2. ANSI B31.7</td> </tr> <tr> <td>II. Max Operating Loads + SSE (emergency)</td> <td style="text-align: center;"><math>P_m \leq 1.2S_m</math> <math>P_L + P_b \leq 1.2(1.5S_m)</math></td> <td style="text-align: center;"><math>P_m \leq 1.2S_m</math> or <math>S_y</math> <math>P_L \leq 1.8S_m</math> or <math>1.5S_y</math> <math>P_L + P_b \leq 1.8S_m</math> or <math>1.5S_m</math></td> </tr> <tr> <td>III. Max Operating + SEE + Pipe Rupture Loads  Faulted</td> <td style="text-align: center;"><math>P_m \leq 2/3S_u</math> <math>P_L + P_b \leq 2/3S_u</math></td> <td style="text-align: center;"><math>P_m \leq</math> <math>P_L \leq 2/3S_u</math>  <math>P_L + P_b \leq</math></td> </tr> </table>		<u>Components</u>	<u>Piping</u>		I. Max Operating Loads + 1/2 SSE (upset)	$P_m \leq 1.0S_m$ $P_L + P_b \leq 1.5S_m$	$P_m \leq S_m$ $P_L + P_b \leq 1.5S_m$	1. ASME, B&PV Code Section III 2. ANSI B31.7	II. Max Operating Loads + SSE (emergency)	$P_m \leq 1.2S_m$ $P_L + P_b \leq 1.2(1.5S_m)$	$P_m \leq 1.2S_m$ or $S_y$ $P_L \leq 1.8S_m$ or $1.5S_y$ $P_L + P_b \leq 1.8S_m$ or $1.5S_m$	III. Max Operating + SEE + Pipe Rupture Loads  Faulted	$P_m \leq 2/3S_u$ $P_L + P_b \leq 2/3S_u$	$P_m \leq$ $P_L \leq 2/3S_u$  $P_L + P_b \leq$
	<u>Components</u>	<u>Piping</u>															
I. Max Operating Loads + 1/2 SSE (upset)	$P_m \leq 1.0S_m$ $P_L + P_b \leq 1.5S_m$	$P_m \leq S_m$ $P_L + P_b \leq 1.5S_m$	1. ASME, B&PV Code Section III 2. ANSI B31.7														
II. Max Operating Loads + SSE (emergency)	$P_m \leq 1.2S_m$ $P_L + P_b \leq 1.2(1.5S_m)$	$P_m \leq 1.2S_m$ or $S_y$ $P_L \leq 1.8S_m$ or $1.5S_y$ $P_L + P_b \leq 1.8S_m$ or $1.5S_m$															
III. Max Operating + SEE + Pipe Rupture Loads  Faulted	$P_m \leq 2/3S_u$ $P_L + P_b \leq 2/3S_u$	$P_m \leq$ $P_L \leq 2/3S_u$  $P_L + P_b \leq$															
Table 3.7-1 p. 3.7-13	Sec 3.9.1.2.1 p. 3.9-1,-2	<p>P = Primary bending stress  <math>P^n</math> = Primary local membrane stress  <math>P^L</math> = Primary general membrane stress  <math>S^m</math> = Allowable stress  <math>S^m</math> = Minimum yield strength at temp.  <math>S^y</math> = Ultimate strength of material at temp.                      For components: Table 3.6-1, p. 3.6-5                      Table 5.2-4, p. 5.2-34                      For piping: Table 5.2-3, p. 5.2-33</p>	Table 3.6-1 p. 3.6-5														





SEISMIC REVIEW TABLE

Docket Number  
50-344

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION	DESIGN SPECTRA				
	OBE		SSE				EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g						
<p>Trojan Nuclear Plant, Unit No. 1</p> <p>Reactor type: PWR</p> <p>Containment type: 3 buttresses with hemispherical dome (prestressed con- crete)</p> <p>NSSS Manufacturer: Westinghouse</p> <p>Architect Engineer: Bechtel</p> <p>2-71/ 11-75</p>	0.15	0.10	VIII	0.25	0.17	<p>Synthetic time history</p>	<p>Horizontal combined with verti- cal com- ponent</p> <p>combined absolutely</p>	SRSS	<p>Developed by Dr. I. M. Idriss for 2% critical damping. For other damping values Newmark's amplification factors were used.</p>	<p>For Westinghouse equipment: horizontal and ver- tical seismic were used. They were compared with the horizontal and vertical floor response spectra developed by Bechtel Corporation.</p> <p>Time-history used to generate re- sponse spectra</p> <p>BC-TOP-4</p>	
	<p>Sec. 2.5 p. 2.5 -19</p> <p>Sec. 3.7 p. 3.7-1</p>	<p>Sec. 3.7 p. 3.7-1</p>	<p>Sec. 2.5 p. 2.5-19</p>	<p>Sec. 3.7 p. 3.7-1</p>	<p>Sec. 3 .7 p. 3.7 -1</p>	<p>Sec. 3.7 p. 3.7-3</p>	<p>Sec. 3.7 p. 3.7-8 p. 3.7-12</p>	<p>Sec. 3.7 p. 3.7-22</p>	<p>Sec. 3.7 p. 3.7-2 Fig. 3.7-1 &amp; 3.7-2</p>	<p>Sec. 3.7 p. 3.7-31</p>	

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
For containment: Rigid base mat foundation. Depth is not available. Administration building supported by steel H-piles which go to rock 15 ft to 53 ft below grade. Sec. 3.7, p. 3.7-9 Sec. 3.7, p. 3.7-4	The site is underlain by bedrock and recent alluvium. The bedrock is volcanic in origin and consists principally of tuffs, breccias, agglomerates, and basalt flow. Alluvium consists of soft to very*	The thickness of the alluvium is considered to be close to 280ft. The upper approx. 80 to 100 ft of the alluvium: soft to very soft clayed silt. At 50 ft depth decomposed wood fragments and vegetation**	4500 fps to 5000 fps.  Sec. 2.5 p. 2.5-15  DEPTH(cont.) ** upper 25 ft to 35 ft. Predominately silty fine sand. All holes in the alluvium encountered principally soft clayed silt between 30 ft to 90 ft.	Wells vary in depth from 50 feet to over 200 feet.  Sec. 2.4 p. 2.4-54	Grand Coulee Dam at Columbia River mile 597.  Sec. 2.4 p. 2.4-33	The dynamic analysis was performed using stick model with fixed-base assumption. Results were compared with respect to flexible-base model and found to be conservative.  Sec. 3.7 p. 3.7-6	0.7 x 10 <sup>6</sup> psi  Sec. 2.5 p. 2.5-12	Not available.	Not available.
* soft clayed silt to silty clay with varying amounts of intermixed fine sand and layers of silty fine sand. Sec. 2.5, p. 2.5-9									

Sec. 2.5,  
p. 2.5-9

SEISMIC REVIEW TABLE

STRUCTURES			
DAMPING OBE/SSE		DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
	Stress Level		
	Low	Working	At yield point
Steel Structure			
Prestressed concrete	1.0	2.0	5.0
Reinforced concrete			
	$C=1/\phi \{(1.0 \pm 0.05)D + 1.5P + 1.0T_A + 1.0F\}$ $C=1/\phi \{(1.0 \pm 0.05)D + 1.25P + 1.0T_A + 1.0H_A + 1.25E + 1.0F\}$ $C=1/\phi \{(1.0 \pm 0.05)D + 1.25P + 1.0T_O + 1.25H_O + 1.25E + 1.0F\}$ $C=1/\phi \{(1.0 \pm 0.05)D + 1.0H_A + 1.0R + 1.0F + 1.25E + 1.0T_A\}$ $C=1/\phi \{(1.0 \pm 0.05)D + 1.25H_O + 1.0R + 1.0F + 1.25E + 1.0T_O\}$ $C=1/\phi \{(1.0 \pm 0.05)D + 1.0P + 1.0T_A + 1.0H_A + 1.0E' + 1.0F\}$ $C=1/\phi \{(1.0 \pm 0.05)D + 1.0P + 1.0T_O + 1.25H_O + 1.0E' + 1.0F\}$ $C=1/\phi \{(1.0 \pm 0.05)D + 1.0H_A + 1.0R + 1.0E' + 1.0F + 1.0T_A\}$ $C=1/\phi \{(1.0 \pm 0.05)D + 1.25H_O + 1.0R + 1.0E' + 1.0F + 1.0T_O\}$ $C=1/\phi \{(1.0 \pm 0.05)D + 1.0A + 1.0F + 1.0T_O\}$		ACI 315-65 ACI 318-63 AISC 6th edition (1967) ASCE paper no. 3269
	For the combinations of category I structures other than containment refer to p. 3.8-13.		
Sec. 3.7 Table 3.7-1 p. 3.7-3			Sec. 3.8 p. 3.8-38
			Sec. 3.8 p. 3.8-12, 33

SEISMIC REVIEW TABLE

MECHANICAL & PIPING														
DAMPING OBE/SSE (% critical damping)			METHOD OF QUALIFICATION	DESIGN CRITERIA										
				LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES									
<table border="1"> <thead> <tr> <th colspan="3">Stress Level</th> </tr> <tr> <th>Low</th> <th>Working</th> <th>At yield point</th> </tr> </thead> <tbody> <tr> <td>0.5</td> <td>0.5</td> <td>0.5</td> </tr> </tbody> </table>			Stress Level			Low	Working	At yield point	0.5	0.5	0.5	Analytical and testing.	<p>For reactor vessel internals: Normal+OBE &lt; ASME, BPVC Code, Sec. III for upset condition.</p> <p>For ANSI B31.7 Class II and III and ANSI B31.1.0 seismic category I piping systems: --For O.B.E.:</p> $S_T = S_{OBE} + S_{lp} + S_{wT} \leq 1.2S_h$ <p>where: <math>S_T</math> = maximum total longitudinal stress  <math>S_{OBE}</math> = maximum bending stress due to O.B.E.  <math>S_{lp}</math> = longitudinal pressure stress  <math>S_{wT}</math> = bending stress due to weight effect  <math>S_h</math> = basic material allowable stress at maximum (hot) temperature</p> <p>--For S.S.E.:</p> $S_{T(S.S.E.)} = S_{SSE} + S_{lp} + S_{wT} \leq 1.8S_h$ <p>where: <math>S_{T(S.S.E.)}</math> = maximum longitudinal stress  <math>S_{SSE}</math> = maximum bending stress due to SSE</p> <p>Sec. 3.7; p. 3.7-12; p. 3.7-26.</p>	<p>For reactor vessel internals: ASME, BPVC Code, Section III</p> <p>For piping: ANSI B31.7 and ANSI B31.1.0</p>
Stress Level														
Low	Working	At yield point												
0.5	0.5	0.5												
<p>Vital piping:</p>				<p>Sec. 3.7; p. 3.7-12 Sec. 3.7; p. 3.7-26</p>										





SEISMIC REVIEW TABLE

Docket Number  
50-250,251

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION	DESIGN SPECTRA				
	OBE		INTENSITY mm	SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g		HOR. g	VERT. g						
Turkey Point Plant Unit No. 3 & 4  Reactor type: PWR  Containment type: 6 buttresses with shallow dome (pre- stressed concrete)  NSSS Manufacturer: Westinghouse  Architect Engineer: Bechtel	0.05	0.033	VII	0.15	0.10	Synthetic time history	Vertical & Horizontal Components Applied Simultan- eously	SRSS (Response Spectrum Analysis) Sec. 5.1 p 5.1.3-13  For reactor internals Summing the Absolute values ob- tained for all modes.	The Response Spectra used are those based on TID-7074 scaled to the appropriate ground accel. (Fig. 5A-1 & 2) Ref. Report to the AEC Regulatory Staff. Dockets No. 50-250 & 50-251 by N. M. Newmark & W. J. Hall, p. 5)	TIME HISTORY METHOD	
Unit 3: 4-67/7-72 Unit 4: 4-67/4-73	Sec. 2.11 p. 2.11-2	Sec. 2.11 p. 2.11-2		Sec. 2.11 p. 2.11-2	Sec. 2.11 p. 2.11-2	p. 5.1.3-11	Appen. 5A p. 5A-12	Appen. 5A p. 5A-9b	Sec. 5.1 p. 5.1.3-13	Sec. 5.1 p. 5.1.3-11 REV. 5 - 8-28-70 6 - 10-2-70	

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT				SOIL - STRUCTURE INTERACTION					
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL % Critical Damping	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
For containment: reinforced concrete slab. Thickness: 10 ½ feet  Sec. 5.1 p. 5.1.2-1	Organic, Mangrove swamp soils overlies the Miami oolite bedrock formation which extends to about 20' below sea level (site elevation less than 10') Small voids and solution channels are present. Below this are the Fort Thompson*	4ft to 8ft of swamp soils - overlies the Miami oolite bedrock formation..  Extends to 70ft below sea level	NOT AVAILABLE  TYPE THICKNESS (cont.) * Formation (Limestone and calcareous sandstone The Tamiami Formation (clayey and calcareous marl indurated locally to limestone with beds of silty and shell sands) and the Hawthorne and Tampa Formations	UNCLEAR INFORMATION	NOT AVAILABLE	FIG. 5.1-13 indicates stick model with soil springs  p. 5.1.3-13	NOT AVAILABLE	O.B.E./S.S.E. Soil: 5.0/10.0  Vol. 1 Append. 5A p. 5A-13	Composite with Soil: 5.0/7.5

Tampa Formations  
Vol. 1, Sec. 2.9  
p. 2.9-4

**SEISMIC REVIEW TABLE**

<b>STRUCTURES</b>		
<b>DAMPING OBE/SSE</b>	<b>(% criti- cal damping)</b>	<b>DESIGN CRITERIA</b>
		<b>LOAD COMBINATION</b>
		<b>ACCEPTANCE CRITERIA &amp; ALLOWABLE STRESSES</b>
Welded steel framed structure:  Bolted steel framed structure:  Concrete equipment supports on another structure:  Prestressed concrete containment structure:  Prestressed containment including interior concrete and soil composite:  R.C. frames and buildings:	2.0/2.0  2.0/2.0  2.0/2.0  2.0/5.0  3.5/7.5  3.0/5.0	<p>For class I structure outside the containment structure:</p> $Y=1/\phi(1.25D+1.25E)$ $Y=1/\phi(1.25D+1.0R)$ $Y=1/\phi(1.25D+1.25H+1.25E)$ $Y=1/\phi(1.0D+1.0E')$ <p>where:</p> <p>Y = regular D yield strength of the structure.                      D = dead load of structure and equipment plus any other permanent loads contributing stress. In addition, a portion of "live load" is added when such load is expected to be present when the unit is operating.                      R = force or pressure on structure due to rupture of any one pipe.                      H = force on structure due to restrained thermal expansion of pipes under operating conditions.                      E = design earthquake load.                      E' = maximum earthquake load.                      W = wind load. (to replace E in the above load equation whenever it produces higher stresses than E does)  <math>\phi</math> = 0.9 for R.C. in flexure.  <math>\phi</math> = 0.85 for tension, shear, bond, and anchorage in R.C.  <math>\phi</math> = 0.75 for spirally R.C. comp. members</p> <p align="right">(cont.)</p>
		ACI 318-63  AISC Manual of Steel Construction (6th edition)  Append. 5A, p. 5A-5 Sec. 5.1, p. 5.1.8-1
		<p align="center"><b>LOAD COMBINATION (cont.)</b></p> $\phi$ = 0.70 for tied comp. members. $\phi$ = 0.9 for fabricated structure of steel.  Vol. 1, Append. 5A p. 5A-5

SEISMIC REVIEW TABLE

MECHANICAL & PIPING						
DAMPING OBE/SSE  (% of Critical Damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA			ACCEPTANCE CRITERIA & ALLOWABLE STRESSES	
		LOAD COMBINATION				
Welded Steel Plate Assemblies	1.0/1.0	For Class I - Analysis and testing	LOADING COMBINATIONS	VESSELS	PIPING	ASME BPVC Sec. III USAS B 31.1 Code for piping.
Steel Piping	0.5/0.5		Normal Loads	$P_m \leq S_m$ $P_L + P_B \leq 1.5 S_m$	$P_m \leq S_m$ $P_L + P_B \leq S$	
			Normal + Design Earthquake Loads	$P_m \leq S_m$ $P_L + P_B \leq 1.5 S_m$	$P_m \leq 1.2 S$ $P_L + P_B \leq 1.2 S$	
			Normal + Maximum Potential Earth- quake Loads	$P_m \leq 1.2 S_m$ $P_L + P_B \leq 1.2 (1.5 S_m)$	$P_m \leq 1.2 S$ $P_L + P_B \leq 1.2 S$	
			Normal + Pipe Rupture Loads	$P_m \leq 1.2 S_m$ $P_L + P_B \leq 1.2 (1.5 S_m)$	$P_m \leq 1.2 S$ $P_L + P_B \leq 1.2 S$	
Append. 5A p. 5A-13	Vol. 1 Append. 5A p. 5A-12 p. 5A-17		Append. 5A p. 5A-6, Table 5A-1		Append. 5A, Table 5A-1 p. 5A-8	





SEISMIC REVIEW TABLE

Docket Number  
50-271

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					EARTHQUAKE TIME HISTORY	METHOD OF COMBINATION		DESIGN SPECTRA	
	OBE		INTENSITY MM	SSE			NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g		HOR. g	VERT. g					
CP/OL ISSUE DATE										
Vermont Yankee Nuclear Power Station  Reactor type: BWR  Containment type: Mark I (steel)  NSSS Manufacturer: General Electric  Architect Engineer: Ebasco	0.07	0.046	V to low VII	0.14	0.093	1952 Taft earthquake N69°W	Each hor- izontal combined with the vertical simulta- neously, resulting two dis- tinct seismic cases.	SRSS	Housner spectra	Time-history method using earthquake N69°W component of Taft earthquake nor- malized to 0.07g (0.14g).  See also "addi- tional informa- tion concerning seismic analysis of piping" in App. I.
12-67/3-72	p. 2.5-9	p. 12.2-6		p.2.5-9	p.12.2-6	App. A	App. C, Sec. C.2.6 p.C.2-22	App. A p. A.5-6	See App. A., Sect. 5, Fig. 10	Question C-1, App. I, p. I.2-144

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT				SOIL - STRUCTURE INTERACTION					
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
<p>Concrete mat. depth is not available.</p> <p>All Class I structures except main stack are founded on bedrock. The main stack rests on end bearing steel piles which transfer the loads to the bedrock.</p> <p>Questions 12.18 12.19 12.22 App. I, p. I2-69</p>	<p>Glacial deposits from pleistocene age which consists of hard biotite gneiss. Rock type = Oliverian Plutonic Series Sec. 2.5.1.1, p. 2.5-1</p>	<p>30 ft. of glacial overburden above local bedrock.</p> <p>Sec. 2.5.1.1, p. 2.5-1</p>	<p>6,500 fps</p> <p>Sec. 2.5.2.5.2 p. 2.5-6</p>	<p>Unclear information (About @ El 230 and existing ground surface is @ 250 from boring logs presented in sec. 2.5)</p>	<p>1. Vernon Dam is about 3,500 ft. downstream.</p> <p>2. Other dams are 32, 75 and 132 miles upstream. But have relatively low heads from 29 to 62 ft.</p> <p>Sec. 2.4 p. 2.4-1</p>	<p>Lumped mass with soil springs</p> <p>Fig. 3, App. A.1</p>	<p>1.53 x 10<sup>6</sup> lb/in<sup>2</sup></p> <p>Sec. 2.5.2.5.2, p. 2.5-6</p>	<p>Not available</p>	<p>Not available</p>

SEISMIC REVIEW TABLE


STRUCTURES		
DAMPING OBE/SSE (% critical damping)	DESIGN CRITERIA	
	LOAD COMBINATION (Allowable Stress)	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
1. Reinforced concrete structures      5.0 2. Steel frame structure                      2.0 3. Bolted or riveted assembly              2.0	1. D + L + E  2. D + L + R + E' D + L + W'	1. Normal allowable code stresses are used. No increase in design stresses for the load combinations considered is premitted.  2. Yield stresses for ductile materials 0.85 times of ultimate strength concrete.
	D = Dead load ,                      R = Jet force or pressure due to L = Live load                              rupture of one pipe E = OBE E' = DBE                                      Sec. 12.2.1, p. 12.2-2	
	Note that no load factors were applied to the equations above because no plastic strength design for steel structures or ultimate strength design for concrete was used. "Allowable stress design."	
Sec. 12.2.1.2.1, p. 12.2-6	Question 12.15, App. I, p. I.2-66	Sec. 12.2.1, p. 12.2-1

SEISMIC REVIEW TABLE

MECHANICAL & PIPING			
DAMPING OBE/SSE (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
-Welded assembly (Equipment and supports) 1.0  -Vital Piping System 0.5	1. Analytical 2. Testing	<p><u>Primary containment</u></p> <p><u>L.C.</u></p> <p>Normal &amp; Upset</p> <ol style="list-style-type: none"> <li>DL</li> <li>Design pressure</li> <li>Design temperature</li> <li>Piping and mechanical loads</li> <li>Design basis earthquake</li> </ol> <p>Emergency condition loads</p> <ol style="list-style-type: none"> <li>Dead load</li> <li>Design pressure</li> <li>Design temperature</li> <li>Piping and mechanical loads</li> <li>Maximum hypothetical earthquake</li> </ol> <p>For flooded containment condition</p> <ol style="list-style-type: none"> <li>Dead weight</li> <li>Design basis earthquake</li> <li>Flooding water load</li> </ol> <p>App. C. pg. C.2-30</p>	<p><u>Stress Limit</u></p> <p>ASME B&amp;PV Code, Sect. III, Subsection B.                      Membrane stress intensity <math>S_A = 1.0 S_M = 17,500</math> psi                      Primary local membrane and bending:  <math>S_{limit} = 1.5 S_M = 26,250</math> psi</p> <p>Membrane plus secondary bending  <math>S_{limit} = 3.0 S_M = 52,500</math> psi</p> <p>Primary local stress = 90%                      of yield strength @ design                      temperature  <math>S_a = 0.90 \times 33,700 = 30,330</math> psi</p> <p>Primary local stress = 90%                      of yield strength @ 100°F  <math>S_a = 0.90 \times 38,000 = 34,200</math> psi</p>
Sec. 12.2.1.2.1, p. 12.2-6	App. C		

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available	Not available	Not available	Not available





SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
<p>"All structures and equipment should be founded on spread footings. Where there is possibility of heaving due to frost action, footings should be carried to a minimum depth of 5'-0" below ground surface"- summary of Stone and Webster's structural design requirements 10-17-57. General design of turbine generator foundation conform to "GET-1749A"- "turbine generator foundations" and Stone and Webster Reinforcing Standard for Turbine Supports ' 4-20-48</p> <p>"The plant is situated on medium to fine sands with some clay and silt, cobbles and boulders".</p>		Not available	Not available	Not available	Sherman Dam		No soil-structure Interaction analysis		

SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING OBE/SSE	DESIGN CRITERIA	
	LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
None used	"Neither structures nor equipment were classified into seismic categories, e.g., seismic category I or equivalent, but instead were classified as safety related or non-safety related. These systems were designed and analyzed in accordance with the design codes in effect in 1955. For structures, the design of lateral load restraint systems was dictated by wind requirements. No lateral force provisions were made for internal structures or equipment."	AISC American Standard Building Code requirements A58.1-1955 ACI 318-56 ASTM - specifications for structural steel for bridges. ASA A56.1 - 1952 Stone and Webster "Summary of Structural Design Requirements, Yankee Atomic Electric Co." J. O. No. 9699, October 1957.

SEISMIC REVIEW TABLE

MECHANICAL & PIPING			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
None used	None used	Not available	ASME B and PV Code, Section VIII "Unfired Pressure Vessels" 1955 and code case 1226  ASTM specification for A300 (Class A201, Grade B, Firebox Quality)

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
None used	None	"Electrical penetrations, control room systems, etc, were designed based on nuclear, mechanical and functional criteria. No provisions for lateral loads."	Not available



SEISMIC REVIEW TABLE

Docket Number  
50 - 295, 304

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION	DESIGN SPECTRA				
	OBE		SSE				EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g						
Zion Nuclear Plant Unit 1 and 2  Reactor type: PWR  Containment type: 6 buttresses with shallow dome (pre- stressed concrete)  NSSS Manufacturer: Westinghouse  Architect Engineer: Sargent and Lundy Engineers  Unit 1: 12-68/4-73 Unit 2: 12-68/11-73	0.08	0.05	VII	0.17	0.11	Compared with the 1940 El Centro (N-S) earthquake record with maximum ac- celeration of 0.08g.	Each hor- izontal was com- bined with the verti- cal com- ponents simulta- neously.	SRSS with closely spaced modes com- bined by absolute sum method (response spectrum)	Design response spectra using 1940 El Centro (N-S) earthquake record with maximum ac- celeration of 0.08g at the rock level.	Time-history method using 1940 El Centro (N-S) earthquake record.	
	p.2.11-2	p.2.11-2	Q.2.26-1	p.2.11-3	p.2.11-3	Amend. 18 Q.5.79	Amend. 14 Q.4.23	Amend. 14 Q.4.23	Amend. 19 Q.5.83	Amend. 14, Q. 4.25 Amend. 19, Q. 5.83	

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G <sub>s</sub> PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V <sub>s</sub> PROFILE						
Reinforced concrete slab 9ft thick  p. 5.1-5	The plant will be founded on relatively firm partly preconsolidated. Pleistocene glacial deposits. Formations below the site consist of: 1) 24-33 ft. of lake deposits-sand, gravel and pockets of peat and organic material. 2) Glacial deposits extending to a depth of 102-116 ft. below the surface - silt, clay, sand and gravel. 3) Niagara dolomite is 250' thick 4) Lower bedrock formations consists of sandstone and dolomite, some shale and siltstone layers. Several thousands of ft. thick. 5) Precambrian basement.*		Not available	Ground water is near the surface over much of the site area  p. 2.9-5	Not available	Aux. building was modelled as fixed base assumptions with lumped mass building model. Reactor building model has a rocking soil spring only. A comparison study was made with a soil model by finite element mesh.  Amend. 18 Q. 5.79 Amend. 14 Q.5.3,Q.4.23	Not available	Soil % critical damping: OBE 2 DBE 5  Q. 5.80	Not available

p. 2.9-4

\* Type and thickness of bearing information are presented together.

SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING OBE/SSE (% critical damping)	DESIGN CRITERIA	
	LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Reactor containment: 0.5/2.0	<p>1) <math>C = (1/\phi) (1.05 D + 1.25 P + 1.0 T + 1.25 E)</math>                      2) <math>C = (1/\phi) (1.05 D + 1.5 P + 1.0 T)</math>                      3) <math>C = (1/\phi) (1.05 D + 1.0 P + 1.0 T + E')</math></p> <p>C = Required yield strength of the structure as defined below                      D = Dead loads                      P = Design accident pressure                      T = Thermal loads due to the temperature gradient through the wall and expansion of the liner and based on a temperature corresponding to the factored design accident pressure                      E = Operating basis earthquake (OBE) load                      E' = Design basis earthquake (DBE) load                      W = Wind load  <math>\phi</math> = Capacity reduction factor</p>	<p>ACI Code 318-63                      refer to page 5.1-41                      for <math>\phi</math> values.</p> <p>AISC Manual of Steel Construction (6th Edition)</p>
Q. 4.23	p. 5.1-38	p. 5.1-41

SEISMIC REVIEW TABLE

MECHANICAL & PIPING				
DAMPING OBE/SSE (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA		ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
		LOAD COMBINATION		
		Pressure Vessels	Pressure Piping	
Piping  OBE = 0.5	Analytical and Testing	1) Normal condition a) $P_m \leq S_m$ b) $P_m \text{ (or } P_L) + P_B \leq 1.5 S_m$ c) $P_m \text{ (or } P_L) + P_B + Q \leq 3.0 S_m$	a) $P_m \leq S$ b) $P_m \text{ (or } P_L) + P_B \leq S$	ASME B&PV Code Section III, Nuclear Vessels for limit curves: WCAP 5890, Rev. 1
		2) Upset condition a) $P_m \leq S_m$ b) $P_m \text{ (or } P_L) + P_B \leq 1.5 S_m$ c) $P_m \text{ (or } P_L) + P_B + Q \leq 3.0 S_m$	a) $P_m \leq 1.2 S$ b) $P_m \text{ (or } P_L) + P_B \leq 1.2 S$	
		3) Emergency condition a) $P_m \leq 1.2 S_m$ or $S_y$ whichever is larger b) $P_m \text{ (or } P_L) + P_B \leq 1.5$ ( $1.2 S_m$ ) or $1.5 S_y$ which- ever is larger	a) $P_m \leq 1.2 S$ b) $P_m \text{ (or } P_L) + P_B \leq 1.5 (1.2 S)$	
		4) Faulted condition Design limit curves as discussed in the text	Design limit curves as discussed in the text	
	Appendix D Amend. 14 Q. 4.23 p. Q4.23-3	$P_m$ = Primary general membrane stress intensity $P_L$ = Primary local membrane stress intensity $P_B$ = Primary bending stress intensity $Q$ = Secondary stress intensity $S_m$ = Stress intensity from ASME B&PV Code, Section III, nuclear vessels $S_y$ = Minimum specified material yield (ASME B&PV Code, Section III, Table N-421 or equivalent) $S$ = Allowable stress from USASI B31.1 Code for pressure piping. Table B1-2, Appendix D		Appendix D

P. Q. §.32-1

SEISMIC-REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available	Not available	Not available	Not available



<b>NRC FORM 335</b> (7-77)		<b>U.S. NUCLEAR REGULATORY COMMISSION</b> <b>BIBLIOGRAPHIC DATA SHEET</b>		<b>1. REPORT NUMBER (Assigned by DDC)</b> NUREG/CR-1429	
<b>4. TITLE AND SUBTITLE (Add Volume No., if appropriate)</b> Seismic Review Table		<b>2. (Leave blank)</b>		<b>3. RECIPIENT'S ACCESSION NO.</b>	
<b>7. AUTHOR(S)</b> M. Subudhi, J. Lane, M. Reich, B. Koplik		<b>5. DATE REPORT COMPLETED</b> MONTH   YEAR April   1980		<b>DATE REPORT ISSUED</b> MONTH   YEAR May   1980	
<b>9. PERFORMING ORGANIZATION NAME AND MAILING ADDRESS (Include Zip Code)</b> Brookhaven National Lab Upton, N.Y. 11973		<b>6. (Leave blank)</b>		<b>8. (Leave blank)</b>	
<b>12. SPONSORING ORGANIZATION NAME AND MAILING ADDRESS (Include Zip Code)</b> U.S. Nuclear Regulatory Commission Division of Operating Reactors Seismic Review Group Washington, D. C. 20555		<b>10. PROJECT/TASK/WORK UNIT NO.</b>		<b>11. CONTRACT NO.</b> FIN No. A3326	
<b>13. TYPE OF REPORT</b> Final		<b>PERIOD COVERED (Inclusive dates)</b> October 1979-April 1980			
<b>15. SUPPLEMENTARY NOTES</b>		<b>14. (Leave blank)</b>			
<b>16. ABSTRACT (200 words or less)</b> The Seismic Review Table is a summary of Engineering Design parameters that were employed in the seismic analysis and design of nuclear power plants. The table covers 71 reactors licensed to operate by the U.S.N.R.C. The information contained is listed plant by plant and consists of <u>OBE and SSE "g" level and Modified Mercalli Intensity; Earthquake Time History used to develop the ground response spectra or as input in the dynamic analysis; Number of Earthquake Components used and Method of Combining Them; Method of Modal Combination; Type of Ground Design Spectra; Method of Generation of Floor Response Spectra; Type of Foundation and Depth; Type, Thickness, Shear Wave Velocity and Shear Modulus Profile of the Surrounding Sub-grade Soil and Bedrock; Ground Water Table Depth; nearby Dams; Modelling Method used for soil-structure interaction; Material Damping of Soil; Limitation on Modal Damping. Damping Values and Loading Combinations, and Acceptance Criteria for Category I Structures, Mechanical Equipment, Piping, and Electrical systems.</u> The goal of the Seismic Review Table is to provide a reference of the available information relevant to the seismic design of currently licensed nuclear power plants.					
<b>17. KEY WORDS AND DOCUMENT ANALYSIS</b>		<b>17a. DESCRIPTORS</b>			
seismic data, earthquake design, dynamic analysis, soil-structure interaction load combinations, design criteria					
<b>17b. IDENTIFIERS/OPEN-ENDED TERMS</b>					
<b>18. AVAILABILITY STATEMENT</b> Unlimited		<b>19. SECURITY CLASS (This report)</b> unclassified		<b>21. NO. OF PAGES</b>	
		<b>20. SECURITY CLASS (This page)</b> unclassified		<b>22. PRICE</b> S	









UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

OFFICIAL BUSINESS  
PENALTY FOR PRIVATE USE, \$300

POSTAGE AND FEES PAID  
U.S. NUCLEAR REGULATORY  
COMMISSION

