



CONTROLLED DEVICE IN IX-IR-008-A	FUNCTION / SLOT						SSCS CID DRAWING NUMBER
	PLOP	PSUM	PSUV	PTG 1	PTG 2	PTG 3	
VA-MAHU-181-A	33						2GB0910-VA-21
KE-MPMP-002-A	63	60	60		60		2GB0910-KE-15
*OVC-MACU-184-A						44	2GB0910-VC-04
VB-MFAN-001-A						41	2GB0910-VB-04
VB-MFLT-009-A						43	2GB0910-VB-05
VITAL CONT PWR	56	56	56			56	2GB0910-IL-08
TIE CB & MCC SHEDS	65						2GB0910-IL-10
EG-AUX PWR DISTR SYS	21						2AW0900-EG-01
NV-MPMP-002-A	05	01	29	02, 03, 29			2GW0910-NV-01
RT-EGEN-001-A			28				2GB0910-RT-05

* UNIT 1 ONLY ** UNIT 2 ONLY

APERTURE
CARD

3 1169, 1170, 1171, 1172, 1173, 1174, 1175, 1176, 1177, 1178, 1179, 1180, 1181, 1182, 1183, 1184, 1185, 1186, 1187, 1188, 1189, 1190, 1191, 1192, 1193, 1194, 1195, 1196, 1197, 1198, 1199, 1200

REVISED SLOT ASSIGNMENTS PER ECN 1169.
CHANGED TIMING GROUP OF SLOT 60 - ECN 1170.

CORRECTED AS NOTED

POWERHOUSE
UNITS 1 & 2

SSCS CIRCUIT
INTERFACE DIAGRAM
LOAD SEQUENCER

BELLEFONTE NUCLEAR PLANT
TENNESSEE VALLEY AUTHORITY
DIVISION OF ENGINEERING & MAINTENANCE

DATE: 8/20/82

BY: [Signature]

APPROVED: [Signature]

NO. 2680910-IL-15 R3

Docket # 50-438
Contract # 8002080064
Date 8/20/82

