

From: Gibson, Lauren
Sent: Friday, April 01, 2011 11:57 AM
To: 'Russell.Stroud@aps.com'
Cc: Hall, Randy
Subject: Draft Request for Additional Information- Revision of Feedwater Line Break with Loss of Offsite Power and Single Failure Analysis (TAC Nos. ME4596,7,8)
Attachments: RAIs 2 ME4596,7,8.pdf

April 1, 2011

Mr. Russell A. (Rusty) Stroud
Licensing Section Leader
Regulatory Affairs
Palo Verde Nuclear Generating Station
Arizona Public Service Company

Rusty,

By a letter dated August 27, 2010 (Agencywide Documents Access and Management System (ADAMS) Accession No.ML102510161), Arizona Public Service Company (APS) requested a license amendment to Operating Licenses NPF-41, NPF-51, and NPF-74, for Palo Verde Nuclear Generating Station (PVNGS) Units 1, 2, and 3 respectively, to allow credit for reducing the available time for an existing manual operator action to initiate pressurizer level control. The revised analysis would assume that the action is initiated at twenty minutes into the scenario as opposed to the current assumption of thirty minutes. The staff requested additional information in its letter dated December 21, 2010 (ADAMS Accession No.ML103500510). The licensee responded with supplementary information in its submittal dated February 11, 2011 (ADAMS Accession No. ML110550323).

The NRC staff has reviewed the information provided by APS and determined that the additional information requested in the attachment to this e-mail message is needed to complete its review of the LAR. In order to complete our review of the LAR in a timely manner, please submit your response to the attached RAI by May 2, 2011. Please contact me if APS would like to have a conference call to discuss this second request for additional information.

Sincerely,

Lauren Gibson, Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation
USNRC
(301) 415-1056
Lauren.Gibson@nrc.gov