

Attachment 2

W3F1-2011-0021

Proposed Waterford 3 Operating License Change (mark-up)

- (a) The first performance of SR 6.5.17, in accordance with Specification 6.5.17.c.(i), shall be within the specified Frequency of 6 years, plus the 18-month allowance of SR 4.0.2, as measured from April 17, 2004, the date of the most recent successful tracer gas test, as stated in the October 8, 2004 letter response to Generic Letter 2003-01, or within the next 18 months if the time period since the most recent successful tracer gas test is greater than 6 years.
 - (b) The first performance of the periodic assessment of CRE habitability, Specification 6.5.17.c.(ii), shall be within 3 years, plus the 9-month allowance of SR 4.0.2, as measured from April 17, 2004, the date of the most recent successful tracer gas test, as stated in the October 8, 2004 letter response to Generic Letter 2003-01, or within the next 9 months if the time period since the most recent successful tracer gas test is greater than 3 years.
 - (c) The first performance of the periodic measurement of CRE pressure, Specification 6.5.17.d, shall be within 18 months, plus the 138 days allowed by SR 4.0.2, as measured from August 13, 2008, the date of the most recent successful pressure measurement test, or within 138 days if not performed previously.
- D. The facility requires an exemption from certain requirements of Appendices E and J to 10 CFR Part 50. These exemptions are described in the Office of Nuclear Reactor Regulation's Safety Evaluation Report, Supplement No. 10 (Section 6.1.2) and Supplement No. 8 (Section 6.2.6), respectively. These exemptions are authorized by law and will not endanger life or property or the common defense and security and are otherwise in the public interest. These exemptions are, therefore, hereby granted pursuant to 10 CFR 50.12. With the granting of these exemptions, the facility will operate, to the extent authorized herein, in conformity with the application, as amended, the provisions of the Act, and the rules and regulations of the Commission.
- E. EOI shall fully implement and maintain in effect all provisions of the Commission-approved physical security, training and qualification, and safeguards contingency plans including amendments made pursuant to provisions of the Miscellaneous Amendments and Search Requirements revisions to 10 CFR 73.55 (51 FR 27817 and 27822) and to the authority of 10 CFR 50.90 and 10 CFR 50.54(p). The plan, which contains Safeguards Information protected under 10 CFR 73.21, is entitled: "Physical Security, Safeguards Contingency and Training & Qualification Plan," and was submitted on October 4, 2004.

EOI shall fully implement in accordance with an NRC-approved implementation schedule and maintain in effect all provisions of the Commission-approved Waterford 3 Cyber Security Plan pursuant to 10 CFR 73.55(c)(6) and 10 CFR 73.54 (74 FR 13970) and to the authority of 10 CFR 50.90 and 10 CFR 50.54(p).

Attachment 3

W3F1-2011-0021

Revised Waterford 3 Operating License Page

- (a) The first performance of SR 6.5.17, in accordance with Specification 6.5.17.c.(i), shall be within the specified Frequency of 6 years, plus the 18-month allowance of SR 4.0.2, as measured from April 17, 2004, the date of the most recent successful tracer gas test, as stated in the October 8, 2004 letter response to Generic Letter 2003-01, or within the next 18 months if the time period since the most recent successful tracer gas test is greater than 6 years.
 - (b) The first performance of the periodic assessment of CRE habitability, Specification 6.5.17.c.(ii), shall be within 3 years, plus the 9-month allowance of SR 4.0.2, as measured from April 17, 2004, the date of the most recent successful tracer gas test, as stated in the October 8, 2004 letter response to Generic Letter 2003-01, or within the next 9 months if the time period since the most recent successful tracer gas test is greater than 3 years.
 - (c) The first performance of the periodic measurement of CRE pressure, Specification 6.5.17.d, shall be within 18 months, plus the 138 days allowed by SR 4.0.2, as measured from August 13, 2008, the date of the most recent successful pressure measurement test, or within 138 days if not performed previously.
- D. The facility requires an exemption from certain requirements of Appendices E and J to 10 CFR Part 50. These exemptions are described in the Office of Nuclear Reactor Regulation's Safety Evaluation Report, Supplement No. 10 (Section 6.1.2) and Supplement No. 8 (Section 6.2.6), respectively. These exemptions are authorized by law and will not endanger life or property or the common defense and security and are otherwise in the public interest. These exemptions are, therefore, hereby granted pursuant to 10 CFR 50.12. With the granting of these exemptions, the facility will operate, to the extent authorized herein, in conformity with the application, as amended, the provisions of the Act, and the rules and regulations of the Commission.
- E. EOI shall fully implement and maintain in effect all provisions of the Commission-approved physical security, training and qualification, and safeguards contingency plans including amendments made pursuant to provisions of the Miscellaneous Amendments and Search Requirements revisions to 10 CFR 73.55 (51 FR 27817 and 27822) and to the authority of 10 CFR 50.90 and 10 CFR 50.54(p). The plan, which contains Safeguards Information protected under 10 CFR 73.21, is entitled: "Physical Security, Safeguards Contingency and Training & Qualification Plan," and was submitted on October 4, 2004.

EOI shall fully implement in accordance with an NRC-approved implementation schedule and maintain in effect all provisions of the Commission-approved Waterford 3 Cyber Security Plan pursuant to 10 CFR 73.55(c)(6) and 10 CFR 73.54 (74 FR 13970) and to the authority of 10 CFR 50.90 and 10 CFR 50.54(p).