Summary of Stress Analysis Results for the US-APWR Reactor Coolant Pump

Non-Proprietary Version

March 2011

©2011 Mitsubishi Heavy Industries, Ltd.

All Rights Reserved

Mitsubishi Heavy Industries, LTD.

Revision History

| Revision | Page | Description | | | | |
|----------|------------------|---|--|--|--|--|
| 0 | All | Original Issue | | | | |
| | Abstract | - Changed sentences. | | | | |
| | i, ii | - Revised table of contents and page numbers. | | | | |
| | iii, iv | - Revised list of tables and page numbers. | | | | |
| | v | - Revised list of figures and page numbers. | | | | |
| | 1-1 | - Changed sentences. | | | | |
| | 1-2 | - Revised evaluated parts in Figure 1-1. | | | | |
| 1 | 2-1 | - Deleted analysis results of Seal Water Injection Nozzle, and revised analysis results. | | | | |
| | 7-1 | - Revised document number in Tables 7-1 and deleted material of Seal Water Injection Nozzle in Table 7-2. | | | | |
| | 7-3 and 7-4 | - Revised material properties and Table numbers. | | | | |
| | 7-5 | - Revised Table numbers. | | | | |
| | 7-7 through 7-18 | - Revised external loads. | | | | |
| | 7-19 | - Revised Table number. | | | | |
| | 7-21 | - Revised Table number. | | | | |
| | 8-2 | - Added program in Figure 8-1 | | | | |

Revision History (Cont'd)

| Revision | Page | Description | | |
|----------|-------------------------------|--|--|--|
| | 9-1 | - Revised program revisions and added program in Table 9-1 | | |
| 1 | 10-1 through 10-3 and 10-5 | - Deleted analysis results of Seal Water Injection Nozzle, and revised analysis method and analysis results. | | |
| | 11-1 | - Revised revisions of references. | | |
| | i, ii | - Revised table of contents and page numbers. | | |
| | iv | - Revised list of tables and page numbers. | | |
| 2 | v | - Revised list of figures and page numbers. | | |
| | 1-1 | - Modified sentences. | | |
| | 2-1 | - Added evaluation results. | | |
| | 7-1 | - Revised document number in Tables 7-1. | | |
| | 7-6 | - Modified sentences. | | |
| | 10-1 through 10-24 | - Added analysis results. | | |
| | 10-25 | - Changed table format. | | |
| | 11-1 | - Corrected typo and revised revisions of references. | | |

© 2011

MITSUBISHI HEAVY INDUSTRIES, LTD.

All Rights Reserved

This document has been prepared by Mitsubishi Heavy Industries, Ltd. ("MHI") in connection with the U.S. Nuclear Regulatory Commission's ("NRC") licensing review of MHI's US-APWR nuclear power plant design. No right to disclose, use or copy any of the information in this document, other than by the NRC and its contractors in support of the licensing review of the US-APWR, is authorized without the express written permission of MHI.

This document contains technology information and intellectual property relating to the US-APWR and it is delivered to the NRC on the express condition that it not be disclosed, copied or reproduced in whole or in part, or used for the benefit of anyone other than MHI without the express written permission of MHI, except as set forth in the previous paragraph.

This document is protected by the laws of Japan, U.S. copyright law, international treaties and conventions, and the applicable laws of any country where it is being used.

MITSUBISHI HEAVY INDUSTRIES, LTD. 16-5, Konan 2-chome, Minato-ku Tokyo 108-8215 Japan

<u>Abstract</u>

This report contains a summary of the results of the structural evaluation of the Reactor Coolant Pump (RCP) parts.

The results presented are based on calculations that were performed using the loading conditions defined in the US-APWR Reactor Coolant Pump ASME Design Specification (Reference 4) and on the procedures per ASME Boiler & Pressure Vessel Code Section III (Reference 1).

The RCP satisfies all of the applicable structural limits of the 2001 Edition of Section III of the ASME Code up to and including the 2003 addenda (Reference 1).

Table of Contents

| 1.0 | INTR | RODUCTION | 1-1 |
|------|------|---|------|
| 2.0 | SUM | MARY OF RESULTS | 2-1 |
| 3.0 | CON | CLUSIONS | 3-1 |
| 4.0 | NOM | IENCLATURE | 4-1 |
| 5.0 | ASSI | UMPTIONS AND OPEN ITEMS | 5-1 |
| | 5.1 | Assumptions | 5-1 |
| | 5.2 | Open Items | 5-1 |
| 6.0 | ACC | EPTANCE CRITERIA | 6-1 |
| 7.0 | DES | IGN INPUT | 7-1 |
| | 7.1 | Geometry | 7-1 |
| | 7.2 | Material | 7-1 |
| | 7.3 | Loads, Load Combinations, and Transients | 7-6 |
| | | 7.3.1 Pressure Loads and Temperature | 7-6 |
| | | 7.3.2 External Mechanical Loads | 7-6 |
| | | 7.3.3 Thermal and Pressure Transient Loads | 7-19 |
| | | 7.3.4 Load Combinations | 7-21 |
| 8.0 | MET | HODOLOGY | 8-1 |
| | 8.1 | Heat Transfer Coefficients and Thermal Analysis | 8-1 |
| | 8.2 | Stress Analysis | 8-1 |
| | 8.3 | Fatigue Analysis Model and Method | 8-3 |
| 9.0 | COM | IPUTER PROGRAMS USED | 9-1 |
| 10.0 | STR | UCTURAL ANALYSIS RESULTS | 10-1 |
| | 10.1 | Pump Casing Lugs | 10-1 |
| | | 10.1.1 Pump Casing Lugs Modeling and Analysis | 10-1 |

| | | 10.1.2 Pump Casing Lugs Stress Results10-4 |
|------|------|--|
| | 10.2 | Discharge Nozzle10-5 |
| | | 10.2.1 Discharge Nozzle Modeling and Analysis10-5 |
| | | 10.2.2 Discharge Nozzle Stress Results |
| | 10.3 | Suction Nozzle10-9 |
| | | 10.3.1 Suction Nozzle Modeling and Analysis10-9 |
| | | 10.3.2 Suction Nozzle Stress Results10-12 |
| | 10.4 | Main Flange10-13 |
| | | 10.4.1 Main Flange Modeling and Analysis10-13 |
| | | 10.4.2 Main Flange Stress Results10-16 |
| | 10.5 | No.1 and 2 Seal Housings10-17 |
| | | 10.5.1 Seal Housings Modeling and Analysis10-18 |
| | | 10.5.2 Seal Housings Stress Results10-19 |
| | 10.6 | Diffuser Flange |
| | | 10.6.1 Diffuser Flange Modeling and Analysis10-21 |
| | | 10.6.2 Diffuser Flange Stress Results |
| | 10.7 | Heat Exchanger Tubing10-23 |
| | | 10.7.1 Heat Exchanger Tubing Modeling and Analysis |
| | | 10.7.2 Heat Exchanger Tubing Stress Results |
| 11.0 | REFE | ERENCES |

List of Tables

| Table No. | Title | Page |
|------------|---|------|
| Table 2-1 | Summary of Most Limiting Results | 2-1 |
| Table 6-1 | Class 1 Component Stress Limits (other than Bolts) | 6-1 |
| Table 6-2 | Class 1 Bolt Stress Limits | 7-2 |
| Table 7-1 | RCP Basic Design Drawing List | 7-1 |
| Table 7-2 | Materials of Construction | 7-1 |
| Table 7-3 | Material Properties for SA-351 Grade CF8 | 7-2 |
| Table 7-4 | Material Properties for SA-213 Type 316 | 7-2 |
| Table 7-5 | Material Properties for SA-182 Grade F316(t \leq 5) | 7-3 |
| Table 7-6 | Material Properties for SA-182 Grade F316(t > 5) | 7-3 |
| Table 7-7 | Material Properties for SA-182 Grade F304(t \leq 5) | 7-4 |
| Table 7-8 | Material Properties for SA-182 Grade F304(t >5) | 7-4 |
| Table 7-9 | Material Properties for SA-540 Grade B24 Class 2 | 7-5 |
| Table 7-10 | 0 Material Properties for SA-540 Grade B24 Class 4 | 7-5 |
| Table 7-12 | 1 Pressures and Temperatures | 7-6 |
| Table 7-12 | 2-1 Loads Applied to the Pump Casing Lug #1 (1/2) | 7-7 |
| Table 7-12 | 2-2 Loads Applied to the Pump Casing Lug #1 (2/2) | 7-8 |
| Table 7-12 | 2-3 Loads Applied to the Pump Casing Lug #2 (1/2) | 7-9 |
| Table 7-12 | 2-4 Loads Applied to the Pump Casing Lug #2 (2/2) | 7-10 |
| Table 7-12 | 2-5 Loads Applied to the Pump Casing Lug #3 (1/2) | 7-11 |
| Table 7-12 | 2-6 Loads Applied to the Pump Casing Lug #3 (2/2) | 7-12 |
| Table 7-13 | 3 Loads Applied to the Discharge Nozzle (1/2) | 7-13 |
| Table 7-14 | 4 Loads Applied to the Discharge Nozzle (2/2) | 7-14 |

| Table 7-15 Loads Applied to the Suction Nozzle (1/2) | 7-15 |
|---|-------|
| Table 7-16 Loads Applied to the Suction Nozzle (2/2) | 7-16 |
| Table 7-17 Loads Applied to the Lower Motor Stand (1/2) | 7-17 |
| Table 7-18 Loads Applied to the Lower Motor Stand (2/2) | 7-18 |
| Table 7-19 Design Transients | 7-19 |
| Table 7-20 Load Combinations | 7-21 |
| Table 9-1 Computer Program Description | 9-1 |
| Table 10-1 Summary of Results for Pump Casing Lugs (1/2) | 10-4 |
| Table 10-1 Summary of Results for Pump Casing Lugs (2/2) | 10-5 |
| Table 10-2 Summary of Results for Discharge Nozzle (1/2) | 10-8 |
| Table 10-2 Summary of Results for Discharge Nozzle (2/2) | 10-9 |
| Table 10-3 Summary of Results for Suction Nozzle (1/2) | 10-12 |
| Table 10-2 Summary of Results for Suction Nozzle (2/2) | 10-13 |
| Table 10-4 Summary of Results for Main Flange | 10-16 |
| Table 10-5 Summary of Results for Seal Housings | 10-19 |
| Table 10-6 Summary of Results for Diffuser Flange | 10-22 |
| Table 10-7-1 Summary of Results for Heat Exchanger Tubing | 10-25 |

List of Figures

| Figure No. | Title | Page |
|---------------|--|-------|
| Figure 1-1 | Reactor Coolant Pump Component and Evaluated Parts | 1-2 |
| Figure 8-1 | Stress Evaluation Process | 8-2 |
| Figure 10.1-1 | Pump Casing Lug Dimensions | 10-2 |
| Figure 10.1-2 | Pump Casing Lug Finite Element Model | 10-3 |
| Figure 10.2-1 | Discharge Nozzle Dimensions | 10-6 |
| Figure 10.2-2 | Discharge Nozzle Finite Element Model | 10-7 |
| Figure 10.3-1 | Suction Nozzle Dimensions | 10-10 |
| Figure 10.3-2 | Suction Nozzle Finite Element Model | 10-11 |
| Figure 10.4-1 | Main Flange Dimensions | 10-14 |
| Figure 10.4-2 | Main Flange Finite Element Model | 10-15 |
| Figure 10.5-1 | Seal Housings Dimensions | 10-17 |
| Figure 10.5-2 | Seal Housings Finite Element Model | 10-18 |
| Figure 10.6-1 | Diffuser Flange Dimensions | 10-20 |
| Figure 10.6-2 | Diffuser Flange Finite Element Model | 10-21 |
| Figure 10.7-1 | Heat Exchanger Tube Dimensions | 10-23 |
| Figure 10.7-2 | Heat Exchanger Tubing Finite Element Model | 10-24 |

List of Acronyms

The following list defines the acronyms used in this document.

| DCD | Design Control Document |
|------|---------------------------------------|
| FEA | Finite Element Analysis |
| FSRF | Fatigue Strength Reduction Factor |
| LOCA | Loss-of-Coolant Accident |
| RCP | Reactor Coolant Pump |
| RCS | Reactor Coolant System |
| RT | Radiographic Examination |
| SRSS | Square Root of the Sum of the Squares |
| SSE | Safe Shutdown Earthquake |

1.0 INTRODUCTION

This Technical Report was prepared in support of the US-APWR DCD review process. It contains a summary of the results of the stress and fatigue analyses of the US-APWR Reactor Coolant Pump (RCP). Fracture mechanics analysis was not performed since the pressure retaining parts are all made of austenitic stainless steels. The content of this report follows the ASME guidelines for Design Reports (Section III Division 1 Appendix C).

Figure 1-1 shows the general configuration of the US-APWR RCP.

This report provides structural evaluations for seven RCP parts. The seven evaluated RCP parts are listed in Table 2-1. This Technical Report summarizes the results of detailed RCP stress, fatigue and fracture mechanics analyses and demonstrates that the RCP components evaluated meet the requirements of the Design Specification (Reference 4).





2.0 SUMMARY OF RESULTS

The structural analysis results for each of these parts are listed in Section 10. The most limiting results for each part that was evaluated are listed in Table 2-1, below.

| Section | Evaluated Part | Max Stress / Allowable Ratio | Highest Fatigue Usage Factor (note 2) |
|---------|------------------------------|---------------------------------|---|
| 10.1 | Pump Casing Lugs | $\left(\right)$ | |
| 10.2 | Discharge Nozzle | | |
| 10.3 | Suction Nozzle | | |
| 10.4 | Main Flange | | |
| 10.5 | Seal Housing (No.1 and No.2) | | |
| 10.6 | Diffuser Flange | | |
| 10.7 | Heat Exchanger Tubing | | |

 Table 2-1
 Summary of Most Limiting Results

Note-1 The allowable ratio is the "ratio" of the calculated stress intensity to the allowable stress intensity. Therefore, any ratio less than or equal to 1.0 is acceptable.

 $Ratio = \frac{Calculated \cdot Stress \cdot Integrationsity}{Allowable \cdot Stress \cdot Intensity}$

Note-2 The fatigue calculations performed in this report meet the requirements of the ASME code. Environmental fatigue per RG 1.207 will be evaluated separately.

3.0 CONCLUSIONS

The US-APWR RCP is designed to the requirements of the ASME Boiler and Pressure Vessel Code, 2001 Edition up to and including the 2003 Addenda for the Design, Service Loadings, Operating Conditions, and Test Conditions as specified in the Design Specification (Reference 4).

From the results summarizes in this report and a review of the component design drawings, it is concluded that the US-APWR RCP satisfies all of the requirements of the Design Specification.

4.0 NOMENCLATURE

| Symbol | Unit | Definition | | |
|----------------|-----------------|--|--|--|
| Pm | ksi | General Primary Membrane Stress | | |
| P_{L} | ksi | Local Primary Membrane Stress | | |
| Pb | ksi | Primary Bending Stress | | |
| Q | ksi | Secondary Stress | | |
| Sm | ksi | Design Stress Intensity | | |
| Sy | ksi | Yield Stress | | |
| Su | ksi | Tensile Strength | | |
| A _b | in ² | Actual Total Cross-Sectional Area of Bolts at Root of Thread or Section of Least Diameter Under Stress | | |
| A _m | in ² | Required Total Design Cross-Sectional Area of Bolts, taken as the greater of A_{m1} and A_{m2} | | |
| St | ksi | Averaged Stress for Bolt (neglecting stress concentration) | | |
| | | Tension plus Bending Stress for Bolt | | |
| $S_t + S_b$ | 651 | (neglecting stress concentration) | | |
| УA | - | Thermal Ratcheting Factor | | |
| SS | ksi | Thermal Stress Range | | |
| α | - | Shape Factor | | |
| Р | - | Design Pressure | | |
| 1/3 SSE | - | Level B Service Loading Earthquake | | |
| SSE | - | Safe Shutdown Earthquake | | |

5.0 ASSUMPTIONS AND OPEN ITEMS

5.1 Assumptions

The basic modeling assumptions used in the analyses are as follows:

- 1. The inside diameter is taken as the drawing nominal value.
- 2. The wall thickness is the drawing nominal value.
- 3. The corrosion allowance is assumed to be zero.

5.2 Open Items

There are no open items in this Technical Report.

6.0 ACCEPTANCE CRITERIA

The stress intensity acceptance criteria for Class 1 components are specified in NB-3220, 3230 and Appendix F of Section III. Table 6-1 lists the stress limits for components other than bolts, and Table 6-2 lists the stress limits for bolts.

| Condition | Stress Category Stress Limits | | Remarks | |
|-------------|--|--|----------------------|--|
| | P _m | S _m | NB-3221.1 | |
| | PL | 1.5 S _m | NB-3221.2 | |
| | P _L + P _b | $\alpha S_{m}^{(1)2)}$ or 1.5 S _m | NB-3221.3 | |
| Design | Bearing Stress | $S_v^{(6)}$ or 1.5 $S_v^{(6)}$ | NB-3227.1(a) | |
| | Shear Stress | 0.6 S _m | NB-3227.1(b) | |
| | Pure Shear Stress | 0.6 S _m | NB-3227.2(a) | |
| | Triaxial Sress ⁴⁾ | 4 S _m | NB-3227.4 | |
| | $P_L + P_b + Q$ | 3 S _m | NB-3222.2 | |
| | Thermal Ratchet, SS | ⁵⁾ S _v × y _A | NB-3222.5 | |
| | Usage Factor | 1.0 | NB-3222.4 | |
| Level A & B | Bearing Stress | S_{v}^{6} or 1.5 S_{v}^{6} | NB-3227.1(a) | |
| | Shear Stress | 0.6 S _m | NB-3227.1(b) | |
| | Pure Shear Stress | 0.6 S _m | NB-3227.2(a) | |
| | Triaxial Sress ⁴⁾ | 4 S _m | NB-3224.3 | |
| | Pm | 1.1 S _m | NB-3223 | |
| Level B | PL | 1.5 (1.1 S _m) | NB-3223 | |
| | P _L + P _b | $\alpha (1.1 S_m)^{1/2}$ or 1.5 (1.1 S _m) | NB-3223 | |
| | P _m | Max (1.2 S _m , S _y) Max (1.1 S _m , 0.9 S _y) ³⁾ | NB-3224.1 | |
| | PL | Max (1.8 S _m , 1.5 S _y) | NB-3224.1 | |
| Level C | P _L + P _b | Max (α (1.2 S _m), α S _y) ¹⁾²⁾ or Max (1.8 S _m , 1.5 S _y) | NB-3224.1 | |
| | Bearing Stress | S_{y}^{6} or 1.5 S_{y}^{6} | NB-3227.1(a) | |
| | Shear Stress | 0.6 S _m | NB-3227.1(b) | |
| | Pure Shear Stress | 0.6 S _m | NB-3227.2(a) | |
| | Triaxial Sress ⁴⁾ | 4.8 S _m | NB-3224.3 | |
| Level D | P _m | For ferritic materials, 0.7 S _u For austenitic and high alloy steels, Min (2.4 S _m , 0.7 S _u) | | |
| | P _L For ferritic materials, 1.5 (0.7 S _u) For austenitic and high alloy steels, 1.5 Min (2.4 S _m , 0.7 S _u) | | NB-3225 (Appendix | |
| | P _L +P _b | For ferritic materials, 1.5 (0.7 S _u) For austenitic and high alloy steels, 1.5 Min (2.4 S _m , 0.7 S _u) | F-1331.1) | |
| | Pure Shear | 0.42 S _u | | |

| Table 6-1 | Class 1 | Component Stress | Limits | (other than | Bolts) |
|-----------|---------|-------------------------|--------|-------------|--------|
|-----------|---------|-------------------------|--------|-------------|--------|

| Condition | Stress Category | Stress Limits | Remarks | | | | |
|-----------|--|---|--------------|--|--|--|--|
| | Pm | 0.9 S _v | | | | | |
| | | (1.35 $S_y)$ - for $P_m \leq 0.67 \ S_y$ | NB-3226 | | | | |
| | P _m + P _b | (or 0.9 α S _y for non-rectangular sections) | | | | | |
| Test | | $(2.15 \text{ S}_{y} - 1.2 \text{ P}_{m}) - \text{ for } 0.67 \text{ S}_{y} < \text{P}_{m} \le 0.9 \text{ S}_{y}$ | | | | | |
| 1000 | Bearing Stress | S_{y}^{6} or 1.5 S_{y}^{6} | NB-3227.1(a) | | | | |
| | Shear Stress | 0.6 S _m | NB-3227.1(b) | | | | |
| | Pure Shear Stress | 0.6 S _m | NB-3227.2(a) | | | | |
| | Triaxial Sress ⁴⁾ 4 S _m NB-3227.4 | | | | | | |
| Note-1 | $e-1$ The shape factor of α for solid rectangular sections is 1.5, α shall not exceed 1.5. | | | | | | |
| Note-2 | " α " is considered where stresses are classified as primary bending. | | | | | | |
| Note-3 | The stress limits for press | ure loading alone for ferritic material. | | | | | |
| Note-4 I | NB-3227.4 states that the Triaxial Stress limit is 4 S_m and does not apply to Level D. | | | | | | |
| I | NB-3224.3 states the Lev | el C limit is 4.8 S _m . | | | | | |
| Note-5 I | NB-3222.5 requires evaluation of Thermal Stress Ratcheting for Level A Service Loads. In all | | | | | | |
| (| cases where elastic analysis indicates that the primary membrane stress is less than S_m a | | | | | | |
| t | the primary plus secondary stress is less than 3 S_m , then thermal stress ratcheting will not | | | | | | |
| occur. | | | | | | | |
| Note-6 | S_y when the distance to a free edge is less than the distance over which the bearing load is | | | | | | |
| i | applied; 1.5 S _y when the distance to a free edge is larger. | | | | | | |

| Condition | Stress Category | Stress Limits | Remarks | |
|-------------|---|--|--------------------|--|
| Design | A _b | A _m | NB-3231, E-1000 | |
| | Average Service Stress ¹⁾ , St | 2 S _m | NB-3232.1 | |
| Level A & B | Max Service Stress ¹⁾ , S _t + S _b | 3 S _m | NB-3232.2 | |
| | Fatigue Usage Factor ²⁾ | 1.0 | NB-3232.3 | |
| | Average Service Stress ¹⁾ , S _t | 2 S _m | NB-3234 | |
| LeverC | Max Service Stress ¹⁾ , S _t + S _b | 3 S _m | NB-3234 | |
| | Average Tensile Stress ³⁾ , St | Min (S _y , 0.7 S _u) | NB-3235 & F-1335.1 | |
| | Max Tensile Stress ³⁾ , S _t + S _b | S _u | NB-3235 & F-1335.1 | |
| | Average bolt shear | Min (0.6 S _y , 0.42 S _u) | F-1335.2 | |
| Level D | Combined tensile and shear | $f_t^2 / F_{tb}^2 + f_v^2 / F_{vb}^2 \le 1 $ ⁴⁾ | F-1335.3 | |
| | Distance from bolt center to edge | d [0.5 + 1.2 (fp / S _u)] ⁵⁾ | F-1335.4(a) | |
| | Nominal bearing stress | 2.1 S _u | F-1335.4(b) | |
| Note-1 | Includes preload, pressure, and differential thermal expansion, excludes stress concentrations. | | | |
| Note-2 | Includes a fatigue strength reduction factor of 4 for the threads. | | | |
| Note-3 | Includes preload, pressure, differential thermal expansion, and prying action produced by deformation of the connected parts, excludes stress concentrations. | | | |
| Note-4 | f_t =computed tensile stress, f_v =computed shear stress, F_{tb} =allowable tensile stress at operating temperature. | | | |
| Note-5 | d= nominal bolt diameter; fp = nominal bearing stress. | | | |

Table 6-2 Class 1 Bolt Stress Limits

7.0 DESIGN INPUT

7.1 Geometry

The US-APWR RCP basic drawings used to supply dimensions for the stress analyses are listed in Table 7-1. Figures describing the detailed geometry of the parts evaluated can be found in Section 10.

| No. | Drawing Title | Reference Number |
|-----|--------------------------------------|------------------|
| 1 | Reactor Coolant Pump Design Drawings | N0-F600102 Rev.4 |

7.2 Material

The materials of construction for the RCP pressure boundary and internals are listed in the Table 7-2, below.

| Table 7-2 | Materials | of | Construction |
|-----------|-----------|----|--------------|
|-----------|-----------|----|--------------|

| Part or Assembly | Material |
|---|------------------------------------|
| Casing (including Suction Nozzle, Discharge Nozzle and Casing Lugs) | SA-351 Grade CF8 |
| Main Flange | SA-182 Grade F316 |
| Diffuser Flange | SA-182 Grade F304 |
| No.1 and No.2 Seal Housing | SA-182 Grade F316 |
| Heat Exchanger Tubing | SA-213 Type 316 |
| Closure Studs, Nuts and Washers | SA-540 Grade B24 Class 4 & Class 2 |

The material strength properties used in the stress analyses are presented in Tables 7-3 through 7-11, below. These material strength properties were obtained from Section II of the ASME Code (Reference 2).

| Temperature, °F | Sm [ksi] | Sy [ksi] | Su [ksi] |
|-----------------|-------------|-------------|-------------|
| 70 | 20.0 | 30.0 | 70.0 |
| 100 | 20.0 | 30.0 | 70.0 |
| 200 | 20.0 | 25.0 | 66.3 |
| 300 | 20.0 | 22.4 | 61.8 |
| 400 | 18.6 | 20.7 | 59.7 |
| 500 | 17.5 | 19.4 | 59.2 |
| 600 | 16.6 | 18.4 | 59.2 |
| 650 | 16.2 | 18.0 | 59.2 |

Table 7-3 Material Properties for SA-351 Grade CF8

Table 7-4 Material Properties for SA-213 Type 316

| Temperature, °F | Sm [ksi] | Sy [ksi] | Su [ksi] |
|-----------------|-------------|-------------|-------------|
| 70 | 20.0 | 30.0 | 75.0 |
| 100 | 20.0 | 30.0 | 75.0 |
| 200 | 20.0 | 25.9 | 75.0 |
| 300 | 20.0 | 23.4 | 72.9 |
| 400 | 19.3 | 21.4 | 71.9 |
| 500 | 18.0 | 20.0 | 71.8 |
| 600 | 17.0 | 18.9 | 71.8 |
| 650 | 16.6 | 18.5 | 71.8 |

| Temperature, °F | Sm [ksi] | Sy [ksi] | Su [ksi] |
|-----------------|-------------|-------------|-------------|
| 70 | 20.0 | 30.0 | 75.0 |
| 100 | 20.0 | 30.0 | 75.0 |
| 200 | 20.0 | 25.9 | 75.0 |
| 300 | 20.0 | 23.4 | 72.9 |
| 400 | 19.3 | 21.4 | 71.9 |
| 500 | 18.0 | 20.0 | 71.8 |
| 600 | 17.0 | 18.9 | 71.8 |
| 650 | 16.6 | 18.5 | 71.8 |

Table 7-5 Material Properties for SA-182 Grade F316(t \leq 5)

Table 7-6 Material Properties for SA-182 Grade F316(t > 5)

| Temperature, °F | Sm [ksi] | Sy [ksi] | Su [ksi] |
|-----------------|-------------|-------------|-------------|
| 70 | 20.0 | 30.0 | 70.0 |
| 100 | 20.0 | 30.0 | 70.0 |
| 200 | 20.0 | 25.9 | 70.0 |
| 300 | 20.0 | 23.4 | 68.0 |
| 400 | 19.3 | 21.4 | 67.1 |
| 500 | 18.0 | 20.0 | 67.0 |
| 600 | 17.0 | 18.9 | 67.0 |
| 650 | 16.6 | 18.5 | 67.0 |

| Temperature, °F | Sm [ksi] | Sy [ksi] | Su [ksi] |
|-----------------|-------------|-------------|-------------|
| 70 | 20.0 | 30.0 | 75.0 |
| 100 | 20.0 | 30.0 | 75.0 |
| 200 | 20.0 | 25.0 | 71.0 |
| 300 | 20.0 | 22.4 | 66.2 |
| 400 | 18.6 | 20.7 | 64.0 |
| 500 | 17.5 | 19.4 | 63.4 |
| 600 | 16.6 | 18.4 | 63.4 |
| 650 | 16.2 | 18.0 | 63.4 |

Table 7-7 Material Properties for SA-182 Grade F304(t \leq 5)

Table 7-8 Material Properties for SA-182 Grade F304(t >5)

| Temperature, °F | Sm [ksi] | Sy [ksi] | Su [ksi] |
|-----------------|-------------|-------------|-------------|
| 70 | 20.0 | 30.0 | 70.0 |
| 100 | 20.0 | 30.0 | 70.0 |
| 200 | 20.0 | 25.0 | 66.3 |
| 300 | 20.0 | 22.4 | 61.8 |
| 400 | 18.6 | 20.7 | 59.7 |
| 500 | 17.5 | 19.4 | 59.2 |
| 600 | 16.6 | 18.4 | 59.2 |
| 650 | 16.2 | 18.0 | 59.2 |

| Temperature, °F | Sm [ksi] | Sy [ksi] | Su [ksi] |
|-----------------|-------------|-------------|-------------|
| 70 | 46.7 | 140.0 | 155.0 |
| 100 | 46.7 | 140.0 | 155.0 |
| 200 | 44.6 | 134.4 | 155.0 |
| 300 | 43.1 | 131.0 | 155.0 |
| 400 | 41.8 | 128.7 | 155.0 |
| 500 | 40.5 | 126.9 | 155.0 |
| 600 | 38.7 | 124.5 | 155.0 |
| 650 | 37.5 | 122.7 | 152.6 |

 Table 7-9
 Material Properties for SA-540 Grade B24 Class 2

Table 7-10 Material Properties for SA-540 Grade B24 Class 4

| Temperature, °F | Sm [ksi] | Sy [ksi] | Su [ksi] |
|-----------------|-------------|-------------|-------------|
| 70 | 40.0 | 120.0 | 135.0 |
| 100 | 40.0 | 120.0 | 135.0 |
| 200 | 38.2 | 115.2 | 135.0 |
| 300 | 36.9 | 112.2 | 135.0 |
| 400 | 35.9 | 110.3 | 135.0 |
| 500 | 34.7 | 108.8 | 135.0 |
| 600 | 33.1 | 106.7 | 135.0 |
| 650 | 32.1 | 105.2 | 132.9 |

7.3 Loads, Load Combinations, and Transients

The loads, load combinations and transients used in the structural analyses are defined in the RCP ASME Design Specification (Reference 4). Following is a summary of the loads used for the RCP structural evaluations.

7.3.1 Pressure Loads and Temperature

| Parameter | Value |
|--|-----------|
| Casing Design Pressure | 2485 psig |
| Casing Design Temperature | 650°F |
| Heat Exchanger Design Pressure (External pressure) | 2485 psig |
| Heat Exchanger Design Temperature | 650°F |
| Casing Hydrostatic Test Pressure | () |
| Casing Minimum Hydrostatic Test Temperature | 70°F |
| No.1 and No.2 Seal Housing Hydrostatic Test Pressure | 3107 psig |
| No.1 and No.2 Seal Housing Minimum Hydrostatic Test Temperature | 70°F |
| Heat Exchanger Inlet & Outlet Nozzle Design Pressure | 2485 psig |
| Heat Exchanger Inlet & Outlet Nozzle Design Temperature | 650°F |
| Heat Exchanger Inlet & Outlet Nozzle Hydrostatic Test Pressure | 3107 psig |
| No.1 and No.2 Seal Housing Minimum Hydrostatic Test Temperature | 70°F |

Table 7-11 Pressures and Temperatures

7.3.2 External Mechanical Loads

The external loads, obtained from the Design Specification, are dead weight, thermal expansion, seismic I and accident loads. These external loads were applied at the RCP pressure boundary nozzles and supports.

The bolt preload values were the minimum required bolt loads for the design pressure calculated in accordance with Article E-1000 of the ASME code.

| | 5 | | (kips) | (kips) | (kips) | (in-kips) | (in-kips) | ivi∠ (in-kips) |
|---------|---------|----------------------|--|--|---|---|--|--|
| Dead | Lo | op-A,D | $\left(\right)$ | | | | | |
| Weight | Lo | op-B,C | | | | | | |
| | | Gr.1 | | | | | | |
| | | Gr.2 | | | | | | |
| | | Gr.3 | | | | | | |
| | | Gr.4 | | | | | | |
| | | Gr.5 | | | | | | |
| | Loop | Gr.6 | | | | | | |
| | -A,D | Gr.7 | | | | | | |
| | | Gr.8 | | | | | | |
| | | Gr.9 | | | | | | |
| | | (1/2) | | | | | | |
| Thormol | | Gr.9 (2/2) | | | | | | |
| mermai | | Gr.1 | | | | | | |
| | | Gr.2 | | | | | | |
| | | Gr.3 | | | | | | |
| | | Gr.4 | | | | | | |
| | | Gr.5 | | | | | | |
| | Loop | Gr.6 | | | | | | |
| | -B,C | Gr.7 | | | | | | |
| | | Gr.8 | | | | | | |
| | | Gr.9 (1/2) | | | | | | |
| | | Gr.9 (2/2) | | | | | | |
| | Thermal | Thermal Loop -A,D | Gr.2 Gr.3 Gr.4 Gr.5 Loop Gr.6 Gr.7 Gr.8 Gr.9 (1/2) Gr.3 Gr.4 Gr.5 Gr.9 (1/2) Gr.3 Gr.4 Gr.5 Gr.6 Gr.7 Gr.8 Gr.9 (1/2) Gr.4 Gr.5 Gop Gr.4 Gr.5 Gr.6 Gr.7 Gr.8 Gr.4 Gr.5 Gr.6 Gr.7 Gr.8 Gr.9 (1/2) Gr.9 (1/2) Gr.9 (1/2) | Gr.2 Gr.3 Gr.4 Gr.5 Gr.5 Gr.6 Gr.7 Gr.7 Gr.8 Gr.9 (1/2) Gr.9 (2/2) Gr.3 Gr.9 Gr.9 (2/2) Gr.3 Gr.3 Gr.4 Gr.9 Gr.9 (2/2) Gr.3 Gr.3 Gr.3 Gr.4 Gr.3 Gr.4 Gr.3 Gr.3 Gr.4 Gr.4 Gr.3 Gr.5 Gr.3 Gr.8 Gr.3 Gr.9 Gr.4 Gr.9 Gr.9 (1/2) Gr.9 (1/2) Gr.9 (2/2) Gr.9 | Gr.2 Gr.3 Gr.4 Gr.4 Gr.5 Gr.6 Gr.7 Gr.8 Gr.9 Gr.9 (1/2) Gr.9 Gr.3 Gr.4 Gr.7 Gr.8 Gr.9 Gr.9 (2/2) Gr.9 Gr.3 Gr.9 Gr.3 Gr.9 Gr.3 Gr.9 Gr.4 Gr.9 Gr.3 Gr.9 Gr.4 Gr.9 Gr.4 Gr.9 Gr.4 Gr.9 Gr.4 Gr.9 Gr.4 Gr.9 Gr.4 Gr.9 Gr.9 Gr.9 Gr.9< | Thermal $\left \begin{array}{c c c c c c c c c c c c c c c c c c c $ | Gr.2 Image: Constraint of the system of the sy | Gr.2 Image: Constraint of the second se |

Table 7-12-1 Loads Applied to the Pump Casing Lug #1 (1/2)

| No. | Loading | Fx (kips) | Fy (kips) | Fz (kips) | Mx (in-kips) | My (in-kips) | Mz (in-kips) | |
|-----|------------------|--------------|--------------|--------------|-----------------|-----------------|-----------------|----|
| 3 | Seismic (1/3SSE) | | | | | | |]- |
| 4 | Seismic (SSE) | | | | | | | |
| 5 | Accident | | | | | | | |

Table 7-12-2 Loads Applied to the Pump Casing Lug #1 (2/2)





| No. | Lo | oading | | Fx (kips) | Fy (kips) | Fz (kips) | Mx (in-kips) | My (in-kips) | Mz (in-kips) |
|-----|-------------------|--------|---------------|--------------|--------------|--------------|-----------------|-----------------|-----------------|
| 1 | Dead | Lo | op-A,D | | | | | | |
| | Weight | Lo | op-B,C | | | | | | |
| | | | Gr.1 | | | | | | |
| | | | Gr.2 | | | | | | |
| | | | Gr.3 | | | | | | |
| | | | Gr.4 | | | | | | |
| | | | Gr.5 | | | | | | |
| | | Loop | Gr.6 | | | | | | |
| | | -7,0 | Gr.7 | | | | | | |
| | | | Gr.8 | | | | | | |
| | | | Gr.9 (1/2) | | | | | | |
| | The second | | Gr.9 (2/2) | | | | | | |
| 2 | Inermai | | Gr.1 | | | | | | |
| | | | Gr.2 | | | | | | |
| | | | Gr.3 | | | | | | |
| | | | Gr.4 | | | | | | |
| | | | Gr.5 | | | | | | |
| | | Loop | Gr.6 | | | | | | |
| | | -B,C | Gr.7 | | | | | | |
| | | | Gr.8 | | | | | | |
| | | | Gr.9 (1/2) | | | | | | |
| | | | Gr.9 (2/2) | | | | | | |

Table 7-12-3 Loads Applied to the Pump Casing Lug #2 (1/2)

| No. | Loading | Fx (kips) | Fy (kips) | Fz (kips) | Mx (in-kips) | My (in-kips) | Mz (in-kips) | - |
|-----|------------------|--------------|--------------|--------------|-----------------|-----------------|-----------------|---|
| 3 | Seismic (1/3SSE) | | | | | | | |
| 4 | Seismic (SSE) | | | | | | | |
| 5 | Accident | | | | | | | |

Table 7-12-4 Loads Applied to the Pump Casing Lug #2 (2/2)





| No. | Lo | bading | | Fx (kips) | Fy (kips) | Fz (kips) | Mx (in-kips) | My (in-kips) | Mz (in-kips) |
|-----|---------|--------|---------------|--------------|--------------|--------------|-----------------|-----------------|-----------------|
| 1 | Dead | Lo | op-A,D | | | | | | |
| • | Weight | Lo | op-B,C | | | | | | |
| | | | Gr.1 | | | | | | |
| | | | Gr.2 | | | | | | |
| | | | Gr.3 | | | | | | |
| | | | Gr.4 | | | | | | |
| | | | Gr.5 | | | | | | |
| | | Loop | Gr.6 | | | | | | |
| | | -A,D | Gr.7 | | | | | | |
| | | | Gr.8 | | | | | | |
| | | | Gr.9 | | | | | | |
| | | | (1/2) | | | | | | |
| 2 | Thormol | | Gr.9 (2/2) | | | | | | |
| 2 | mermai | | Gr.1 | | | | | | |
| | | | Gr.2 | | | | | | |
| | | | Gr.3 | | | | | | |
| | | | Gr.4 | | | | | | |
| | | | Gr.5 | | | | | | |
| | | Loop | Gr.6 | | | | | | |
| | | -B,C | Gr.7 | | | | | | |
| | | | Gr.8 | | | | | | |
| | | | Gr.9 | | | | | | |
| | | | (1/2) | | | | | | |
| | | | Gr.9 | | | | | | |
| | | | (2/2) | Ц | | | | | |

Table 7-12-5 Loads Applied to the Pump Casing Lug #3 (1/2)

| No. | Loading | Fx (kips) | Fy (kips) | Fz (kips) | Mx (in-kips) | My (in-kips) | Mz (in-kips) |
|-----|------------------|--------------|--------------|--------------|-----------------|-----------------|-----------------|
| 3 | Seismic (1/3SSE) | | | | | | |
| 4 | Seismic (SSE) | | | | | | |
| 5 | Accident | | | | | | |
| | | | • | • | | | |





| No. | Lo | oading | | Fx (kips) | Fy (kips) | Fz (kips) | Mx (in-kips) | My (in-kips) | Mz (in-kips) |
|-----|---------|--------|---------------|--------------|--------------|--------------|-----------------|-----------------|-----------------|
| 1 | Dead | Lo | op-A,D | | | | | | |
| | Weight | Lo | op-B,C | | | | | | |
| | | | Gr.1 | | | | | | |
| | | | Gr.2 | | | | | | |
| | | | Gr.3 | | | | | | |
| | | | Gr.4 | | | | | | |
| | | | Gr.5 | | | | | | |
| | | Loop | Gr.6 | | | | | | |
| | | -A,D | Gr.7 | | | | | | |
| | | | Gr.8 | | | | | | |
| | | | Gr.9 | | | | | | |
| | | | (1/2) | | | | | | |
| | | | Gr.9 | | | | | | |
| 2 | Thermal | | (2/2) | | | | | | |
| | | | Gr.1 | | | | | | |
| | | | Gr.2 | | | | | | |
| | | | Gr.3 | | | | | | |
| | | | Gr.4 | | | | | | |
| | | Loop | Gr.5 | | | | | | |
| | | -B,C | Gr.6 | | | | | | |
| | | | Gr.7 | | | | | | |
| | | | Gr.8 | | | | | | |
| | | | Gr.9 (1/2) | | | | | | |
| | | | Gr 9 | | | | | | |
| | | | (2/2) | | | | | | |

 Table 7-13 Loads Applied to the Discharge Nozzle (1/2)

|--|

| No. | Loading | Fx (kips) | Fy (kips) | Fz (kips) | Mx (in-kips) | My (in-kips) | Mz (in-kips) |
|-----|------------------|--------------|--------------|--------------|-----------------|-----------------|-----------------|
| 3 | Seismic (1/3SSE) | | | | | | |
| 4 | Seismic (SSE) | | | | | | |
| 5 | Accident | | | | | | |

RCP Suction Nozzle



RCP Discharge Nozzle

| No. | Loading | | Fx (kips) | Fy (kips) | Fz (kips) | Mx (in-kips) | My (in-kips) | Mz (in-kips) | |
|-----|---------|----------|---------------|--------------|--------------|-----------------|-----------------|-----------------|--|
| 1 | Dead | Loop-A,D | | | | | | | |
| | Weight | Lo | op-B,C | | | | | | |
| | | | Gr.1 | | | | | | |
| | | | Gr.2 | | | | | | |
| | | | Gr.3 | | | | | | |
| | | | Gr.4 | | | | | | |
| | | | Gr.5 | | | | | | |
| | | Loop | Gr.6 | | | | | | |
| | | -A,D | Gr.7 | | | | | | |
| | | | Gr.8 | | | | | | |
| | Thermal | | Gr.9 | | | | | | |
| | | | (1/2) | | | | | | |
| 2 | | | Gr.9 (2/2) | | | | | | |
| 2 | merma | | Gr.1 | | | | | | |
| | | | Gr.2 | | | | | | |
| | | | Gr.3 | | | | | | |
| | | | Gr.4 | | | | | | |
| | | | Gr.5 | | | | | | |
| | | Loop | Gr.6 | | | | | | |
| | | -в,С | Gr.7 | | | | | | |
| | | | Gr.8 | | | | | | |
| | | | Gr.9 | | | | | | |
| | | | (1/2) | | | | | | |
| | | | Gr.9 (2/2) | | | | | | |

Table 7-15 Loads Applied to the Suction Nozzle (1/2)

| Table 1-10 Loads Applied to the Suction Nozzie (2/2 | Table 7-16 | Loads | Applied to t | the Suction | Nozzle | (2/2) |
|---|------------|-------|--------------|-------------|--------|-------|
|---|------------|-------|--------------|-------------|--------|-------|

| No. | Loading | Fx (kips) | Fy (kips) | Fz (kips) | Mx (in-kips) | My (in-kips) | Mz (in-kips) |
|-----|------------------|--------------|--------------|--------------|-----------------|-----------------|-----------------|
| 3 | Seismic (1/3SSE) | | | | | | |
| 4 | Seismic (SSE) | | | | | | |
| 5 | Accident | | | | | | |

RCP Suction Nozzle



RCP Discharge Nozzle

| No. | Loading | | Fx (kips) | Fy (kips) | Fz (kips) | Mx (in-kips) | My (in-kips) | Mz (in-kips) | |
|-----|---------|----------|--------------|--------------|--------------|-----------------|-----------------|-----------------|--|
| 1 | Dead | Loop-A,D | | | | | | | |
| | Weight | Lo | op-B,C | | | | | | |
| | | | Gr.1 | | | | | | |
| | | | Gr.2 | | | | | | |
| | | | Gr.3 | | | | | | |
| | | | Gr.4 | | | | | | |
| | | | Gr.5 | | | | | | |
| | | Loop | Gr.6 | | | | | | |
| | | -A,D | Gr.7 | | | | | | |
| | | nermal | Gr.8 | | | | | | |
| | | | Gr.9 | | | | | | |
| | | | (1/2) | | | | | | |
| | | | Gr.9 | | | | | | |
| 2 | Thermal | | (2/2) | | | | | | |
| | | | Gr.1 | | | | | | |
| | | | Gr.2 | | | | | | |
| | | | Gr.3 | | | | | | |
| | | | Gr.4 | | | | | | |
| | | | Gr.5 | | | | | | |
| | | Loop | Gr.6 | | | | | | |
| | | -B,C | Gr.7 | | | | | | |
| | | | Gr.8 | | | | | | |
| | | | Gr.9 | | | | | | |
| | | | (1/2) | | | | | | |
| | | | Gr.9 | | | | | | |
| | | | (2/2) | | | | | | |

 Table 7-17 Loads Applied to the Lower Motor Stand (1/2)

| Table 7-18 Loads Applied to the Lower Motor Stand (| 2/2) |
|---|------|
|---|------|

| No. | Loading | Fx (kips) | Fy (kips) | Fz (kips) | Mx (in-kips) | My (in-kips) | Mz (in-kips) |
|-----|------------------|--------------|--------------|--------------|-----------------|-----------------|-----------------|
| 3 | Seismic (1/3SSE) | | | | | | |
| 4 | Seismic (SSE) | | | | | | |
| 5 | Accident | | | | | | |

RCP Motor Stand

Lower

RCP Motor Stand Upper



RCP Casing Bolt



7.3.3 Thermal and Pressure Transient Loads

The design transients used in the structural evaluations are listed in the Table 7-19. These transients were determined based on a 60-year plant operating period and classified as ASME Level A, Level B, Level C, Level D service conditions, or Test conditions, depending on the expected frequency of occurrence and severity of the event.

| Level | Level A Service Conditions | | | | | | | | |
|---------|---|---------------------|--|--|--|--|--|--|--|
| Mark | Transient | Occurrence | Remark | | | | | | |
| l-a | Plant heat-up (50F/h) | 120 | | | | | | | |
| I-b | Plant cooldown (100F/h) | 120 | Includes Transient for Loss of offsite power with natural circulation cooldown (10 times) and Safe shutdown (1 time) | | | | | | |
| I-c-1 | Ramp load increase between 15% and 100% of full power (5% or full power per minute) | 600 | | | | | | | |
| I-c-2 | Ramp load increase between 50% and 100% of full power (5% or full power per minute) | 19,200 | | | | | | | |
| I-d-1 | Ramp load decrease between 15% and 100% of full power (5% or full power per minute) | 600 | | | | | | | |
| I-d-2 | Ramp load decrease between 50% and 100% of full power (5% or full power per minute) | 19,200 | | | | | | | |
| l-e | Step load increase of 10% of full power | 600 | | | | | | | |
| l-f | Step load decrease of 10% of full power | 600 | | | | | | | |
| l-g | Large step load decrease with turbine bypass | 60 | | | | | | | |
| l-h i) | Steady-state fluctuations and load regulation (Steady state fluctuations) | 1 x 10 ⁶ | P _P +/- 50psi, T _{hot} ,T _{cold} , T _{ave} +/- 3.1F | | | | | | |
| l-h ii) | Steady-state fluctuations and load regulation (Load regulation) | 8 x 10 ⁵ | | | | | | | |
| I-i | Main feedwater cycling | 2,100 | | | | | | | |
| l-j | Refueling | 60 | Water is replaced in 10minutes | | | | | | |
| l-k | Ramp load increase between 0% and 15% of full power | 600 | | | | | | | |
| I-I | Ramp load decrease between 0% and 15% of full power | 600 | | | | | | | |
| l-m | RCP startup | 3,000 | | | | | | | |
| l-n | RCP shutdown | 3,000 | | | | | | | |
| l-o | Core lifetime extension | 60 | | | | | | | |
| I-p | Primary leakage test | 120 | | | | | | | |
| l-q | Turbine roll test | 10 | | | | | | | |

Table 7-19 Design Transients

| II-a Loss of offsite power 60 II-b Loss of offsite power 60 II-c Partial loss of reactor coolant flow 30 II-dii) Reactor trip from full power With no inadvertent cooldown 60 II-diii) Reactor trip from full power With cooldown and no safety 30 Includes Transient for excessive feedwater flow II-diii) Reactor trip from full power With cooldown and safety 10 Includes Transient for excessive feedwater flow II-d iii) Reactor trip from full power With cooldown and safety 10 Includes Transient for excessive feedwater flow II-d iii) Reactor trip from full power With cooldown and safety 10 Includes Transient for excessive feedwater flow II-d iii) Indvertent RCS depressurzation 30 III-t Covered by Transient for reactor trip from full power if Covered by Transient for reactor trip from full power if Covered by Transient for plant cooldown — Covered by Transient for plant cooldown II-d Excessive feedwater flow — Covered by Transient for plant cooldown — II-k Loss of emergency feedwater 30 Use Figure for Transient of plant cooldown Use So offsite power II-m Safe Shutdown — Covered by | Level E | 3 Service Conditions | | | | |
|--|-----------|---|-----|--|--|--|
| II-b Loss of offsite power 60 II-c Partial loss of reactor coolant flow 30 II-d ii) Reactor trip from full power With no inadvertent cooldown 60 II-d ii) Reactor trip from full power With cooldown and no safety 30 II-d iii) Reactor trip from full power With cooldown and safety 10 II-d iii) Reactor trip from full power With cooldown and safety 10 II-e Inadvertent RCS depressurization 30 II-f Control rod drop 30 II-g Inadvertent safeguards actuation 30 II-f Cold over-pressure 30 II-f Cold over-pressure 30 II-k Loss of offsite power with natural circulation cooldown — II-k Loss of offsite power with natural circulation cooldown — II-k Loss of offsite power with natural circulation cooldown — Covered by Transient for plant cooldown II-k Loss of offsite power with natural circulation cooldown — Covered by Transient for plant cooldown II-k Safe Shutdown — Covered by Transient for plant cooldown Use Figure for Transient for plant cooldown | ll-a | Loss of load | 60 | | | |
| II-c Partial loss of reactor coolant flow 30 II-d i) Reactor trip from full power With no inadvertent cooldown 60 II-d ii) Reactor trip from full power With cooldown and safety 30 II-d iii) Reactor trip from full power With cooldown and safety 10 II-d iii) Reactor trip from full power With cooldown and safety 10 II-d iii) Reactor trip from full power With cooldown and safety 10 II-d iii) Indvertent RCS depressurization 30 II-g Inadvertent RCS depressurization 30 II-g Inadvertent RCS depressure 30 II-g Inadvertent RCS depressure 30 II-h Emergency feedwater cycling 700 II-i Cold over-pressure 30 II-j Excessive feedwater flow — II-k Loss of offsite power with natural circulation cooldown — II-k Loss of emergency feedwater 30 Use Figure for Transient for plant cooldown II-m Safe Shutdown — — Covered by Transient for plant cooldown II-m Safe Shutdown — Covered by Transient for plant cooldown </td <td>II-b</td> <td>Loss of offsite power</td> <td>60</td> <td></td> | II-b | Loss of offsite power | 60 | | | |
| II-d i) Reactor trip from full power With no inadvertent cooldown 60 II-d ii) Reactor trip from full power With cooldown and no safety 30 Includes Transient for II-d iii) Reactor trip from full power With cooldown and safety 10 10 II-d iii) Reactor trip from full power With cooldown and safety 10 10 II-e Inadvertent RCS depressurization 30 11 II-g Inadvertent RCS depressurization 30 11 II-h Emergency feedwater cycling 700 700 II-i Cold over-pressure 30 11 II-k Loss of offsite power with natural circulation cooldown - Covered by Transient for reactor trip from full power i II-k Loss of offsite power with natural circulation cooldown - Covered by Transient for plant cooldown II-h Partial loss of emergency feedwater 30 Use Figure for Transient or loss of offsite power II-m Safe Shutdown - Covered by Transient for plant cooldown - II-m Safe Shutdown - Covered by Transient for plant cooldown - II-m Safe Shutdown - Cover | II-c | Partial loss of reactor coolant flow | 30 | | | |
| II-d ii) Reactor trip from full power With cooldown and no safety 30 Includes Transient for excessive feedwater flow II-d iii) Reactor trip from full power With cooldown and safety 10 10 II-e Inadvertent RCS depressurization 30 30 II-e Inadvertent RCS depressurization 30 30 II-g Inadvertent RCS depressurization 30 30 II-g Inadvertent safeguards actuation 30 30 II-h Emergency feedwater cycling 700 700 II-h Cold over-pressure 30 Covered by Transient for reactor trip from full power i for full power i for reactor trip from full power i for reactor trip from full power i covered by Transient for reactor trip from full power i covered by Transient for set of fiste power with natural circulation cooldown — Covered by Transient for loss of offsite power with natural circulation cooldown — Covered by Transient for plant cooldown II-H Partial loss of emergency feedwater 30 Use Figure for Transient for plant cooldown — II-m Safe Shutdown — — Covered by Transient for plant cooldown II-m Safe Shutdown — — Covered by Transient for plant cooldown | ll-d i) | Reactor trip from full power With no inadvertent cooldown | 60 | | | |
| II-d iii) Reactor trip from full power With cooldown and safety 10 II-e Inadvertent RCS depressurization 30 II-g Inadvertent RCS depressurization 30 II-g Inadvertent safeguards actuation 30 II-h Emergency feedwater cycling 700 II-i Cold over-pressure 30 II-j Excessive feedwater flow — II-k Loss of offsite power with natural circulation cooldown — II-k Loss of offsite power with natural circulation cooldown — II-k Loss of offsite power with natural circulation cooldown — Covered by Transient of loss of offsite power II-m Safe Shutdown — Covered by Transient of loss of offsite power Covered by Transient of loss of offsite power II-m Safe Shutdown — Covered by Transient of loss of offsite power II-m Safe Shutdown — Covered by Transient of loss of offsite power II-m Safe Shutdown — Covered by Transient of loss of offsite power II-m Safe Shutdown — Covered by Transient of loss of offsite power III-m Safe Shutdown <t< td=""><td>ll-d ii)</td><td>Reactor trip from full power With cooldown and no safety injection</td><td>30</td><td>Includes Transient for excessive feedwater flow</td></t<> | ll-d ii) | Reactor trip from full power With cooldown and no safety injection | 30 | Includes Transient for excessive feedwater flow | | |
| II-e Inadvertent RCS depressurization 30 II-f Control rod drop 30 II-g Inadvertent safeguards actuation 30 II-h Emergency feedwater cycling 700 II-h Emergency feedwater cycling 700 II-i Cold over-pressure 30 II-j Excessive feedwater flow — II-k Loss of offsite power with natural circulation cooldown — II-k Loss of offsite power with natural circulation cooldown — II-k Safe Shutdown — Covered by Transient for plant cooldown II-m Safe Shutdown — Covered by Transient for plant cooldown II-m Safe Shutdown — Covered by Transient for plant cooldown II-m Safe Shutdown — Covered by Transient for plant cooldown II-m Safe Shutdown — Covered by Transient for plant cooldown II-m Safe Shutdown — Covered by Transient for plant cooldown II-m Safe Shutdown — Covered by Transient for plant cooldown II-m Safe Shutdown 5 Incooldown | II-d iii) | Reactor trip from full power With cooldown and safety injection | 10 | • <u>-</u> | | |
| II-f Control rod drop 30 II-g Inadvertent safeguards actuation 30 II-h Emergency feedwater cycling 700 II-i Cold over-pressure 30 II-j Excessive feedwater flow - II-k Loss of offsite power with natural circulation cooldown - II-k Loss of offsite power with natural circulation cooldown - II-k Loss of emergency feedwater 30 II-l Partial loss of emergency feedwater 30 II-m Safe Shutdown - Covered by Transient of loss of offsite power II-m Safe Shutdown - Covered by Transient of plant cooldown II-m Safe Shutdown - Covered by Transient of plant cooldown II-m Safe Shutdown - Covered by Transient of plant cooldown III-m Safe Shutdown - Covered by Transient of plant cooldown III-m Safe Shutdown - Covered by Transient of plant cooldown III-m Small steam line break 5 III-dower III-d Small steam line break 5 III-dower <tr< td=""><td>ll-e</td><td>Inadvertent RCS depressurization</td><td>30</td><td></td></tr<> | ll-e | Inadvertent RCS depressurization | 30 | | | |
| II-g Inadvertent safeguards actuation 30 II-h Emergency feedwater cycling 700 II-i Cold over-pressure 30 II-j Excessive feedwater flow — II-k Loss of offsite power with natural circulation cooldown — II-k Loss of offsite power with natural circulation cooldown — II-k Loss of emergency feedwater 30 II-l Partial loss of emergency feedwater 30 II-m Safe Shutdown — Covered by Transient for loss of offsite power Covered C Service Condition — Covered by Transient for plant cooldown III-m Safe Shutdown — Covered by Transient for plant cooldown Level C Service Condition — Covered by Transient for plant cooldown III-m Safe Shutdown — Covered by Transient for plant cooldown III-m Safe Shutdown — Covered by Transient for plant cooldown Level C Service Condition 5 1 1 III-a Small feedwater line break 5 1 III-b Small feedwater line break 5 1 | II-f | Control rod drop | 30 | | | |
| II-h Emergency feedwater cycling 700 II-i Cold over-pressure 30 II-j Excessive feedwater flow — II-k Loss of offsite power with natural circulation cooldown — II-k Loss of offsite power with natural circulation cooldown — II-k Loss of offsite power with natural circulation cooldown — II-l Partial loss of emergency feedwater 30 II-m Safe Shutdown — — II-m Safe Shutdown — — Level C Service Condition — — Covered by Transient for plant cooldown III-a Small loss of coolant accident 5 … … III-a Small loss of coolant accident 5 … … III-a Small steam line break 5 … … … III-a Small feedwater line break 5 … … … III-a Small feedwater line break 5 … … … III-a Small feedwater line break 1 … … … III-a | ll-g | Inadvertent safeguards actuation | 30 | | | |
| II-i Cold over-pressure 30 II-j Excessive feedwater flow — Covered by Transient for reactor trip from full power i II-k Loss of offsite power with natural circulation cooldown — Covered by Transient for plant cooldown II-l Partial loss of emergency feedwater 30 Use Figure for Transient of loss of offsite power II-m Safe Shutdown — — Covered by Transient of loss of offsite power II-m Safe Shutdown — — Covered by Transient of loss of offsite power II-m Safe Shutdown — — Covered by Transient of loss of offsite power II-m Safe Shutdown — — Covered by Transient of loss of offsite power III-m Safe Shutdown — — Covered by Transient of loss of offsite power III-a Small loss of coolant accident 5 … … … III-a Small steam line break 5 … … … III-c Complete loss of flow 5 … … … III-d Small feedwater line break 5 … … … | ll-h | Emergency feedwater cycling | 700 | | | |
| II-j Excessive feedwater flow — Covered by Transient for reactor trip from full power i II-k Loss of offsite power with natural circulation cooldown — Covered by Transient for plant cooldown II-I Partial loss of emergency feedwater 30 Use Figure for Transient of loss of offsite power II-m Safe Shutdown — Covered by Transient of loss of offsite power II-m Safe Shutdown — Covered by Transient of loss of offsite power Level C Service Condition — Covered by Transient for plant cooldown III-a Small loss of coolant accident 5 III-b Small steam line break 5 III-c Complete loss of flow 5 III-d Small feedwater line break 5 III-e SG tube rupture 5 Level D Service Condition 1 IV-a Large loss of coolant accident 1 IV-a Large loss of coolant accident 1 IV-b Large steam line break 1 IV-c RCP locked rotor 1 IV-d Control rod ejection 1 IV-e Large feedwater | II-i | Cold over-pressure | 30 | | | |
| II-k Loss of offsite power with natural circulation cooldown — Covered by Transient for plant cooldown II-I Partial loss of emergency feedwater 30 Use Figure for Transient of loss of offsite power II-m Safe Shutdown — Covered by Transient for plant cooldown II-m Safe Shutdown — Covered by Transient for plant cooldown II-m Safe Shutdown — Covered by Transient for plant cooldown Level C Service Condition — — Covered by Transient for plant cooldown III-a Small loss of coolant accident 5 … … III-b Small steam line break 5 … … … III-c Complete loss of flow 5 … … … … … III-d Small feedwater line break 5 … <td>II-j</td> <td>Excessive feedwater flow</td> <td></td> <td>Covered by Transient for reactor trip from full power ii)</td> | II-j | Excessive feedwater flow | | Covered by Transient for reactor trip from full power ii) | | |
| II-I Partial loss of emergency feedwater 30 Use Figure for Transient of loss of offsite power II-m Safe Shutdown — Covered by Transient for plant cooldown Level C Service Condition 5 | ll-k | Loss of offsite power with natural circulation cooldown | | Covered by Transient for plant cooldown | | |
| II-m Safe Shutdown Covered by Transient for plant cooldown Level C Service Condition Covered by Transient for plant cooldown III-a Small loss of coolant accident 5 III-b Small steam line break 5 III-c Complete loss of flow 5 III-d Small feedwater line break 5 III-d Small feedwater line break 5 III-e SG tube rupture 5 Level D Service Condition 1 IV-a Large loss of coolant accident 1 IV-b Large steam line break 1 IV-c RCP locked rotor 1 IV-d Control rod ejection 1 IV-e Large feedwater line break 1 IV-e Large feedwater line break 1 V-a Primary-side hydrostatic test 10 | II-I | Partial loss of emergency feedwater | 30 | loss of offsite power | | |
| Level C Service Condition III-a Small loss of coolant accident 5 III-b Small steam line break 5 III-c Complete loss of flow 5 III-d Small feedwater line break 5 III-d Small feedwater line break 5 III-d Small feedwater line break 5 III-e SG tube rupture 5 Level D Service Condition 1 IV-a Large loss of coolant accident 1 IV-b Large steam line break 1 IV-c RCP locked rotor 1 IV-d Control rod ejection 1 IV-e Large feedwater line break 1 IV-e Large feedwater line break 1 V-a Primary-side hydrostatic test 10 | II-m | Safe Shutdown | — | Covered by Transient for plant cooldown | | |
| III-a Small loss of coolant accident 5 III-b Small steam line break 5 III-c Complete loss of flow 5 III-d Small feedwater line break 5 III-e SG tube rupture 5 III-e SG tube rupture 5 III-e SG tube rupture 5 IV-a Large loss of coolant accident 1 IV-a Large steam line break 1 IV-b Large steam line break 1 IV-c RCP locked rotor 1 IV-d Control rod ejection 1 IV-e Large feedwater line break 1 IV-e Large feedwater line break 1 V-a Primary-side hydrostatic test 10 | Level | C Service Condition | | _ | | |
| III-b Small steam line break 5 III-c Complete loss of flow 5 III-d Small feedwater line break 5 III-e SG tube rupture 5 III-e SG tube rupture 5 IV-a Large loss of coolant accident 1 IV-b Large steam line break 1 IV-c RCP locked rotor 1 IV-d Control rod ejection 1 IV-e Large feedwater line break 1 V-e Large feedwater line break 1 V-a Primary-side hydrostatic test 10 | III-a | Small loss of coolant accident | 5 | | | |
| III-c Complete loss of flow 5 III-d Small feedwater line break 5 III-e SG tube rupture 5 III-e SG tube rupture 5 Level D Service Condition 1 IV-a Large loss of coolant accident 1 IV-b Large steam line break 1 IV-c RCP locked rotor 1 IV-d Control rod ejection 1 IV-e Large feedwater line break 1 IV-e Primary-side hydrostatic test 10 | III-b | Small steam line break | 5 | | | |
| III-d Small feedwater line break 5 III-e SG tube rupture 5 Level D Service Condition 1 IV-a Large loss of coolant accident 1 IV-b Large steam line break 1 IV-c RCP locked rotor 1 IV-d Control rod ejection 1 IV-e Large feedwater line break 1 IV-e Primary-side hydrostatic test 10 | III-c | Complete loss of flow | 5 | | | |
| III-e SG tube rupture 5 Level D Service Condition 1 IV-a Large loss of coolant accident 1 IV-b Large steam line break 1 IV-c RCP locked rotor 1 IV-d Control rod ejection 1 IV-e Large feedwater line break 1 IV-e Primary-side hydrostatic test 10 | III-d | Small feedwater line break | 5 |] | | |
| Level D Service Condition IV-a Large loss of coolant accident 1 IV-b Large steam line break 1 IV-c RCP locked rotor 1 IV-d Control rod ejection 1 IV-e Large feedwater line break 1 IV-e Darge feedwater line break 1 V-a Primary-side hydrostatic test 10 | III-e | SG tube rupture | 5 | | | |
| IV-a Large loss of coolant accident 1 IV-b Large steam line break 1 IV-c RCP locked rotor 1 IV-d Control rod ejection 1 IV-e Large feedwater line break 1 IV-e Large feedwater line break 1 V-a Primary-side hydrostatic test 10 | Level | D Service Condition | | | | |
| IV-b Large steam line break 1 IV-c RCP locked rotor 1 IV-d Control rod ejection 1 IV-e Large feedwater line break 1 IV-e Large feedwater line break 1 V-a Primary-side hydrostatic test 10 | IV-a | Large loss of coolant accident | 1 | | | |
| IV-c RCP locked rotor 1 IV-d Control rod ejection 1 IV-e Large feedwater line break 1 IV-e Description 1 V-a Primary-side hydrostatic test 10 | IV-b | Large steam line break | 1 | | | |
| IV-d Control rod ejection 1 IV-e Large feedwater line break 1 Test Condition 1 V-a Primary-side hydrostatic test 10 | IV-c | RCP locked rotor | 1 |] | | |
| IV-e Large feedwater line break 1 Test Condition V-a Primary-side hydrostatic test 10 | IV-d | Control rod ejection | 1 | | | |
| V-a Primary-side hydrostatic test 10 | IV-e | Large feedwater line break | 1 | | | |
| V-a Primary-side hydrostatic test 10 | Test C | Condition | | | | |
| | V-a | Primary-side hydrostatic test | 10 | | | |

7.3.4 Load Combinations

The loading conditions analyzed consist of various combinations of pressure, temperature and external loads consistent with the Design Specification (Reference 4). The load combinations analyzed are listed in Table 7-20.

The names used for the external loads refer directly to names specified in Table 7-12-1 through 7-18.

| System Operating Cond | dition and Service Levels | Service Loading Combination | | |
|-----------------------|--|---|--|--|
| Design | Design | Design Pressure Dead Weight Loads Thermal Loads (note 1) Seismic(1/3 SSE) Loads (note 5) | | |
| Normal | Level A | Level A Thermal & Pressure Transients Dead Weight Loads Thermal Loads (note 1) | | |
| Upset | Level B | Level B Maximum Pressure (note 2) Level B Thermal & Pressure Transients Dead Weight Loads Thermal Loads (note 1) Seismic(1/3 SSE) Loads Level C Maximum Pressure Level C Thermal & Pressure Transients(note 3) Dead Weight Loads Thermal Loads (note 1) | | |
| Emergency | Level C | | | |
| Faulted | Level D | Level D Maximum Pressure Dead Weight Loads Thermal Loads (note 1) +/- SRSS(Seismic(SSE) Loads + Accident Loads (note 4)) | | |
| Test | Test | Dead Weight Loads Hydrostatic Test Pressure | | |
| Note 1 | Applied to the nozzles stress evaluation.(NB-32 | within the limits of reinforcement in the primary (27.5) | | |
| Note 2 | Applied for the primary s | tress evaluation. | | |
| Note 3 | Applied for the bolts inste | ead of Maximum Pressure. | | |
| Note 4 | It more than one Accider | nt Load, each is to be analyzed separately. | | |
| Note 5 | Design Loads are larger | than CDS, so result is conservative. | | |

Table 7-20 Load Combinations

8.0 METHODOLOGY

The ABAQUS computer program was used to determine mechanical loads, temperature distributions, stresses, and deformations. ABAQUS is a general purpose finite element computer program used by MHI in the design and analysis of nuclear components. ABAQUS is available in the public domain and has been used by MHI for U.S. replacement steam generator and replacement reactor vessel closure head projects.

8.1 Heat Transfer Coefficients and Thermal Analysis

Heat transfer coefficients on the inner and outer surfaces of the component are required to define the temperature distributions during transients. Classical Handbook heat transfer equations (References 6, 7 and 8) were used to calculate the heat transfer coefficients.

Finite element thermal analyses were performed for all Level A and Level B transients to define the time-dependent temperature distributions in the structure. The RCS fluid temperature versus time curves were applied to all wetted surfaces with appropriate heat transfer coefficients as described, above. The outside surfaces under the vessel insulation were assumed to be adiabatic.

8.2 Stress Analysis

Finite element stress analyses were performed for given loads and boundary conditions. The thermal loads were input from the thermal solution into each node of the structural model. The calculation of NB-3200 stress intensities, stress classifications, and stress evaluations were performed using a set of in-house proprietary computer programs (CLASS2D, CLASS3D, EDITSTRS, EVALPRI, EVALSEFAV, and RATCHET). These programs are described in Section 9.

Figure 8-1 shows the stress evaluation process.

CLASS2D and CLASS3D classify the stresses resulting from pressure, thermal loads, and externally applied forces and moments. EDITSTRS creates input files for the stress evaluation programs EVALPRI, EVALSEFAV, and RATCHET. EVALPRI and EVALSEFAV quantify the primary stress intensities, quantify primary plus secondary stress ranges, and perform the fatigue evaluation. The RATCHET program was used for the thermal ratchet evaluation.

Detailed assumptions associated with the finite element model development and mesh refinement are documented in the detailed calculations. Finite element models were verified by hand calculations using handbook equations.

Figure 8-1 Stress Evaluation Process

8.3 Fatigue Analysis Model and Method

The fatigue analysis was based on the rules of NB-3216.2 and NB-3222.4(e) of ASME Section III (Reference 1). These rules require calculation of the total stress, including the peak stress, to determine the allowable number of stress cycles for the specified service loadings at every point in the structure. In some cases, a fatigue strength reduction factor (FSRF) was used where the peak stress could not be accurately calculated. In these cases, the factor was applied to the surface stress produced by a linear stress distribution (through the wall thickness) that produced the identical displacement / rotation of the section (i.e. equivalent structural equilibrium).

The design transients for ASME Level A and B service conditions (Table 7-19) were used in the evaluation of cyclic fatigue. The effect of 300 cycles of a 1/3 SSE seismic event was also included in the evaluation of cyclic fatigue, treated as a Level B service condition. The number of cycles assumed for the 1/3 SSE seismic event was based on a fatigue usage for a single SSE event of 20 cycles.

9.0 COMPUTER PROGRAMS USED

Refer to Figure 8-1 for a visual description of the Stress Evaluation Process. Table 9-1 provides a brief description of each of the computer programs used.

| No. | Program Name | Version | Description |
|-----|-----------------|---------|---|
| 1 | ABAQUS | 6.7-1 | ABAQUS is a general purpose finite element computer code that performs a wide range of linear and nonlinear engineering simulations |
| 2 | CLASS2D | 4.0 | CLASS2D is an MHI code for classifying the stresses for axisymmetric models |
| 3 | CLASS3D | 4.0 | CLASS3D is an MHI code for classifying the stresses for 3D solid models |
| 4 | EDITSTRS | 4.0 | EDITSTRS is an MHI code that creates input files for the stress evaluation programs |
| 5 | EVALPRI | 7.0 | EVALPRI is an MHI code that performs the primary stress evaluation |
| 6 | EVALSEFAV | 7.0 | EVALSEFAV is an MHI code that performs the secondary stress and fatigue evaluation |
| 7 | RATCHET | 8.0 | RATCHET is an MHI code that evaluates thermal stress ratcheting |
| 8 | ASMETEMP | 1.0 | ASMETEMP is an MHI code that creates temperature files for the stress evaluation program |
| 9 | EB3500 | 3.0 | EB3500 is an MHI code that perform the general primary membrane stress evaluation |

 Table 9-1 Computer Program Description

All these computer programs were verified and validated and are maintained in compliance with the MHI quality assurance program. The computer programs were validated using one of the methods described below. Verification tests demonstrate the capability of the computer program to produce valid results for the test problems encompassing the range of permitted usage defined by the program documentation.

- Hand calculations
- Known solution for similar or standard problem
- Acceptable experimental test results
- Published analytical results
- Results from other similar verified programs

10.0 STRUCTURAL ANALYSIS RESULTS

This Section summarizes the results of the analyses for the seven parts of the RCP that were analyzed. Dimensional drawings, illustrations of the finite element models and summaries of the stress and fatigue analysis results are presented for each of the seven parts of the RCP. The results of the stress and fatigue analyses presented are generally conservative. It is expected that the resulting stress values and fatigue usage factors would be lower if more detailed calculations were performed; but since the results of the analyses all meet the ASME Code allowable limits, further analysis is not necessary.

10.1 Pump Casing Lugs

This section describes the stress evaluation results for the pump casing lugs. Three lugs are located on the side of the casing. Figures 10-1-1 shows the dimensions of the casing lugs.

10.1.1 Pump Casing Lugs Modeling and Analysis

Figure 10.1-1 Pump Casing Lug Dimensions

Figure 10.1-2 Pump Casing Lug Finite Element Model

10.1.2 Pump Casing Lugs Stress Results

The calculated stresses divided by the corresponding allowable values and the cumulative fatigue usage factors for the most limiting locations in the RCP casing lugs are summarized in Table 10-1.

| | Part | | | | | | |
|-----------|------|----------------|---------------------------|--------------------|--|--------------------|----------------------------|
| Condition | | Pi | rimary Str | ess | Primary plus Secondary Stress | Thermal Ratchet | Fatigue Usage Factor |
| | | P _m | P∟or P∟+P _b | Triaxial Stress | P _L +P _b +Q | | |
| | | | | | | | |
| Design | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| Level A/B | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| Level C | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| Level D | | | | | | | |
| | | | | | | | |

Table 10-1 Summary of Results for Pump Casing Lugs (1/2)

| Condition | | | | | | | |
|-----------|------|----------------|---------------|---|-----------------------------------|----------------------------|---|
| | Part | Primary Stress | | Primary plus Secondary Stress Ratchet | | Fatigue Usage Factor | |
| | | P _m | P∟or P∟+P₀ | Triaxial Stress | P _L +P _b +Q | Thermal Ratchet | |
| | | | | | | | J |
| Test | | | | | | | |
| | | | | | | | J |
| | | | | | | | J |
| | | | | | | | |
| | | | | | | | |

Table 10-1 Summary of Results for Pump Casing Lugs (2/2)

10.2 Discharge Nozzle

This section describes the stress evaluation results for the discharge nozzle. The discharge nozzle is located on the bottom of the casing. Figures 10-2-1 shows the dimensions of the discharge nozzle.

10.2.1 Discharge Nozzle Modeling and Analysis

Figure 10.2-1 Discharge Nozzle Dimensions

Figure 10.2-2 Discharge Nozzle Finite Element Model

10.2.2 Discharge Nozzle Stress Results

The calculated stresses divided by the corresponding allowable values and the cumulative fatigue usage factors for the most limiting locations in the discharge nozzle are summarized in Table 10-2.

| | | | 1 | | | | |
|-----------|------|----------------|---------------------------|--------------------|--|--------------------|----------------------------|
| Condition | Part | Primary Stress | | | Primary plus Secondary Stress | Thermal Ratchet | Fatigue Usage Factor |
| | | P _m | P∟or P∟+P _b | Triaxial Stress | P _L +P _b +Q | | |
| | | | | | | | |
| Design | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| Level A/B | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| Level C | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| Level D | | | | | | | |
| | | | | | | | |

 Table 10-2
 Summary of Results for Discharge Nozzle (1/2)

| Condition | Part | Primary Stress | | | Primary plus Secondary Stress | Thermal Ratchet | Fatigue Usage Factor |
|-----------|------|----------------|---|--------------------|--|--------------------|----------------------------|
| | | P _m | P _L or P _L +P _b | Triaxial Stress | P _L +P _b +Q | | |
| | ſ | | | | | | J |
| Test | | | | | | | |
| | | | | | | | J |
| | | | | | | | J |
| | | | | | | | |
| | | | | | | | |
| C C | | | | | | | J |

Table 10-2 Summary of Results for Discharge Nozzle (2/2)

10.3 Suction Nozzle

This section describes the stress evaluation results for the suction nozzle. The suction nozzle is located on the side of the casing. Figures 10-3-1 shows the dimensions of the suction nozzle.

10.3.1 Suction Nozzle Modeling and Analysis

Figure 10.3-1 Suction Nozzle Dimensions

Figure 10.3-2 Suction Nozzle Finite Element Model

10.3.2 Suction Nozzle Stress Results

The calculated stresses divided by the corresponding allowable values and the cumulative fatigue usage factors for the most limiting locations in the suction nozzle are summarized in Table 10-3.

| Condition | Part | Primary Stress | | | Primary plus Secondary Stress | Thermal Ratchet | Fatigue Usage Factor |
|-----------|------|----------------|---------------------------|--------------------|--|--------------------|----------------------------|
| | | P _m | P∟or P∟+P _b | Triaxial Stress | P _L +P _b +Q | | |
| | | | | | | | |
| Design | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| Level A/B | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| Level C | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| Level D | | | | | | | |
| | | | | | | | |

Table 10-3 Summary of Results for Suction Nozzle (1/2)

| Condition | Part | Primary Stress | | | Primary plus Secondary Stress | Thermal Ratchet | Fatigue Usage Factor |
|-----------|------|----------------|---------------|--------------------|--|--------------------|----------------------------|
| | | P _m | P∟or P∟+P₀ | Triaxial Stress | P _L +P _b +Q | | |
| | ſ | | | | | | J |
| Test | | | | | | | |
| | | | | | | | j |
| | | I | I | 1 | I | 1 |] |
| | | | | | | | |
| | | | | | | | |
| l | | | | | | | J |

Table 10-2 Summary of Results for Suction Nozzle (2/2)

10.4 Main Flange

This section describes the stress evaluation results for the main flange. The main flange is bolted on the top of the casing via the diffuser flange. Figures 10-4-1 shows the dimensions of the main flange.

10.4.1 Main Flange Modeling and Analysis

Figure 10.4-1 Main Flange Dimensions

Figure 10.4-2 Main Flange Finite Element Model

10.4.2 Main Flange Stress Results

The calculated stresses divided by the corresponding allowable values and the cumulative fatigue usage factors for the most limiting locations in the main flange are summarized in Table 10-4.

| Condition | Part | Primary Stress | | | Primary plus Secondary Stress | Thermal Ratchet | Fatigue Usage Factor |
|-----------|------|----------------|---|--------------------|--|--------------------|----------------------------|
| | | P _m | P _L or P _L +P _b | Triaxial Stress | P _L +P _b +Q | | |
| Design | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| Level C | | | | | | | |
| Level o | | | | | | | |
| Level D | | | | | | | |
| LeverD | | | | | | | |
| Tost | | | | | | | |
| 1651 | | | | | | | |
| | | | | | | | |

Table 10-4 Summary of Results for Main Flange

10.5 No.1 and 2 Seal Housings

This section describes the stress evaluation results for the No.1 & No.2 seal housings. The seal housings are bolted on the main flange. Figures 10-5-1 shows the dimensions of the seal housings.

Figure 10.5-1 Seal Housings Dimensions

10.5.1 Seal Housings Modeling and Analysis

Figure 10.5-2 Seal Housings Finite Element Model

10.5.2 Seal Housings Stress Results

The calculated stresses divided by the corresponding allowable values and the cumulative fatigue usage factors for the most limiting locations in the seal housings are summarized in Table 10-5.

| Condition | Part | Primary Stress | | | Primary plus Secondary Stress | Thermal Ratchet | Fatigue Usage Factor |
|-----------|------|----------------|---------------------------|--------------------|--|--------------------|----------------------------|
| | | P _m | P∟or P∟+P _b | Triaxial Stress | P _L +P _b +Q | | |
| Design | | | | | | | |
| Design | | | | | | | |
| | | | | | | | |
| Level A/D | | | | | | | |
| | | | | | | | |
| Level C | | | | | | | |
| | | | | | | | |
| LeverD | | | | | | | |
| | | | | | | | |
| Test | | | | | | | |
| | | | | | | | |

Table 10-5 Summary of Results for Seal Housings

10.6 Diffuser Flange

This section describes the stress evaluation results for the diffuser flange. The diffuser flange is located between the casing and the main flange. Figures 10-6-1 shows the dimensions of the diffuser flange.

Figure 10.6-1 Diffuser Flange Dimensions

10.6.1 Diffuser Flange Modeling and Analysis

Figure 10.6-2 Diffuser Flange Finite Element Model

10.6.2 Diffuser Flange Stress Results

The calculated stresses divided by the corresponding allowable values and the cumulative fatigue usage factors for the most limiting locations in the diffuser flange are summarized in Table 10-6.

| Condition | Part | Primary Stress | | | Primary plus Secondary Stress | Thermal Ratchet | Fatigue Usage Factor |
|-----------|------|----------------|---------------------------|--------------------|--|--------------------|----------------------------|
| | | P _m | P∟or P∟+P _b | Triaxial Stress | P _L +P _b +Q | | |
| Design | | | | | | | |
| Boolgii | | | | | | | |
| Level A/B | | | | | | | |
| | | | | | | | |
| Level C | | | | | | | |
| | | | | | | | |
| l evel D | | | | | | | |
| | | | | | | | |
| Test | | | | | | | |
| | | | | | | | |
| | | | | | | |) |

Table 10-6 Summary of Results for Diffuser Flange

10.7 Heat Exchanger Tubing

10.7.1 Heat Exchanger Tubing Modeling and Analysis

Figure 10.7-1 Heat Exchanger Tube Dimensions

Figure 10.7-2 Heat Exchanger Tubing Finite Element Model

10.7.2 Heat Exchanger Tubing Stress Results

The calculated stress and corresponding allowable values and the cumulative fatigue usage factor for the most limiting locations in the RCP thermal barrier heat exchanger are summarized in Table 10.7-1.

| Condition | Part | Primary Stress | | | Primary plus Secondary Stress | Thermal Ratchet | Fatigue Usage Factor | |
|------------|------|----------------|---|--------------------|--|--------------------|----------------------------|--|
| | | P _m | P _L or P _L +P _b | Triaxial Stress | P _L +P _b +Q | | | |
| Design | | | | | | | | |
| | | | | | | | | |
| l evel A/B | | | | | | | | |
| | | | | | | | | |
| l evel C | | | | | | | | |
| | | | | | | | | |
| l evel D | | | | | | | | |
| | | | | | | | | |
| Test | | | | | | | | |
| | | | | | | | Ţ | |
| | | | | | | | | |

Table 10-7-1 Summary of Results for Heat Exchanger Tubing

11.0 REFERENCES

- 1. ASME Boiler and Pressure Vessel Code, Section III, Nuclear Power Plant Components, 2001 Edition through 2003 Addenda
- 2. ASME Boiler and Pressure Vessel Code, Section II Material Specification, 2001 Edition through 2003 Addenda
- 3. N0-FB10L01 Rev.2, "US-APWR General ASME Design Specification for Class 1 and CS Components", February 2010
- 4. N0-F600001, Rev.4, "Reactor Coolant Pump Design Specification", December 2010
- 5. "Manual of Steel Construction", Eighth Edition, American Institute of Steel Construction Inc.
- 6. Warren M. Rohsenow, James P. Hartnett and Yung I. Cho, "Handbook of Heat Transfer", Third Edition, McGraw Hill, 1998
- 7. Eckert and Drake, "Heat & Mass Transfer", Second Edition, 1959
- 8. Frank Kreith, Principles of HEAT TRANSFER third edition, 1976
- 9. N0-F600102 Rev.4, "Reactor Coolant Pump Design Drawings", February 2011