

From: Singal, Balwant
Sent: Wednesday, April 06, 2011 3:02 PM
To: Slough, Rob
Cc: Hope, Timothy; Hicks, Jack
Subject: Relief Requests C-6 and C-7 - Request for Additional Information (TACs ME5216 and ME5215)

By letters dated December 15, 2010 (Agencywide Documents Access and Management System (ADAMS), Accession Nos. ML103560593 and ML103560594), Luminant Generation Company, LLC (the licensee), submitted Relief Requests (RRs) C-6 and C-7 for Comanche Peak Nuclear Power Plant, Unit 1.

In order to complete its review of the licensee's submittal, the U.S. Nuclear Regulatory Commission (NRC) staff has the following request for additional information (RAI).

Generic Question Pertaining to RRs C-6 and C-7

1. Please confirm that all examinations included in RRs C-6 and C-7 resulted in no indications, recordable or otherwise. If indications were found, please provide a full description of each indication.

RR C-7

2. Based on the precedent referenced in RR C-7 (Letter No. TXX-98170, dated July 22, 1998, RR C-9), weld TBX-2-1180-2-2 received a coverage of 73% for the First ISI Interval examination. Does RR C-7 apply to the same weld discussed in the RR C-9 (weld TBX-2-1180-2-2)? If so, please explain why the coverage for this inspection cycle was 41.47% as compared to the prior 73% coverage?

These RAIs were discussed with Mr. Rob Slough of your organization. Mr. Slough confirmed that a clarification conference call is not required and agreed to provide the RAI response within 30 days from the date of this e-mail.

Thanks.

Balwant K. Singal
Senior Project Manager (Comanche Peak, and STP)
Nuclear Regulatory Commission
Division of Operating Reactor Licensing
Balwant.Singal@nrc.gov
Tel: (301) 415-3016
Fax: (301) 415-1222

