COMPT B5

COMPT F1(L)

COMPT L5

COMPT H6

COMPT D1

PNL J

COMPT F1(R)

COMPT E3

COMPT F6

COMPT L2

COMPT S1

COMPT S2

FUTURE

SPARE

MECH EQPT RM SUMP PUMP A 1WE-EMOT-067

CONTROL XFMR

FUTURE

BUS TIE BKR

SPARE

FUTURE

MECH EQPT ROOM SUMP PUMP B 2WE-EMOT-068

SCREEN WASH PUMP DISCH MOV 2KE-EMOT-533-B

SCREEN WASH PUMP

SPARE

COMPT L(L)

COMPT L1(L)

COMPT L1(H)

COMPT M3(R)

COMPT M3(L)

COMPT C4

COMPT C3

COMPT U4

COMPT E2

COMPT A(L)

COMPT SG(R)

HEAT TRACE ALARM AND DISTR PNL XFMR 2MC-ET-5A

ELECTRICAL EQPT ROOM UNIT HEATER 2B-B 2VP-ENTR-314

ELECTRICAL EQPT ROOM DUCT HEATER-2B 2VP-ENTR-319

480V POWER RECEPTACLES

SPARE

SPARE

SPARE

SPARE

SPARE

SPARE

SPARE

SPARE

FUTURE

FUTURE

FUTURE

FUTURE

FUTURE

COMPT G3

COMPT G4

COMPT G5

COMPT E6

COMPT E4

COMPT L6(R)

COMPT K5

COMPT C5

COMPT F2

COMPT E

HEAT TRACE ALARM AND DISTR PNL XFMR 1MC-ET-5B

CONTROL XFMR

SPARE

SPARE

SPARE

SPARE

SPARE

FOR LIST OF NOTES AND REFERENCE DWGS SEE 9KW2733-E1-1

NO.	DATE	DESCRIPTION
5	9/27	ECN 927 - ADDED HEAT TRACE PNLS.
4	7/29/75	ECN 729-CHANGED TIE BKR TRIP DEVICE, ADDED REF TO NOTE ECN 734-EXCHANGE COMPT, ECN SI-MINOR CHANGES.
3	4/22/75	ECN 442 - MOVED 1SW PUMP B STRAINER FROM TE TO NON-TE SIDE OF BUS. SI - VARIOUS MINOR REVISIONS.
2	1/29/75	ECN 151 - ADDED DISCH MOV & ADDITIONAL SPARE COMPTS. SI-MINOR CHGS PER MFR'S INFO.
1	1/25/74	ECN 35 - ADDED 'C' RELAYS. - 11/74 - ADDED ECN 478 ETC, SI-MINOR REV

DSGN S. BRIDGES
DWN W. P. MANLEY
CHKD W. PERRY
SUPV J. E. LOW

INSP
ENGINEER

INTAKE PUMPING STATION
UNIT 2

SINGLE LINE
480V MCC 2E3-B
2E1-EMCC-68-B

BELLEFONTE NUCLEAR PLANT
TENNESSEE VALLEY AUTHORITY
DIVISION OF ENGINEERING DESIGN

Q

SUBMITTED	RECOMMENDED	APPROVED
Robert F. Hunt	K. H. Hinkle	John E. Hackney

KNOXVILLE 12 20 74 | 88 E | 9KW2733-E1-2 R5

RECORD DRAWING AS CONSTRUCTED

COMPANION DWG 9KW2733-E1-1

INSPECTED AND APPROVED FOR ISSUE
DESIGN PROJECT MANAGER

PRINTS REQD-R
80 ea
PROJ DWG SIZE
P H
WE 4
EE
CE
AD
CO
ED
MD
PD
SW
NL
PA

PRC APERTURE CARD

Docket # 50-438
Control # 8304050536
Date 3-25-83
REGULATORY DOCKET FILE