COMPT NO	LOAD	UNID	DETAIL	LOAD SIZE	SCHEMATIC DWG REFERENCE
A1	MAIN BREAKER	IED-52NA-ARF		SEE KEY DIAG	
A1L	24V DC BAT CHGR 1A VOLTAGE	IES-EBC-10	A	6KVA	5GWO640-EP-02
A1R	AIRBORNE RADIATION MON 1CR	1IR-ILPA-006	A	3.4KVA	5GWO640-IR-02
B2	CONT BLDG EL 629 AHU ISOLATION MOV	OVL-IFCV-019	H	0.13HP	5GW0640-VK-23
B3	CONT BLDG EL 629 AHU ISOLATION MOV	OVL-IFCV-268	H	0.13HP	5GW0640-VK-23
B4	HOT MACHINE SHOP SUPPLY FAN	IVA-EMOT-C05	D	20HP	5GWI740-VA-28
B5	STARTUP CIRCULATION PUMP 1A	ICR-EMOT-002	G	50HP	5GWI640-CR-03
		1145			
C1	MAIN STEAM SAFETY VALVE RM EXH VENTILATION FAN	IVC-EMOT-815	D	5HP	5GWO740-VC-17
C2	CONT BLDG BATTERY BOARD ROOM AHU	OVL-EMOT-S67	D	15HP	5GWO640-VK-22
C3	ANNULUS PURGE SUPPLY FAN	IVH-EMOT-010	M	15HP	5GWI740-VH-04
C4	RB INSTR ROOM PURGE SUPPLY FAN	IVH-EMOT-008	M	3HP	5GWI740-VH-02
C5	COMPONENT DRAIN PUMP 1A1	IWL-EMOT-004	D	10HP	5GWI740-WD-04
C6	CRD ROOM 1 AHU	IV4-EMOT-020	D	7.5HP	5GWI740-VA-18
D1	HOT SAMPLING ROOM HOOD FAN	IV4-EMOT-183	D	5HP	5GWI740-VA-18
D2	SPARE	IED-	H		
D3	LC SURGE TANK 1A STATION CR SUPPLY MOV	IKC-IFCV-015	H	0.13HP	5GWI740-KC-05
D4	RCP P1A2 SEAL AREA COOLER INLET MOV	IKC-IFCV-153	J	0.7HP	5GWI740-KC-10
D5	RB NORMAL CIRCULATION FAN	IVH-EMOT-107	L	20HP	5GWI740-VH-05
E1	RC PUMP P1A1 SPACE HTR	INC-EHTR-005	U	0.94KW	5GWI740-NC-02
E2	RB INSTR ROOM AHU	IVJ-EMOT-001	L	3HP	5GWI740-VJ-05
F4	STARTUP DISCHARGE TO CONDENSER ISLN MOV	ICR-IFCV-048	H	3.3HP	5GWI640-CR-05
F5	CONT BLDG EL 629 AHU	OVL-EMOT-208	G	40HP	5GWO640-VK-22
F1	CRDM STRUCTURE FAN	IVH-EMOT-114	L	7.5HP	5GWI740-VH-07
F2	SPARE	IED-	L		
F4	24,48,125V BATTERY RM AHU	OVL-EMOT-S65	D	3 HP	5GWO640-VK-22
F5	CORE FLOOD TK TANKS RECIRCULATION PUMP	INL-EMOT-200	E	20HP	5GWO640-NL-06
F6	FUTURE-12 INCH 11/4	IEC-			
G1	ANNULUS PURGE EXH FAN	IVH-EMOT-001	AC	15HP	5GWI740-VH-02
G2	CRDM STRUCTURE FAN	IVH-EMOT-118	L	7.5HP	5GWI740-VH-08
G3	LB ESF MECH EQPT ROOM EXHAUST FAN	OVK-EMOT-310	E	0.75HP	5GWO640-VK-16
G4	CONT BLDG EL 610 AHU	OVL-EMOT-205	G	30HP	5GWO640-VK-20
G6	FUTURE-6 INCH	IED-			
H1	MCC LOSS OF VOLTAGE RLY			SEE KEY DIAG	
H2	120V-1P CKT BKR COMPT			SEE KEY DIAG	
H4	FUSE COMPT			SEE KEY DIAG	
H5	MCC CONTROL TRANSFORMER AND DISCONNECT SWITCH			SEE KEY DIAG	

S1

COMPT NO.	LOAD	UNID	DETAIL	LOAD SIZE	SCHEMATIC DWG REFERENCE
J1L	HOT INSTR SHOP HOT WATER HTR	OVP-EHTR-761	A	9KW	5GWO740-VP-02
J1R	CCS LIQUID RADN MON #1 FOR	1IR-ILPA-037	A	2.5KVA	5GWO640-IR-02
J2L	VITAL BATTERY RM 1D DUCT HTR	IVA-EHTR-187	A	25KW	5GWI740-VA-21
J2R	24V DC BAT CHGR 1B ALT FOR	IES-EBC-11	A	6KVA	5GWO640-EP-02
J3	TECHNICAL SUPPORT CENTER CHILLER ROOM AHU 1	OVL-EMOT-W24	D	2HP	5GWO640-VK-16
J4	TECHNICAL SUPPORT CENTER AIR HANDLING UNIT 1	OVL-EMOT-W22	AY	20HP	
J6	OIL PUMP FOR WATER CHILLER # 1	OVL-EMOT-D11	D	0.25HP	
K1	SEC K BUS GRD RLY	IED-50GS-488	SEE KEY DIAG		
K3L	AB 480V PWR RCPT A,B,C,D	IED-ERCP-007	B		5GWI740-ED-18
K3R	HOT MACH SHOP MONORAIL HOIST	IMM-MMHE-093	A		5GWI740-MM-03
K4	FUTURE-12 INCH	IED-			
K5	TECHNICAL SUPPORT CENTER CHILLED WATER PUMP 1	OVL-EMOT-W30	G	40HP	
L1L	6 TON SEAL INJ FILTER HOIST	IMM-MMHE-018	A	7.5HP	5GWI740-MM-02
L1R	VITAL BAT RM 1F DUCT HTR	IVA-EHTR-188	A	25KW	5GWI740-VA-21
L2	STEAM GEN 1A STARTUP ISLN MOV	ICR-IFCV-018	H	1.6HP	5GWI640-CR-04
L3	SPARE	IED-	L		
L4	RCP P1A2 SEAL AREA COOLER OUTLET MOV	IKC-IFCV-156	J	0.7HP	5GWI740-KC-10
L6	PURGE COMPR FOR WATER CHILLER # 1	OVL-EMOT-012	D	0.5HP	
M1	RCP P1B2 SEAL AREA COOLER INLET MOV	IKC-IFCV-204	J	0.7HP	5GWI740-KC-13
M2	RCP P1B2 SEAL AREA COOLER OUTLET MOV	IKC-IFCV-207	J	0.7HP	5GWI740-KC-13
M4	ST GEN A STARTUP & RECIRC MAIN STEAM LINE DRAIN	ISM-IFCV-321	J	1.6HP	5GWI640-SM-02
M5	SPARE	IED-	J		
N1L	ZONE 1A EL 686 UNIT HTR	IVA-EHTR-190	A	15KW	5GWI740-VA-19
N1R	PURGE EXH ROOM UNIT HTR B	OVC-EHTR-140	A	20KW	5GWO740-VC-11
N2	SPARE	IED-	H		
N3	FUTURE-12	IED-			
N4	SPARE	IED-	J		
N5	WD RB NORMAL SUMP PUMP SUCTION MOV	IWL-IFCV-080	J	0.33HP	5GWI740-WD-05
P1L	ZONE 1A EL 629 RB INTERFACE A UH	IVA-EHTR-194	A	.6KW	5GWI740-VA-19
P1R	ZONE 1A EL 669 RB INTERFACE A UH	IVA-EHTR-192	A	5KW	5GWI740-VA-19
P2L	EL 649 MAIN ST SAF VLV RM 1A UH	IVC-EHTR-146	A	25KW	5GWO740-VC-05
P2R	PURGE EXH RM UNIT HTR A	OVC-EHTR-139	A	20KW	5GWO740-VC-11
P3	STEAM GEN 1A STARTUP MAIN FW ISLN MOV	ICR-IFCV-029	H	2.6HP	5GWI640-CR-06
P4	SPARE	IED-	J		
P5	SPARE	IED-	J		
Q1	MKUP LETDOWN ORIFICE SHUTOFF MOV	INV-IFCV-042	H	0.66HP	5GWI740-NV-11
Q2	MKUP PURIFICATION BYPASS TO BLEED MOV (MU-HV11)	INV-IFCV-347	H	0.13HP	5GWI740-NV-35
Q3L	TENDON PMP DISTR PNL A	IWE-ET-275	A	375KVA	5GWI740-WE-07
Q3R	FUTURE - HALF COMPT	IED-			
Q4	SPARE	IED- 1007	J		
Q5	SPARE	IED-	C		

S1



NOTES

1. 480V MOTOR CONTROL CENTER PROVIDED ON TVA CONTRACT NO 76KS-86242 BY GOULD/ITE.
2. ALL MOLDED CASE 480V CIRCUIT BREAKERS ARE 3P, 600V WITH 4W INTERRUPTING RATING OF NOT LESS THAN 25,000 RMS SYMMETRICAL AMPS AT 480V. CIRCUIT BREAKERS SHOWN WITH SHUNT TRIP COILS HAVE A TRIP COIL CAPABLE OF OPERATING AT 55 PERCENT RATED VOLTAGE. ALL 100A FRAME 480V CIRCUIT BREAKERS ARE ITE "HE" SERIES AND THE 400A FRAME 480V CIRCUIT BREAKERS ARE ITE "JL" SERIES
3. ALL MOLDED CASE 120V CIRCUIT BREAKERS AR 1P, 100A FRAME, THERMAL MAGNETIC WITH 15A TRIP, ITE "BQ" SERIES
4. ALL 5A AND 10A FUSES ARE GOULD/SHAWMUT, 2AMP-TRAP, FORM 600, WIDGET TYPE 2
5. FUSES IN THE POWER CIRCUITS ARE GOULD/SHAWMUT CLASS "J" CURRENT LIMITING FUSES ARE REQUIRED TO PROVIDE REDUNDANT PROTECTION FOR PRIMARY CONTAINMENT PENETRATIONS
6. ALL CONTROL TRANSFORMERS ARE 1Ø, 480-120V WITH GROUNDED SECONDARY. THE SECONDARY OF THE 150 VA TRANSFORMER IS FUSED WITH A 1 5A DUAL-ELEMENT TIME-DELAY, BUSSMAN TYPE FNQ FUSE. THE SECONDARY OF THE 350 VA TRANSFORMER IS FUSED WITH 2 3 5A DUAL-ELEMENT TIME-DELAY GOULD/SHAWMUT TYPE TRM FUSE
7. GROUND FAULT PROTECTION (50GS), ITE TYPE GRM-FC, PICKS UP AT APPROXIMATELY 10 AMPS PRIMARY CURRENT WITH NO INTENTIONAL TIME DELAY.
8. THE PRIMARY OF THE 5KVA CONTROL POWER TRANSFORMER IS FUSED WITH A 15A TIME DELAY, BUSSMAN TYPE JHC-15 FUSE. S1
9. THE MOTOR CONTROL CENTER ARRANGEMENT IS CONTROLLED BY THE FRONT VIEW LOCATED ON THIS DRAWING. COMPARTMENT CONFIGURATION CONTROL DRAWINGS ARE REFERENCED IN THE MOTOR CONTROL CENTER COMPUTERIZED CIRCUIT SCHEDULE. THE MOTOR CONTROL CENTER COMPUTERIZED CIRCUIT SCHEDULE DOCUMENTS DEVICE RATINGS AND ADJUSTABLE CIRCUIT BREAKER SETTINGS. S1
10. THIS MCC IS NON-CLASS 1E LOCATED IN A CATEGORY I STRUCTURE
11. ALL AGASTAT RELAYS ARE OF THE 7000 SERIES

REFERENCED DRAWINGS AND DOCUMENTS

PLANT AC AUXILIARY POWER SYSTEM SINGLE LINE	2GWO720-RP-01
SINGLE LINE DIAGRAM 480V SWITCHGEAR 1AA2	2AW1726-ED-1
480V NORMAL AC AUXILIARY POWER DISTRIBUTION SYSTEM SCHEMATIC	5GWI740-ED-18
480V MCC COMPARTMENT TYPICALS	5GW0747-RP
480V MCC 1A3 COMPUTERIZED CIRCUIT SCHEDULE	5AC1762-ED

SYMBOLS:

- MAGNETIC TRIP ONLY CIRCUIT BREAKER (ADJUSTABLE)



Docket # 50-438
Control # 8304050536
Date 3-25-83 of Document
REGULATORY DOCKET FILE

PRC APERTURE CARD

S1 COMPANION DWG: 5AW1732-ED-03
5AW1732-ED-02 HAS BEEN VOIDED

INSPECTED AND APPROVED FOR ISSUE

REV NO	ECN NO	DATE	DESCRIPTION	CHK	SUP	ENGR	MGR	SUBMITTED	APPD
4	886, 1007, 1174 1189, S1, 1191								
	ADDED "VL" SYSTEM LOAD TO COMPTS C2, F4, J4, J5, K5 AND L6. ADDED "WE" SYSTEM LOAD TO COMPT Q3L. ADDED "NL" SYSTEM LOAD TO COMPT F5. CHANGED UNID IN COMPT C1. ADDED LOAD SIZE AND SCHEMATIC DWG REF COLUMN TO TABLES, REVISED NOTES 9 AND 9 AND MOVED KEY DIAGRAM TO SHEET 3. ADDED "VL" SYSTEM LOAD TO COMPT J3.								
3	614, S1	12-6-80	BJH	RLC	RWB	WEH	-	WRL	AS	KMH
	MOVE LOAD IVA-EMOT-C05 FROM COMPT J3 TO B4 BECAUSE OF HORSEPOWER INCREASE MADE MINOR CHANGES								
2	S1	4-23-81	RCH	RWB	MJH	-	SAW	LES	CAW	
	RECORD DWG REV FOR THE MCC COMPUTERIZED CKT SCH HISTORICAL DATA BASE R4.								
1	62, S1	4-15-76	AH	BM 200	RGL	MRT	CTG	-	CTG	LLS	KMH
	ADDED 4KV IN CB NOMINAL KV. 80 FROM PER ECN 62. INCORPORATED S1(6/5/75, UFR RL. FOR ECN S1=KAY150).								

ORGN: ROGER F. HALL
DRFTR: C. A. TEMPLETON 6/10/3/85
CHKD: D. M. LASHLEY
SUPV: W. L. ALDRIDGE
INSP:
ENGINEER: C. T. Barner

SCALE: EXCEPT AS NOTED

AUXILIARY BUILDING UNIT 1

SINGLE LINE
480V MCC 1A3
1ED-EMCC-48

BELLEFONTE NUCLEAR PLANT
TENNESSEE VALLEY AUTHORITY
DIVISION OF ENGINEERING DESIGN

N

SUBMITTED	RECOMMENDED	APPROVED
C. T. Barner	G. L. Gomyo	R. M. Bolger

KNOXVILLE 12-6-74 | 88 | E | SAW1732-ED-1 R4

RECORD DRAWING AS CONSTRUCTED