NOTES:
1. FOR SYMBOLS AND ADDITIONAL NOTES SEE SHEET 01.
2. 52H CONTACTS ARE SHOWN IN THEIR "OPEN" POSITION AND THEIR DESIGNATION IS SUFFIXED WITH "-IN OR -OUT TO INDICATE THEY ARE CLOSED WHEN THE BREAKER IS RACKED IN OR RACKED OUT RESPECTIVELY.

SYMBOLS:
- -LOW VOLTAGE SWITCHGEAR TERMINAL
- -MEDIUM VOLTAGE SWITCHGEAR TERMINAL

6900V-480V TRANSFORMER FEEDER FOR 1XC1

480V SWGR SUPPLY BKR 52N FOR 1XC1

480V SWGR EMER TIE BKR 52E FOR 1XC1

480V SWGR DC BUS FOR 1XC1

PRC APERTURE CARD

REV	DESCRIPTION
3	1133 — REPLACED 3 AMP FUSES WITH 6 AMP FUSES
2	SI — CHANGED LOW VOLTAGE SWGR TERM. SYMBOL & MINOR CHANGES.
1	SI — ADDED INFORMATION ON TIME DELAY RELAYS, REPOSITION UNITS & GEN. REVISION PER SI

SCALE: EXCEPT AS NOTED

GENERAL
UNIT 1

SYSTEM SCHEMATIC 480V NORMAL AC AUXILIARY POWER DISTRIBUTION SYSTEM

BELLEFONTE NUCLEAR PLANT
TENNESSEE VALLEY AUTHORITY
DIVISION OF ENGINEERING DESIGN

SUBMITTED	RECOMMENDED	APPROVED
W.K. Wehby	R.L. Springer	R.M. Bridges
KNOXVILLE	1-11-77	88 E 66W1740-ED-15 R3

INSPECTED AND APPROVED FOR ISSUE

50-438
50-439
DATE 3-25-83
REGULATORY DOCKET FILE