



- NOTES:
- FOR INTERNAL DETAILS SEE WESTINGHOUSE ELECTRIC CO DRAWING C031302-2 ON CONTRACT 75C5-15160-2
 - ALL UNIQUE IDENTIFIERS ARE PREFIXED WITH OXE UNLESS OTHERWISE NOTED.
 - FOR INTERNAL DETAILS SEE GENERAL ELECTRIC CO DRAWING 212-8109 SH-1 ON CONTRACT 75C5-15160-2
 - FOR INTERNAL DETAILS SEE GENERAL ELECTRIC CO DRAWING DT-D248146 SH-1 ON CONTRACT 74-823198
 - HAND SWITCH CONTACT CLOSURES THAT ARE MADE BEFORE BREAK ARE INDICATED BY ASTERISKS.
 - STUD ID OF RELAY 503B-50C MUST BE 2104000.
 - FOR CT GROUND PROTECTION SEE PCB 50292 (98M0540-XE-01). WIRE NUMBER PREFIX AND RELAY NUMBER FOR PCB 50338 WILL BE 50C AND 64-50C RESPECTIVELY.

PRC
APERTURE
CARD

Bucket # 50-438
Control # 930 4650 532
Date 3-25-83
REGULATORY DOCKET FILE

REV	ECN NO.	DATE	DSGN	ORGN	CHG	APP	TRNG	INSP	INSTR	APPR
1	1029	11-10-79
2	1029	11-10-79
3	1029	11-10-79
4	1029	11-10-79
5	1029	11-10-79
6	1029	11-10-79
7	1029	11-10-79
8	1029	11-10-79
9	1029	11-10-79
10	1029	11-10-79
11	1029	11-10-79
12	1029	11-10-79

SW: TCHYARD

WIRING DIAGRAMS
500KV AC SCHEMATIC SHEET 2
BAYS 3 AND 4

BELLEVILLE NUCLEAR PLANT
TENNESSEE VALLEY AUTHORITY
DIVISION OF ENGINEERING DESIGN

SUBMITTED: Robert J. Hammett
RECOMMENDED: R.H. Henderson
APPROVED: John C. McWhorter

INSPECTED AND APPROVED FOR ISSUE: R. McWhorter
DESIGN PROJECT MANAGER

KNOXVILLE 9-20-76 88 E 98M0540-XE-02

THIS DRAWING IS UNDER CONFIGURATION CONTROL