



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

April 27, 2011

Mr. M. J. Ajluni
Nuclear Licensing Director
Southern Nuclear Operating Company, Inc.
40 Inverness Center Parkway
P. O. Box 1295, Bin - 038
Birmingham, AL 35201-1295

SUBJECT: VOGTLE ELECTRIC GENERATING PLANT, UNITS 1 AND 2 – CLOSEOUT OF
GENERIC LETTER 2008-01, "MANAGING GAS ACCUMULATION IN
EMERGENCY CORE COOLING, DECAY HEAT REMOVAL, AND CONTAINMENT
SPRAY SYSTEMS" (TAC NOS. MD7892 AND MD7893)

Dear Mr. Ajluni:

On January 11, 2008, the U.S. Nuclear Regulatory Commission (NRC) issued Generic Letter (GL) 2008-01, "Managing Gas Accumulation in Emergency Core Cooling, Decay Heat Removal, and Containment Spray Systems" (Agencywide Documents Access and Management System (ADAMS), Accession No. ML072910759). The stated purpose of GL 2008-01 was (a) to request addressees to submit information to demonstrate that the subject systems are in compliance with the current licensing and design bases and applicable regulatory requirements, and that suitable design, operational, and testing control measures are in place for maintaining this compliance; and, (b) to collect the requested information to determine if additional regulatory action is required.

GL 2008-01 requested that licensees provide the following information within 9 months of the date of the GL:

- (a) A description of the results of evaluations that were performed pursuant to requested actions specified in the GL. This description should provide sufficient information to demonstrate that you are or will be in compliance with the quality assurance criteria in Sections III, V, XI, XVI, and XVII of Appendix B to Title 10 of the *Code of Federal Regulations*, Part 50 and the licensing basis and operating license as those requirements apply to the subject systems;
- (b) A description of all corrective actions, including plant, programmatic, procedure, and licensing basis modifications that you determined were necessary to assure compliance with these regulations; and,
- (c) A statement regarding which corrective actions were completed, the schedule for completing the remaining corrective actions, and the basis for that schedule.

In your letters dated October 10, 2008 (ADAMS Accession No. ML082880119), January 21, 2009 (ADAMS Accession No. ML090220333), January 20, 2010 (ADAMS Accession No. ML100220234), and July 28, 2010 (ADAMS Accession No. ML102140115), you provided information in response to the GL. The NRC staff has reviewed the submitted information and has concluded that the licensee has acceptably addressed each request.

M. Ajluni

- 2 -

Consequently, your GL response is considered closed and no further information or action is requested of you with the exception of any commitments you have made with respect to the GL responses. Notwithstanding, the NRC's Region II staff may decide to perform (and would contact you to schedule) an inspection using Temporary Instruction (TI) 2515/177, "Managing Gas Accumulation in Emergency Core Cooling, Decay Heat Removal, and Containment Spray Systems (NRC Generic Letter 2008-01)" (ADAMS Accession No. ML082950666). The TI 2515/177 is confirmatory in nature in that it directs NRC inspectors to selectively verify that the licensee has implemented or is in the process of acceptably implementing the commitments, modifications, and programmatically controlled actions described in the licensee's response to GL 2008-01 and the plant-specific information supports a conclusion that subject systems operability is reasonably ensured.

If you have any questions regarding this letter, please feel free to contact Patrick Boyle at (301) 415-3936.

Sincerely,

A handwritten signature in black ink, appearing to read "Patrick G. Boyle", with a stylized flourish at the end.

Patrick G. Boyle, Project Manager
Plant Licensing Branch II-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-424 and 50-425

cc: Distribution via Listserv

M. Ajluni

- 2 -

Consequently, your GL response is considered closed and no further information or action is requested of you with the exception of any commitments you have made with respect to the GL responses. Notwithstanding, the NRC's Region II staff may decide to perform (and would contact you to schedule) an inspection using Temporary Instruction (TI) 2515/177, "Managing Gas Accumulation in Emergency Core Cooling, Decay Heat Removal, and Containment Spray Systems (NRC Generic Letter 2008-01)" (ADAMS Accession No. ML082950666). The TI 2515/177 is confirmatory in nature in that it directs NRC inspectors to selectively verify that the licensee has implemented or is in the process of acceptably implementing the commitments, modifications, and programmatically controlled actions described in the licensee's response to GL 2008-01 and the plant-specific information supports a conclusion that subject systems operability is reasonably ensured.

If you have any questions regarding this letter, please feel free to contact Patrick Boyle at (301) 415-3936.

Sincerely,

/RA/

Patrick G. Boyle, Project Manager
Plant Licensing Branch II-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-424 and 50-425

cc: Distribution via Listserv

DISTRIBUTION:

Public
LPL2-1 R/F
RidsNrrDorlLpl2-1 Resource
RidsNrrPMVogtle Resource
RidsRgn2MailCenter Resource
RidsNrrLAMOBrien Resource

RidsOgcRp Resource
RidsNrrDssSrxs Resource
RidsAcrrAcnw_MailCTR Resource
AUIses, NRR
JGall, NRR

ADAMS Accession No. ML11101A097

*transmitted by memo dated 4/6/11

OFFICE	NRR/LPL2-1/PM	NRR/LPL2-1/LA	NRR/SRXB/BC	NRR/LPL2-1/BC	NRR/LPL2-1/PM
NAME	PBoyle	MOBrien	AUIses*	GKulesa	PBoyle
DATE	4/20/11	4/26/11	04/06/11	4/27/11	4/27/11

OFFICIAL RECORD COPY