

From: Paige, Jason
Sent: Tuesday, April 12, 2011 11:36 AM
To: Abbatiello, Tom
Cc: Abbott, Liz; Hoffman, Jack; Tiemann, Philip; Tomonto, Bob
Subject: Turkey Point EPU - Instrumentation and Controls (EICB) Request for Additional Information - Round 3

Tom,

Below is a request for additional information (RAI) regarding the Turkey Point extended power uprate license amendment request. On April 12, 2011, you stated that a call is not needed to discuss the draft RAI sent to you via email. The below RAI reflects the question that was sent to you and agreed upon by Florida Power & Light Company (FPL). FPL agreed upon providing its responses within 30 days of the date of this email. If you have any questions, feel free to contact me.

EICB-3.1 Table 3-11 of WCAP-17070-P, Rev. 0 (page 43 & page 44) indicates that the Safety Analysis Limits of "Overtemperature ΔT " and "Overpower ΔT " are Function (11), which refers to Note 11, "As noted in Figure 7.2-1 of the UFSAR". Will Note 11 be revised so that Figure 7.2-1 of the UFSAR will be replaced with Figure 2.8.5.0-2 "Illustration of OT ΔT and OP ΔT Protection" on the page 2.8.5.0-39 of Attachment 4 of Licensee Amendment Request?

Jason Paige, Turkey Point Project Manager
Plant Licensing Branch II-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation
US Nuclear Regulatory Commission
Phone: (301) 415-5888