

NRR-PMDAPEm Resource

From: Feintuch, Karl
Sent: Tuesday, April 05, 2011 4:41 PM
To: 'Jeff.kitsembel@psc.state.wi.us'
Subject: ME4011 pertaining to Kewaunee Power Station - State Consultation

April 5, 2011

Jeff Kitsembel
Public Service Commission of Wisconsin
P.O. Box 7854
Madison, WI 53707-7854
608-266-9658
Jeff.kitsembel@psc.state.wi.us

Subj: TAC No. ME4011 pertaining to Kewaunee Power Station - State Consultation

This email documents a phone call to you on April 5, 2011, at approximately 4:30 PM ET. I customarily call, leave a message if no one answers the call, and send the information below, to minimize the need for note taking. In this instance the message service recording indicated that your message feature may not be available. Please accept the following information for the purpose of the State Consultation pertaining to license amendments for the Kewaunee Power Station..

Pursuant to 10CFR50.91(b), "State Consultation", I am notifying you that the NRC is currently processing an amendment (internally identified at this time as TAC Number ME4011) for the Kewaunee Power Station (KPS). The NRC staff has determined that the amendment request involves no significant hazards consideration. The analysis on the issue of no significant hazards consideration is published in the *Federal Register* on page 75 FR 48374 (dated August 10, 2010)

Kewaunee Power Station requested an amendment to its Renewed Operating License to revise its current licensing basis documents to allow use of new automatic load tap changers (LTCs) on new transformers that provide offsite power to KPS. The revised CLB documents are the KPS Updated Safety Analysis Report (USAR) section 8.2 and the Technical Specifications (TS) Bases section B3.7. The TS are not revised.

The current amendment is in response to application dated June 1, 2010 (Agencywide Documents Access management System (ADAMS) Accession No. ML101590218), as supplemented by letters dated January 18, 2011 (ADAMS Accession No. ML110250287), and March 14, 2011 (ADAMS Accession No. ML110740158). The supplements did not expand the scope of the application and did not change the Commission's proposed no significant hazards consideration determination as it appeared in 75 FR 48374

You may contact me if you have any comments on this amendment.

Karl Feintuch
Project Manager
USNRC
301-415-3079

Hearing Identifier: NRR_PMDA
Email Number: 6

Mail Envelope Properties (26E42474DB238C408C94990815A02F094C09C3B073)

Subject: ME4011 pertaining to Kewaunee Power Station - State Consultation
Sent Date: 4/5/2011 4:41:06 PM
Received Date: 4/5/2011 4:41:00 PM
From: Feintuch, Karl

Created By: Karl.Feintuch@nrc.gov

Recipients:
"Jeff.kitsembel@psc.state.wi.us" <Jeff.kitsembel@psc.state.wi.us>
Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

| Files | Size | Date & Time |
|--------------|-------------|------------------------|
| MESSAGE | 2318 | 4/5/2011 4:41:00 PM |

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: