



APR 13 2011

L-2011-145
10 CFR 50.90

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 2055-0001

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Withdrawal of License Amendment Request (LAR) No. 210, Proposed Changes to
Turkey Point Technical Specifications Regarding D.C. Sources
Surveillance Requirements

References:

1. M. Kiley (FPL) to U.S. Nuclear Regulatory Commission (L02011-072), Proposed Changes to Turkey Point Technical Specifications Regarding D.C. Sources Surveillance Requirements License Amendment Request (LAR) No. 210
2. Email from Jason Paige (NRC) to Olga Hanek (FPL), Re : Turkey Point 3 & 4 Acceptance Review: Changes to Technical Specifications Regarding DC Sources Surveillance Requirements LAR No. 210 (TAC ME5775 & ME5776)

In Reference 1, Florida Power & Light (FPL) requested a License Amendment to Operating Licenses DPR-31 and DPR-41 for Turkey Point Units 3 and 4. The proposed amendment would have modified Technical Specification (TS) Surveillance Requirements (SR) 4.8.2.1 pertaining to periodic verification of battery bank capacity and intercell and connection resistance. In Reference 2, the NRC recommended that the licensee either supplement the amendment request or withdraw and resubmit the license amendment request (LAR) in accordance with TSTF-500 (when approved). In subsequent discussions with the NRC on April 5th and 7th, the NRC clarified their suggestion by requesting that FPL withdraw the LAR and submit TS changes similar to those recently accepted by the NRC on Cooper, Wolf Creek, Callaway, Catawba, and McGuire. This change would add table(s) of battery resistance values to the Technical Specifications.

Based on the NRC's recommendations, FPL has decided to withdraw the referenced LAR and resubmit accordingly in the near future.


Should you have any questions regarding this submittal, please contact Mr. Robert J. Tomonto, Licensing Manager, at 305-246-7327.

A001
NRR

Turkey Point Nuclear Plant
Docket Nos. 50-250 and 50-251
License Amendment Request No. 210

L-2011-145
Page 2 of 2

Very truly yours,

A handwritten signature in black ink, appearing to read "Michael Kiley", with a long, sweeping flourish extending to the right.

Michael Kiley
Vice President
Turkey Point Nuclear Plant

cc: USNRC Regional Administrator, Region II
USNRC Project Manager, Turkey Point Nuclear Plant
USNRC Senior Resident Inspector, Turkey Point Nuclear Plant
Mr. W. A. Passetti, Florida Department of Health