

WBN2Public Resource

From: Clark, Mark Steven [msclark0@tva.gov]
Sent: Thursday, April 07, 2011 1:25 PM
To: Poole, Justin
Subject: WBT-D-2782.pdf - Adobe Acrobat Standard
Attachments: WBT-D-2782.pdf - Adobe Acrobat Standard.pdf

Hearing Identifier: Watts_Bar_2_Operating_LA_Public
Email Number: 304

Mail Envelope Properties (7AB41F650F76BD44B5BCAB7C0CCABFAF1816A014)

Subject: WBT-D-2782.pdf - Adobe Acrobat Standard
Sent Date: 4/7/2011 1:25:12 PM
Received Date: 4/7/2011 1:25:47 PM
From: Clark, Mark Steven

Created By: msclark0@tva.gov

Recipients:
"Poole, Justin" <Justin.Poole@nrc.gov>
Tracking Status: None

Post Office: TVANUCXVS2.main.tva.gov

Files	Size	Date & Time
MESSAGE	3	4/7/2011 1:25:47 PM
WBT-D-2782.pdf - Adobe Acrobat Standard.pdf		80539

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Response to Request for Loose Parts Monitoring System Qualification Documents

Westinghouse DMIMS-DX In-Containment equipment environmental specifications

The Westinghouse Digital Metal Impact Monitoring System (*DMIMS-DX*) is designed to meet or exceed all the requirements of United States Nuclear Regulatory Commission Regulatory Guide (RG) 1.133, Rev. 1, "Loose Part Detection Program for the Primary System of Light-Water-Cooled Reactors." Section C-1.g of the RG states the following:

g. *Operability for Seismic and Environmental Conditions.*

Components of the loose-part detection system within containment should be designed and installed to perform their function following all seismic events that do not require plant shutdown, i.e., up to and including the Operating Basis Earthquake (OBE). Recording equipment need not function without maintenance following the specified seismic event provided the audio or visual alarm capability remains functional. The system should also be shown to be adequate by analysis, test, or combined analysis and test for the normal operating radiation, vibration, temperature, and humidity environment.

The seismic qualification of the *DMIMS-DX* in-containment equipment is summarized in EQ-QR-33-WBT, Rev. 0, "Seismic Evaluation of the Digital Metal Impact Monitoring System (DMIMS-DX) for Watts Bar Unit 2." provided to TVA under Reference 2.

Westinghouse is providing TVA with the *DMIMS-DX* in-containment equipment listed below. The environmental specification for the equipment is listed, along with the normal environmental conditions. The normal environmental conditions for a Westinghouse containment are reported in Tables 6-1 and 6-2 from WCAP 8587 Rev. 6, "Methodology for Qualifying Westinghouse WRD Supplied NSSS Safety Related Electrical Equipment". These tables are attached.

- **5357C52G01 – Accelerometer with 4' integral hardline cable**

Radiation: Specification: Gamma dose \geq 200 R/hr with a TID of 10^8 R

Vibrations: Specification: 200g (Peak) Maximum

Temperature: Specification: -65°F to 625°F at sensor face, max of 185°F at connector

Humidity: Specification: 5% to 95% relative humidity

- **5359C29G44 – 120' soft line cable assembly**

Radiation: Specification: Radiation resistant, no specification given

Vibrations: Specification: No specification given

Temperature: Specification: -140°F to 302°F on the cable, max of 185°F at connectors

Humidity: Specification: 95%, connector should be the same as the hard line cable.

- **2657C47G01 – Charge Preamplifier**

Radiation: Specification: Radiation resistant, no specification given

Vibrations: Specification: No specification given

Temperature: Specification: 40°F to 212°F

Humidity: Specification: No specification given