

Official Transcript of Proceedings  
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards  
Materials, Metallurgy and Reactor Fuels

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Wednesday, April 6, 2011

Work Order No.: NRC-819

Pages 1-142

**NEAL R. GROSS AND CO., INC.**  
**Court Reporters and Transcribers**  
**1323 Rhode Island Avenue, N.W.**  
**Washington, D.C. 20005**  
**(202) 234-4433**

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

SUBCOMMITTEE ON MATERIALS, METALLURGY AND

REACTOR FUELS

+ + + + +

WEDNESDAY

APRIL 6, 2011

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Subcommittee met at the Nuclear  
Regulatory Commission, Two White Flint North, Room  
T2B1, 11545 Rockville Pike, at 1:30 p.m., Dr. Joy  
Rempe, Chair, presiding.

SUBCOMMITTEE MEMBERS PRESENT:

JOY REMPE, Chair

SAID ABDEL-KHALIK

J. SAM ARMIJO

DENNIS C. BLEY

MICHAEL CORRADINI

DANA A. POWERS

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 HAROLD B. RAY  
2 WILLIAM J. SHACK  
3 JOHN D. SIEBER  
4 JOHN W. STETKAR

5

6 NRC STAFF PRESENT:

7 CHRISTOPHER L. BROWN, Designated Federal  
8 Official

9 RAJ IYENGAR

10 ANTONIOS ZOULIS

11 CHARLES HARRIS

12 SEE MENG WONG

13 AL CSONTOS

14 RICHARD LEE

15 ED FULLER

16 EMMITT MURPHY

17 KEVIN COYNE

18 SELIM SANCAKTAR

19

20

21

22

23

24

25

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

T-A-B-L-E O-F C-O-N-T-E-N-T-S

Opening Remarks and Objectives

Joy Rempe . . . . . 4

Staff Opening Remarks

Raj Iyengar . . . . . 7

Origin of the User Need

User Need Details and Regulatory Implications

Antonios Zoulis . . . . . 10

RES Project Plan to Address NRR User Need

Raj Iyengar . . . . . 16

Phenomenological Aspects of the C-SGTR

Richard Lee . . . . . 33

Technical Approach

Charles Harris . . . . . 72

Raj Iyengar . . . . . 80

Selim Sancaktar . . . . . 103

Committee Discussion

Joy Rempe . . . . . 127

Adjourn . . . . . 142

P-R-O-C-E-E-D-I-N-G-S

1:30 p.m.

CHAIR REMPE: This meeting will now come to order. This is a meeting of the Advisory Committee on Reactor Safeguards, Subcommittee for Materials, Metallurgy and Reactor Fuels.

I'm Dr. Joy Rempe, Chairman of today's subcommittee. Subcommittee members in attendance are Dr. William Shack, Sam Armijo, Dana Powers, Dennis Bley, Mr. Harold Ray, Mr. Jack Sieber and Dr. Said Abdel-Khalik. And we anticipate that Dr. Mike Corradini will be joining us later this afternoon.

Oh, excuse me. And Mr. John Stetkar is here. I apologize.

The purpose of this meeting is to receive an information briefing from staff in the Office of Nuclear Regulatory Research and the Office of Nuclear Reactor Regulation on enhanced risk assessment procedures for consequential steam generator tube rupture, C-SGTR, which are events in which steam generator tubes leak or fail as a consequence of high differential pressures and/or tube temperatures that occur in certain accident sequences.

Today we're going to be hearing about

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 guidance and tools being developed to support risk  
2 assessments of C-SGTR. The subcommittee will gather  
3 information, analyze relevant issues and facts and  
4 formulate proposed positions and actions as  
5 appropriate for deliberation by the full committee.

6 Christopher Brown is the designated  
7 federal official for this meeting.

8 The rules for participation in today's  
9 meeting have been announced as part of the notice of  
10 this meeting which was previously published in the  
11 *Federal Register* on March 22, 2011.

12 A transcript of the meeting is being  
13 kept and will be made available as stated in the  
14 *Federal Register* notice.

15 It's requested that speakers first  
16 identify themselves and speak with sufficient  
17 clarity and volume so that they can be readily  
18 heard.

19 Also, silence your cell phones, PDAs,  
20 BlackBerrys, et cetera.

21 We've not received any requests from  
22 members of the public to make oral statements or  
23 written comments.

24 Colleagues, the staff and industry have  
25 expended considerable resources over the last few

1 decades to better understand the safety implications  
2 and risks associated with C-SGTR events. Key  
3 previous activities include an assessment of  
4 temperature-induced creep rupture of the reactor  
5 coolant system and NUREG-1150 study, a  
6 representative analysis of the potential for induced  
7 containment bypass by an ad hoc NRC staff working  
8 group and NUREG-1570, and recent thermal hydraulic  
9 analyses and risk analyses as part of the steam  
10 generator action plan. Severe accident analyses  
11 performed as part of the state-of-the-art reactor  
12 consequence analyses, or SOARCA project, provide  
13 additional insights into the likelihood and impact  
14 of subsequent failure of the reactor hot leg shortly  
15 following a C-SGTR event.

16 Today we're going to hear about the  
17 research program proposed to address user need  
18 NRR-2010-005 support and development analytical  
19 bases and guidance for future risk assessments of  
20 consequential steam generator tube rupture events.  
21 This research program is being developed to assist  
22 risk-informed decision making related to C-SGTR. In  
23 particular, we'll hear about the staff's plan for  
24 evaluation of proposed modifications to existing  
25 requirements and in evaluating the risk significance

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 of SG tube degradation. In addition, the staff will  
2 discuss the software that's being developed to  
3 estimate SG probabilities for given RCS and  
4 secondary side conditions.

5 As we hear the staff's presentation, I'd  
6 like for us to focus our comments and offering  
7 suggestions on the revised plans when it's in its  
8 initial stages so it can be more easily redirected  
9 if needed. In addition, to assist us in providing  
10 these comments, I'd like to ask staff to identify  
11 what issues will and won't be addressed by your  
12 proposed plan so that all of us agree on what is and  
13 isn't being addressed and that the outstanding items  
14 that will not be resolved by the proposed research  
15 program as appropriate.

16 We're now going to proceed with the  
17 meeting and I would like to call upon Dr. Raj  
18 Iyengar, lead project manager for this effort, to  
19 begin.

20 DR. IYENGAR: Thank you very much. Good  
21 afternoon. It's indeed a pleasure and privilege to  
22 be spending this afternoon with such highly  
23 accomplished and committed experts.

24 MEMBER POWERS: Oh, let's not -- too  
25 much here. It won't help.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 DR. IYENGAR: I'll try again.

2 MEMBER CORRADINI: You get a do over.

3 One.

4 DR. IYENGAR: I'm Raj Iyengar. I'm from  
5 Division of Engineering, Office of Research and I  
6 would be pleased to -- along with the team members,  
7 we would be presenting to you the project status,  
8 early status of the consequential steam generator  
9 tube rupture.

10 This project originated from a User Need  
11 that NRR had requested Office of Research to  
12 conduct. Because this required multi-divisional  
13 effort with the Office of Research due to its  
14 technical complexities, even though this is a small  
15 to medium level project, we decided that it was  
16 prudent for us to develop a proper plan, project  
17 plan in accordance with our office instructions of  
18 research so that we can have a seamless technical  
19 coordination and information exchange between the  
20 various teams within research, as well as NRR.

21 This project plan was developed and  
22 discussed with NRR staff last year. And  
23 subsequently we engaged early on through an informal  
24 meeting with Dr. Powers. Dr. Powers was very  
25 interested in hearing about this project and the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 details of how we are going to be executing this  
2 project. And he did encourage us to meet again with  
3 Dr. Rempe and Dr. Shack, which we did in early  
4 January. And that's how we ended up here.

5 And so actually it's pretty early in the  
6 project, so we would like to get your feedback so  
7 that the path we are traveling on is not perilous  
8 and if there are any roadblocks that you anticipate,  
9 perhaps you can give advice and some insight so that  
10 we end with the simplified risk assessment tool.  
11 The difficulty is that there's so much complexity,  
12 technical complexity in the project, but yet at the  
13 end of it the NRR requires a simplified assessment  
14 tool. That is a big challenge. So I think this  
15 early engagement would be very beneficial for us and  
16 we thank you for participating and helping us  
17 through this effort.

18 Now with that said, I did want to say to  
19 you that Dr. Powers was so enthusiastic when I met  
20 with him, he did mention that it was such a juicy  
21 problem many times and that he was jealous. And he  
22 also said that you should -- and you should let the  
23 ACRS members work for you.

24 MEMBER CORRADINI: Do you have a tape of  
25 that conversation?

1 MEMBER POWERS: Everybody except  
2 Corradini. Corradini will set you back a ways.

3 MEMBER CORRADINI: That's what was said  
4 earlier today, too.

5 MEMBER POWERS: And it's true.

6 DR. IYENGAR: And that said, I will turn  
7 it over to my colleague from NRR, Antonios Zoulis.  
8 He will be giving the details of the User Need.

9 MR. ZOULIS: Good afternoon. Thank you,  
10 Raj.

11 I'm Antonios Zoulis from NRR, Division  
12 of Risk Assessment and I'll go over a little bit of  
13 the background, the tasks associated with the user  
14 need and give you a little brief summary of what we  
15 discussed.

16 Basically the committee and staff  
17 understood that the need to continue to do future  
18 research on the topic of consequential steam  
19 generator tube rupture. And for simplicity I will  
20 be referring to it as C-SGTR.

21 I want to emphasize that my team members  
22 will be going over each of these topics in great  
23 detail later on in the presentation and to give you  
24 the opportunity to interrupt. And as Commissioner  
25 Apostolakis said, the enjoyment of interrupting that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 he now misses the Chairman.

2 MEMBER POWERS: Don't encourage him,  
3 Antonios. They need no encouragement.

4 MR. ZOULIS: Basically what we did was  
5 we -- we're grouping these items into three areas:  
6 One is TH analyses. The other one has to do with  
7 materials and structural analysis. And finally, the  
8 risk assessment piece. But these issues were the  
9 ones that came out of the -- that we felt would  
10 require further work going forward and again  
11 involves further TH analysis to understand the  
12 phenomenon with Combustion Engineering plants. We  
13 wanted to update the steam generator flaw  
14 distributions so that we can incorporate that  
15 information when developing the probabilities for  
16 our -- on the chance of having a conflict of  
17 consequential steam generator tube rupture.

18 We then wanted to develop a simplified  
19 method to use when either an application comes in or  
20 an SDP analysis is required to -- that involves  
21 steam generator tube rupture. We have guidance or  
22 tools similar to the simplified LERF method to use  
23 in assessing that.

24 And finally, out of this endeavor we  
25 want kind of like a knowledge management effort

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 where we -- someone could go and find the history  
2 and all this stuff that was done in reference to C-  
3 SGTR.

4 MEMBER POWERS: There's no question that  
5 that last item is an item for the staff. I also  
6 point out that the problem that you have with the CE  
7 steam generator is a problem. I mean, the thermal  
8 hydraulic situation with the -- probably also arises  
9 in connection with the EPR where they have a  
10 similarly small plenum and small loop seal flat  
11 entry coming in a lower plenum and the steam  
12 generator. So it may have more --

13 MR. ZOULIS: More applications.

14 MEMBER POWERS: -- implications than  
15 just the CE plants.

16 MR. ZOULIS: Thank you. A little bit  
17 more background. The staff decided to pursue the  
18 further research items on a follow-on NRR User Need  
19 Memo. I have added the ML number for you. I'm sure  
20 you've all seen it, but for your convenience it's  
21 there. This approach was presented to the committee  
22 back in October of 2009 and it was found an  
23 acceptable way to resolve these ongoing research  
24 issues in the appropriate venue of the different  
25 offices and different organizations of the agency.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           So again, we've broken down into three  
2 areas: The thermal hydraulic analysis is going to  
3 focus on updating the CFD codes and the models to  
4 address the issues of Combustion Engineering-  
5 designed plants. We also wanted to find out how  
6 incore instruments and the tube failure -- what  
7 impact they have on natural circulation for both  
8 Westinghouse and Combustion Engineering plants.

9           MEMBER RAY: Dana, does this apply also,  
10 for example, to AP1000, which basically uses a CE  
11 steam generator?

12           MEMBER POWERS: It depends on the depth  
13 of the lower plenum and how flat the entry is into  
14 it, and how much internal mixing you get there.

15           Now, I would suspect that before --  
16 before I said anything about a particular plant,  
17 what you want them to do is develop this CFD code,  
18 then just go in and check for the amount of mixing  
19 that they get in those lower plena. And I mean, the  
20 nice thing about this CFD update is that once you  
21 have it it's pretty generic. I mean, it's just the  
22 boundary conditions that -- I mean, the boundary  
23 geometry that has to be changed.

24           MEMBER SIEBER: Yes, but all steam  
25 generators are subject to the configuration that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 determines how high the temperature gets.

2 MEMBER POWERS: That's right. That's  
3 right. Just how hot and how much Delta-T you get.

4 MEMBER SIEBER: Right. Yes, because  
5 it's a streaming effect.

6 MEMBER POWERS: Yes.

7 MR. ZOULIS: The next area was the  
8 materials and structural analysis. Again, as I  
9 mentioned before, one update, the steam generator  
10 flaw distributions for the current fleet  
11 incorporating the current operating history and  
12 improvements that industry has done over the last 10  
13 or 20 years in steam generator chemistry and  
14 integrity.

15 The structural part deals with the RCS  
16 components and it's prediction to RCS piping  
17 failure. And I'm sure is all going to understand,  
18 you know, the surge line or what's going to happen  
19 in terms of -- and during a severe accident how  
20 those components are going to behave and the  
21 phenomenon that influences the C-SGTR.

22 CHAIR REMPE: Could you comment on how  
23 good you think the industry flaw distribution update  
24 will be? How good is that data, the quality, and  
25 give us a little insights on that?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 DR. IYENGAR: Yes, Charlie?

2 MR. HARRIS: Hi, this is Charles Harris  
3 from the Office of Research; and I'll talk a little  
4 bit later in the slides on the flaw distributions,  
5 but your specific question, industry update, there  
6 is no industry update on flaw distribution. The  
7 information from the industry is contained in the  
8 in-service inspection reports. And here at NRC  
9 we'll go through that to update the information, but  
10 specifically from EPRI or any of the utilities  
11 there's no direct input on flaw distributions.

12 MR. ZOULIS: The third section involves  
13 the risk assessment portion. Here, when we get all  
14 the information, we want to be able to utilize it.  
15 As I mentioned earlier, in the applications that we  
16 do in NRR, specifically either an SDP or license  
17 amendment review -- and the whole purpose is to have  
18 efficient tools that allow the analyst to come with  
19 a best estimate answer that won't take up  
20 significant resources and time to do. And lastly,  
21 we said the summary report compiling the key  
22 insights and the state-of-knowledge.

23 So to summarize, what to understand the  
24 -- and further develop the steam generator tube  
25 rupture phenomenon and how it -- its implications to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 risk. Again, develop the efficient tools to be used  
2 by SRAs or risk analysts in either evaluating  
3 findings or risk-informed applications and any other  
4 future issues that we may not have foreseen. And  
5 again, document and develop the guidance to capture  
6 the information.

7 If there aren't any questions, I would  
8 like to allow Raj to continue on with his  
9 presentation. Thank you.

10 DR. IYENGAR: Thank you, Antonios. So  
11 as we saw that there were these three major  
12 components involved in developing this risk  
13 assessment tool, and so it just fell very nicely  
14 between the various divisions in RES, which of  
15 course as I mentioned earlier, requires continuous  
16 and intense coordination.

17 We did outline specific tasks involved  
18 in the process; 1.1 to 1.3. I don't want to go  
19 through this because it's a kind of a busy chart.

20 Just to let you know that we have  
21 identified other people who would be leading on the  
22 Office of Research side, as well as from the NRR.  
23 In essence, this project as it stands now has two  
24 external contracts from DRA and DSA and the Division  
25 of Engineering work. There are two elements to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 that. One is the updated flaw distributions for the  
2 steam generator tubes, which the corrosion and  
3 metallurgy branch will be leading. Charlie Harris  
4 will be leading that effort and he's trying to  
5 coordinate and work with the industry, too. And of  
6 course, as he said, looking at the in-service  
7 inspection to get all the information that's need.  
8 This is very critical information. Without that,  
9 any risk assessment took that you develop would not  
10 be accurate or appropriate.

11 And then there's another element of the  
12 work which involves the analysis and prediction of  
13 RCS other component failure, which will let us know  
14 whether the containment bypass has occurred or not.  
15 That would be done largely in house and at the DEE,  
16 which is the branch of component integrity branch of  
17 Al Csontos. And I've been penciled in to complete  
18 the analysis as in when we get the thermal hydraulic  
19 input from DSA.

20 Now, I did say that, you know, this is  
21 -- you know, the difficulty in this project is the  
22 coordination between the various divisions, but also  
23 we need information flowing from one side to another  
24 so that we can get all the analysis and the  
25 predictions done so that we can get a sound risk

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 assessment tool.

2 Here what I show you is the simplified  
3 flow chart, if you will, which just tells you we  
4 define these accident scenarios. And in MELCOR will  
5 be used to develop, you know, the thermal hydraulic  
6 input that would be fed into the RCS component  
7 analysis to let us know when the RCS component will  
8 fail, which is then -- will be fed into a  
9 calculator, a risk assessment calculator, which is  
10 part of a separate project. And that calculator  
11 will also have the updated flaw distribution so that  
12 you would in essence get the, you know, appropriate  
13 risk assessment for C-SGTR.

14 And additionally, there's some LERF  
15 assessment that's required and was requested by NRR.  
16 That will be handled as well. And in the end what  
17 we envision is we envision a simplified useful tool  
18 that the NRR staff can use to assess the risk  
19 assessment. And of course we will also compile and  
20 summarize all the activities that have gone on in  
21 this project.

22 So, what it requires is we do have very  
23 periodic meetings with RES staff, informal as well  
24 as formal meeting, monthly meetings. And we do  
25 expect to provide updates, frequent updates to NRR.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 And as I said, this is the start of our technical  
2 engagement with the ACRS and we hope to have one or  
3 two of them throughout the project as we go on.

4 The next slide is -- oh, it's deleted?

5 That's fine. It was too busy a chart.

6 That's okay. Just I'll play the Vizio, MS Vizio.

7 Yes, that's one. Just to tell you that, hey, we  
8 know how -- where the information has to come from,  
9 where it has to go and all of this end up in a final  
10 product.

11 Well, it was not part of a detailed  
12 discussion anyway, so I think, I don't know, whoever  
13 deleted it did me a favor.

14 CHAIR REMPE: Well actually; again I'll  
15 wait until Mr. Harris or Dr. Harris comes up and  
16 talks, but in that flow diagram that's where I got  
17 the impression that it had in here obtain flaw  
18 distribution from EPRI for CE and W plants. And so,  
19 I would like to at some point talk about that a  
20 little bit more and how that process is going to  
21 occur.

22 DR. IYENGAR: Most certainly.

23 CHAIR REMPE: Yes.

24 DR. IYENGAR: Charlie would talk to  
25 that.

1 CHAIR REMPE: Okay.

2 DR. IYENGAR: If there is any error,  
3 it's my fault in producing this chart here.

4 Now at the end of it, as I mentioned,  
5 the research products we envision are very  
6 simplified risk assessment tools. That's the key  
7 thing that NRR staff needs so that they can do their  
8 job appropriately and accurately.

9 MEMBER CORRADINI: What are they doing  
10 now without this? How are they accomplishing their  
11 tasks now because this is not here?

12 MR. ZOULIS: Fortunately, we haven't had  
13 issues that involve consequential steam generator  
14 tube rupture since I've been with the agency, which  
15 is about five years, and I think --

16 MEMBER CORRADINI: But you must be doing  
17 something.

18 MR. ZOULIS: Well, if an issue occurs,  
19 we have experts in research and as well as NRR,  
20 myself and others included, could assess the risk.  
21 It may take us a little longer than without this  
22 method, but we can still do it.

23 MEMBER CORRADINI: Well, I guess what  
24 I'm trying to get at is just -- let me just ask the  
25 question differently: The value added through this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 is more comprehensive with less uncertainly in what  
2 the staff is currently -- how the staff currently  
3 analyses these sorts of possibilities? I'm just  
4 trying to understand if today you're doing X and  
5 tomorrow you can do Y, the benefit between X and Y  
6 is what?

7 MR. ZOULIS: I think it's going to be  
8 a --

9 MEMBER CORRADINI: Faster, better,  
10 cheaper? What?

11 MR. ZOULIS: I think it's going to be a  
12 better understanding of the phenomenon of  
13 consequential steam generator tube rupture and its  
14 implication to risk.

15 MEMBER CORRADINI: Okay.

16 MR. ZOULIS: And that follows that is  
17 less uncertainty and more realistic numbers.

18 MEMBER CORRADINI: Thank you.

19 CHAIR REMPE: But there have been, years  
20 ago, analyses done with SCDAP/RELAP5 that again was  
21 based on limits with data and they would predict  
22 using structural-failure-type of correlations when a  
23 steam generator tube would fail. But I thought the  
24 benefit would be that you would (1) have better  
25 data, from what I've read; and you're going to try

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 and have a simpler tool when to have to go through  
2 these detailed assessments. Is that not a correct  
3 understanding of the situation?

4 MR. ZOULIS: That's correct.

5 MR. WONG: Can I make a comment?

6 CHAIR REMPE: Sure. Yes.

7 MR. WONG: I'm See Meng Wong and I'm the  
8 senior risk analyst in the NRR Division of Risk  
9 Assessment.

10 In response to Dr. Corradini, it is a  
11 question. Yes, we have developed guidance, but the  
12 guidance we have used; and as Antonios stated, we  
13 did not have with the last few years issues related  
14 to steam generator tube integrity, issues that we  
15 have to analyze extensively. But there was guidance  
16 developed before.

17 So, this project would I think -- will  
18 have to improve, you know, the tools that we have in  
19 existence. And so, that's why we are proposing this  
20 point.

21 MEMBER POWERS: So, let me see if I can  
22 offer some perspective here. The challenge we have  
23 faced since entering into the risk-informed world is  
24 understanding what happens in accidents that are not  
25 an initiated by pipe rupture, but they're initiated

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 by transient and station blackout events. And what  
2 we find is that eventually, sooner or later the  
3 reactor coolant system ruptures itself and we get a  
4 depressurization. If it ruptures itself in general  
5 locations, we get venting into the containment that  
6 looks indifferent from a pipe rupture.

7           Unfortunately, we can also rupture in a  
8 steam generator tube, which gives us a containment  
9 bypass. That has dramatically different  
10 consequences. So you would like to know for sure  
11 where you rupture in these accidents, especially as  
12 we find that the classic rupture-initiated accidents  
13 decline in probability in station blackouts and  
14 other transient events become the more dominant  
15 feature.

16           When we try to apply mechanistic models,  
17 accident analysis models. We find that the answer  
18 always comes back, well, it's a horse race. They in  
19 fact predict various locations depending on how they  
20 configure the analyses. But if they artificially  
21 arrest that location, it promptly fails at another  
22 location a few seconds, tens, maybe a 100 seconds  
23 later. so small in difference that you call into  
24 question how well do you know this sort of thing,  
25 how well do you know the piping system and where the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 failure will occur? Because it makes a huge  
2 difference to us where it occurs.

3 So, but what these gentlemen are trying  
4 to do is -- and focusing appropriately is the one  
5 that makes a difference is failing at the steam  
6 generator, too, because that has big implications  
7 and it has implications across the board; emergency  
8 planning implications, accident management  
9 implications, all kinds of things come in there.

10 So they're trying to say, gee, I don't  
11 really care whether it fails at a surge line or a  
12 nozzle. Either of those is about the same to me.  
13 What really makes a difference is for me to  
14 understand well that if it will fail at steam  
15 generator to give me a containment bypass. And  
16 quite frankly, our existing models you can -- well,  
17 calculate all these things out to six significant  
18 figures and what not, but the physical understanding  
19 there is poverty-stricken. The research has done  
20 enough work in the CFD area to say, well, we can  
21 inform these accident analysis codes about these  
22 things.

23 Some of these flow things and some of  
24 the heat transfer things, we really don't have that  
25 comprehensive understanding that allows us to make

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 confident predictions on these things. And it's a  
2 confidence and it's a classic risk analysis where  
3 risk is the product of probabilities times  
4 consequences. It happens that this one -- doesn't  
5 matter what the probability is. The consequences  
6 are so large that it over weighs everything else.

7 So I would say that's what they're --  
8 they're trying to get enough put into the accident  
9 analysis models that people will come back and not  
10 say it's a horse race. They'll say I can  
11 confidently say it will not fail at a steam  
12 generator tube, because that's the one that makes a  
13 difference. It fails at a surge line or a nozzle.  
14 Those are about the same.

15 MR. CSONTOS: And let me just add one  
16 thing; this is Al Csontos from Office of Research.

17 You know, that's where we're updating --  
18 the flaw distributions is one area that we're  
19 updating information. But another one that we're  
20 looking at; and I think Raj will talk about later,  
21 is we've done a lot of activities to mitigate  
22 against cracking, okay, on surge nozzles, hot leg  
23 nozzles, things like that, or we've done overlays,  
24 for example. And so, places where we thought we  
25 were helping to stop, okay, may be actually causing

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 us other issues down the line, unintended  
2 consequences. And that's some of the things that  
3 we're going to be also looking at as well.

4 MEMBER POWERS: Very good point. Very,  
5 very good point.

6 MEMBER CORRADINI: That helps a lot. So  
7 just to make sure I understand; so the assumptions  
8 going into this are I'm not going to have the  
9 ability nor do I count on any sort of operator  
10 action to depressurize? I am staying at high  
11 pressure and cooking the system and looking for --  
12 or are you going to look for operator actions also  
13 as mitigating effects in all this?

14 MR. CSONTOS: I'm sure the latter.

15 MEMBER CORRADINI: The latter? And then  
16 the second part is; I guess maybe you're going to  
17 get to this, what experiments are you going to do so  
18 I trust the CFD?

19 MR. CSONTOS: That would be a  
20 multimillion dollar question.

21 DR. IYENGAR: Conveniently, our CFD  
22 expert is out of town, Chris Boyd, but --

23 MEMBER CORRADINI: Where did you send  
24 him?

25 MEMBER POWERS: Well, I mean, it's an

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 issue that we're going to have to explore. They're  
2 -- fortunately these are single-phase analyses and  
3 they're not involving condensation phenomena. So,  
4 CFD doesn't face formidable challenges there, but  
5 I'm sure the issue will come down to -- at some  
6 point you're going to have to think about, okay, if  
7 it turns out that the thermal hydraulic issues are  
8 of paramount importance here, they're not the flaw  
9 size distribution. Everybody knows the flaw size  
10 distribution is the most important thing; just ask  
11 Dr. Shack.

12 MEMBER SHACK: Best case thermal  
13 hydraulic --

14 MEMBER POWERS: Well, thermal hydraulics  
15 is the dominant thing. You'll want to have a fair  
16 amount of confidence in those calculations. Like I  
17 said, it's single phase, it doesn't involve  
18 condensation, doesn't involve a lot of the problems  
19 where CFD becomes more questionable. So it may be  
20 in fairly good shape.

21 MEMBER SHACK: Or you have the one-  
22 seventh scale test, too, for one geometry which --

23 MEMBER POWERS: Well, I think the one-  
24 seventh scale test is at least part of the problem  
25 in that that test did not extend out to the parts

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 that we're interested in. And what you find in  
2 these calculations is the knee bone is connected to  
3 the thigh bone and it does make a difference out  
4 there.

5 And so, clearly one of the things that  
6 you all have to think about in going along here,  
7 should we redo the one-seventh scale and get rid of  
8 that problem that they had on the outlet nozzles?  
9 That boundary condition is just the wrong boundary  
10 condition for these calculations.

11 MEMBER BLEY: I don't know, I just have  
12 to toss something in here.

13 MEMBER POWERS: Yes, because the risk  
14 guys can't leave this alone, right?

15 MEMBER BLEY: If the situation develops  
16 that this becomes important, it's certainly a lot  
17 more than a \$1 million calculation. If we ever get  
18 to the point that we have such confidence in one  
19 failure beating another to save the day, I think  
20 we're in a relatively indefensible position. So  
21 somewhere out of this has to come something more  
22 than that that provides assurance or provides a way  
23 for operators to confidently do something to avoid  
24 getting into the place that we're relying on a horse  
25 race between failure modes. That just troubles me

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 as a -- it's not good engineering practice to rely  
2 on these failure modes occur in the right sequence.

3 MEMBER CORRADINI: I'm taking away from  
4 the Dana explained this, which I think I get it, is  
5 in some essence you're trying to better inform what  
6 was done years ago and expand the calculational  
7 database to understand where the uncertainties are  
8 and which one's dominant. To me that's important  
9 because all I do remember is the EPR and NRC stuff  
10 from I don't know how many years ago. Twenty pops  
11 in my head, but longer, right? So that to me is a  
12 useful thing to do. I'm guess I'm kind of curious  
13 about the context in which you'd do it.

14 MEMBER POWERS: You remembering back  
15 when you were in grade school?

16 MEMBER CORRADINI: God bless you.

17 MEMBER ABDEL-KHALIK: I guess relative  
18 to this timing issue, I'm just wondering about  
19 reactor coolant pump seal failure. Where does the  
20 timing for that come in? I mean, that must come  
21 very early in this process.

22 MEMBER POWERS: And sometimes is a  
23 dominant sequence. But remember, the Licensees have  
24 gone to substantial effort to upgrade those seals.

25 PARTICIPANTS: Depends on the seal.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   MEMBER POWERS: And that's what creates  
2 -- used to be that you always got out of it because  
3 you blew the seals.

4                   MEMBER ABDEL-KHALIK: Right.

5                   MEMBER POWERS: And now you don't.

6                   MEMBER SHACK: What you want is a seal  
7 that hangs in there until you've melted the core and  
8 then you want --

9                   MEMBER POWERS: And it goes away, yes.

10                  MEMBER BLEY: Yes, but if you go back to  
11 the original work on -- the seals, I mean, the  
12 position that was -- came out of the disputes  
13 between industry and NRC, and the tests that were  
14 done up in Canada led to what I would call a  
15 conservative agreement that leaned toward early  
16 failure of the seals. There's a -- at least to me,  
17 when you look through the data, there was great  
18 uncertainty about when those seals would actually  
19 let go. Was it 20 minutes or 5 hours? And it  
20 wasn't as clear as it began to be assumed after  
21 there was a negotiated position. And that's what it  
22 was, it was a negotiated position, not a real  
23 scientific analysis including all the uncertainties  
24 that came up with that. So, and we never knew for  
25 sure when those seals were going to go.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER ABDEL-KHALIK: And I'm not sure  
2 we know for sure now. Well, we don't.

3 MEMBER BLEY: As to when the seals will  
4 actually --

5 MEMBER ABDEL-KHALIK: We know they're  
6 going to last longer, but they're less likely to get  
7 challenged.

8 MEMBER POWERS: Yes.

9 MEMBER ABDEL-KHALIK: And the ones we  
10 have are better than the ones we had then.

11 MEMBER STETKAR: And there are  
12 manufacturers now who claim their seals will not  
13 fail. You know, there are manufacturers and have  
14 run -- you know, believe 24-hour endurance tests  
15 that temperature and pressure with essentially no  
16 leakage. So a lot of the new plants that you see  
17 coming down the line are indeed, you know, making  
18 those claims and there are manufacturers that do  
19 make those claims with, you know, some test-based  
20 justification.

21 MEMBER SHACK: So once you're into the  
22 severe accident, that's not so good news. You know,  
23 just thinking about this, I mean, there's the  
24 insight and the actions that you take. If you think  
25 about it from the regulatory basis, it's not always

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 clear to me what you'd do. I mean, we by and large  
2 regulate on a kind of design basis accident basis,  
3 not a severe accident basis. One regulatory  
4 decision that I know was sort of made on this basis  
5 was the electrosleeve repair, which looked wonderful  
6 in a design basis situation, but was in fact bad  
7 news in the severe accident. I'm not sure, you  
8 know, it will help you perhaps understand actions  
9 that you should take in SBO situations, but you  
10 know, will it change the way you regulate SBOs?  
11 It's harder to see.

12 DR. IYENGAR: Yes, we will be --

13 MEMBER CORRADINI: We're just talking to  
14 each other.

15 DR. IYENGAR: No, no, we will be  
16 revisiting the thermal hydraulic uncertainties when  
17 Dr. Richard Lee will be talking about it little bit  
18 later. We had some not difficulty -- some  
19 difficulty with our team members. One of them is  
20 now in Japan who probably would have chimed in  
21 little bit more on this; Mike Salay.

22 Anyway, so that's most important key;  
23 deliverability. In addition, we do have -- NRR has  
24 requested some kind of regulatory guidance, which we  
25 will be undertaking. And the other thing we have

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 done is we have compiled and collected all the  
2 publicly available C-SGTR, SGTR-related information  
3 in a repository in our SharePoint, in the inter  
4 SharePoint for our team members to have access to  
5 all the needed documents. Once we are done with  
6 this project, that probably will be available, the  
7 portal will be available for public as well. So we  
8 will have, you know, 20 or 30 years of research  
9 products and developmental activities in this area.

10 With that, I will turn over to Richard  
11 Lee who will talk about the steam phenomenological  
12 aspects of C-SGTR so that this will be a very nice  
13 overview that he plans to present.

14 MR. LEE: Okay. I'm Richard Lee from  
15 the Office of Research. Too bad Mike cannot be here  
16 because we send him over there to collect samples in  
17 Japan. And first thing he did, he send me his  
18 viewgraphs. First thing I did I delete half of his  
19 viewgraphs because it was too long.

20 I was involved with the steam generator  
21 tube rupture analysis that Dr. Rempe mentioned back  
22 in late nineties using SCDAP/RELAP5 and I thought  
23 the problem went away, but it didn't. So I'm asked  
24 to just talk about the phenomenological aspect of  
25 it.

1           The steam generator tube rupture is a  
2 design basis event. Those are the single tube or a  
3 few. And as far as in U.S., like we have been able  
4 to cope with it so far. But the one that we're  
5 talking about is something that more severe that you  
6 go from design base to a much more severe  
7 conditions. And this was -- the one that we're  
8 talking about is a severe incident induced steam  
9 generator tubes rupture. Basically you have much  
10 more events that happens beyond the design base.

11           And you look at the risk assessment. As  
12 we said, it is -- as Dana mentioned, that it's a low  
13 probability, but if it happens it's bypassing  
14 containment because that's a direct path that go out  
15 into the environment when the core start to release  
16 fission products and so forth.

17           Recently, when we were at training for  
18 the severe accident management guidelines by  
19 Westinghouse, actually they mention that they were  
20 supposed to recover water at a certain later time.  
21 Instead of putting in the core, they decided they  
22 going to put some of them back in the steam  
23 generator. So, this is one thing we should keep in  
24 mind.

25           The second thing is the -- as Dana

1 mentioned, that the failure at the time that we talk  
2 about failure of the primary system that include  
3 overhead. Those overhead cases are usually the  
4 traditional accident analysis that you don't do the  
5 bypass. If that fail, you relocate materials into  
6 the cavity and you have the other events like the  
7 molten core concrete and the actions like fuel  
8 cooling action. Those are thing you deal with.

9           And then for the steam generator tube  
10 rupture, there are three things that we look at  
11 previously is the hot leg rupture, the surge line  
12 failure versus the steam in the tube. The other two  
13 are inside the containment. The steam in the tube  
14 is of course a bypass event.

15           When the core to uncover, you have is --  
16 the case that we analyze is a station blackout  
17 event. Loss of all AC power. Loss of all  
18 feedwater. There's no recovery. No operator  
19 actions. And as the core boil down, you can see  
20 that as it's uncovered, the hot gas flow from the  
21 core up into the hot legs. And then especially  
22 when there's a loop seal there, so there's -- you  
23 cannot have a -- how do you call it -- complete  
24 circulation of the steam that go through the entire  
25 loop going back to the core and heat up and then go

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 to steam generator. So you have a loop that go -- a  
2 tube carrying hot gas up and come back down some of  
3 the tube return flow. So you have a mixing of  
4 cooler fluid mixing with the hotter fluid. So there  
5 are -- they are counter fluid in the hot leg.

6 And so you eventually have three  
7 circulation loop. One is the mixing from the core  
8 coming back, flow, going back out from the upper  
9 plenum, the hot legs one and then the mixing in the  
10 steam generators in that plant.

11 At that time we look at the Surry plant  
12 and also the ANO2 plant, which is a CE plant. They  
13 are different types of -- one is a Westinghouse 3-  
14 loop plant. They have different loop seal  
15 conflagration. The power density is different. The  
16 secondary site stimulator water inventories are also  
17 different. So we look at those type of variations.

18 The case that -- when you challenge the  
19 tube, has to fulfill three conditions. It's that  
20 you have a very high -- the primary pressure should  
21 be high. So in other words, the RCS doesn't have  
22 much significant leakage. Of course we take into  
23 account for example the seal leakage for 21 gallons  
24 at the beginning when you lose the loop seal  
25 cooling, but later when you can continue to heat up

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 higher temperature, the loop seal fail and then you  
2 go to -- like for the Westinghouse plant is like 250  
3 gallons per minute. But I believe that the newer  
4 seal may be better, so they may have less.

5 I believe that we did some more work on  
6 looking at the loop seal for the SOARCA project, but  
7 I don't know what those numbers are. So I probably  
8 -- for this project they're going to bring in some  
9 of the knowledge for this, latest knowledge about  
10 these loop seal leakage.

11 Then of course you have to have a steam  
12 generator secondary side dry. That's mean you don't  
13 have any aux feed and also basically the other side  
14 should stuck open, so you really have a  
15 depressurized steam generator and dry condition. So  
16 you have a low pressure and no water.

17 MEMBER CORRADINI: When you get into  
18 this -- I guess I don't remember any of this other  
19 than just the net result that you explained in terms  
20 of phenomenon. Do you get into this situation that  
21 by procedures that you would not have a main steam  
22 isolation issue, or you wouldn't have main steam  
23 isolation, you'd be having essentially an open path  
24 to bypass containment through the main steam? Or  
25 even if they were closed, the leakage is such that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 it doesn't really matter from a dose standpoint? You  
2 know what I'm asking?

3 MR. LEE: No.

4 MEMBER CORRADINI: Okay. So are the  
5 main steam line valves closed at this point in time  
6 so you would have it simply from a leakage through  
7 them to create a dose problem if -- you would have  
8 radiologically? I'm trying to understand the path.

9 MR. LEE: You're talking about the  
10 bypass sequence?

11 MEMBER CORRADINI: Yes.

12 MR. LEE: It goes right outside.

13 MEMBER CORRADINI: So it goes to the  
14 safety release valves as --

15 MR. ZOULIS: Right, they're stuck open.  
16 They're -- or they're -- the high pressure's -- then  
17 that's the direct pathway to the atmosphere.

18 MR. LEE: Yes, because the thing is  
19 stuck open, too. That's why.

20 MEMBER CORRADINI: Oh, it is?

21 MR. LEE: Yes. Right.

22 MEMBER CORRADINI: Excuse me. Okay.

23 MEMBER POWERS: Typically when your  
24 safeties pop on the secondary side they just don't  
25 close. And if they do --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER CORRADINI: Okay. I didn't  
2 realize.

3 MR. LEE: Can recycle --

4 MEMBER POWERS: Even if they do start  
5 cycling, the gas is hot enough that you erode the --  
6 and they leak like sieves.

7 MEMBER CORRADINI: Okay.

8 MEMBER POWERS: Yes.

9 MEMBER CORRADINI: Right. Thanks.

10 MEMBER POWERS: Leakage pathways are  
11 huge compared to the aerosols, so it's like they're  
12 not there.

13 MEMBER CORRADINI: Okay. Thank you.

14 MEMBER POWERS: Gets us into some  
15 serious trouble because it's a high-pressure leakage  
16 and so you're decontamination efficiency in the aux  
17 building goes to zero.

18 MEMBER CORRADINI: Right. Okay.

19 MEMBER POWERS: I mean, it goes to what?  
20 You don't get any.

21 MEMBER ABDEL-KHALIK: If you have total  
22 loss of feedwater, you don't have aux feed and one  
23 of the safeties pops open and you get a puff of  
24 release when the steam generator is dry, wouldn't  
25 the steam generator pressure drop down to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 atmospheric and stay down there because you don't  
2 have any water?

3 MR. LEE: Right, That's what we have  
4 now, is the secondary became very low pressure. So  
5 the steam generator tube failure is due because of  
6 the high-Delta P across the tube.

7 MEMBER ABDEL-KHALIK: Across the steam  
8 generator tube?

9 MR. LEE: That's the reason of it. Is  
10 primary to secondary Delta P is very large.

11 MEMBER ABDEL-KHALIK: Okay.

12 MR. LEE: But if you don't have it --  
13 because the failure of the steam generator tube is  
14 due to two things; is the Delta P and the  
15 temperature.

16 MEMBER POWERS: Right.

17 MR. LEE: So those are the two criteria  
18 we used. At the time of the SCDAP/RELAP5 analysis  
19 we used adopted criteria for the tube rupture  
20 calculation for the so-called index of failure and  
21 so forth. That's what we used.

22 MEMBER ABDEL-KHALIK: Okay.

23 MR. LEE: What's shown on this figure is  
24 all the variation that have been study between the  
25 late nineties and now on what are the different

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 things that they look at. Is the loop seal  
2 clearing? If the loop seal clear, then it depends  
3 on the depth. What is the volume and the location  
4 and so forth? And how you model is because we have  
5 found differences between the MAAP modeling versus  
6 our SCDAP/RELAP5 modeling. So there always be  
7 questions arise about how do you model the loop seal  
8 clearing. Because if you clear the loop seal, the  
9 flow will became one way and then you will -- the  
10 flow will go through the core and then you  
11 essentially -- the steam will transcend to the steam  
12 generator tube even hotter than when you don't have  
13 the loop seal clear. So those are the things that  
14 we look at. That's why the loop seal clearing is  
15 important.

16 The pump seal leakage is going from 21  
17 to whatever the values that we use for different  
18 pump seal. The CE pumps are different than the  
19 Westinghouse pump. And we also look at the core  
20 nodalization inside the core. I remember for the  
21 Zion and the Surry plant, there are certain  
22 difference between the downcomer. There is a  
23 leakage path there. So when the flow come in, they  
24 can bypass each other. So the downcomer mixing also  
25 affects how the loop seal clearing occur. And of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 course all the oxidation, how you assume in the core  
2 will determine the melt progressions.

3 CHAIR REMPE: Richard, did you say the  
4 difference between MAAP and SCDAP --

5 MR. LEE: MAAP and always big discussion  
6 between -- because the -- if you clear the loop  
7 seal, then you will have higher -- hotter  
8 temperature going to steam generator tube, so you  
9 will fail the tube --

10 CHAIR REMPE: Okay.

11 MR. LEE: -- because of the temperature.  
12 Giving that the high-Delta P. So there is always  
13 discussion about those issues between the industry  
14 calculation versus our calculation. I'm telling you  
15 just these are the issues that we deal with when we  
16 do our analysis.

17 The surge line orientation is also  
18 important because the CE will connect it up. So  
19 basically the hot flow on the upside so you will be  
20 sucking it up, so the surge line may fail first.  
21 But if you go to the Westinghouse connecting on the  
22 side. So you tend to pull the colder fluid into the  
23 surge line, so into the pressurizer. So that change  
24 also the sequence of calculation whether you have a  
25 hot leg rupture first or the surge line fail first

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 or the steam generator tube fail. And then of  
2 course the big thing is to do the one-seventh scale  
3 that gave us the benchmarking for the mixing in the  
4 inner plenum. And that always a big discussion.

5 CHAIR REMPE: So my memory's not so  
6 good. Wasn't water chemistry also an effect that  
7 they thought could impact steam generator tube  
8 ruptures? And what about like -- you have here like  
9 the hot tube fraction, but there were a lot of  
10 things I thought they considered back then. And is  
11 that something that they thought was or wasn't an  
12 important parameter?

13 MR. LEE: Water chemistry may have to do  
14 with the -- how -- what effects it has on the pre-  
15 existing --

16 CHAIR REMPE: Tubes?

17 MR. LEE: -- tube structure itself.

18 CHAIR REMPE: Yes. Right. Okay.

19 MR. LEE: Okay. But not during the  
20 transient. Water chemistry doesn't come.

21 CHAIR REMPE: That's right.

22 MR. LEE: We also look at the -- for  
23 example, the hot leg, we also did some calculation  
24 by deposit fission products on it. Does the decay  
25 heat make any difference?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIR REMPE: Okay.

2 MR. LEE: As you remember, in the  
3 SCDAP/RELAP5 calculation we split the hot leg into  
4 two. One, because it was not a multi-dimensions or  
5 is one dimensional. So we have the hot one going  
6 up, the cold one coming down. They don't  
7 communicate.

8 CHAIR REMPE: Yes.

9 MR. LEE: So we also did some re-  
10 coupling of those two. We also look at radiation  
11 heat transfer in those pipe because it is very hot.  
12 So we like to look at the heat loss.

13 Heat transfer coefficient variation, we  
14 look at that, too, but that doesn't make that much  
15 difference.

16 Then we also do a lot of nodalization  
17 near -- we're talking about the SCDAP/RELAP5 system  
18 level

19 CHAIR REMPE: Yes.

20 MR. LEE: At that time we didn't use too  
21 much of CFD, but since then there's a lot of CFD  
22 analysis. So that gave us a more informed analysis,  
23 how should you do -- with SCDAP/RELAP5 or MELCOR,  
24 for example, how will you do those type of analysis?  
25 Give you some guidance on how you do the mixing. So

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 these are the variation that has been conducted.

2 Now, this is a CFD calculation that  
3 Chris Boyd gave me. And you can see this is one of  
4 the -- this is not a CE plant. And you can note  
5 that the surge line connection is on the side, is  
6 pulling relatively cold water from the lower stream  
7 into the pressurizer. If it is a CE plant, it will  
8 be pulling hotter gas from the upper part. So the  
9 surge line will have a higher propensity of failure.  
10 And the flow stream going into the plenum of the  
11 Westinghouse-type connection, which is connected  
12 very further down and you see the jet going into the  
13 -- this is a CFD simulation. I don't have the --  
14 how do you call it -

15 MEMBER ABDEL-KHALIK: What causes the  
16 surge line failure? Is it the high temperature in  
17 and of itself, or the high temperature gradients?

18 MR. LEE: It fail at the connection  
19 right there.

20 MEMBER ABDEL-KHALIK: But is it caused  
21 really by temperature gradients?

22 (Simultaneous speaking.)

23 MEMBER SHACK: Right, you know, it's the  
24 pressure stresses and the weakening from the --

25 MEMBER ABDEL-KHALIK: Oh, as a result of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the elevated temperature?

2 MR. LEE: It actually has two points  
3 that -- we calculate the failure over here, the  
4 failure over here, or you have failure over --  
5 inside here.

6 MEMBER SHACK: But that news that the  
7 pressurizer or the surge line gets hot in the CE  
8 plant is the best news I've heard in a while.

9 MR. LEE: This is a Westinghouse --

10 MEMBER SHACK: Well, it gives you a  
11 chance to fail something.

12 MR. LEE: These are pictorial comparison  
13 between the two type of simulator. This is a  
14 Westinghouse connection. You see it coming very  
15 deep. This one come in very shallow on the top  
16 close to here. So when you have a flow coming in,  
17 it will tends to go up into -- there's a jet of  
18 stream going up to some of these tubes. Okay? So  
19 what Chris did is that if you plug a normalize  
20 fraction between temperature, the Westinghouse index  
21 is about here, the CE index is about here.

22 Another thing you need to know is that  
23 some of the replacement steam generator for  
24 Westinghouse went to this type of steam generator.  
25 So when you go to a Westinghouse plant, is not

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 necessary having a steam generator of this type  
2 anymore. Because when they replace the steam  
3 generator, it could be a different manufacturer and  
4 the connection is at this fashion. So these are the  
5 type of analysis that CFD can perform and tell you  
6 that what type of risk that steam generator tube can  
7 face.

8 This is a qualitative explanation about  
9 what can happen looking at just two parameters and  
10 mapping out. Actually this is multi-dimension  
11 mapping of a potential containment bypass. So the  
12 first one you look at the seal leakage. When you  
13 have small leakage and you have very large leakage  
14 on the other side, that's mean you can induce a very  
15 large Delta P across. So you have a lot of  
16 potential failing and bypass. So but this path here  
17 is that you do not -- basically it's a match with  
18 Delta P and the temperature.

19 Now, on this one here is, when you have  
20 a very large leakage in a seal you can clear the  
21 loop seal so you essentially will fail. Now you  
22 have much hotter gas coming into the steam  
23 generator. So this is sort of a so-called MAAP.

24 MEMBER ABDEL-KHALIK: But the RCS  
25 pressure is going to be very low if that is the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 case. Would it?

2 MR. LEE: It can be low, but the thing  
3 is that it's still very hot, because the -- your  
4 flow is going through the core and circulating and  
5 picking up the heat from the accident core. So and  
6 transferring very high temperature into the steam  
7 generator tubes, because is a Delta P and the  
8 temperature both. Either one will get you in  
9 trouble.

10 MEMBER SHACK: It's still a horse race.  
11 I mean, it's the P going down and the T going up  
12 and --

13 MR. LEE: So you have something of a  
14 MAAP like this, but don't take this is a  
15 quantitative MAAP. This is just give you some idea  
16 what the variation of two parameters would look  
17 like, but there are other parameters.

18 MEMBER CORRADINI: What -- okay. Fine.

19 MR. LEE: Don't ask anything.

20 CHAIR REMPE: Did you have a question?

21 MEMBER CORRADINI: No, I've stored that  
22 one way. That's one for him.

23 MR. LEE: I brought this up because at  
24 the time of the steam generator tube rupture  
25 analysis going on the Paul Schermer Institute in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Switzerland launch a so-called ARTIST project. And  
2 they were studying the behavior of aerosol transport  
3 in the secondary side of the pressurizer and they  
4 were doing flooded pressurizer, but we are  
5 interested in the dry case, which is a completely  
6 dry aerosol transport in the secondary side. And we  
7 were hoping that even you have a -- let's say you  
8 have a break in the steam generator and it's  
9 transferring through the forest of these pipes of  
10 tubes and plates, because it depends on the -- where  
11 the location of the break. It has to go through  
12 many levels.

13 So we was thinking do you have any  
14 attenuation or decontamination factor that ones can  
15 get from aerosol transport in the second side even  
16 you have a steam generator tube rupture? Back in  
17 NUREG-1150 time, the DF factor, it was around five.  
18 Okay? So we said perhaps maybe from this experiment  
19 we can get a larger number, but it didn't turn out  
20 that way. What happened is that these aerosol get  
21 transport. First it come up from the break. It  
22 could be big size, but what happened is it get hit  
23 on these tubes and it breaks unto smaller part and  
24 it get transported with the flow stream. So the  
25 overall decontamination factor we get is around

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 five.

2 MEMBER BLEY: Rather than having more  
3 surface area where --

4 MR. LEE: Right.

5 MEMBER BLEY: -- it actually makes it  
6 worse?

7 MR. LEE: Yes, it didn't do anything and  
8 so we didn't get anything out of this. But that was  
9 not something we count on. We thought we may get  
10 some more DF that are different than the time of  
11 NUREG-1150, but it didn't turn out that way.

12 MEMBER BLEY: And these tests, they  
13 included some mock-up of this, steam separators and  
14 all that stuff?

15 MR. LEE: They have all those thing in  
16 there.

17 MEMBER BLEY: Yes.

18 MEMBER ABDEL-KHALIK: How about the tube  
19 support plates?

20 MR. LEE: They have all the tube support  
21 plate, too. Because it is a simulation thing, I  
22 forgot what the size of this was. It's a full --

23 MEMBER POWERS: It's about a third of  
24 the full height and about a twentieth of the  
25 diameter. It was chosen so that the jet would lose

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 its horizontal component of momentum before it got  
2 to the walls of the experimental apparatus. And it  
3 used a broached-hole tub support plates which are of  
4 the more modern design than the others. The steam  
5 separators and steam dryers were full size. I mean,  
6 they took them out of a steam generator and put them  
7 up. They just don't have as many as a steam  
8 generator. They have one. You have to understand  
9 the separators and dryers are meant for separating  
10 water droplets which are around 50 microns. These  
11 aerosol particles are around a micron. And so it's  
12 like driving through the Grand Canyon. You know,  
13 they don't even see the steam separators and dryers.

14 We expected to get a lot of deposition.  
15 And a little white powder on stainless steel looks  
16 like you get a lot of deposition, but in truth the  
17 DFs were 1.1, 1.2. And they get them for -- DFs for  
18 each of the tube support plates and the spans and  
19 whatnot. So you can just hypothesize where a leak  
20 goes, because we have a fairly continuous  
21 distribution of where leaks will occur in tubes, you  
22 know, based on historical evidence. And so you can  
23 just multiply it together to get the DF and they're  
24 like five.

25 MR. LEE: And actually some of those are

1 so-called break openings and you did some of those  
2 openings for them at Argonne, busted some of the  
3 tubes that we sent over there.

4 MEMBER SHACK: Yes, we made the fish-  
5 mouth --

6 MR. LEE: Fish-mouth.

7 MEMBER POWERS: Yes, you made a fish-  
8 mouth.

9 MEMBER SHACK -- ruptures. So I mean,  
10 these things sort of look relatively realistic as  
11 far as the exit goes.

12 MR. LEE: Another thing that Chris Boyd  
13 told me is that the problem with the one-seventh  
14 scale tests, he went back and look at the geometry,  
15 the way the scaling look and see how the connections  
16 come in. Is actually the one-seventh scale have  
17 certain distortion that gave these mixing  
18 coefficients that may not be correct.

19 MEMBER CORRADINI: You mean geometrical  
20 distortions? How things are connected?

21 MR. LEE: That's correct, how they were  
22 connected. You scale it back just by volume. You  
23 see that the connections as slightly distorted.

24 MEMBER CORRADINI: And that means they  
25 don't correspond to anything?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. LEE: No, they correspond to  
2 something, but it's distorted. So when you get  
3 these mixing parameters, like the hot flow mixing in  
4 the plenum, those three mixing parameters that we  
5 use that were derived from the Westinghouse.

6 MEMBER CORRADINI: Right. I understand.  
7 But then to get back to Bill's question originally  
8 when you and Dana were talking, even though they're  
9 distorted if a single phase super-heated gas  
10 calculation can benchmark against it and then you  
11 can do slight parametric variations off of that,  
12 that leaves you some experimental confidence. Okay.

13 MR. LEE: Chris can do those things,  
14 because --

15 MEMBER CORRADINI: Well, it's --

16 MR. LEE: -- this is a 1D-type flow, so  
17 you can see if you can sort out some of those.

18 MEMBER POWERS: Yes, I mean, in defense  
19 of the people that did the test, they set up the  
20 test when the debate was one area. By the time they  
21 ran the experiment the debate had moved down the  
22 piping system. And so they're connecting positions.  
23 Where they stopped their experiment is where the  
24 debate wanted the answer. And so it gives you -- it  
25 is better suited for looking at the flows within the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 vessel and not in the piping system. So you get  
2 some confidence always when you're matching  
3 anybody's experiment for anything.

4 The critical question that you'd like to  
5 have when you say get some validation of -- maybe it  
6 isn't addressed by the one-seventh scale. And so I  
7 think this program is the one that's going to help  
8 us define where out of all this should we ever do  
9 the next experiment.

10 MEMBER CORRADINI: Where you need it,  
11 yes.

12 MEMBER POWERS: Yes, quite frankly, at  
13 the time the debate was going fast and furious and  
14 people were cobbling things together as fast as they  
15 could. Now we have a chance to go back and kind of  
16 look at it in a very definitive fashion and say,  
17 okay, now we've looked at it. Here's where the  
18 crucial experiment is and do this one. And then we  
19 come away with the warm fuzzy inside and can wrap a  
20 bow around this experiment, around this technical  
21 issue. Which I mean, this DF plot says it all to  
22 you. You ain't getting any.

23 MEMBER ABDEL-KHALIK: Well, back to the  
24 tube support question, in this scaled facility did  
25 they keep the spacing of the tube supports the same,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 or were simply a number of tube supports the same?

2 MEMBER POWERS: They kept the spacing  
3 the same.

4 MR. LEE: The spacing the same only  
5 because they could not afford the entire height.

6 MEMBER ABDEL-KHALIK: I understand.  
7 That's why I'm asking the question. Doesn't the  
8 attenuation depend on the number of tube supports?

9 MEMBER POWERS: It does.

10 MR. LEE: It does.

11 MEMBER POWERS: And so you --

12 MEMBER ABDEL-KHALIK: And how do they  
13 account for that?

14 MEMBER POWERS: Well, you get the DF per  
15 plate, so just count plates. And the DF is like 20  
16 percent per plate, so you can even just -- it's  
17 really easy, so you don't even distort the  
18 distribution.

19 MEMBER ABDEL-KHALIK: So it's just  
20 assumed logarithmic attenuation essentially by doing  
21 that, by assuming the same --

22 MEMBER SHACK: He's got multiple plates  
23 to begin with, so he has to check on --

24 MEMBER POWERS: Yes you can have  
25 three --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   MEMBER SHACK:  -- what the approximation  
2                   is.

3                   MEMBER POWERS:  -- and the DF is so  
4                   small per plate that linearizing the logarithm is a  
5                   pretty darn good approximation.  It's a very good  
6                   approximation.  In fact, when you do it -- they do  
7                   it both -- they can do it both ways.  And so you get  
8                   an internal check on that, adding things together,  
9                   or multiplying probabilities.  And so you get a very  
10                  accurate indication that the DF is really low.

11                  MEMBER ARMIJO:  I had a question on the  
12                  previous slide.  Looking at the tubes, 26, those  
13                  tubes are bright and shiny in this test.  Does it  
14                  make any difference whether they're oxidized steam  
15                  generator tubes?  Does decontamination surface?

16                  MR. LEE:  They start off with the  
17                  stainless steel tube bright and shiny.  And all  
18                  those white stuff are the deposit that they --

19                  MEMBER ARMIJO:  Yes, I understand, but  
20                  if in a real case you --

21                  MEMBER SHACK:  He wants to put a  
22                  corrosion film on the thing.

23                  MEMBER ARMIJO:  Yes, would it make any  
24                  difference, or do these aerosols bounce off of that  
25                  just as well?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER POWERS: Yes, they did some  
2 separate effects tests looking explicitly at that.  
3 They roughed them up, they had bashed them and  
4 things like that. Understand that outlet is sonic.  
5 It doesn't even notice.

6 MEMBER ARMIJO: Just another surface.

7 MEMBER POWERS: Yes, it's just -- in  
8 fact, typically the particles don't even actually  
9 touch the surface. They're just following the  
10 stream lines around it.

11 MEMBER ARMIJO: Right.

12 MR. LEE: Because they're so small  
13 there's no reason for the particle to get out of the  
14 stream line, do more work and deposit itself on the  
15 surfaces.

16 MEMBER ARMIJO: Okay. So that's --

17 MR. LEE: So it just go over the stream  
18 line.

19 MEMBER ARMIJO: Okay.

20 MEMBER SIEBER: Now, the non-fresh tube  
21 support plates actually have flow holes drilled in  
22 them that don't have tubes in them, right?

23 So you still get the same relative flow.

24 MR. LEE: Yes, we were also informed  
25 recently that the Paul Schermer Institute want to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 launch a program to look at the steam generator in  
2 that scale, seven scale type, so we are looking into  
3 whether we should participate on that.

4 MEMBER SIEBER: Okay.

5 MEMBER POWERS: Yes, this isn't -- if  
6 you want to see stainless steel, this Paul Schermer  
7 facility. I think they've got the market cornered  
8 in stainless steel.

9 MEMBER CORRADINI: You're talking the --  
10 I'm trying to think what it's called now -- the  
11 PANDA facility?

12 MEMBER POWERS: Well, that's another  
13 facility made out of stainless steel. This is even  
14 a second one. This is a different facility.

15 MEMBER SHACK: Well, it's a lot cheaper  
16 than making it out of 690.

17 MEMBER POWERS: Well, the tubes are.

18 MEMBER SHACK: Oh, the --

19 MEMBER POWERS: Yes, the tubes are real  
20 tubes. I mean, they just -- one of the utilities  
21 gave them a steam generator to tear apart and put  
22 this thing together with -- because the guy that  
23 runs the program went in and pretty much sold it as  
24 he was going to show them the DF was 10,000.

25 MEMBER SHACK: Yes.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   MEMBER POWERS:  And it's 10,000 -- I  
2                   think he was looking for a DF on the order of 100 or  
3                   200 and that got some enthusiasm for the program and  
4                   leads to some amusing mathematics, because 1.2,  
5                   that's close enough to 2, so he called it 2.  And 10  
6                   times 2 is 4, but that's really 10 in log space,  
7                   so --

8                   MR. LEE:  So he estimate about 100.

9                   But if you look at the data, it didn't  
10                  show that, so it's around five.

11                  So what do you want me to do now?

12                  CHAIR REMPE:  Actually, I think we're  
13                  scheduled for a break that was supposed to start at  
14                  2:45, and we're five minutes ahead for a change.  So  
15                  should we take -- come back at five to 3:00 then?

16                  (Whereupon, at 2:40 a.m. the above-  
17                  entitled matter went off the record and resumed at  
18                  1:54 a.m.)

19                  CHAIR REMPE:  Okay.  Shall we go back in  
20                  session?  Are you going to start, Richard?

21                  MR. LEE:  I guess so.  I'm going to go  
22                  to the next three viewgraphs that Mike prepare.  
23                  Actually I have look at it carefully trying to find  
24                  out what the heck he's talking about, so we just  
25                  look.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           The TH analysis, it has to do with the  
2           CFD and the MELCOR I believe that we're going to be  
3           using for the analysis and focus on the CE plant.

4           The next bullet say un-fail thermal  
5           hydraulic behavior. What I believe has to do with  
6           even though you calculate when a component is  
7           supposed to fail, you don't fail it. You continue  
8           the calculation. So you can see the timing between  
9           the hot leg failure, surge line and steam generator  
10          tubes just looking at the Delta T between -- I mean  
11          Delta time between each of these components.

12          The next type of calculation you can do  
13          is let it fail and then you can calculate what type  
14          of fission products get transport out to the --  
15          especially the one if it go to a steam generator  
16          tube. But I have to say that all these analyses are  
17          still up to discussion among the groups. Right?

18                 DR. IYENGAR: Yes.

19                 MEMBER ABDEL-KHALIK: The thermal  
20                 hydraulic calculation and the stress analysis  
21                 calculation are run sort of sequentially or are they  
22                 run simultaneously or --

23                 MEMBER ARMIJO: Sure, should be  
24                 iterating.

25                 MR. LEE: It would be iterating. For

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 example, the steam generator tube flaw distribution  
2 can be fed into -- as a preexistent flaw. You can  
3 use those to start with. You can have pristine  
4 tube. You can have distribution of flaw already  
5 there. And depending --

6 MEMBER ABDEL-KHALIK: No, I'm talking  
7 about the failures of -- you know, like the surge  
8 line, for example.

9 MR. LEE: Yes.

10 MEMBER ABDEL-KHALIK: Would you do that  
11 simultaneously with a thermal hydraulic calculation?

12 MR. LEE: Well, I think we going to give  
13 the boundary conditions so they can do more detail  
14 analysis. For example, the hot leg, you give the  
15 pressure and temperature and whatever the condition  
16 they need for the more detail analysis of the --

17 MEMBER ABDEL-KHALIK: So would they have  
18 done sequentially --

19 MR. LEE: It would be sequentially, yes.

20 MEMBER ABDEL-KHALIK: -- rather than  
21 simultaneously?

22 MR. LEE: No, it's not.

23 (Simultaneous speaking.)

24 MEMBER ABDEL-KHALIK: Yes.

25 MR. LEE: That's how we typically do.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. CSONTOS: This is Al Csontos from  
2 Research. Yes, what we're doing is we're getting  
3 the thermal hydraulics data from Chris Boyd and then  
4 we put that into -- we have models that we develop  
5 for hot legs, cold lets at different areas,  
6 different locations, different fabrication  
7 techniques, different conditions that we either  
8 degraded; like for example, some plants may not --  
9 if they have superficial cracking, they may just  
10 leave that in service. If they have deeper than  
11 certain amount, then they'll put a different type of  
12 mitigation on. Some plants may have cracks that go  
13 to leaking and they put an overlay on. Like Davis  
14 Besse had that on a drain line, okay, for example.

15 So, we have all these things that we're trying  
16 to place together and put into some sort of -- and  
17 that's what Raj will talk about is he's trying to  
18 create a nice kind of database or a finite element  
19 modeling repository of all these different locations  
20 and conditions. And then what we'll get is we'll  
21 get Chris Boyd's results from the thermal hydraulics  
22 information and we'll feed it into the analysis that  
23 Raj is doing. So it sort of is a sequential effort,  
24 but there's a lot of conditions that we're looking  
25 at.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   And then that's where Charlie's flaw  
2                   distributions come into play, but that's where we  
3                   place in close to the steam generators.

4                   CHAIR REMPE:   So is this an ABAQUS model  
5                   for the structural behavior, or is it a simpler tool  
6                   like they used years ago with --

7                   MR. CSONTOS:   Oh, no, it's -- yes,  
8                   that's not what we're -- not the simplified tool.  
9                   That's what we saw before.

10                  CHAIR REMPE:   Right.   So you're doing  
11                  this like ABAQUS or something?

12                  MR. CSONTOS:   And we're going way beyond  
13                  that.   Yes, we're -- Raj can talk to -- a little bit  
14                  more on that.

15                  MR. LEE:   And from Chris Boyd, he can  
16                  nodalize those thing up to whatever details they  
17                  need it.   There's no problem for the CFD.

18                  And then from there you can give some  
19                  guidance to how do you average these temperature for  
20                  MELCOR nodalization.

21                  And at this time now we are developing  
22                  the CE Calvert Cliffs plant models at Sandia.   We  
23                  ask them to take the Calvert Cliffs stack and update  
24                  it.   Of course now we are up to the ears with this  
25                  Fukushima thing, so everything is secondary now.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 What impacts it on the schedule, we don't know at  
2 this time.

3 We're not going to start from scratch  
4 because we have a SCDAP/RELAP MELDOR deck. We're  
5 going to start from whatever we have and try to  
6 build upon what we have learn. As I mention to you,  
7 we have extensive analysis done with SCDAP/RELAP5.  
8 We're going to go back and look at what has been  
9 done through that. And we'll work very close with  
10 Chris Boyd on how to do the parameters -- I mean,  
11 for the so-called system level analysis. The reason  
12 you do the -- because all the fission products and  
13 melt progressions are in the MELCOR decks. Is not  
14 in the CFD. So we have to iterate between the two  
15 closely.

16 MEMBER SIEBER: When you talk about  
17 instrument tube failures, what instrument tubes are  
18 you talking about?

19 MR. LEE: Ah, that's -- what happened is  
20 that last year or so Bob Henry brought up from the  
21 TMI.

22 MEMBER SIEBER: Okay.

23 MR. LEE: And during the accident, they  
24 noted that there was instrumentation failure, tube  
25 failure was evident, because if you look at the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 instrument tube, it goes up to a seal table. There  
2 was a -- radiation detection went up. So Bob Henry  
3 brought up that during this accident instrumentation  
4 tube failure, it is a possibility.

5 MEMBER SIEBER: You're talking about  
6 incore instrumentation?

7 MR. LEE: Incore instrumentation, right.

8 MEMBER SIEBER: Now that is always  
9 filled with water and it's outside the hot flow  
10 path, right?

11 MR. LEE: Yes, but the thing is that the  
12 melt are relocating into the lower plenum. So there  
13 can be a --

14 MEMBER SIEBER: So you're assuming there  
15 is core melt going on?

16 MR. LEE: We look at that one with the  
17 -- for the TMI case --

18 MEMBER SIEBER: Okay.

19 MR. LEE: -- with melt core. What it  
20 did is that it did not make the problem goes away.  
21 All it does it delay the severe accident  
22 progression.

23 MEMBER SIEBER: Well, they aren't that  
24 big.

25 MR. LEE: That's right.

1 MEMBER SIEBER: And they plug --

2 MR. LEE: Yes.

3 MEMBER SIEBER: -- with molten material.

4 And all kind of debris --

5 MR. LEE: Yes.

6 MEMBER SIEBER: -- is coming down.

7 MR. LEE: Correct. We look at that.

8 MEMBER SIEBER: And it's not that hot  
9 that it will -- you know, instruments will melt.

10 MR. LEE: But we're going to go back and  
11 look at that, what impacts that one has, because  
12 that was -- instrumentation tube is not one thing we  
13 have considered the analysis.

14 MEMBER ABDEL-KHALIK: Let me just try to  
15 understand this, because somewhere earlier you say  
16 the impact of instrument tube failure on natural  
17 circulation.

18 MR. LEE: What happened is that --

19 MEMBER ABDEL-KHALIK: There's a hole in  
20 the center of the lower plenum and that sort of  
21 somehow disrupts the vertical part of natural  
22 circulation, or what --

23 MR. LEE: Will depressurize the system,  
24 so if the instrument tube fail, then you are failing  
25 inside the containment. So you will not --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER ABDEL-KHALIK: Right.

2 MR. LEE: It will be less risky to  
3 assume -

4 MEMBER SIEBER: The motive force goes  
5 down.

6 MEMBER ABDEL-KHALIK: Depending on the  
7 size, the neat break might be less than the 400 gpm  
8 that you were talking about in your diagram.

9 MR. LEE: It's a race between all these  
10 leak gauges we have; the seal leak gauge, the -- and  
11 Ed?

12 MR. FULLER: Is this on?

13 MR. LEE: Think so. Yes.

14 MR. FULLER: It is? Ed Fuller in the  
15 Office of New Reactors.

16 One of the things that we've noticed in  
17 the process of doing our reviews for new reactors is  
18 in a confirmatory assessment activity that what --  
19 it looks like the instrument tubes would probably  
20 fail just when all the other action is going on from  
21 the Zircaloy oxidation. And the problem is that the  
22 inside of the tubes is at the reactor containment  
23 pressure. So the instrument tubes become part of  
24 the RPV boundary.

25 For traditional PWRs where the

1 instrument tubes come out the bottom, the flow of  
2 gases and fission products from the core would go  
3 down the tubes, up the seal table and into the  
4 containment. For PWRs of the new designs with clean  
5 bottom heads, the instrument tubes come in from the  
6 top, so the gases and radioactive materials would go  
7 out that way.

8 The difference between going up and  
9 going down is in an accident scenario, severe  
10 accident scenario, as core melt progression  
11 proceeds, you can eventually block off those  
12 pathways with molten re-solidified debris. And  
13 that's why in TMI it's postulated that these flows  
14 stopped after awhile. One would not expect that if  
15 the flows were going to go upward as in new  
16 reactors.

17 We haven't really examined that for the  
18 BWRs yet, but in principle one could have the same  
19 issue.

20 CHAIR REMPE: Richard, just to be clear,  
21 when you're talking about an instrument tube  
22 failure, you're talking about away from the lower  
23 head, not anywhere near where the nozzles attach to  
24 the lower head? He's talking about that it was up  
25 higher and there was some sort of radiation coming

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 down?

2 MR. LEE: No, what happened is that  
3 there is a -- the evidence is that it was fail in  
4 the lower part. So the gas got transfer up to the  
5 seal table. So the detectors detect a high  
6 radiation level for awhile, but that went away after  
7 awhile. So we did the analysis. As Ed mentioned,  
8 even though you may have open the path earlier, but  
9 the melt relocated, got solidified and blocked the  
10 thing so there is not more transport of anything  
11 that go. For example, the noble gas or whatever  
12 down there transport out to the -- into the  
13 containment.

14 CHAIR REMPE: I'm aware of the fact that  
15 radiation leaked --

16 MR. LEE: Yes.

17 CHAIR REMPE: -- and I can remember from  
18 looking at the data years ago that we could see when  
19 they removed the nozzle above the lower head that  
20 there might be a few piece of melt that had come  
21 down, but I don't believe that anybody ever had  
22 enough evidence to really say that the melt actually  
23 traveled below the lower head.

24 MR. LEE: The reason that point was  
25 brought up is that in case if you really have a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 instrument tube failure, then the steam generator  
2 tube rupture problem goes away.

3 CHAIR REMPE: Yes.

4 MR. LEE: So we went and look at it.

5 CHAIR REMPE: Okay.

6 MR. LEE: And it didn't go away.

7 CHAIR REMPE: Okay.

8 MR. LEE: It didn't go away. That's the  
9 bottom line.

10 MEMBER SIEBER: So it's conservative  
11 what you're doing?

12 MR. LEE: Yes. Okay. Since someone  
13 brought it up, we have to look at it.

14 CHAIR REMPE: Sure.

15 MR. LEE: And we did.

16 MEMBER SIEBER: Okay.

17 MR. LEE: And it did not go away. The  
18 uncertainties analysis are base on these parameters  
19 as that's what we plan to investigate.

20 Raj, is there more than these  
21 parameters? I don't know, are these agree upon?

22 DR. IYENGAR: No, this is -- yes, after  
23 this Charlie had -- if you have any questions for  
24 Richard --

25 MR. LEE: Okay. So this is only for the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 TH part of it.

2 DR. IYENGAR: Yes.

3 MR. LEE: And there are more other  
4 uncertainty, but in terms of the tubes and all the  
5 other components will be discussed afterwards.

6 Any questions?

7 MEMBER ABDEL-KHALIK: Turbine-driven aux  
8 feedwater availability, I mean, if you have turbine-  
9 drive aux feedwater would you ever get into this  
10 kind of scenario?

11 MR. LEE: But I think after awhile it  
12 doesn't exist anymore because basically there's no  
13 more steam supply, so that's the end of it.

14 MEMBER RAY: You get into it in the --  
15 if you've lost cooling to the shaft seals because  
16 you can naturally circulate and remove steam from  
17 the steam generators using the turbine-drive aux  
18 feed pump, which is probably what you're talking  
19 about. But pretty quickly the reactor coolant pump  
20 seals will fail and you'll have a loss of coolant  
21 accident and the turbine-drive aux feed pump's  
22 useless then. You need to get the pressure down and  
23 that's not easy.

24 MR. LEE: So they're looking at those  
25 type of sensitive -- whatever the case is. So that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 is one of parameters that they've been looking.

2 Okay. All yours.

3 DR. IYENGAR: Charlie?

4 MR. HARRIS: Okay. My name's Charles  
5 Harris from the Office of Nuclear Regulatory  
6 Research and I was asked to provide information for  
7 this project regarding the current condition of the  
8 tubes in the current steam generator fleet.

9 If you have questions, you should have  
10 them ready, because I only have two slides.

11 As I said, we want to represent the  
12 current fleet and that would include getting the  
13 condition of CE plants, Westinghouse and Babcock &  
14 Wilcox once-through steam generators.

15 The flaws. To describe the flaws, we  
16 would want to know the number of flaws, the size of  
17 each, what type of flaw it is and where they're  
18 located to get a total leak area to do all the  
19 probability calculations. Work had been done in the  
20 past on steam generator flaw distributions in the  
21 early nineties, early to mid-nineties, but previous  
22 work was done with Alloy 600 material. Of course  
23 most of the Alloy 600 is now either replaced or  
24 being replaced. So information that I'm providing  
25 is on still some Alloy 600 thermally-treated

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 materials. The Alloy 600 in the past of course was  
2 the mill-annealed. So there's still Alloy 600  
3 thermally-treated, and of course the newer  
4 replacements in the U.S. are Alloy 690.

5 MEMBER SHACK: You do plan to update the  
6 distributions for the Alloy 600 plants that are left  
7 though, right?

8 PARTICIPANT: Yes, they're not all --

9 MR. HARRIS: Let me start on the next  
10 slide. The work that was done in the past was done  
11 by Gorman and others from Dominion Engineering in  
12 Oregon and there was a NUREG contractor report 6521,  
13 which was published in 1998.

14 So as far as describing the  
15 distributions, the sizes and the numbers of the  
16 flaws, that report we feel is still valid as far as  
17 the statistics go, but as I just said, this was done  
18 on -- with information, you know, only up to that  
19 point on the existing fleet and it was done on 600  
20 mill-annealed tubes. So to update that information  
21 we want to use information on flaws in -- that  
22 aren't thermally-treated and 690.

23 Emmitt Murphy is here. Did we decide on  
24 the significance of 600 mill-annealed? How many --  
25 or will they soon be replaced anyway? I'm not sure.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. MURPHY: This is Emmitt Murphy from  
2 NRR, DCI. There are a handful; five, six, seven  
3 PWRs with steam generators with Alloy 600 mill-  
4 annealed material and most of these will run a few  
5 more years. I didn't come prepared with the actual  
6 end dates on these plants, but for the next few  
7 years we're going to have a handful of such plants,  
8 and certainly we could develop a flaw distribution  
9 -- a representative flaw distribution for the  
10 remaining plants. That's certainly doable.

11 Just maybe one piece or clarification  
12 with respect to what you were talking about. Our  
13 thinking, our current thinking that the statistics  
14 from the Gorman report were still valid, we're  
15 talking about the probability density functions that  
16 were published for each of the flaw mechanisms.

17 For the generators that are out there  
18 right now, with the mill-annealed to the thermally-  
19 treated 600 to 690, to the extent that you have a  
20 degradation mechanism, you're probably dealing, at  
21 least with the stress corrosion, a smaller number of  
22 such flaws than you had back in the nineties. So  
23 you would be interrogating the probability density  
24 functions with a smaller number of flaws.

25 MEMBER SHACK: But for the new plants

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 these flaws would be mostly fretting-type things  
2 rather than cracks, right?

3 MR. MURPHY: For the 690 it's the  
4 fretting associated with the support structure and  
5 loose parts. Loose parts will continue to be a key  
6 player.

7 MR. HARRIS: All right. Of course, in  
8 the past the major problem was cracking and Alloy  
9 690 has more chrome to prevent the cracking. So as  
10 Dr. Shack was saying, where is more of a problem  
11 that we're looking at now with the Alloy 690? And  
12 where NRC is coming up with the information is from  
13 in-service inspection reports on history, of course  
14 the past history and the newer replacement steam  
15 generators since the early nineties, taking from the  
16 ISI data to get the updated flaw information.

17 Okay. That's all I had.

18 MEMBER ARMIJO: These materials, the new  
19 materials, you have a perfect un-flawed Alloy 690  
20 tube compared to something with a realistic flaw,  
21 whether by fretting or whatever. How much  
22 difference does it make in the life at these  
23 temperatures, which are really very high? I mean,  
24 you know, is it a big difference?

25 MEMBER SIEBER: Ten minutes.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: Seconds? Well, it is --  
2 you know, I'm just trying to get a feel for how --

3 MR. HARRIS: I'm not the thermal  
4 hydraulics person, but --

5 MEMBER ARMIJO: Well, you know --

6 MR. HARRIS: -- it is possible to do  
7 calculations on a pristine tube, that pristine tubes  
8 can fail in certain plants.

9 MEMBER ARMIJO: Yes, that's what I would  
10 expect.

11 MR. HARRIS: And flaws in the tubes only  
12 make it worse.

13 MEMBER ARMIJO: I'm just trying to get a  
14 feel for how much worse.

15 MR. HARRIS: Weld overlays can possibly  
16 even make it worse.

17 MEMBER SHACK: Well, think of something  
18 like, you know, failure at 850 C versus failure at  
19 750 C.

20 MEMBER ARMIJO: Okay. That's good.

21 MEMBER SHACK: And then you sort of  
22 figure out how long it takes you to --

23 MEMBER ARMIJO: Go from 750 to 850.

24 MEMBER SHACK: Eighty-fifty.

25 MEMBER ARMIJO: Yes. Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIR REMPE: When they did the  
2 calculations a long time ago with SCDAP, I thought  
3 that it did make a big difference if they assumed --  
4 and they only had one plant that they'd inspected  
5 and all that. But it made a difference in the  
6 likelihood of steam generator tube rupture. Is that  
7 not a correct statement?

8 MEMBER SHACK: Oh, yes. I mean, that  
9 temperature difference is important. I mean, you  
10 know, don't expect it to go -- it doesn't process  
11 hours though, or days.

12 CHAIR REMPE: Yes.

13 MEMBER SHACK: When these rates are  
14 fairly steep, you know, things just sort of happen  
15 and you may not know exactly when this thing is  
16 going to go steep, but once it decides it's really  
17 going to light up, things are going to happen fairly  
18 quickly.

19 CHAIR REMPE: Today I heard that we were  
20 going to use some of the results from this activity  
21 to determine tube repair criteria. And respect to  
22 the design basis and severe accident conditions, is  
23 the database that we're getting appropriate for  
24 making such decisions, or are there any suggestions  
25 that it should be expanded upon or anything? Are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 you -- this is -- what we're doing is the  
2 appropriate way to go?

3 MR. HARRIS: Yes. We're looking at  
4 design basis accidents also, yes.

5 MEMBER SHACK: No, what I was looking at  
6 was the regulatory impact of this work. And by and  
7 large the regulations governing the flaws that  
8 you're allowed to have in the steam generator tube  
9 are primarily based on design basis accidents.  
10 Sometimes when reflect on this, it makes decisions  
11 though. You know, when they've done it, they -- as  
12 I mentioned, the one that comes to mind is the  
13 electrosleeve repair which did meet all the  
14 requirements for the design basis accidents, but  
15 because it looked so bad in the severe accidents,  
16 its use was discouraged.

17 And, you know, I was just trying to  
18 think of how this impacts regulatory decisions and,  
19 you know, since they're primarily based on design  
20 basis accidents, sometimes it's fairly indirect. As  
21 I say, I keep thinking that most of the impact will  
22 be in deciding how you perhaps do operator actions  
23 in certain classes of accidents and would give  
24 different perspectives on that. But the insights  
25 are useful.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIR REMPE: Yes. I just was wondering  
2 if what we're getting from the data for the flaw  
3 distribution is appropriate, there's nothing else  
4 you can do. And is it less important than the  
5 thermal data that could -- the thermal hydraulic  
6 data that could be obtained is why I'm kind of  
7 pushing the issue.

8 MR. HARRIS: Oh, it's not less  
9 important. If you have a lot of flaws in the tubes,  
10 that's important.

11 CHAIR REMPE: Sure. Yes.

12 MEMBER SHACK: Maybe less important is  
13 the steam generator gets in better and better  
14 condition I guess is -- you know, I --

15 CHAIR REMPE: Okay.

16 MEMBER SHACK: We had sort of multi-  
17 level distributions in the old NUREG and I think  
18 most of the ones at the bad end of that are history.

19 CHAIR REMPE: Okay.

20 MEMBER SHACK: Those are steam  
21 generators that are gone. So, you know, I think  
22 we've skewed the statistics that you've developed  
23 from 6521 just because more modern inspection  
24 treatments and that don't let them get in that  
25 conditions, but --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. HARRIS: Never.

2 CHAIR REMPE: Okay.

3 MR. HARRIS: Anything else?

4 No? Okay. Thank you.

5 MEMBER SHACK: The good news is we're  
6 much better at characterizing fretting than we are  
7 cracks.

8 MEMBER POWERS: Well, it's easier to see  
9 frets than a crack.

10 DR. IYENGAR: The next step of analysis  
11 that we would be undertaking, it would be the  
12 failure of RCS components. We've talked about it at  
13 length as well in the past. The main tasks are to  
14 identify and characterize, and model of course, the  
15 RCS nozzles, as well as other potential weak areas  
16 to see when they would fail in terms of time so that  
17 that could be fed into the calculator to make the  
18 assessment of containment bypass or not.

19 So what we have to do is we will get the  
20 thermal hydraulic input from MELCOR, as earlier  
21 indicated. We will feed that into a finite element  
22 model of the RCS components with the properly-  
23 bounded conditions for both the Westinghouse side  
24 and the CE plants.

25 The challenge here I -- well, we're not

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 doing this from scratch at this moment, because we  
2 have some work with the past ANL which we will rely  
3 upon. Some nice analysis have been done by Dr.  
4 Majumdar on this. What they had done was done for  
5 one Westinghouse-type plant. But now we have a  
6 little bit more of a challenge here in that we are  
7 -- in order to become consistent with the steam  
8 tubes -- steam generator tubes, we are hoping to  
9 develop some kind of a failure model for our  
10 critical RCS component; perhaps what comes to mind  
11 is a hot leg nozzle; that seems to be the most  
12 critical based on many studies that Dr. Majumdar had  
13 done, which would not be specific to one particular  
14 geometry in one particular plant.

15 Can we develop a model that's creep  
16 rupture or tensile rupture depending on -- which  
17 would involve, you know, some geometry changes. If  
18 you have -- from plant-to-plant, you know, the  
19 diameter or the thickness changes. Can we have the  
20 appropriate model? That is a little bit of a  
21 challenging task. And if that's not much of a  
22 challenge, as my boss had indicated, we want to do  
23 some weld overlay, which is going to complicate  
24 matters as well. So these are some of the  
25 challenges that we are, you know, trying to address

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 right now. And if you have any advice or input on  
2 that, we certainly would welcome that.

3 MEMBER ABDEL-KHALIK: How big a sub-  
4 component or a sub-part of the system would you have  
5 to model --

6 DR. IYENGAR: Well, yes.

7 MEMBER ABDEL-KHALIK: -- to capture the  
8 behavior of this particular component?

9 DR. IYENGAR: Yes, there are two issues.  
10 Now that's what we do for component integrity. We  
11 do the sub-model. Here you have, in the severe  
12 accident condition you have very high temperatures.  
13 So you have substantial thermal stresses which will  
14 -- much more than the design basis. And then over  
15 that you have primary stresses.

16 Now, if your primary stresses are  
17 changing substantially, those are things we do not  
18 know yet. The ANL work had not addressed that  
19 because that was only one plant and the sub-model.  
20 That's what we are trying to see in this. We are  
21 trying to see if we can take the weakest link; for  
22 example, hot leg and do a sub-model of that. Would  
23 that capture all the important essence of doing a  
24 full-fledged model? That we haven't done yet. And  
25 if that were possible, that will help us a lot,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       tremendously in terms of addressing weld overlay and  
2       the different thicknesses.

3                   MEMBER ABDEL-KHALIK:   Would you have to  
4       do a transient three-dimensional model for each  
5       component covering the entire history of the --

6                   DR. IYENGAR:   Well, what we have to do  
7       is we have to take the first full line.  We do the  
8       transient analysis of the critical ones.  And then  
9       we take a sub-model of that and just do -- put the  
10      -- apply the thermal hydraulic boundary only to the  
11      sub-model and see if you get, you know, fairly close  
12      results.  That's one way to approach.  If you do,  
13      then, you know, probably you want to try for other  
14      transients.  And then once we have that confidence,  
15      and you can take the sub-model and do different  
16      geometries, different weld overlay thickness.  
17      That's one approach.

18                   The other approach is you -- I mean,  
19      while the other approach is in the finite element  
20      context, you can do the shell model of the entire  
21      structure, which is, you know, a little bit less  
22      expensive.  And then take the sub-domain that you're  
23      interested in and do a three-dimensional analysis of  
24      the sub-domain.  But that still doesn't tell us  
25      whether you can just do the sub-components for your

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 analysis with different geometries. So, these are  
2 the two things that we would try.

3 MEMBER ABDEL-KHALIK: Well, I'm trying  
4 to even find out whether you need to do transient  
5 analyses for the sub-components or a sequence of  
6 steady state calculations with different pressures  
7 and temperatures.

8 DR. IYENGAR: We do need to do the  
9 transient because the temperature changes during  
10 these accident scenarios. The rate is extremely  
11 high. And I do not know if without doing transient  
12 analysis you would be able to capture the thermal  
13 stress changes and if any primary stress change  
14 effects.

15 Dr. Shack?

16 MEMBER SHACK: Yes, I mean, I think  
17 you'd have to do that in that hot -- you know, the  
18 nozzle reach in which -- again, the reason we did  
19 such a detailed calculation was we weren't sure  
20 where the thing was going to be and in fact it  
21 shifted around. As the CFD went through its  
22 analysis, they had sort of underestimated some of  
23 those entrance effects. And as the CFD analysis  
24 became refined, the location of the likely failures  
25 had changed. And I think everybody sort of now

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 agrees it probably is the hot leg.

2 DR. IYENGAR: Okay.

3 MEMBER SHACK: Whether that will change  
4 when you go to a CE plant is, you know, perhaps  
5 another question, but -- for these plants and so --  
6 but at least in that region you would still be doing  
7 the transient because again the walls are thick  
8 enough and the prime temperatures are changing fast  
9 enough that you really can't do --

10 MEMBER ABDEL-KHALIK: A sequence of  
11 steady state calculations.

12 MEMBER SHACK: -- a sequence of steady  
13 state calculations.

14 DR. IYENGAR: Yes, if you did --  
15 actually there is. For a creep rupture at least, if  
16 we could do the steady state analysis, we have  
17 equations that would give some kind of estimate for  
18 timed rupture for -- you know, given pipe geometry.  
19 We could use that and we don't have to do all these  
20 things, but --

21 MEMBER ABDEL-KHALIK: Yes, that's why I  
22 was asking.

23 DR. IYENGAR: Yes, we have textbook  
24 solutions for that. That would be easy on me.

25 MEMBER POWERS: Dr. Shack, I'm slow.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Earlier we discussed flaw size distribution. We  
2 didn't discuss shape and we certainly in connection  
3 with overlay analysis and things like that we found  
4 that shape made a difference. Should we consider in  
5 this program flaw shape?

6 MEMBER SHACK: Well, we haven't gotten  
7 to the tube models yet where the flaw shapes will  
8 presumably be important if you want to do a  
9 realistic-type analysis.

10 MEMBER POWERS: Yes.

11 MEMBER SHACK: I don't know what the  
12 plans are to refine that. Because we dealt with  
13 flaw shapes for ductile failures, we really did the  
14 -- at least the experimental confirmation of the  
15 creep models basically for rectangular cracks. And  
16 the way that we treat multi-shaped cracks in the  
17 ductile model gives you a guide for the way you  
18 might attack the problem for the creep problem, but  
19 I'm not sure you'd -- you know, you'd presumably  
20 want some experimental verification of that and I  
21 don't know whether that's included in the plan or  
22 not.

23 MEMBER POWERS: Well, it seems to me  
24 this general issue of shape out to be at least  
25 considered, as the revered Dr. Rempe pointed out at

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the beginning of the program, so we can make  
2 adjustments, or so she tells me.

3 MEMBER SHACK: I'm assuming if they have  
4 any significant flaw, this thing is going to be  
5 overlaid and then so they'll be looking at the  
6 overlay configuration, which will make the flaw much  
7 less important.

8 MR. CSONTOS: Yes, different components  
9 have different types of mitigation strategies. For  
10 a hot leg and cold leg the sizes are so large it  
11 would take on the order of three weeks to four weeks  
12 and maybe more to do a full structural weld overlay.

13 So since plants had that problem with  
14 having an extended outage for doing a full-structure  
15 weld overlay, many of these locations went to MSIP,  
16 mechanical stress improvement, squeezing or there's  
17 a new approach that industry is looking at with  
18 doing flaw evaluations in lieu of doing mitigations  
19 and doing inspections every four years. And if they  
20 do find a flaw, can they go on for another one or  
21 two cycles type of thing? And it's an individual  
22 case-by-case evaluation plant-by-plant.

23 Another thing is that they've also  
24 looked at --

25 MEMBER POWERS: It's had a pretty poor

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 track record, too.

2 MR. CSONTOS: And the other part to this  
3 is optimized weld overlays. And optimized weld  
4 overlays is basically I wouldn't say a full -- it's  
5 in between doing nothing at a full structure weld  
6 overlay. It's about half of a full structure weld  
7 overlay. And it's specifically designed for the  
8 pressure temperature and the situation of the crack  
9 or a potential crack that would be there.

10 And so there are different types of  
11 mitigations and these are the types of things that  
12 do you analyze a situation for a creep or other type  
13 of failures modes, you know, with a crack, without a  
14 crack? Do you have it with MSIP? Do you have it  
15 with an optimize weld overlay? Do you have it with  
16 a full structural weld overlay? And then what kind  
17 of size cracks? What shape are the cracks? Are  
18 there multiple cracks? These are questions that,  
19 you know, it just goes into the level of complexity  
20 into the details of what's really out there in  
21 plants right now.

22 And so that's some of the discussions of  
23 what level of detail do we go down? Do we start off  
24 from the generic pipe analysis, you know, just a  
25 general pipe stressed analysis or do you go all the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 way down to a degraded condition with different  
2 types of mitigations? Does that --

3 MEMBER POWERS: Well, I think you make  
4 my point that we need to look at some of these real  
5 plant issues and say are they important or not  
6 important? And if they look like they're important,  
7 the overall goal is to put into hands of the line  
8 organizations tools for making those tough decisions  
9 on --

10 MR. CSONTOS: Right.

11 MEMBER POWERS: And it is explicitly can  
12 I go another outage before I do anything because  
13 it's going to take me some time to set up to do  
14 something and I'd just as soon do that while I'm  
15 generating kilowatts rather than twiddling my  
16 thumbs. And that's a tough decision to make because  
17 the consequences of being wrong are really, really  
18 bad.

19 MEMBER SIEBER: I think the problem  
20 though that seems to be coming out is if you repair  
21 your plant, then you move the vulnerability point  
22 back to the steam generator, which is the cause of  
23 the bypass. And, you know, it seems like there's a  
24 horse race amongst a lot of different candidates for  
25 the failure point, some of which are not as bad as

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 others. And I suspect that there are a lot of  
2 plants that are unique out there as far as strength  
3 at various points. And I think it's very difficult.  
4 You almost have to do an assessment of every plant  
5 in order to figure out what's going to fail first.

6 MEMBER BLEY: Let me ask you a question.  
7 What's industry doing in this area? Are they  
8 participating with you at all? Are they following  
9 it? And do you know what the SAMGs say about this  
10 kind of event?

11 MEMBER SIEBER: Put your respirator on.

12 MEMBER BLEY: It says more than that  
13 actually. I've seen the European ones and they do  
14 have some aimed at address this very scenario, but I  
15 don't know about the ones here.

16 DR. IYENGAR: Well, as far as industry  
17 goes, I think we have been in contact regarding this  
18 project. They are aware of this project. I do not  
19 know if they are developing methodology on their own  
20 or not. That I do not know.

21 But, Al, do you have any --

22 MR. CSONTOS: Can you repeat the  
23 question about the Europeans?

24 MEMBER BLEY: Well, the question had  
25 nothing to do with the Europeans.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. CSONTOS: Okay.

2 MEMBER BLEY: That was an example. The  
3 question had three parts: What's industry doing  
4 with respect to this creep rupture possibility for  
5 the steam generators? Are they involved with you at  
6 all? And do you know what they've already done  
7 within the context of the severe accident management  
8 guidelines aimed at this particular possible failure  
9 mode?

10 MR. CSONTOS: Well, I know my group has  
11 not been that involved working with industry on  
12 this, to be perfectly blunt. But that's my group.

13 MEMBER BLEY: Come back, Ed.

14 MR. FULLER: This is Ed Fuller again  
15 from the Office of New Reactors. In my previous  
16 incarnation in the industry, EPRI developed a steam  
17 generator tube integrity risk assessment methodology  
18 which utilized pretty much all of the concepts that  
19 you're hearing today, although things are maturing  
20 much, much more now than they were then. These  
21 documents were provided to the various utilities in  
22 the industry and they use them to varying degrees.  
23 Since I've been at the NRC nearly five years now,  
24 I've lost track of what they might be doing in this  
25 area. Regarding accident management, yes, in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 particular the Westinghouse SAMGs do address the  
2 possibility of induced tube rupture and --

3 MEMBER BLEY: Do they try to act before  
4 the event or is it following up after?

5 MR. FULLER: Well, generally speaking  
6 they try to keep track of the core exit temperature  
7 and when it gets up to around 1,200 degrees  
8 Fahrenheit, if they can depressurize they will try.  
9 Otherwise, they'll try other techniques to minimize  
10 the probability that a tube would fail before some  
11 other point.

12 MEMBER BLEY: Okay. Thanks.

13 MR. FULLER: And for the new reactors  
14 they all come with depressurization systems designed  
15 to prevent just this.

16 MEMBER BLEY: Thanks very much. And I  
17 know you've got some slides on PRA, so I hope when  
18 you get there you'll talk about what you're thinking  
19 about from the standpoint of the operators'  
20 involvement in this.

21 DR. IYENGAR: Sure, Selim would gladly  
22 address that.

23 MR. LEE: This is Richard Lee. As I  
24 mentioned to you earlier, a few weeks ago when we  
25 went to a SAMG training given by Westinghouse.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           My staff went; I didn't go. They told  
2           us that they're going to put water back into a steam  
3           generator, which surprised us, because most of the  
4           time when recover you put in a core. So perhaps we  
5           should revisit. It may be the case that they just  
6           say the core is gone so you might want to put it  
7           into the steam generator because that -- if the path  
8           open up there, there will be a direct out.

9           MEMBER BLEY: Yes. Okay.

10          MR. LEE: So we need to really look at  
11          that one again, see what it is.

12          MR. ZOULIS: I had the opportunity to be  
13          a severe accident management implementer at Indiana  
14          Point, my previous incarnation. And one of the  
15          strategies is to keep the steam generators covered.  
16          And the emphasis of the SAMGs that you're aware of  
17          is not core damage anymore. It's containment and  
18          release challenges. So the whole emphasis; and that  
19          was part of the training to the operations, was to  
20          refocus them on that issue. Forget the core. It's  
21          releases and containment. The core is already  
22          melted. You know, you're above 400 degrees  
23          according to thermal temperatures; you need to focus  
24          on that. And one of the main strategies was to keep  
25          the core -- the steam generator tubes covered to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 prevent a steam generator-induced rupture.

2 MEMBER SIEBER: Let me ask a question  
3 that's a little bit off the subject. So far this  
4 afternoon we've talked almost exclusively about  
5 Combustion Engineering and Westinghouse reactors.  
6 What about B&W reactors? Where do they fit into all  
7 of this?

8 MR. LEE: At the time of the B&W  
9 reactor, because it's a once-through steam generator  
10 with a very large hot leg going up --

11 MEMBER SIEBER: Right.

12 MR. LEE: -- and the --

13 MEMBER SIEBER: And it comes out the  
14 top.

15 MR. LEE: -- we didn't do that analysis  
16 back in the late nineties because they said the  
17 super heated steam really don't go up there with the  
18 circulation coming -- hitting back like the new tube  
19 seal behavior like this type.

20 MEMBER SIEBER: Okay. So the  
21 vulnerability --

22 MR. LEE: So we didn't look at the -

23 MEMBER SIEBER: Okay. The vulnerability  
24 is not there?

25 MR. LEE: Correct.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: All right.

2 MR. LEE: And also the steam generator  
3 tubes history in terms of flow and all those, they  
4 perform better than the Westinghouse U-tube steam  
5 generator. That's what I remember.

6 MEMBER SIEBER: Okay. Thank you.

7 CHAIR REMPE: I guess I'm a little  
8 confused because when we were looking at the user  
9 need background information that Christopher sent to  
10 us, wasn't there a request that came back from NRR  
11 saying that RES should modify the assessment method  
12 to include consideration of tube failure in one-  
13 through steam generators? Am I misunderstanding  
14 some of this information?

15 DR. IYENGAR: Yes, there is a task for  
16 once-through steam generator, which Charlie Harris  
17 was going to get some data.

18 Emmitt, do you work with Charlie on  
19 that, the once-through steam generator information  
20 or update?

21 MR. MURPHY: As memory serves me, that  
22 request was not related to severe accident-type  
23 analyses. We were interested in looking for tools  
24 to allow us to predict tube severance in once-  
25 through steam generators, circumferential failure

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 under extreme differential thermal conditions that  
2 one might get outside of severe accident space like  
3 when you put a lot of cold water in with hot tubes.

4 CHAIR REMPE: Okay.

5 DR. IYENGAR: Thank you. We'll provide  
6 additional clarification --

7 CHAIR REMPE: Yes, it's not --

8 MEMBER POWERS: Raj, your job's not  
9 getting smaller is it?

10 DR. IYENGAR: I know we are all  
11 interested in the role of uncertainties in these  
12 predictions, and of course these are all analytical  
13 or numerical kind of predictions, and so we have to  
14 feed in a lot of information and information that we  
15 get will have more uncertainties. So certainly one  
16 of the most critical -- some of this work in terms  
17 of finding sensitivity with the respective material  
18 properties was done at ANL. Dr. Majumdar with  
19 respect to the hot leg failure.

20 We do have data available for the creep  
21 regime as well as the tensile properties of these --  
22 I mean, temperatures for the carbon steel and  
23 stainless steel material that we are interested in.  
24 So that's a little bit comforting. At least we have  
25 properties which are available, so that might reduce

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 some of the uncertainties involved in that. And  
2 geometry uncertainties will be there in terms of  
3 geometric dimensions, as well as weld overlay in  
4 terms of the defect.

5 Now, here is what I want to caution  
6 though. In terms of normal component integrity  
7 analysis that we do, we do idealize the different  
8 geometry of the dimensions such that the resulting  
9 analysis prediction will be somewhat conservative in  
10 terms of component integrity. But that's not what  
11 we can do here, because here conservative in one  
12 side implies non-conservative. Because what we are  
13 trying to do is to see if these would fail before  
14 the steam generators. And if you try to put in  
15 largely conservative geometry and conservative  
16 defects, then you will not have -- you'll have a  
17 non-conservative prediction. So we have to be --  
18 you're flirting on the -- little bit of difficulty  
19 there. We have to be careful what we input in terms  
20 of distribution there.

21 And we do have -- we will be using both  
22 the creep rupture and the tensile kind of models,  
23 and that has been addressed in terms of how the  
24 property and certainly it will influence the results  
25 to some extent by Dr. Majumdar. So we rely on that,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 but we will do our somewhat sensitivity studies on  
2 that as well.

3 Now, as far as thermal properties, the  
4 ANL studies have shown that the thermal property,  
5 the thermal expansion coefficient variation is not  
6 that significant in terms of effected the results.  
7 The conductivity, little bit more than that, but  
8 still not as much as the creep properties. So these  
9 are things that we will address as we travel along  
10 the project.

11 MEMBER ABDEL-KHALIK: Before you go onto  
12 the next topic, there are many plants who test their  
13 aux feedwater pumps by injecting directly into the  
14 steam generators either immediately before they go  
15 into an outage or immediately before they get back  
16 out of an outage. And the question is whether this  
17 is a good practice or something that may have an  
18 impact on this particular issue. And if it does,  
19 would you recommend that people sort of install  
20 recirculation lines so that they can test their aux  
21 feedwater pumps without injecting into the steam  
22 generators while they're hot?

23 DR. IYENGAR: I don't have enough  
24 expertise to provide any answer on that, but I'm  
25 going to have Kevin Coyne or Antonios or Richard to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 chime in. If not, we will have to take this back  
2 and try to find, you know, if there's any  
3 information available that would be helpful to  
4 answer this question and we will get back to you.

5 MR. COYNE: Raj, this is Kevin Coyne  
6 from the Office of Research, Division of Risk  
7 Assessment.

8 That question, we really don't have the  
9 right people here and it's really beyond the scope  
10 of this particular project to answer that.

11 MEMBER ABDEL-KHALIK: But it may. I  
12 mean, if the periodic conduct of these experiments  
13 impacts the flaw size distribution that you  
14 ultimately accumulate in the steam generator tubes,  
15 then it does have a direct impact on what you're  
16 doing.

17 MEMBER STETKAR: I think you also  
18 have --

19 MEMBER ABDEL-KHALIK: And -

20 MEMBER STETKAR: Well, let me chime in  
21 here --

22 MEMBER ABDEL-KHALIK: I don't know  
23 whether --

24 MEMBER STETKAR: -- that there's --

25 MEMBER ABDEL-KHALIK: -- it does or it

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 doesn't.

2 MR. COYNE: In this case we're getting  
3 the flow distributions from recent operating  
4 experience from the steam generator tube  
5 inspections, so it would reflect the current state  
6 of the operating fleet.

7 MEMBER ABDEL-KHALIK: But if it is a bad  
8 practice --

9 MEMBER STETKAR: Before you get too  
10 myopic on one issue, there's also a benefit to be  
11 obtained to know that indeed the lines that deliver  
12 the flow to the steam generators are indeed open,  
13 that, for example, valves in those lines are not  
14 somehow miraculously closed. And without doing an  
15 integrative flow test you don't know that. So  
16 there's benefits to actually putting water from  
17 point A to point B through a line to verify that the  
18 pipe is indeed open, that you have to trade off.  
19 We're talking about risk assessment here and one  
20 shouldn't get too focused one particular issue and  
21 imply that there are things that one should do to  
22 make that issue better, that could indeed make other  
23 issues much, much worse.

24 MEMBER ABDEL-KHALIK: In fact issues  
25 that might be likely to occur.

1                   MEMBER STETKAR: In fact make issues  
2 that risk assessments have shown have been bad for  
3 people who do indeed just do recirc of their aux  
4 feedwater and never verify flow to the steam  
5 generators. They really don't know the internal  
6 status of valves in those lines without actually  
7 putting flow through them.

8                   MEMBER ABDEL-KHALIK: I was just looking  
9 at it from a mechanistic standpoint --

10                  MEMBER STETKAR: Yes.

11                  MEMBER ABDEL-KHALIK: -- how this  
12 practice actually may impact --

13                  MEMBER STETKAR: But I think that's part  
14 of what the risk assessment people are talking  
15 about.

16                  MEMBER BLEY: Those kind of tests have  
17 actually caused some damages in the feed rings, but  
18 you know, you got to come then through -- well, on a  
19 Westinghouse generator you got to come down through  
20 the downcomer or there's going to be mixing because  
21 this is a lower level of flow and you don't run it  
22 forever. So there's a lot of trade-offs there. I'd  
23 be real hesitant to leave this meeting with a  
24 suggestion that that's a -- you know, not that you  
25 shouldn't look at it, but it's --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   MEMBER STETKAR:  Something should look  
2                   at it, but I think the message is in an integrated  
3                   risk sense to see what is the downside of putting  
4                   potentially cold water in there versus the benefit  
5                   that you get in terms of verifying --

6                   MEMBER ABDEL-KHALIK:  That the lines  
7                   are --

8                   MEMBER STETKAR:  -- in an integrated  
9                   risk assessment sense that the fact you have higher  
10                  confidence that you can actually deliver flow under  
11                  most of the conditions when you really want to get  
12                  it in there.

13                  MEMBER ABDEL-KHALIK:  By just verifying  
14                  that the valve's open when you're running the tests?

15                  MEMBER STETKAR:  Simply, an open  
16                  indication on a valve doesn't mean that it's open.  
17                  There have been events where people have believed  
18                  valves were open when indeed the internals believed  
19                  otherwise.  Without actually putting flow through  
20                  that line, you just don't know the internal status  
21                  of the valve.  It's a rare event, but you know --

22                  MEMBER BLEY:  Well, it's not as rare as  
23                  -

24                  MEMBER STETKAR:  So it's -- that's  
25                  right.  Well, the question is is it -

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 (Simultaneous speaking.)

2 MEMBER BLEY: Vis-a-vis those events?

3 MEMBER STETKAR: That's right. They  
4 have happened.

5 DR. IYENGAR: Thank you. If you don't  
6 have any questions on the RCS component analysis, we  
7 will move onto PRA-related activities. Selim  
8 Sancaktar would be presenting that.

9 MR. SANCAKTAR: My name is Selim  
10 Sancaktar from Research, PRA.

11 I have a few slides basically  
12 concentrating on project-related stuff, although  
13 this is under technical section-wise presentation,  
14 technical -- it says technical. I really don't have  
15 any technical details, as you can see, for the  
16 simple reason that we have started relatively  
17 recently and we do not have any detailed information  
18 to present to you yet.

19 The first slide I have, this information  
20 is take from the User Need, and you already saw it  
21 at the beginning of the whole presentation.  
22 Antonios has a slide that's pretty much the same.  
23 These are the titles of the PRA-related tasks and we  
24 are concentrating on the first two. These two would  
25 be like a second phase after we figure out what

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 works in here in the first two pieces, 3.A and 3.B.  
2 So to start the project we are addressing 3.A and  
3 3.B.

4 So we have two PRA-related projects that  
5 are underway. First, after a lengthy effort we  
6 managed to place a commercial contract in place for  
7 creation of a PRA report as a deliverable to address  
8 task 3.A, which would document an acceptable PRA  
9 model acceptable to the NRR, and also to RES of  
10 course, and also other offices that have interest in  
11 this subject. And we are making progress in that,  
12 but we just placed it in the last few months so  
13 there isn't much done yet.

14 And we have a parallel contract, small  
15 contract, relatively small effort to create a  
16 consequential steam generator calculator for the  
17 specific task of estimating steam generator tube  
18 leakage probabilities under different conditions and  
19 for different designs and that said no more than  
20 that. It's not very smart. It's a calculator. So  
21 different people may have different expectations  
22 even in RES about it. And it's not that smart.  
23 It's not like a T&H code. It just tries to do mini  
24 calculations repeatedly without exhausting any  
25 resources trying to calculate some probabilities.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 So that will support task 1 at some point.

2 MEMBER SHACK: But what does this thing  
3 start with?

4 MR. SANCAKTAR: Which one?

5 MEMBER SHACK: The calculator. I mean,  
6 what's the --

7 MR. SANCAKTAR: What it accepts as  
8 inputs, it accepts from T&H analyses a scenario,  
9 temperature and pressure that the tubes see as a  
10 function of time. So it's like a vector of numbers  
11 with Delta time increments of seconds or minutes or  
12 10 minutes, whatever is appropriate. So that comes  
13 from T&H.

14 From the steam generator tube flow  
15 information comes flow type, circumferential or  
16 axial flow depth. And then flow length, flow depth  
17 and type of flow and how many of each, or something  
18 like that. And then of course there are supporting  
19 little libraries that give you material properties  
20 and constants and this and that. And the equations  
21 used are not really probabilistic. I mean, the  
22 equations we have are -- if you meet certain  
23 conditions, you can exactly say that it's going to  
24 fail at this temperature and this pressure, a given  
25 flaw. So what makes this probabilistic is the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       uncertainties assigned to various parameters that  
2       come into the calculators that are assigned by the  
3       users. That's what makes it probabilistic.

4       Otherwise, it just calculates. Basically for each  
5       calculation it gives you the deterministic number.

6       Does that answer your question?

7                   MEMBER SHACK: Yes.

8                   CHAIR REMPE: And what are you going to  
9       use it for? Are you going to take it and put it  
10      into MELCOR?

11                  MR. SANCAKTAR: Oh, no.

12                  CHAIR REMPE: Are you going to use it at  
13      the plant?

14                  MR. SANCAKTAR: Yes, good question. Let  
15      me -- this is counter-intuitive for some reason.

16      I'm going the other way. If you go back, it's going  
17      to address this. Basically, if you go back to the  
18      NUREG-1570 and so on, there are tables that said if  
19      you have this scenario on the risk conditions, the  
20      probability of certain well-defined steam --

21      whatever steam generator tube rupture is defined as  
22      whatever integrated opening area is, it's a  
23      probability 0.005. Change of scenario is 0.007.

24      This is going to give you equivalent numbers to fill  
25      that table so somebody can read if I have this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 scenario, I have this. Or they can go back, change  
2 the flaw distribution for a given plant and  
3 calculate a different number. Change the scenario  
4 parameters and calculate a different number.

5 So we will prepare relatively limited  
6 set of scenarios with a small table for people to  
7 just pick up numbers for typical scenarios and then  
8 let the users who exercise it to change flaw sizes,  
9 flaw distributions and we are -- we defined this --  
10 requirements for this calculator so that you can  
11 just put it on your computer and it works. You  
12 don't have to call your IT. That's very important.  
13 Otherwise, it won't work. Every time you have to  
14 call your IT to install it.

15 And we are pushing hard for people to  
16 use it actually and we are inviting people, too,  
17 from NRR and RES to come and exercise it. And we  
18 offer them opportunities to come out to their room  
19 and show it to them. So we are hoping that people  
20 will actually use this. Whether it will be used or  
21 not, I don't know, but we'll give it a try.

22 These are some words directly taken from  
23 the User Need. Just want to show you some of the  
24 words, you know, so you see what's -- how they're  
25 stated. It's a simplified method. Methods should

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 be based on standard PRA techniques.

2 MEMBER STETKAR: Selim, let me ask you  
3 something about the words, because there are several  
4 words that give me pause for thought, words like  
5 "efficient," "simplified," "very simple," "standard  
6 PRA techniques." You said that you've just recently  
7 issued a contract for the PRA-related work. Does  
8 the scope of work for that contract examine  
9 fundamental changes to Level 1 PRA models such that  
10 they are capable indeed of identifying and  
11 quantifying the scenarios that could leave you  
12 vulnerable to consequential tube ruptures? Because  
13 I submit that the vast majority of existing Level 1  
14 PRA models, with the exception of steam line breaks,  
15 do not because the vast majority do not look at  
16 excessive cooling. They do not look at openings of  
17 secondary relief valves. They do not look at  
18 turbine bypass valves and you should not get myopic  
19 about station blackout is the only thing that could  
20 lead to core damage.

21 And I've thought about this quite a bit  
22 over the last couple of years as I've learned more  
23 about this issue thinking about how I would  
24 restructure a Level 1 PRA model to capture the  
25 scenarios which would leave you vulnerable to this.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 And it's a fundamental restructuring because the  
2 analyst must think now of what events can leave me  
3 vulnerable to depressurizing the secondary side of  
4 steam generators, which is generally considered to  
5 be a good thing. More steam relief is generally a  
6 really good thing in the world of Level 1 PRA.

7 But if you have that, people tend not to  
8 look at, well, okay, I opened up all the relief  
9 valves in the world and, darn it, I couldn't get any  
10 feedwater. And they tend to think that that issue  
11 is not tracked. That is not a scenario that's  
12 tracked. It's simply that I didn't have enough  
13 feedwater. You don't know the status of the relief  
14 valve.

15 So is part of your contract to give  
16 people sensitivity to the fact that this is -- you  
17 know, if you're just identifying scenarios from  
18 existing PRAs that may be vulnerable to this  
19 condition, you're probably only identifying a fairly  
20 small subset of the real scenarios, especially if  
21 the operators are given guidance, for example, on  
22 loss of main feedwater and auxiliary feedwater to  
23 rapidly depressurize the secondary side of the plant  
24 to maybe try to get condensate in there. Those  
25 scenarios aren't looked at.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. SANCAKTAR: Well, although  
2 everything is written in simple English and it's in  
3 black and white, things are -- what they mean like  
4 is when it says design basis accidents. I mean,  
5 that's like a -- that's going to be a huge area and  
6 just like you mentioned. And also the factor of  
7 when you finish this product, who's the cognizant  
8 receiving-end champion who is going to evaluate,  
9 make the scope one way or the other? I mean, we  
10 cannot estimate the scope by purely reading these.  
11 So we have a task one which says interact with NRR  
12 cognizant engineers, RES supporting technical  
13 cognizant engineers and assess the situation.  
14 Figure out what are you going to do with this? What  
15 is this product going to be used?

16 In fact, we have meetings and we ask the  
17 question. And we ask the question to the current  
18 cognizant engineer, not the previous cognizant  
19 engineer who wrote this and retired, or whatever,  
20 gone. And by the time we are finished probably  
21 there will be a new cognizant engineer who might ask  
22 another question like you're asking.

23 So, what's the product for? And the  
24 answer is in the eye of the beholder. For example,  
25 are they going to use this for SDP analyses, for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 event analyses, or is this an encyclopedia of how to  
2 do a PRA for consequential steam generator tube  
3 ruptures, which is kind of what you are getting  
4 into.

5 MEMBER STETKAR: Yes.

6 MR. SANCAKTAR: And we have to define  
7 what are we going to do with this? Is this an  
8 encyclopedia? Is this a catch-all? Or is this a  
9 short orderly procedure that tells you (A) do this;  
10 (B) do this, look at this? It has to be defined up  
11 front with the input of the user or potential users.  
12 And how much it will address your type of  
13 requirements we will certainly see. I mean, I  
14 don't --

15 MEMBER STETKAR: Well, I guess what I'm  
16 struggling with is I can envision this going two  
17 different ways. One way is something that provides  
18 guidance; for example, take the existing suite of  
19 SPAR models and how do you characterize the  
20 scenarios that are generated by those models with no  
21 other modification of the models whatsoever? How do  
22 you characterize that library of scenarios in terms  
23 of conditions which you can then plug into your  
24 little calculator that you like with no IT support  
25 to give me a number for the likelihood that I get a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 consequential tube rupture on a core damage  
2 scenario? That's one way that it could it head.

3 The other way is if we believe that  
4 consequential tube ruptures could be a potentially  
5 important contributor to risk, are our current tools  
6 developed sufficiently to capture that element of  
7 risk? And that's more toward the direction.

8 And I guess I'm not quite sensing from  
9 what you've said so far which of those two -- if I  
10 can characterize those as two extremes of --

11 MR. SANCAKTAR: I have my personal  
12 opinion and preference, but I wouldn't want to put  
13 it on the table until we find out what the user --  
14 how the user visualize and what they need, and then  
15 of course discuss it with them. It's only a matter  
16 of money and time. We can look at everything given  
17 enough money and enough time.

18 MEMBER STETKAR: Yes. Right.

19 MR. SANCAKTAR: So where do you draw the  
20 line to satisfy the needs or the perceived needs of  
21 NRR?

22 Yes, Kevin is dying to say something.

23 MR. COYNE: Well, not dying to say  
24 something. Kevin Coyne, Research.

25 I think that the short answer and what

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Selim is saying is that it's basically too soon to  
2 tell what exactly the PRA model will look like.  
3 We're very early in the process. One of the goals  
4 of this briefing was to get this kind of feedback of  
5 other things to consider. So the points you brought  
6 up are very good points that need to be factored in  
7 as we go through the process of developing what the  
8 PRA approach would look like.

9 But we know for a fact that the SDP  
10 process would be one application, or that was one  
11 that was specifically highlighted under User Need.  
12 Bob Palla was the PRA analyst who initiated the User  
13 Need. He had specific needs in mind of who he  
14 wanted to apply this process that may differ from  
15 how the SDP application would work. So we need to  
16 get a good handle on what the user office intends to  
17 do with the method.

18 MEMBER STETKAR: In that sense, without  
19 out getting in -- too belaboring it, people haven't  
20 really -- well, I have to be careful what I say.  
21 There was an event that happened at Robinson earlier  
22 -- a year ago now, I guess, but -- the fire. You  
23 know, one of the consequences of the fire was their  
24 steam dump stuck open for an awfully long time.  
25 They got a big overcooling event. That is a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 precursor to this type of condition. It probably  
2 was never flagged in terms of risk, that particular  
3 issue as a potential risk precursor from this type  
4 of issue; seal cooling problems, where the loss of  
5 power was, yada, yada, yada. But when I look at  
6 significance determination, if you don't have a tool  
7 that tells you there might be sensitivity to stuck-  
8 open relief valves because your tool doesn't look at  
9 that, you don't even know that -- how to evaluate  
10 the risk significance of that particular event with  
11 respect to this type of contributor. Follow what  
12 I'm saying?

13 So when you strictly look at User Needs  
14 coming in from whether NRR or regions in terms of  
15 significance determination, at times you have to  
16 step back a little bit and say, you know, have you  
17 really thought about what all of your needs might be  
18 and does the tool that you have do that? I think  
19 that's part of what this discussion -- anyway< I get  
20 the message that you're still early in that process.

21 MR. COYNE: Right. And these are the  
22 kind of questions we're trying to get to, so this  
23 feedback is very helpful I think as we go through  
24 that process.

25 MEMBER SIEBER: John, is your concern

1 that a simplified tool used by someone, assuming  
2 that it will answer all the questions, will lead  
3 people to the wrong path and perhaps --

4 MEMBER STETKAR: It might.

5 MEMBER SIEBER: -- perform the wrong  
6 answers?

7 MEMBER STETKAR: It might, yes. Well,  
8 I'm not sure about do the wrong things in the real  
9 world, but at least give you sensitivity that if  
10 you're an operator and you have, you know, emergency  
11 procedures, that there are good things about  
12 reducing steam generator pressure to try to get, you  
13 know, maybe lower pressure feedwater supplies in or  
14 fire water or something like that. But there are  
15 some down sides of that that, for example, you need  
16 to be aware of that you just don't want to leave  
17 valves open.

18 MEMBER SIEBER: It seems to me though  
19 that there ought to be some warning flags somewhere  
20 in this process to make sure -- you know, it looks  
21 to me like there's a balance between a lot of  
22 different things. And the sequence in which those  
23 things can occur determines what kind of action can  
24 you take to mitigate it?

25 MEMBER STETKAR: Exactly. And I think

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 part of my message is is the basic structure of many  
2 -- some Level 1 PRA models for very old plants that  
3 may have -- had been concerned about pressurized  
4 thermal shock conditions, for example, did spend  
5 some extra time looking at too much cooling.

6 MEMBER SIEBER: Right.

7 MEMBER STETKAR: But generally that type  
8 of issue, too much steam relief in particular, is  
9 not something that people wire into the structure of  
10 their model. So they don't even have that knob to  
11 tweak . They don't even develop the scenarios that  
12 give you that information about, you know, what  
13 conditions are, what the timing was to factor into,  
14 you know, then the consequential analysis.

15 MEMBER SIEBER: Well, I think your issue  
16 is a concern. And I think that as this goes on we  
17 have to pay attention as to how people use these  
18 tools.

19 MEMBER STETKAR: It's actually not hard  
20 to change the models if you just know that you need  
21 to change them. But again, it's time and money.

22 MEMBER SIEBER: To me, I envision a  
23 simplified tool as an Android app, if you know what  
24 I mean.

25 MR. ZOULIS: This is Antonios Zoulis

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 from Division of Risk Assessment.

2           Again, as Kevin mentioned, we're  
3 interested in your feedback and we appreciate it,  
4 but I just don't want to leave this meeting with the  
5 false understanding of the phenomenon that we're  
6 interested in. You mentioned low and over-cooling,  
7 but the phenomenon that we're looking at is low, dry  
8 and high. And to get to those three, there are only  
9 so many limited sequences that will get you there.  
10 Are there some that we don't know? Perhaps there  
11 are. But I don't want you to -- because you  
12 mentioned the March event, I was intimately involved  
13 with that event in Region II, that just because it  
14 had over-cooling, it did not increase the chance of  
15 core damage. They had AFW injection. There wasn't  
16 a LOCA. So the conditions that were present did not  
17 warrant or even come close to that we would get a  
18 consequential steam generator tube rupture. So we  
19 need to keep that in perspective.

20           Those are the three conditions, and as  
21 Mr. Lee mentioned earlier, it has to be low, it has  
22 to be dry and it has to be high. And to get to  
23 those conditions in a PWR is not easy.

24           MEMBER STETKAR: Okay. I'm sorry. In  
25 risk-assessment space it can be relatively easy if

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 you have no main feedwater, no emergency feedwater  
2 and now I'm on a trajectory to dry. I'm also a  
3 trajectory to high. Now all I need is low. And  
4 there are many things that will get me low. In  
5 fact, there are many things that operators might be  
6 instructed to do that will get me low. For example,  
7 depressurizing for condensate injection or  
8 depressurizing for that miraculous fire water  
9 injection with subsequent failure of that.

10 So my point is that many risk  
11 assessments ignore the low part of it. They send  
12 you to core damage because you had no feedwater.  
13 You are high and dry. You don't know whether you're  
14 low or not. And the conditional probability of  
15 being low in pressure on the secondary side may be  
16 much higher than your existing risk models tell you  
17 because they don't include that information about  
18 the secondary pressure. Just not a question that's  
19 ever asked. This just says they tried to  
20 depressurize. They didn't get it. Fine, I have no  
21 feedwater. It's modeled as a dry, high situation.

22 MR. ZOULIS: I think you just defined a  
23 station blackout event, but that's okay. We don't  
24 need to belabor the point. We'll let Selim continue  
25 with his presentation.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIR REMPE: Let's do go ahead.

2 MR. SANCAKTAR: Okay. We basically talk  
3 a lot. The first one, we have a basis document for  
4 the correlations or equations, the software uses for  
5 calculating when the tube flaw either leaks or  
6 ruptures. And we are having it reviewed by the  
7 premier expert on the subject matter as we speak.  
8 And so, we want to make sure that what we are using  
9 is kosher and we can continue with the subject.

10 We expect to have the product within the  
11 next two years after we get input from other  
12 disciplines. It's a necessity, we have to do it  
13 otherwise we can't do it. So when I say two years,  
14 I'm assuming everything goes according to the plan.

15 And then once we have something that is  
16 acceptable to us and to NRR and other offices, then  
17 we can address the remaining two tasks of how you  
18 place this into the regulatory context. We are not  
19 worrying about it at this point.

20 Okay. That's all I had. If you have  
21 questions, I'll be happy to try to answer them  
22 without causing any damage.

23 DR. IYENGAR: Thank you very much. I  
24 think it's been an extremely fruitful exchange.

25 MR. CSONTOS: Raj, hold on.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 DR. IYENGAR: Yes?

2 MR. COYNE: At great risk here I'll  
3 bring up a point. You know, part of the simplified  
4 wording in the User Need, Selim had done an earlier  
5 effort that we briefed you on at the closure of the  
6 steam generator action plan to do essentially a  
7 scoping analysis of steam generator tube rupture  
8 based on some earlier work done by both the ?DE and  
9 DSA. One of the base assumptions in that earlier  
10 approach was that the steam generators will be  
11 pressurized during these scenarios. The thermal  
12 hydraulic models were run with -- I'm going to  
13 forget the exact size, but I think a 0.25 --

14 MR. SANCAKTAR: 0.25 square inch.

15 MR. COYNE: -- square-inch hole.

16 MR. SANCAKTAR: Coefficient to -- on the  
17 secondary sufficient to depressurize.

18 MR. COYNE: Right. So all these  
19 scenarios assume that the secondary side would  
20 become depressurized from a thermal hydraulic  
21 standpoint. So although it wasn't explicitly  
22 modeled in the PRA, the --

23 MEMBER STETKAR: You basically assume  
24 that anything that is dry is low?

25 MR. COYNE: Right. So the high and dry,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 you know --

2 MEMBER STETKAR: Okay.

3 MR. COYNE: -- might be low.

4 MEMBER STETKAR: Well, if that's the  
5 case, then a lot of, you know, my concerns regarding  
6 the fundamental structure of, you know, the Level I  
7 models leading into this probably alleviate it. You  
8 know, it's --

9 MR. COYNE: Right.

10 MEMBER STETKAR: So that's a  
11 conservative assumption, but --

12 MR. COYNE: It probably is, but I think,  
13 you know, in light of how we're going to go forward,  
14 if we continue with using that assumption, I think  
15 we still need to consider the point you brought up  
16 and make sure that that accommodates these kind of  
17 issues. But I did want to make that point that --

18 MEMBER STETKAR: That's important. That  
19 helps. That is a good point. Thanks.

20 DR. IYENGAR: Thank you, Kevin. So it  
21 was a extremely fruitful and engaging discussion,  
22 and we will take all these points back and find the  
23 appropriate solution so that we can get the most  
24 thorough and robust product that the NRR wants.

25 And I just want to; perhaps not

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 regurgitate, but just to re-emphasize that this is a  
2 early-on stage in a multi-year project which  
3 involves several disciples and several divisions of  
4 Office of Research. We are making sure that we are  
5 coordinating well between the various experts. We  
6 do have two external contracts, in-house work going  
7 on. Information needs to be fed in many different  
8 ways. So we are actively engaged in the process and  
9 of course we will take all your input back and into  
10 consideration and perhaps meet you back at some  
11 point, at appropriate point as we march along the  
12 project.

13 If you do have any questions or  
14 comments --

15 CHAIR REMPE: Okay. Thank you. I would  
16 like to visit at the end of this discussion period  
17 when is an appropriate time, but I think it might be  
18 good to just go through and summarize what the  
19 comments that we think are important are. And I've  
20 actually asked Christopher to start the process. I  
21 have some notes that -- I am hoping his notes are  
22 better taken than even mine. And I can add my  
23 comments, but we'll go back to the committee members  
24 to --

25 MEMBER SHACK: Can I just put one

1 question in before we start that?

2 CHAIR REMPE: Yes. Okay.

3 MEMBER SHACK: What is the status of the  
4 work on the CE plants?

5 DR. IYENGAR: Chris Boyd has done some  
6 preliminary calculations, CFD calculations on that,  
7 and that's where we stand on the CE plant.

8 MEMBER SHACK: So you haven't done any  
9 structural calculations yet?

10 DR. IYENGAR: No, not yet. Not yet. I  
11 think that ANL had done some preliminary work, I  
12 mean, some work on the CE. Unfortunately, all that  
13 information is lost. No data available which would  
14 have help us tremendously if they had a final model.  
15 But we do have some of the monthly reports that they  
16 -- we don't have the data.

17 MR. BROWN: Okay. All right.

18 CHAIR REMPE: Okay. So you want to  
19 start off?

20 MR. BROWN: Sure. Thanks, Dr. Rempe. I  
21 just wanted to echo John Stetkar's comments. I  
22 basically will try to track that to see if the staff  
23 is going to do anything, because I don't know when  
24 we're going to meet again, so I want to try to track  
25 that.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 And also another item that I liked at --

2 CHAIR REMPE: So, that's the comment  
3 about are they identifying all the key scenarios?

4 MR. BROWN: Yes, the scenarios.

5 MEMBER STETKAR: Although, I must admit,  
6 if indeed that assumption is applied that  
7 essentially every scenario for which the secondary  
8 side of the steam generator is dry is treated as a  
9 low-pressure scenario, if that's the case, then I'd  
10 have to think pretty hard, but you've probably got  
11 most of my concerns handled that way. And whether  
12 that's realistic or not is a different issue, but in  
13 terms of identifying scenarios that are both dry and  
14 low-pressure from, you know, a variety of causes,  
15 that may solve that issue.

16 MR. BROWN: As I said, I don't know when  
17 we're going to meet again, so I want to kind of keep  
18 that fresh --

19 MEMBER STETKAR: Yes, I mean, I think,  
20 you know, just a general concern, as a point of  
21 awareness or sensitivity, when you're having these  
22 discussions; the staff, you know, with whoever your  
23 contractor is, you know, looking at the scope of  
24 what they're doing for this project, it's worth  
25 keeping it in mind certainly. But that may solve --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 you know, your assumption may solve the problem.

2 MR. BROWN: Yes. The other item I'd  
3 like to track is that, Raj, you committed to  
4 providing us some clarification on the User Need  
5 task.

6 DR. IYENGAR: On the once-through steam  
7 generator?

8 MR. BROWN: Yes, and that's page --

9 DR. IYENGAR: Yes, I got that written  
10 down.

11 MR. BROWN -- 4, the User Need. So  
12 I'll --

13 DR. IYENGAR: Right.

14 MR. BROWN: -- be talking with you  
15 further about that. And I know Said had asked a  
16 question on the thermal conductivity experiments.

17 MEMBER ABDEL-KHALIK: No, no, no. This  
18 is the testing of aux feedwater.

19 DR. IYENGAR: Aux feedwater.

20 MR. BROWN: Okay. That was slide 37, if  
21 I recall. That's the one that you committed -- you  
22 didn't have folks here to answer any questions.

23 MR. COYNE: We'd have to think about who  
24 the right person to answer it is.

25 MEMBER ABDEL-KHALIK: Yes, whether

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 that's a good practice or not.

2 MR. BROWN: I want to track that one.

3 Also, Dana brought up about the flaw  
4 shapes. Should we consider flaw shapes? And it was  
5 also what is industry doing in this particular area  
6 of this work being done?

7 Harold had brought up benefits to other  
8 plants. In particular, he's working with the  
9 AP1000. Brought that up.

10 And there was a discussion about should  
11 the one-seventh scale data be redone?

12 Dr. Rempe, would you like to add some  
13 more --

14 MEMBER RAY: Chris, I was particularly  
15 thinking about it in terms of the steam generator.

16 MR. BROWN: Yes. Okay. And if you want  
17 to add more to it when you go around, that's good.

18 CHAIR REMPE: On the one-seventh scale,  
19 others with more background than me; like Dana, has  
20 pointed out the fact that this program could be used  
21 to shape if it's decided additional experiments are  
22 needed what that experiment should be, that when the  
23 tests were done there wasn't a lot of knowledge at  
24 that time. And so, as we go along maybe we can  
25 decide yes something else is needed and get the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 right test this time, is the way I think he's  
2 casted, and I think that makes sense to me.

3 MR. BROWN: Okay.

4 MR. CSONTOS: I think it goes to a  
5 larger point brought -- Corradini, about the  
6 testing, is that right? I mean, you asked me early  
7 on this morning about testing; or not this morning,  
8 but this afternoon.

9 MEMBER CORRADINI: It was something.

10 MR. CSONTOS: It was sometime today.  
11 But you asked about confirmation of what we're doing  
12 here, and I think that kind of goes into that.

13 CHAIR REMPE: Right. Okay. Do we want  
14 to go around the table and see if there's any other  
15 items that come to mind that we should offer up as a  
16 way to improve what they're proposing to do on this  
17 research effort?

18 Want to start, Jack?

19 MEMBER SIEBER: I have no additional  
20 items.

21 MEMBER RAY: Nor myself.

22 MEMBER BLEY: Yes, I'm kind of mixed  
23 mind on this thing. You know, this is a really  
24 interesting problem and there's a lot to learn, and  
25 it's kind of exciting. I'd like -- you know, being

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 involved, seeing what's going on is very  
2 interesting.

3 On the other hand, supposing we learn  
4 everything we set out to learn, it strikes me first  
5 it will be tempting to become a little over-  
6 confident and maybe miss some of the contributions  
7 to uncertainty, which I think will almost certainly  
8 remain large if we're honest about the range of  
9 possibilities for a plant with extensive experience,  
10 a plant that's had many transients, many operational  
11 cycles, various insults, including occasional bad  
12 chemistry or maybe even mixed during installation or  
13 maintenance that we don't know about.

14 So I think when we're all done, we're  
15 still not going to be real sure exactly what's going  
16 to happen in any particular plant. And I wonder if  
17 something simpler than completely understanding the  
18 phenomena; which I'd love to do, might even be more  
19 effective in reducing the risk of what's for most  
20 plants a very unlikely scenario. For some plants  
21 with the right external conditions it might not be  
22 as rare as I'd like it to be.

23 But the simpler things might be things  
24 like SAMGs and maybe hardware that makes it easier  
25 to depressurize or to anticipate the need to do

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 that, things that could reduce the likelihood or the  
2 amount of release if this doesn't go the way we  
3 convince ourselves it's going to go or even some  
4 general purpose devices. And this is something I've  
5 just got an itch for it, came up years ago when we'd  
6 first done some PRAs. What could I do to make my  
7 plant better?

8 Well, for any particular scenario  
9 there's really a good fix. But when we don't know  
10 for sure what scenario we're looking for, some not  
11 really nearly as good fix might be a better one.  
12 And various people have come up with ways to stash  
13 generators, pumps. One place we worked with  
14 designed a skid gadget that had those things on it  
15 and had one at the site and anticipated leaving one  
16 somewhere away, could easily be heloed in, that had  
17 things I didn't even know existed. Well, for the  
18 generator you could pull it up close and run cables  
19 and they've loaded -- the thing was loaded with  
20 cables you could run in and hook right up to a pump.

21 But the other thing it had that I didn't  
22 know was for the pump on board that you'd drive with  
23 a generator, you know, you could have a suction that  
24 would go to the local water supply, but they had  
25 identified; and I don't know if these came out of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the oil industry or where, quick coupling devices.  
2 You could lop off six feet of pipe in the plant and  
3 hook up a quick coupling device that will just clamp  
4 on that end and actually pump water in. So  
5 something that maybe is only a factor of 10, you  
6 know, 0.1 on reliability, might buy you a lot, but  
7 there might be other things.

8 So I think we can spend a lot and learn  
9 a lot of useful things and maybe not solve this  
10 problem the way we're headed. I won't say don't do  
11 it, but I'm wondering if there's an easier solution.  
12 And I also wonder even if we do the best possible,  
13 we might not know what we think we're going to know  
14 when we're all done.

15 CHAIR REMPE: So you're basically saying  
16 instead of addressing the task and the User Need to  
17 look for something different?

18 MEMBER BLEY: And that's a possibility  
19 that maybe ought to be entertained all around. And  
20 I wonder what industry's doing here and if they're  
21 taking an approach; and I don't know for sure.

22 CHAIR REMPE: Well, I think definitely  
23 we want to look at what industry's doing.

24 MEMBER BLEY: Yes.

25 CHAIR REMPE: And then basically add on,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 look for something else, too. It sounds like a good  
2 idea to me. But, go ahead, Said.

3 MEMBER ABDEL-KHALIK: Well, I mean, you  
4 know, of all the questions that were raised today I  
5 think I was disturbed most by the question that was  
6 raised by Dennis, and the question about what is  
7 industry doing? Are they involved with you and why  
8 aren't they? I would go even further than that:  
9 Are they aware of what you're doing? Because  
10 ultimately, I mean, you know, if you're fully  
11 successful this will have some impact in regulatory  
12 space and you want the people who would be affected  
13 to be aware of, you know, which direction you're  
14 heading, what you're doing.

15 CHAIR REMPE: Bill?

16 MEMBER SHACK: I think the work is  
17 interesting. Again, I have feelings somewhat like  
18 Dennis. I mean, you know, I think you're going to  
19 go to the CE plant and you're going to find things  
20 are bad and no matter how much you analyze it, it's  
21 going to be bad. And, you know, should you be sort  
22 of thinking about things to do rather than verifying  
23 that, yes, it's pretty bad? And, you know, I think  
24 we've gotten enough insights on the Westinghouse  
25 style of plants that I'm not sure that understanding

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       them better will get you a whole lot.

2                    You know, it just came back to my  
3       original question of just what is the regulatory  
4       impact of this? And as I say, you know, I'd feel  
5       better if I knew that everybody's SAMGs were  
6       cognizant of this. Maybe the Westinghouse people  
7       are. You know, I'd like to know what the CE people  
8       think that they could do.

9                    So, I don't know. As I say, I think  
10      technically it's interesting. I think the approach  
11      of -- you know, now that we sort of understand  
12      locally where the sensitive thing is, that the  
13      problem is computationally more feasible than I  
14      might have thought once upon a time. But I'm still  
15      not sure what I'd do with the information if I had  
16      it.

17                   CHAIR REMPE: John?

18                   MEMBER STETKAR: I don't have any more,  
19      but, Dennis, you raise a really good point and  
20      something I didn't see here; and that is, you know,  
21      given what we know, looking at SAMGs and the B.5.b  
22      stuff, you know, and perhaps what's in place might  
23      be relatively effective. In other words, it might  
24      not be much more than you would want to do or that  
25      you could do.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 I'd also, you know, just warn people,  
2 don't just talk about CE plants, because I think as  
3 Dana pointed out some, of the new plants coming in  
4 may be susceptible to the same -- EPR has very, very  
5 shallow loop seals and they've got a system that --

6 MEMBER SHACK: Just aren't any of those  
7 at the moment, but there are --

8 MEMBER STETKAR: There aren't, but, you  
9 know, we should keep them in mind, and systems that  
10 really like to blow down the secondary side an awful  
11 lot. So, you know, some of this stuff, regardless  
12 of which direction it goes, you know, isn't just the  
13 legacy that's sitting out there. You might learn  
14 things for some of the new plants coming in also.

15 CHAIR REMPE: Mike?

16 MEMBER CORRADINI: So, I guess I -- the  
17 picture that you happily said you couldn't show  
18 because you didn't have it in your software package,  
19 I started here 30 years ago as a consultant and  
20 Professor Curr usually asked the question when  
21 anything was with Class -- in those days it was  
22 called the Class 9 Accident Subcommittee, what are  
23 you going to do, how do you know when you're going  
24 to get done, and what value is it?

25 So, I'm still struggling with -- the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 what are you going to do part I'm clear. I want to  
2 know how do you know when you're done and what's the  
3 value you're going to get out of this relative to  
4 the bigger picture that Dennis is asking? Right?  
5 And so, I'd like to see instead of a project  
6 execution thing, I'd like to see a -- I'm sorry to  
7 sound so industrial. I start here. I have a branch  
8 point that says I have scoured all this stuff first.  
9 And bringing in the pump, bringing in the pipe, may  
10 not be the most optimally-beautiful elegant rigorous  
11 way to solve the problem, but by God, I solved 90  
12 percent of the problem. Now I do three-dimensional  
13 calculations and I solve five percent of the  
14 problem, but I might have to spend money to  
15 experimentally be clear that whatever I just  
16 calculated I actually believe.

17 I'm looking for a project execution  
18 graphic that says here's the first question I asked.  
19 Here are the things I first thought of just falling  
20 off the turnip truck.

21 MEMBER BLEY: The decision diagram.

22 MEMBER CORRADINI: Decision diagram,  
23 yes. That's what I'm missing here. Instead of a  
24 proxy execution diagram. Because I think you guys  
25 are onto something. The guy that wants to be on

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 your committee happened to leave, right? But Dana I  
2 think has been thinking about this long and hard, so  
3 I wish he was here to tell me that I'm off base.  
4 But I really think a decision matrix or a design  
5 talking through this is very important because  
6 you're into a good amount of effort here.

7 MEMBER BLEY: In decision analysis  
8 there's a concept that's pretty simple. It's the  
9 expected value of perfect information. You lay out  
10 the decision diagram and you say what if I get  
11 everything I could hope for? What am I going to do  
12 with it? It's a real good exercise to go through.  
13 I like what Mike said, yes.

14 MEMBER CORRADINI: Because I think this  
15 is great. I just -- the more you start doing very  
16 complicated calculations where the pipe should be  
17 here, but it was over here, all of a sudden these  
18 geometrical things start compounding. Then you're  
19 going to ask yourself questions. And now you're  
20 into percent -- not even 10 percent, but just  
21 percents of uncertainty that unless you have an  
22 experiment to verify it, I'm not sure if I believe  
23 that you're five percent better than you were  
24 before. You see where I'm going with it?

25 And I think it was somebody over here

1 that said that with whatever measures they've taken  
2 for other things to affect the plant may confound  
3 your analysis.

4 MEMBER BLEY: Right.

5 DR. IYENGAR: The weld overlay, yes.

6 MEMBER CORRADINI: So I really do think  
7 you're onto something. I just think you want to lay  
8 it out in some fashion that really helps you think  
9 through where you get the more bang for your time.  
10 Not buck, but time.

11 MEMBER RAY: Joy, having heard my  
12 colleagues, could I now say something more?

13 CHAIR REMPE: Sure.

14 MEMBER RAY: Particularly since Bill  
15 identified me as the CE person. The reason we  
16 always thought the steam generators, even though  
17 they were vulnerable to this phenomenon; we just  
18 were looking at more so than Westinghouse, were  
19 better was because their natural circulation  
20 capabilities was better, which is I think why it's  
21 part of the AP1000 design. In any event, the  
22 ability to naturally circulate was quite good in  
23 that plant design.

24 MEMBER SIEBER: It doesn't naturally  
25 circulate if you can't remove heat.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER RAY: What, Jack?

2 MEMBER SIEBER: It doesn't naturally  
3 circulate if you can't remove it.

4 MEMBER RAY: That's correct.

5 MEMBER SIEBER: The other thing I want  
6 to comment on is the turbine-driven aux feedwater,  
7 because what Said said stimulated my thinking,  
8 what's the industry doing? At least when I was in  
9 the industry the great campaign was to get rid of  
10 turbine-drive aux feed pump because they're so damn  
11 much trouble to maintain and pass this regular  
12 surveillance test. And at my plant we had -- every  
13 day when I came in, I had the core damage frequency  
14 updated and it was always the same thing. When the  
15 thing would spike, it was because the turbine-driven  
16 aux feed pump was out of service for some reason,  
17 maintenance or surveillance testing or whatever. So  
18 it was a very big player in core damage frequency.

19 And so, I would never buy into this idea  
20 that we ought to try and get rid of turbine-drive  
21 aux feed pumps. But a lot of people do and think  
22 that a motor-driven pump is a heck of a lot better  
23 because I just go over and flip the switch and bingo  
24 it runs and that's the end of it. Now I'm all done.  
25 I go onto whatever else I got to do.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           So, that's my comment on what's the  
2 industry doing. I think they're trying to get rid  
3 of something that I always thought of as being a  
4 important feature of the plant and one that I'd like  
5 to see more of. That's it.

6           CHAIR REMPE: Okay. It's looks like you  
7 have a burning desire to say something, Richard.

8           MR. LEE: My conversation with Chris  
9 Boyd is that if he redo this analysis now is that  
10 you may move those two points down a little bit, but  
11 the difference between the two will remain the same.  
12 So in other words, for CE plant it doesn't matter  
13 much whether you have flow tubes or not because if  
14 the flow go into certain, only selective group of  
15 two. It will put a lot of stress on those tube and  
16 has a possibility of failing those tube.

17           If you continue this analysis, one thing  
18 you need to remember, once you fail more tubes you  
19 will be sucking a lot of hot steam through the --  
20 this pipings here. So you can also -- perhaps the  
21 surge line may fail. So in other words, a steam  
22 generator tube rupture for certain time, but other  
23 component like ex vessel, which is the surge line or  
24 the hot leg will fail. So in other words, your time  
25 of duration of releases to the containment bypass

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 may be limited. So one can investigate when will  
2 the other components will fail that will stop the  
3 fission products going out. I think that's the type  
4 of things that you can evaluate too here.

5 CHAIR REMPE: Okay.

6 MR. LEE: So this is the point that --  
7 from the T-H point of view we -- that's what Chris  
8 has -- came to a conclusion. So I think the group  
9 need to re-discuss what you want to do.

10 CHAIR REMPE: Okay. Sam, do you still  
11 have another comment?

12 MEMBER ARMIJO: Yes, I just caught the  
13 end of what Dennis was saying. I was happy to hear  
14 it. You know, it just seems to me with the  
15 materials we have in these plants and the designs of  
16 the plants, after we do all this more sophisticated  
17 calculation, we'll pretty much be in the same  
18 position we are now. Nothing much is going to  
19 change very different that will make our conclusions  
20 very different, so the emphasis should be more on  
21 what can you do about it with what we already know  
22 and whether it's operator actions, different  
23 devices, focus on that rather than, you know,  
24 getting less -- reducing the uncertainty in what we  
25 already know, because I don't think it's going to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 change fundamentally.

2 MEMBER SHACK: Well, there is the  
3 SOARCA-like statement though that Richard was  
4 attacking here. And if you -- understanding  
5 consequences is something that we do want to do  
6 and --

7 MR. LEE: Right. Perhaps the duration  
8 of the so-called -

9 (Simultaneous speaking.)

10 MEMBER SHACK: -- if -- yes, is  
11 important.

12 MR. LEE: Okay?

13 MEMBER ARMIJO: Well, that's important  
14 across the board. I mean --

15 MEMBER BLEY: And the SAMGs.

16 MEMBER ARMIJO: Yes.

17 CHAIR REMPE: So, I think then expanding  
18 the existing list to include additional items is the  
19 way to look at it.

20 MR. LEE: And I think since Fukushima  
21 the Commission has agreed that they going to start  
22 re-looking at all the plants, and this is one of the  
23 sequences that I think we will examine closely.

24 MEMBER RAY: Well, couldn't this cause  
25 you to say, gee, I really ought to have a second

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 turbine-drive aux feed pump and another water supply  
2 for the secondary side, I'm talking about,  
3 because --

4 MR. LEE: I'm sure we can discuss this  
5 with industry and you will see what the response is.

6 CHAIR REMPE: I think that we're over  
7 time. And so, I would like to briefly suggest that  
8 if it's agreeable to you; we've given you a lot of  
9 suggestions, we'll come up with a list of those  
10 questions that we've brought up. Is six months in  
11 your opinion an appropriate time frame to come back  
12 to us with a revised perhaps plan and a report on  
13 your progress?

14 DR. IYENGAR: I certainly can talk to  
15 our NRR counterparts and research and probably get  
16 back to you on that. Or would Kevin or Al want to  
17 chime in?

18 MR. COYNE: We probably need to think a  
19 little more. My initial reaction is six months  
20 might be early in light of the additional work that  
21 needs to be done particularly with contractors.  
22 Chris Boyd needs to do his C&D work. We need to get  
23 the MELCOR decks for the CE plant. Raj is one of  
24 the key people on the DE analysis and he's on  
25 rotation right now. So nine to twelve seems more --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 that we'd have tangible results to share at that  
2 point.

3 CHAIR REMPE: That sounds fine. I know  
4 Christopher wanted to have an idea on the schedule.  
5 As you can see, we have a lot of input. So it's up  
6 to you how often you want it.

7 MR. COYNE: No, we appreciate that. No,  
8 it's one of the objectives, so --

9 MR. CSONTOS: Yes, Raj comes back on  
10 September.

11 CHAIR REMPE: Okay.

12 MR. CSONTOS: So maybe give us a couple  
13 more months after that.

14 CHAIR REMPE: Then I guess I will close  
15 the meeting.

16 (Whereupon, the above-entitled matter  
17 was concluded at 4:41 p.m.)

18

19

20

21

22

23

24

25

# Consequential Steam Generator Tube Rupture (C-SGTR)

**Subcommittee Briefing  
Advisory Committee On Reactor  
Safeguards  
April 6, 2011**

# Purpose

- Provide project status update on C-SGTR activities
- Outline the project plan that had been developed and discussed with NRR technical staff
- Early engagement with ACRS to gain insight and obtain feedback

# **Origin of User Need, User Need Details & Regulatory Implications**

Antonios Zoulis, NRR

# Outline

- Background
- User Need
- Summary

# Background

- As part of the closure of the NRC's Steam Generator Action Plan in 2009, items were identified that needed further work:
  - Further T-H analyses to address CE plants issues
  - Development of updated SG Flaw distributions and enhanced RCS structural analyses
  - Development of guidance and tools to support future risk assessments
  - Document summarizing key research and state-of-knowledge

# Background (Cont.)

- Staff decided to pursue further research items in a follow-on NRR user need to RES (ML092010380)
- This approach to closing out the SGAP was presented to, and endorsed by, the Advisory Committee on Reactor Safeguards in October 2009

- Thermal-Hydraulic Analyses
  - Request updated CFD and system code models for CE plants
  - Report on impact of incore instrument tube failure on natural circulation for both Westinghouse and CE plants

- **Materials and Structural Analyses**
  - Update SG flaw distributions for current population of SGs
  - Structural analysis of both Westinghouse and CE RCS components to establish confidence in the prediction of RCS piping failure

- Risk Assessment
  - Develop an efficient method for assessing the risk associated with C-SGTR/leakage in DBA and severe accident events
  - Reassess conditional SG tube failure probabilities based on updated flaw distributions and T-H analyses
  - Develop draft Regulatory Guidance on risk-informed decision making regarding C-SGTR
  - Develop Risk Assessment Standardization Project (RASP) Handbook guidance and update Inspection Manual Chapter (IMC) 0609 appendices to support risk assessments (SDP) for the Reactor Oversight Program
- Prepare a summary report compiling key insights and state-of-knowledge

# Summary

- Develop and understand the C-SGTR phenomena and its implication to risk assessments
- Develop efficient tools to be used by SRAs and risk analysts to evaluate findings, risk-informed applications, and future issues involving SGs
- Document and develop guidance to capture knowledge

# **RES Project Plan to Address User Need**

**Raj Mohan Iyengar, RES**


# User Need Tasks

Item	Description	Priority	NRR Lead	RES Lead
1.1.A.i	Update existing computational fluid dynamics (CFD) and system code models (either the MELCOR or RELAP/SCDAP code) for a representative CE plant	High	Antonios Zoulis, DRA/APLA	Michael Salay DSA/FSTB
1.1.A.ii	Evaluate the expected T-H behavior and accident progression for selected risk-significant accidents from the associated PRA	High	Antonios Zoulis DRA/APLA	Michael Salay DSA/FSTB
1.1.B.i	A technical assessment of the impact of incore instrument tube failures on natural circulation for Westinghouse plants	Medium	Antonios Zoulis, DRA/APLA	Michael Salay DSA/FSTB
1.1.B.ii	A technical assessment of the impact of incore instrument tube failures on natural circulation for CE plants	Medium	Antonios Zoulis, DRA/APLA	Michael Salay DSA/FSTB
1.2.A	Updated SG flaw distributions representative of the current population of SGs	High	Emmett Murphy, DCI/CSGB	Charlie Harris DE/CMB
1.2.B.i	Structural analysis of Westinghouse RCS components to establish confidence in the prediction of RCS piping failure	High	Emmett Murphy, DCI/CSGB	Raj Iyengar DE/CIB
1.2.B.ii	Structural analysis of CE RCS components to establish confidence in the prediction of RCS piping failure	High	Emmett Murphy, DCI/CSGB	Raj Iyengar DE/CIB
1.3.A.i	Develop a simplified method for assessing the risk associated with consequential tube rupture/leakage in DBA and severe accident events	High	Antonios Zoulis, DRA/APLA	Selim Sancaktar DRA/PRAB
1.3.A.ii	Modify risk assessment tool to account for elevated axial tube loads due to thermal expansion between the SG shell and tubes during steam line break, loss of coolant accidents, and loss of main feedwater events (work to be sequenced with existing User Need NRR-2008-004 - ML082200693)	High	Antonios Zoulis, DRA/APLA	Selim Sancaktar DRA/PRAB and Charlie Harris DE/CMB
1.3.B	Reassess conditional SG tube failure probabilities based on updated flaw distributions and updated T-H analyses	High	Antonios Zoulis, DRA/APLA	Selim Sancaktar DRA/PRAB
1.3.C.i	Develop draft Regulatory Guidance on Risk-Informed Decision Making Regarding C-SGTR	High	Antonios Zoulis, DRA/APLA	Selim Sancaktar DRA/PRAB
1.3.C.ii	Develop draft RASP Handbook section on assessment of C-SGTR suitable to support revisions to the Inspection Manual Chapter (IMC) 0609 appendices supporting the SDP process	High	Antonios Zoulis, DRA/APLA	Selim Sancaktar DRA/PRAB
1.4	Prepare summary report compiling key research results	High	Antonios Zoulis, DRA/APLA	Raj Iyengar DE/CIB

# Simplified Project Flow Chart

## Communication & Engagement

- RES Task Groups meet at least once a month
- Expect to provide status update and receive feedback from NRR on a quarterly basis
- Technical Engagement with ACRS



# Research Products

- Simplified Method to Assess Risk Associated with Consequential Tube Rupture and a Summary Report
- Draft Regulatory Guidance on Risk-Informed Decision Making Regarding C-SGTR (Nature of this document will be determined later in the project)
- Draft RASP Handbook section on assessment of C-SGTR suitable to support revisions to the Inspection Manual Chapter (IMC) 0609 appendices supporting the Significance Determination Process (SDP)
- Summary report compiling key research results

# Phenomenological Aspects of the C-SGTR

Richard Lee, RES



# Steam Generator Tube Ruptures


- Steam generator tube ruptures are design basis events
  - Plants are designed to cope
  - Have for all events to date
- Progresses to Severe Accident only if something else happens
  - Failure to diagnose and respond can result in core melt
  - Multiple tube failure results in less time to react
- SGTRs (as initiating events) have been considered in risk analyses
  - Low probability to progress to SA but large consequences
    - Containment Bypass
    - Risk-dominant accident in PWRs at the time of NUREG-1150
- Recently risk analyses consider *consequential* SGTR

# Severe Accident Induced Failure

- A primary system break induced by the high temperatures (and pressures) associated with severe accident conditions.
  - water level below the top of the fuel
  - superheated steam above core
- The severe accident conditions, created by the overheated core, are carried out into the RCS loops through natural circulation.
  - severe accidents are associated with core damage, high temperatures, and radionuclide releases
    - core temperatures over 2500 K
  - temperatures in the RCS challenge the structural integrity of the system
    - testing shows that a new steam generator tube will creep rupture at system pressure if exposed to temperatures above (approximately) 1170-1200 K
- Significant induced failure points include the lower head, hot leg, pressurizer surge line, and SG tubing.

# Severe Accident

## Natural Circulation Flows




# High – Dry – Low

- The challenge to the tubes under counter-current flow conditions is maximized when the plant is in a “high-dry-low” condition
  - High primary side pressure
    - RCS must remain intact with no significant leaks
  - Dry steam generator secondary side
    - auxiliary feedwater systems fail
  - Low pressure on the secondary side
    - leakage or valve failure must occur to depressurize the secondary side


# System Code Modeling Considerations

- pressurizer draining
- surge line orientation
- natural circulation
- core bypass flow
- oxidation rate
- core blockage
- nodalization
- natural circulation
- nodalization
- downcomer clearing




- tube heat transfer
- secondary flows
- mass flow
- hot tube fraction
- leakage
- plugging
- vertical node count
- inlet plenum mixing
- recirculation ratio
- plume T distribution
- HL flow rate
- entrainment
- radiation modeling
- entrance effects

# Surge line Flows and Mixing Predicted




# Impact of Inlet Plenum Mixing CFD Predictions for two SG designs



**inlet plenum geometry affects mixing**  
(temperature contours shown)


# Sample Map of Containment Bypass Potential

Considering Primary and Secondary Side Leakage Rates  
(no operator intervention)



# What happens to FPs that make it to SG? (1/2)



- Discrepancies in predictions of SG decontamination factors (DFs) = FP mass into tubes/FP mass out of SG
  - Predictions range from 5 to 10,000
    - Affects risk importance of this type of accident
  - To resolve this issue, NRC participated in the AeRosol Trapping In a STeam generator (ARTIST) project
    - Multinational project, conducted at PSI in Switzerland, involved Separate Effects tests and Integral tests of decontamination for both dry and wet conditions




# What happens to FPs that make it to SG? (2/2)

- What was found:
  - Agglomerates can break-up when going through tubes
    - FPs emanating from degrading core are multi-component agglomerates
  - Particles can bounce
  - Low decontamination observed on SG secondary side

**Through-tube breakup**



**Integral Decontamination**



# Technical Approach

Richard Lee, Charles Harris,  
Raj Iyengar, and Selim Sancaktar  
RES

# TH Analyses

- Update existing CFD and system code models for a CE plant
- Provide un-failed thermal hydraulic behavior for selected accidents (Item 1.1.A.ii)
  - Boundary conditions for failure calculations (T, P)
    - spatially variant tube T
  - TH uncertainty estimate
  - Component failure time estimates
  - Run needed sensitivities (complementary to prior analyses)
- Provide failed thermal hydraulic and volatile (Cs, I, Te) releases based upon provided failures
  - Potential iterative process with failure models needed to obtain releases.
    - Preliminary calculations indicate that temperatures in CE SG will be hot enough for unflawed tubes to fail prior to other RCS components.
      - Likely sufficient to depressurize system preventing failure of other RCS components
  - Provide assessment impact of instrument tube failures for Westinghouse and CE plants

# TH status

- Update existing CFD and system code models for a CE plant (Calvert Cliffs)
  - Generate CFD model of CE hot leg and SG lower plenum
    - Obtained plant info, drawings.
    - Preliminary CFD model developed. Running initial calculations.
  - Generate MELCOR CE deck
    - Obtained some plant info, drawings, R5 deck.
    - Obtained previous MELCOR and SCDAP/RELAP MELCOR decks
    - Deck generation in progress - building upon pre-existing CE (MELCOR and SCDAP/RELAP) decks.
    - Taking into account lessons learned from the previous C-SGTR analysis
  - Communication between MELCOR and FLUENT deck developers
    - ensure consistency between decks
    - Provide mixing parameters
- TH analyses will be conducted with these models
- Will use results of pre-existing analyses for Westinghouse plants if needed
- Instrument tube failure impact
  - Review of existing analysis – due to lower priority and later deadline, will focus on subsequent to TH calculations

# TH Uncertainties

- Base failure timing calculation (tubes & RCS components)
  - Relative failure timing (tubes vs RCS)
- Major TH uncertainties identified in previous analyses – considering:
  - Loop seal clearing – limiting calculations, don't expect a definitive answer
  - Pump shaft seal leakage sensitivity
  - Secondary leakage sensitivity
  - TDAFW availability sensitivity
  - Battery availability sensitivity
  - Stress multiplier sensitivity

# Flaw Distribution in SGs



# Condition of SG Tubes

- Represent current fleet
  - Describe flaws in CE, W, B&W
    - Number, size
    - Type, location
    - Total leak area
  - New Materials
    - Alloy 600TT, alloy 690

# Condition of SG Tubes

- Update NUREG on flaw distributions
  - NUREG/CR-6521 (1998)
    - Original statistics still valid
    - 1998 - applied to Alloy 600MA
  - Adjust for new materials
  - Incorporate newer ISI data
    - number, size, type, location

# Failure of RCS Components

# Failure Prediction of RCS Components

## Tasks

- Identify, characterize, and model relevant RCS nozzles to assess their potential for failure during a severe accident for both Westinghouse and CE plants
- Develop finite-element models, addressing variables such as nozzle geometries/configurations, boundary conditions, loading conditions, fabrication effects, primary water stress corrosion cracking mitigations, and degraded conditions



## Challenges

- Develop failure model for critical RCS components based on numerical experiments – for consistency with the tube rupture assessment
- Resulting methodology will be more conducive to the procedure adopted in the C-SGTR risk assessment method to be developed as part of the Task 1.3.A

# Failure Prediction of RCS Components

## Approach

Validate three-dimensional sub-model of Hot-leg nozzle with shell model of the hot-leg to surge line. This would allow for the development of failure envelope of generic hot-leg nozzle for different thickness of pipe and overlay welds.



## Software Tool

ABAQUS - general purpose finite element analysis software will be used to predict failure time of hot-leg nozzle. Weakest link - the hot-leg nozzle (previous ANL study)

# Uncertainties

- Material Properties – Data available
- Geometry - Geometric dimensions, Defect, Weld Overlay
- Failure Models – Creep Rupture, Tensile Properties
- Thermal Properties – Conductivity, Thermal expansion coefficient

# PRA-Related Activities

# User Need Summary

**PRA-related activities are captured in tasks 3 and 4 of the user need.**

- 3.A** A user-friendly methodology for assessing the risk associated with consequential tube rupture/leakage in DBA and severe accident events.
- 3.B** A reassessment of the conditional probabilities of C-SGTR based on updated flaw distributions and updated T-H analyses.
- 3.C** Regulatory guidance on risk-informed decision-making regarding C-SGTR.
- 4.** Report compiling and summarizing key research, building upon NUREG-1570, work performed as part of SGAP activities, and this user need.

# Current Activities

- Two PRA-related projects are underway:
  1. A contract was recently placed for creation of a PRA report to address task 3.A
  2. A second contract is underway to create a C-SGTR calculator to estimate SG tube leakage probabilities under different conditions and for different SG designs.

- Task 3.A requires that
  - a simplified method for assessing the risk associated with C-SGTR events is to be developed and its use is illustrated taking advantage of updated SG and T-H data.
  - the method should be based on standard PRA techniques and the reference documents supplied by the NRC and should be documented in a report acceptable to RES and the NRR.
  - The method should address design basis accident and severe accident events.
- The report will support risk-informing the regulatory process by assisting the NRC staff to make risk informed decisions concerning C-SGTR events.
- The method and the report will be used to facilitate the quantification of C-SGTR events in future NRC and/or licensee risk models, and the development of guidance for future risk assessments.

# C-SGTR Calculator

- A software package is developed to estimate SG tube leakage probabilities for given RCS and secondary side conditions (scenario parameters)
- The basis document for the software is being peer reviewed by expert(s) cognizant with the subject matter.

# PRA Effort - Conclusion

- The PRA report and the C-SGTR calculator are expected to be ready within the next two years, after incorporating input from other disciplines (T&H analyses, behavior of other RCS components, additional SG tube failure data, etc.).
- Afterwards, the task of providing regulatory guidance on risk-informed decision-making regarding C-SGTR can be addressed.

# CONCLUSION

- A multi-year project involving interdisciplinary technical work by several RES divisions
- A comprehensive project plan developed
- Ongoing continuous engagement and coordination with various divisions