

ACCELERATED DOCUMENT DISTRIBUTION SYSTEM
 REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9309160029 DOC.DATE: 93/09/08 NOTARIZED: YES DOCKET #
 FACIL:50-438 Bellefonte Nuclear Plant, Unit 1, Tennessee Valley Au 05000438
 50-439 Bellefonte Nuclear Plant, Unit 2, Tennessee Valley Au 05000439
 AUTH.NAME AUTHOR AFFILIATION
 MCCLUSKEY,H.F. Tennessee Valley Authority
 RECIPIENT NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Responds to GL 92-08, "Thermo-Lag 330-1 Fire Barriers." Subj
 barrier are not relied upon at plant to meet 10CFR50.48 to
 achieve physical independence of electrical sys or to
 satisfy licensing commitment.

DISTRIBUTION CODE: A029D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: Generic Letter 92-008 Thermal-Log 330 Fire Barrier

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
	PD2-4	1	PD2-4	1
	THADANI,M	1		
INTERNAL:	NRR/DE/EELB	1	NRR/DRPW/PD3-1	1
	NRR/DSSA/SPLB	2	<u>REG FILE</u> 01	1
	RGN2 FILE	1		
EXTERNAL:	NRC PDR	1	NSIC	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 11 ENCL 0



Tennessee Valley Authority, Post Office Bcx 2000, Hollywood, Alabama 35752

H. Fred McCluskey
Site Vice President, Bellefonte Nuclear Plant

SEP 08 1993

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

Gentlemen:

In the Matter of the Application of
Tennessee Valley Authority)

Docket Nos. 50-438
50-439

**BELLEFONTE NUCLEAR PLANT (BLN) - GENERIC LETTER (GL) 92-08 -
THERMO-LAG 330-1 FIRE BARRIERS**

The purpose of this letter is to submit the response for BLN to NRC GL 92-08,
"Thermo-Lag 330-1 Fire Barriers," dated December 17, 1992.

The subject GL identified four items that addressees are required to address. Item one requests the licensee to state whether Thermo-Lag 330-1 barriers are relied upon (a) to meet 10 CFR 50.48, to achieve physical independence of electrical systems, (b) to meet a condition of a plant's operating license, or (c) to satisfy a licensing commitment. Item two is limited to those facilities where Thermo-Lag 330-1 barriers are used and requests specific information on tests, configurations, and ampacity derating. Item three and four request further information pertaining to responses given under the item two.

Thermo-Lag 330-1 barriers are not relied upon at BLN to meet 10 CFR 50.48 to achieve physical independence of electrical systems or to satisfy a licensing commitment. BLN does not use Thermo-Lag 330-1 fire barrier materials in their facilities and, therefore, these actions do not apply to BLN and this letter fulfills the reporting requirement of this GL. No commitments are made in this letter.

15-006

9309160029 930908
PDR ADOCK 05000438
A PDR



Aug 10


U.S. Nuclear Regulatory Commission
Page 2

SEP 08 1993

If you have any questions, please telephone Greg Pierce, BLN Site Licensing Manager,
at (205) 574-8058.


H. Fred McCluskey

Subscribed and sworn to before me this
8 day of Sept, 1993.


Notary Public

My commission expires 6/29/96

cc: NRC Resident Inspector
Bellefonte Nuclear Plant
P. O. Box 2000
Hollywood, Alabama 35752

Mr. M. C. Thadani, Project Manager
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852

Mr. R. V. Crlenjak, Project Chief
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323