

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9403090319 DOC. DATE: 94/03/02 NOTARIZED: YES DOCKET #
 FACIL: 50-438 Bellefonte Nuclear Plant, Unit 1, Tennessee Valley Au 05000438
 50-439 Bellefonte Nuclear Plant, Unit 2, Tennessee Valley Au 05000439

AUTH. NAME AUTHOR AFFILIATION
 MCCLUSKEY, H.F. Tennessee Valley Authority
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Responds to NRC Bulletin 89-001, including Suppls 1 & 2 re failure of Westinghouse SG tube mechanical plugs.

DISTRIBUTION CODE: IE31D COPIES RECEIVED: LTR 1 ENCL P SIZE: 4
 TITLE: Bulletin Response 89-01 re Failure of Westinghouse Steam Gen. Mech. T

NOTES:

	RECIPIENT		COPIES		
	ID CODE/NAME		LTTR	ENCL	
	NRR/PD2-2		1	1	
	THADANI, M		1	1	
INTERNAL:	AEOD/DOA		1	1	
	NRR/DE/EMEB		1	1	
	NRR/DSSA		1	1	
	RES/DSIR/EIB		1	1	
EXTERNAL:	NRC PDR		1	1	
		PD2-4	1	1	
		NRR/DE/EMCB	1	1	
		NRR/DRPW/OGCB	1	1	
		REG FILE 02	1	1	
		RGN2 FILE 01	1	1	
		NSIC	1	1	

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM PI-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 13 ENCL ~~13~~ 0

A01



Tennessee Valley Authority, Post Office Box 2000, Hollywood, Alabama 35752

H. Fred McCluskey
Site Vice President, Bellefonte Nuclear Plant

MAR 02 1994

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

Gentlemen:

In the Matter of the Application of)
Tennessee Valley Authority)

Docket Nos. 50-438
50-439

BELLEFONTE NUCLEAR PLANT (BLN) - RESPONSE TO NRC BULLETIN 89-01,
89-01 SUPPLEMENT 1, AND 89-01 SUPPLEMENT 2 - FAILURE OF
WESTINGHOUSE STEAM GENERATOR TUBE MECHANICAL PLUGS (TAC NOS.
M73148, M81592, M73149, M81593)

Pursuant to 10 CFR 50.54(f) this letter provides BLN's response to NRC Bulletin 89-01,
including Supplements 1 and 2, regarding the failure of Westinghouse steam generator
tube mechanical plugs.

The specific responses to the "Actions Requested" in NRC Bulletin 89-01 are as follows:

1. No steam generator mechanical plugs manufactured by Westinghouse are installed. No steam generator mechanical plugs from the subject heat numbers (group 1) are installed.
2. No response is required for items 2a-2c, 2e, 3, and 4 because no Westinghouse steam generator mechanical tube plugs of the applicable heats (group 1) are installed.
- 2.d A statement to preclude the use of Westinghouse steam generator tube mechanical plugs fabricated from Inconel 600 material will be incorporated into the appropriate procedure(s).

NRC Bulletin 89-01 Supplement 1 required no response or specific action.

9403090319 940302
PDR ADDCK 0500043B
D PDR

IFB1
44


MAR 02 1994

The specific responses to the "Actions Requested" in NRC Bulletin 89-01 Supplement 2 are as follows:


1. No steam generator mechanical plugs manufactured by Westinghouse are installed. No steam generator mechanical plugs from the subject heat numbers (group 2) are installed.
2. No response is required for items 2a-2c, 2e, and 2f, because no Westinghouse steam generator mechanical tube plugs of the subject heats (group 2) are installed.
- 2.d A statement to preclude the use of Westinghouse steam generator tube mechanical plugs fabricated from Inconel 600 material will be incorporated into the appropriate procedure(s).

The commitment contained in this letter is listed in the enclosure.

Should there be any questions regarding this information, please telephone G. M. Morrison, Acting BLN Site Licensing Manager, at (205) 574-8057.


H. Fred McCluskey

Subscribed and sworn to before me
on this 1st day of March 1994.


Notary Public

My Commission Expires 6/29/96

Enclosure

cc: see page 3

U.S. Nuclear Regulatory Commission

Page 3

MAR 02 1994

cc (Enclosure):

NRC Resident Inspector
Bellefonte Nuclear Plant
P. O. Box 2000
Hollywood, Alabama 35752

Mr. R. V. Crlenjak
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Mr. M. C. Thadani, Project Manager
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852

ENCLOSURE

**BELLEFONTE NUCLEAR PLANT (BLN) - RESPONSE TO NRC
BULLETIN 89-01, 89-01 SUPPLEMENT 1, AND 89-01 SUPPLEMENT 2
FAILURE OF WESTINGHOUSE STEAM GENERATOR TUBE
MECHANICAL PLUGS**

COMMITMENT

- A statement to preclude the use of Westinghouse steam generator tube mechanical plugs fabricated from Inconel 600 material will be incorporated into the appropriate procedure(s).