

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9407260358 DOC.DATE: 94/07/19 NOTARIZED: NO DOCKET #
 FACIL:50-438 Bellefonte Nuclear Plant, Unit 1, Tennessee Valley Au 05000438
 50-439 Bellefonte Nuclear Plant, Unit 2, Tennessee Valley Au 05000439
 AUTH.NAME AUTHOR AFFILIATION
 KAZANAS,N.C. Tennessee Valley Authority
 RECIPIENT NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Final deficiency rept re failed GE trip breakers. Initially reported on 831214. Condition does not identify substantial safety hazards & therefore not reportable, per 10CFR50.55(e). No commitments included.

DISTRIBUTION CODE: IE27D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: 50.55(e) Construction Deficiency Report

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-4	1	THADANI, M	1
INTERNAL:	ACRS	16	DEDRO	1
	NRR/DORS/OEAB	1	NRR/DRIL/RPEB	1
	NRR/DRIL/RVIB	1	OGC/HDS3	1
	REG FILE 02	1	RES/DSIR/EIB	1
	RGN2 FILE 01	1		
EXTERNAL:	NRC PDR	1	NSIC SILVER	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 504-2083) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 28 ENCL ~~28~~ 0

F
F
I
C
F
I
T
Y
1
E
C
C
U
M
E
N
T



Tennessee Valley Authority, Post Office Box 2000, Hollywood, Alabama 35752

JUL 19 1984

BLRD-50-438/84-01
BLRD-50-439/84-01

10 CFR 50.55(e)

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

Gentlemen:

In the Matter of the Application of)
Tennessee Valley Authority)

Docket Nos. 50-438
50-439

**BELLEFONTE NUCLEAR PLANT (BLN) - FAILED GENERAL ELECTRIC TRIP
BREAKERS - BLRD-50-438/84-01 AND BLRD-50-439/84-01 - FINAL REPORT**

The subject deficiency was reported to the NRC-OIE Inspector P. E. Fredrickson on December 14, 1983 in accordance with 10 CFR 50.55(e)(3) as Nonconformance Report (NCR) 2496. This was followed by our interim reports dated January 11 and May 8, 1984 and October 9, 1985. After further review, this condition does not identify a substantial safety hazard and, therefore, is not reportable. No commitments are included in this submittal.

Should there be any questions regarding this information, please telephone G. D. Pierce, Nuclear Assurance and Licensing Manager, at (205) 574-8058.


Nicholas C. Kazanas
General Manager

cc: See page 2

9407260358 940719
PDR ADDCK 05000438
S PDR

JE27 1/0

U.S. Nuclear Regulatory Commission

Page 2

JUL 18 1994

cc: NRC Resident Inspector
Bellefonte Nuclear Plant
P.O. Box 2000
Hollywood, Alabama 35752

Mr. P. E. Fredrickson
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Mr. M. C. Thadani, Project Manager
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852