

Tennessee Valley Authority

FINAL ENVIRONMENTAL STATEMENT

BELLEFONTE NUCLEAR PLANT

UNITS 1 AND 2

Chattanooga, Tennessee

SUMMARY SHEET  
ENVIRONMENTAL STATEMENT  
BELLEFONTE NUCLEAR PLANT

[ ] Draft      [ X ] Final environmental statement prepared by the  
Tennessee Valley Authority

For additional information contact:

Peter A. Krenkel, Director  
Division of Environmental Planning  
268 401 Building  
Chattanooga, Tennessee 37401  
(615) 755-3161

1. [ X ] Administrative action      [ ] Legislative action
2. This action is the construction and operation of a 2-unit nuclear power plant in Jackson County, Alabama.
3. Construction and operation of the plant is expected to have no significant adverse impact on land use and water use. No significant adverse impact is expected on water quality, fish, or aquatic life resulting from discharges of heated water and treated radioactive, chemical, and sanitary wastes into the Tennessee River. The small quantities of radioactive materials that are released will result in doses within the limits of the Atomic Energy Commission's proposed Appendix I to 10 CFR Part 50. There should be no detectable impact due to these releases. A long-term favorable impact on the economy of the area is expected. Operation of the closed-cycle cooling towers will result in evaporation of water and release of heat into the air. The cooling tower plumes may result in occasional local fog and ice and some visual obstruction. There will be a slight increase in temperature of water returned to the Tennessee River. The small quantities of fish larvae and plankton drawn into the closed cooling system will be destroyed. Construction of the plant will result in some reservoir turbidity. A small amount of land will be converted from agricultural to industrial use. Buildup of construction employees may initially strain the public and private sectors to provide housing, schools, and other services.
4. Baseloaded coal-fired and nuclear-fueled units were considered to meet the 1979-80 winter peak load. Nuclear units were selected due to the significant environmental advantages and lower costs. Due to similar power supply situations faced by other utilities, the purchase of power in the quantities needed was not a realistic alternative.

Alternative systems were considered for heat dissipation, reduction in releases of radioactive products from the plant, and reduction in releases of nonradioactive products from the plant.

Summary Sheet (Continued)

Alternative heat dissipation facilities considered included:

- (1) Once-through cooling
- (2) Dry cooling towers
- (3) Cooling lake
- (4) Spray canal
- (5) Mechanical draft cooling towers
- (6) Natural draft cooling towers

Considering feasibility, environmental impact, and cost, the natural draft cooling towers represent the best balance and have been adopted.

Alternatives considered for reducing releases of radioactive gases included:

- (1) 60-day holdup system
- (2) Cryogenic distillation
- (3) Gas absorption
- (4) Hydrogen recombiners

Selection of a 60-day holdup system was made as a result of balancing feasibility, environmental benefit, and cost.

5. Comments were received from the following agencies:

Advisory Council on Historical Preservation	Department of Commerce
Alabama Development Office	Department of Health, Education and Welfare
Atomic Energy Commission	Department of Housing and Urban Development
Environmental Protection Agency	Department of the Interior
Federal Power Commission	Department of Transportation
Department of Agriculture	
Department of the Army	

6. The draft statement was sent to the Council on Environmental Quality and made available to the public on March 6, 1973. The final statement was sent to the Council on Environmental Quality and made available to the public on May 24, 1974.

## DETAILED TABLE OF CONTENTS

	<u>Page No.</u>
SUMMARY SHEET . . . . .	frontispiece
DETAILED TABLE OF CONTENTS . . . . .	(i)
1.0 INTRODUCTION . . . . .	1.0-1
1.1 General Information. . . . .	1.1-1
1. Location of the Facility . . . . .	1.1-1
2. Physical Characteristics of the Facility . . . . .	1.1-1
1.2 Environment of the Area . . . . .	1.2-1
1. History . . . . .	1.2-1
2. Topography . . . . .	1.2-1
3. Geology . . . . .	1.2-1
4. Soils . . . . .	1.2-3
5. Seismology . . . . .	1.2-4
6. Climatology and Meteorology . . . . .	1.2-5
7. Hydrology and Water Quality . . . . .	1.2-9
(1) Ground Water . . . . .	1.2-9
(2) Surface Water . . . . .	1.2-10
(a) Reservoir Description . . . . .	1.2-10
(b) Streamflow . . . . .	1.2-10
(c) Water Quality . . . . .	1.2-11
(d) Water Temperature and Dissolved Oxygen . . . . .	1.2-12
(3) Water Use . . . . .	1.2-13
8. Land Use . . . . .	1.2-14
(1) Industrial Operations . . . . .	1.2-15
(2) Farming . . . . .	1.2-15
(3) Transportation . . . . .	1.2-16

	<u>Page No.</u>
(4) Recreation . . . . .	1.2-16
(5) Wildlife Areas . . . . .	1.2-17
(6) Population Distribution . . . . .	1.2-17
(7) Waterways . . . . .	1.2-17
(a) Navigation Use . . . . .	1.2-17
(b) Growth . . . . .	1.2-18
(8) Forestry . . . . .	1.2-18
(9) Government Reservations and Installations . . . . .	1.2-19
9. Ecological Surveys . . . . .	1.2-19
(1) Fish and Aquatic Macrophytes . . . . .	1.2-19
(2) Mammals, Birds, Herptiles, and Rare and Endangered Animal Species . . . . .	1.2-21
(a) Mammals . . . . .	1.2-21
(b) Birds . . . . .	1.2-21
(c) Herptiles . . . . .	1.2-23
(d) Rare and Endangered Animal Species . . . . .	1.2-23
(3) Vegetation . . . . .	1.2-24
(a) Elm-Ash-Soft Maple . . . . .	1.2-25
(b) Mixed Conifers and Hardwoods . . . . .	1.2-25
(c) Oak-Hickory . . . . .	1.2-26
(d) Black Locust . . . . .	1.2-26
(e) Oak-Gum . . . . .	1.2-26
(f) Broom Sedge-Lespedeza . . . . .	1.2-27
(g) Ragweed . . . . .	1.2-27
(4) Other Aquatic Life . . . . .	1.2-27
10. Historical and Archaeological Significance of the Site . . . . .	1.2-28

	<u>Page No.</u>
1.3 Electric Power Supply and Demand . . . . .	1.3-1
1. Power Needs . . . . .	1.3-3
2. Consequence of Delays . . . . .	1.3-5
1.4 Environment Approvals and Consultations . . . . .	1.4-1
1.5 Emergency Planning . . . . .	1.5-1
1. Meetings with Outside Agencies . . . . .	1.5-3
2. Responsible Agencies to be Notified in case of Accident . . . . .	1.5-3
2.0 ENVIRONMENTAL IMPACT OF THE PROPOSED FACILITY . . . . .	2.0-1
2.1 Transportation of Nuclear Fuel and Radioactive Wastes . . . . .	2.1-1
1. New Fuel Shipment . . . . .	2.1-1
(1) Method and Frequency of Shipment . . . . .	2.1-2
(a) Shipping Routes . . . . .	2.1-3
(b) Shipment Activity . . . . .	2.1-3
(2) Environmental Effects . . . . .	2.1-4
(a) Normal Shipments . . . . .	2.1-4
(b) Accident Occurrences . . . . .	2.1-5
2. Spent Fuel Shipment . . . . .	2.1-5
(1) Method and Frequency of Shipment . . . . .	2.1-6
(a) Shipping Routes . . . . .	2.1-7
(b) Shipment Activity . . . . .	2.1-7
(2) Environmental Effects . . . . .	2.1-8
(a) Normal Shipment . . . . .	2.1-8
(b) Accident Occurrences . . . . .	2.1-10
3. Radioactive Waste Shipment . . . . .	2.1-12
(1) Method and Frequency of Shipment . . . . .	2.1-12
(a) Shipping Routes . . . . .	2.1-13

	<u>Page No.</u>
(b) Shipment Activity . . . . .	2.1-14
(2) Environmental Effects . . . . .	2.1-14
(a) Normal Shipment . . . . .	2.1-15
(b) Accident Occurrences . . . . .	2.1-16
4. Shipping Safeguards . . . . .	2.1-18
(1) Governing Regulations . . . . .	2.1-19
(2) Package Design . . . . .	2.1-20
(a) New Fuel Container Description and Licensing . . . . .	2.1-21
(b) Spent Fuel Container Description and Licensing . . . . .	2.1-22
(c) Radwaste Container Description and Licensing . . . . .	2.1-25
(3) Transportation Procedures . . . . .	2.1-27
(a) Onsite Procedures . . . . .	2.1-27
(b) Offsite Procedures . . . . .	2.1-27
(c) Accident Occurrences During Transport . . .	2.1-28
5. Conclusion . . . . .	2.1-29
2.2 Environmental Aspects of Transmission Lines . . . . .	2.2-1
1. General Considerations . . . . .	2.2-4
2. Impacts of Transmission Line Rights of Way Clearing and Control Practices . . . . .	2.2-7
(1) Shear Clearing . . . . .	2.2-7
(a) Impact on Flora . . . . .	2.2-8
(b) Impact on Fauna . . . . .	2.2-9
(c) Impact on Waterfowl . . . . .	2.2-10
(d) The "Edge Effect" on Wildlife Benefits . .	2.2-11
(e) Chemical Maintenance of Right of Way . . .	2.2-12

	<u>Page No.</u>
(2) Multiple Use of Rights of Way . . . . .	2.2-14
3. Solid Waste Disposal . . . . .	2.2-15
4. Erosion Control Practices . . . . .	2.2-16
5. Miscellaneous Impacts . . . . .	2.2-17
(1) Ozone . . . . .	2.2-17
(2) Compatibility with Communications Equipment . .	2.2-18
(3) Historical and Archaeological Compatibility . .	2.2-18
(4) Impacts on Aviation . . . . .	2.2-19
(5) Impact of Support Facilities . . . . .	2.2-20
(6) General Impacts . . . . .	2.2-20
6. Tentative Transmission Line Route Selections . . . .	2.2-21
(1) Bellefonte-Madison 500-kV and Bellefonte- Widows Creek No. 1 500-kV Transmission Lines . . . . .	2.2-23
(2) Bellefonte-Widows Creek and Bellefonte- Scottsboro 161-kV Transmission Lines . . . . .	2.2-25
(3) Bellefonte-Widows Creek No. 2 500-kV Transmission Line . . . . .	2.2-25
(4) Bellefonte-Guntersville 500-kV Transmission Line . . . . .	2.2-29
2.3 Radiological Effects of Accidents . . . . .	2.3-1
2.4 Radioactive Discharges . . . . .	2.4-1
1. Waste Management Policy . . . . .	2.4-1
2. Origins of Radioactivity Released . . . . .	2.4-2
3. Radioactive Waste Disposal System . . . . .	2.4-4
(1) Makeup and Purification, Chemical Addition and Boron Recovery Systems . . . . .	2.4-4
(2) Liquid Waste Disposal System . . . . .	2.4-6

	<u>Page No.</u>
(a) Tritiated Liquid Waste . . . . .	2.4-6
(b) Nontritiated Liquid Waste . . . . .	2.4-9
(c) Discharge of Radioactive Liquids . . . . .	2.4-12
(3) Gaseous Waste Disposal System . . . . .	2.4-13
(4) Solid Waste Disposal System . . . . .	2.4-16
4. Radioactivity Releases . . . . .	2.4-17
(1) Liquid Releases . . . . .	2.4-18
(2) Gaseous Releases . . . . .	2.4-19
(a) Containment Purge . . . . .	2.4-19
(b) Instrument Room Purge . . . . .	2.4-20
(c) Releases Through the Auxiliary Building Ventilation System . . . . .	2.4-20
(d) Waste Gas Decay Tank Venting . . . . .	2.4-21
(e) Steam Leakages . . . . .	2.4-22
(f) Turbine Gland Sealing System Leakage . . . . .	2.4-22
(g) Condenser offgas . . . . .	2.4-22
(h) Feedwater Leakage . . . . .	2.4-23
5. Alternative Waste Treatment . . . . .	2.4-23
(1) Liquid Waste Disposal Alternatives . . . . .	2.4-23
(2) Gaseous Waste Disposal Alternatives . . . . .	2.4-24
(a) Addition of Recombiner . . . . .	2.4-24
(b) Addition of Noble Gas Removal System . . . . .	2.4-25
(3) Conclusions . . . . .	2.4-26
6. Environmental Radiological Monitoring Program . . . . .	2.4-27
(1) General . . . . .	2.4-27
(2) Atmospheric Monitoring . . . . .	2.4-28

	<u>Page No.</u>
(3) Terrestrial Monitoring . . . . .	2.4-29
(4) Reservoir Monitoring . . . . .	2.4-30
(a) Water . . . . .	2.4-32
(b) Fish . . . . .	2.4-33
(c) Plankton . . . . .	2.4-33
(d) Sediment . . . . .	2.4-34
(e) Aquatic Macrophytes . . . . .	2.4-34
(f) Bottom Fauna . . . . .	2.4-34
(5) Domestic Water Supplies Monitoring . . . . .	2.4-34
(6) Quality Control . . . . .	2.4-35
7. Estimated Increase in Annual Environmental Radioactivity Levels and Potential Annual Radiation Doses from Principal Radionuclides . . . . .	2.4-35
(1) Radionuclides in Liquid Effluents . . . . .	2.4-35
(2) Radionuclides in Gaseous Effluents . . . . .	2.4-36
(3) Summary of Radiological Impact . . . . .	2.4-37
2.5 Nonradioactive Discharges . . . . .	2.5-1
1. Chemical Discharges . . . . .	2.5-1
(1) Cooling Tower Blowdown and Drift . . . . .	2.5-1
(2) Cooling Tower Makeup and Essential Raw Cooling Water Systems . . . . .	2.5-4
(3) Water Filtration Plant . . . . .	2.5-5
(4) Steam Systems Makeup Demineralizers . . . . .	2.5-6
(5) Main Steam System . . . . .	2.5-8
(6) Alternative Treatment of Wastes from Makeup and Condensate Demineralizers . . . . .	2.5-8
(7) Component Cooling Water System . . . . .	2.5-11
(8) Reactor Coolant System . . . . .	2.5-12

	<u>Page No.</u>
(9) Auxiliary Steam Generator Blowdown . . . . .	2.5-12
(10) Chemical Cleaning During Construction . . . . .	2.5-13
(11) Miscellaneous . . . . .	2.5-13
2. Yard Drainage System . . . . .	2.5-14
3. Transformers and Electrical Machinery . . . . .	2.5-14
4. Sanitary Wastes . . . . .	2.5-15
5. Gaseous Emissions . . . . .	2.5-16
6. Normal Solid Waste Disposal . . . . .	2.5-17
2.6 Heat Dissipation . . . . .	2.6-1
1. Water Temperature Standards . . . . .	2.6-1
2. Thermal Regime of Gunterville Reservoir . . . . .	2.6-1
3. Description of Cooling System . . . . .	2.6-2
4. Impact of Heat Dissipation Facilities . . . . .	2.6-6
(1) Physical and Chemical Characteristics of the Tower Effluent . . . . .	2.6-7
(2) Local Fogging and Icing . . . . .	2.6-10
(a) General Conditions . . . . .	2.6-10
(b) Method of Analysis . . . . .	2.6-10
(c) Effects of Natural Draft Towers . . . . .	2.6-13
(3) Aesthetics . . . . .	2.6-14
(4) Noise . . . . .	2.6-14
5. Applicability of Water Quality Certification . . . . .	2.6-15
6. Alternative Heat Dissipation Facilities . . . . .	2.6-15
(1) Once-through Cooling . . . . .	2.6-15
(2) Dry Cooling Towers . . . . .	2.6-16
(3) Alternative Systems of Operation . . . . .	2.6-19

	<u>Page No.</u>
(4) Cooling Lake (Scheme 1) . . . . .	2.6-24
(a) Feasibility . . . . .	2.6-24
(b) Environmental Considerations . . . . .	2.6-27
(c) Land . . . . .	2.6-31
(d) Economic Considerations . . . . .	2.6-32
(5) Spray Canal System (Schemes 2A, 2B, and 3) . . . . .	2.6-33
(a) Feasibility . . . . .	2.6-33
(b) Environmental Considerations . . . . .	2.6-36
(c) Land . . . . .	2.6-40
(d) Economic Considerations . . . . .	2.6-40
(6) Mechanical Draft Cooling Towers (Schemes 4 and 5) . . . . .	2.6-42
(a) Feasibility . . . . .	2.6-42
(b) Environmental Considerations . . . . .	2.6-42
(c) Land . . . . .	2.6-46
(d) Economic Considerations . . . . .	2.6-46
(7) Natural Draft Cooling Towers (Schemes 6 and 7) . . . . .	2.6-49
(a) Feasibility . . . . .	2.6-49
(b) Environmental Considerations . . . . .	2.6-50
(c) Economic Considerations . . . . .	2.6-51
(8) Evaluation of Alternative Heat Dissipation Facilities . . . . .	2.6-52
(9) Alternative Intake Designs . . . . .	2.6-54
(a) Alternate 1 . . . . .	2.6-54
(b) Alternate 2 . . . . .	2.6-54
(c) Alternate 3 . . . . .	2.6-55
(d) Alternate 4 . . . . .	2.6-55

	<u>Page No.</u>
(e) Alternate 5 . . . . .	2.6-56
(f) Alternate 6 . . . . .	2.6-56
(g) Evaluations of Alternate Intake Designs . . . . .	2.6-56
2.7 Construction Effects . . . . .	2.7-1
1. General Construction Considerations . . . . .	2.7-1
(1) General Clearing . . . . .	2.7-2
(2) General Grading and Excavation . . . . .	2.7-4
2. Siltation Control . . . . .	2.7-6
3. Solid Waste . . . . .	2.7-9
4. Sanitary Waste . . . . .	2.7-9
5. Chemical Cleaning . . . . .	2.7-10
6. Miscellaneous . . . . .	2.7-11
7. Impact of Construction Traffic . . . . .	2.7-12
2.8 Socioeconomic Impact . . . . .	2.8-1
1. Construction Employment Impact . . . . .	2.8-1
(1) Population Impact . . . . .	2.8-2
(2) Impact on Schools . . . . .	2.8-3
(3) Impact on Economy; Personal Income . . . . .	2.8-4
(4) Impact on Economy; Wholesale Trade . . . . .	2.8-5
(5) Impact on Housing . . . . .	2.8-5
(6) Impacts on Traffic . . . . .	2.8-7
2. Permanent Employment Impact . . . . .	2.8-8
3. Mitigation of Impacts . . . . .	2.8-9
2.9 Other Impacts . . . . .	2.9-1
1. Access Facilities . . . . .	2.9-1
2. Aesthetics . . . . .	2.9-7

	<u>Page No.</u>
3. Archaeology . . . . .	2.9-8
4. Cemetery Relocation and Protection . . . . .	2.9-9
5. Water Use Compatibility . . . . .	2.9-10
6. Land Use Compatibility . . . . .	2.9-11
(1) Onsite Use Compatibility . . . . .	2.9-11
(2) Existing Land Use Compatibility . . . . .	2.9-11
(3) Future Land Use Compatibility . . . . .	2.9-12
3.0 ADVERSE ENVIRONMENTAL EFFECTS WHICH CANNOT BE AVOIDED . . . . .	3.0-1
1. Water Pollution . . . . .	3.0-1
2. Air Pollution . . . . .	3.0-3
3. Impact on Land Use . . . . .	3.0-4
4. Damage to Life Systems . . . . .	3.0-4
5. Threats to Health . . . . .	3.0-5
6. Socioeconomic Effects . . . . .	3.0-5
7. Conclusions . . . . .	3.0-6
4.0 ALTERNATIVES . . . . .	4.0-1
4.1 Alternative Generation . . . . .	4.1-1
4.2 Alternative Sites . . . . .	4.2-1
1. Sites Studies . . . . .	4.2-1
2. Area Requirements . . . . .	4.2-4
3. Site Descriptions . . . . .	4.2-8
(1) Site C . . . . .	4.2-8
(2) Site D . . . . .	4.2-9
(3) Site E . . . . .	4.2-10
(4) Site F . . . . .	4.2-11
(5) Site G . . . . .	4.2-12
(6) Site H . . . . .	4.2-12

	<u>Page No.</u>
4. Physical Environment . . . . .	4.2-14
(1) Chickamauga Site (Site G) . . . . .	4.2-14
(a) Hydrology . . . . .	4.2-14
(b) Seismology . . . . .	4.2-14
(c) Meteorology . . . . .	4.2-15
(d) Population . . . . .	4.2-16
(e) Land Requirements . . . . .	4.2-16
(f) Conclusion . . . . .	4.2-16
(2) Gunterville Reservoir Sites (Sites C and D) . . . . .	4.2-16
(a) Hydrology . . . . .	4.2-16
(b) Seismology . . . . .	4.2-17
(c) Meteorology . . . . .	4.2-17
(d) Population . . . . .	4.2-19
(e) Land Requirements . . . . .	4.2-19
(f) Conclusion . . . . .	4.2-19
5. Environmental Considerations . . . . .	4.2-19
(1) Aesthetics . . . . .	4.2-19
(2) Recreation . . . . .	4.2-21
(3) Land Use Compatibility . . . . .	4.2-22
(a) Site C . . . . .	4.2-22
(b) Site E . . . . .	4.2-23
(c) Site G . . . . .	4.2-23
(4) Impacts on Fisheries and Wildlife . . . . .	4.2-24
6. Economic Considerations . . . . .	4.2-25
(1) Site C . . . . .	4.2-25
(a) Access Facilities . . . . .	4.2-25

	<u>Page No.</u>
(b) Transmission Connections . . . . .	4.2-26
(c) Site Development . . . . .	4.2-26
(2) Site E . . . . .	4.2-26
(a) Access Facilities . . . . .	4.2-26
(b) Transmission Connections . . . . .	4.2-27
(c) Site Development . . . . .	4.2-27
(3) Site G . . . . .	4.2-27
(a) Access Facilities . . . . .	4.2-27
(b) Transmission Connections . . . . .	4.2-28
(c) Site Development . . . . .	4.2-28
6. Conclusion . . . . .	4.2-28
5.0 SHORT-TERM USES VERSUS LONG-TERM PRODUCTIVITY . . . . .	5.0-1
6.0 IRREVERSIBLE AND IRRETRIEVABLE COMMITMENTS OF RESOURCES . . . . .	6.0-1
7.0 AGENCY REVIEW COMMENTS . . . . .	7.0-1
8.0 BENEFIT-COST ANALYSIS . . . . .	8.0-1
8.1 Benefits . . . . .	8.1-1
1. Electric Power Produced and Sold . . . . .	8.1-1
2. Payments in Lieu of Taxes . . . . .	8.1-3
3. Regional Gross Product . . . . .	8.1-4
4. Recreation . . . . .	8.1-5
5. Air Quality . . . . .	8.1-5
6. Employment . . . . .	8.1-6
7. Education . . . . .	8.1-6
8.2 Monetary and Environmental Costs . . . . .	8.2-1
1. Effects on Natural Surface Water Body . . . . .	8.2-1
(1) Cooling Water Intake Structure . . . . .	8.2-1

	<u>Page No.</u>
(2) Passage Through the Condensers and Retention in Closed-Cycle Cooling Systems . . . . .	8.2-2
(a) Primary Producers and Consumers . . . . .	8.2-2
(b) Fish . . . . .	8.2-3
(3) Discharge Area and Thermal Plume . . . . .	8.2-3
(a) Physical Water Quality . . . . .	8.2-3
(b) Dissolved Oxygen . . . . .	8.2-4
(c) Aquatic Biota . . . . .	8.2-4
(d) Wildlife . . . . .	8.2-4
(e) Migratory Fish . . . . .	8.2-4
(4) Chemical Effluents . . . . .	8.2-4
(5) Radionuclides Discharged to Water Body . . . . .	8.2-5
(a) Aquatic Organisms . . . . .	8.2-5
(b) People - External . . . . .	8.2-5
(c) People - Ingestion . . . . .	8.2-5
(6) Consumption of Water . . . . .	8.2-6
(7) Plant Construction . . . . .	8.2-6
(a) Physical Water Quality . . . . .	8.2-6
(b) Chemical Water Quality . . . . .	8.2-6
(8) Other Impacts . . . . .	8.2-6
(9) Combined or Interactive Effects . . . . .	8.2-7
(10) Net Effect on Guntersville Reservoir . . . . .	8.2-7
2. Effects on Ground Water . . . . .	8.2-7
(1) Raising or Lowering of Ground Water Levels . . . . .	8.2-7
(2) Chemical Contamination of Ground Water . . . . .	8.2-7
(3) Radionuclide Contamination of Ground Water . . . . .	8.2-8
(a) People . . . . .	8.2-8

	<u>Page No.</u>
(b) Plants and Animals . . . . .	8.2-8
(4) Other Impacts on Ground Water . . . . .	8.2-8
3. Effects on Air . . . . .	8.2-8
(1) Fogging and Icing Caused by Evaporation and Drift . . . . .	8.2-8
(a) Effects on Local Ground Transportation . . . . .	8.2-8
(b) Effects on Air Transportation . . . . .	8.2-9
(c) Local Effects on Water Transportation . . . . .	8.2-9
(d) Effects on Plants . . . . .	8.2-10
(2) Chemical Discharge to Ambient Air . . . . .	8.2-10
(3) Radionuclides Discharged to Ambient Air . . . . .	8.2-11
(a) People - External . . . . .	8.2-11
(b) People - Ingestion . . . . .	8.2-11
(c) Plants and Animals . . . . .	8.2-11
(4) Other Impacts on Air . . . . .	8.2-11
4. Effects on Land . . . . .	8.2-12
(1) Preemption of Land . . . . .	8.2-12
(2) Plant Construction . . . . .	8.2-12
(a) Noise Effects on People . . . . .	8.2-12
(b) Accessibility of Historical Sites . . . . .	8.2-12
(c) Accessibility of Archaeological Sites . . . . .	8.2-12
(d) Wildlife . . . . .	8.2-12
(e) Erosion Effects . . . . .	8.2-12
(3) Plant Operation . . . . .	8.2-13
(a) Noise Effects on People . . . . .	8.2-13
(b) Aesthetic Effects on People . . . . .	8.2-13
(c) Wildlife . . . . .	8.2-13

	<u>Page No.</u>
(d) Flood Control . . . . .	8.2-13
(4) Salts Discharged in Drift From Cooling Towers . . . . .	8.2-13
(5) Transmission Route Selection . . . . .	8.2-14
(a) Preemption of Land . . . . .	8.2-14
(b) Land Use and Land Value . . . . .	8.2-14
(c) Aesthetic Effects on People . . . . .	8.2-15
(6) Transmission Facilities Construction . . . . .	8.2-15
(a) Land Adjacent to Rights of Way . . . . .	8.2-15
(b) Land Erosion . . . . .	8.2-15
(c) Wildlife . . . . .	8.2-15
(7) Transmission Line Operation . . . . .	8.2-16
(a) Land Use . . . . .	8.2-16
(b) Wildlife . . . . .	8.2-16
(8) Other Land Impacts . . . . .	8.2-16
(9) Combined or Interactive Effects . . . . .	8.2-17
(10) Net Effects on Land . . . . .	8.2-17
5. Cross Category Effects . . . . .	8.2-17
(1) Transportation . . . . .	8.2-17
(2) Accidents . . . . .	8.2-18
8.3 Weighing and Balancing of Alternative Generation, Alternative Sites, and Alternative Subsystems . . . . .	8.3-1
1. Alternative Generating Capacity . . . . .	8.3-1
2. Alternative Sites . . . . .	8.3-1
3. Heat Dissipation . . . . .	8.3-3
4. Chemical Discharges . . . . .	8.3-6
5. Gaseous Radwaste System . . . . .	8.3-7
6. Liquid Radwaste System . . . . .	8.3-9

9.0 CONCLUSION . . . . .	9.0-1
APPENDIX A Land Use in the Vicinity of the Bellefonte Site . . . . .	A-1
APPENDIX B1 Fish and Other Aquatic Life . . . . .	B1-1
APPENDIX B2 Terrestrial and Amphibious Fauna . . . . .	B2-1
APPENDIX B3 Vegetation . . . . .	B3-1
APPENDIX B4 Other Aquatic Life Surveys . . . . .	B4-1
APPENDIX C An Archaeological Survey of the Bellefonte Power Plant Site . . . . .	C-1
APPENDIX D Radiological Analysis for Transportation of Spent Fuel and Radioactive Waste . . . . .	D-1
APPENDIX E Relation of 10 CFR Part 71 Accident Requirements to Actual Shipping Environment . . . . .	E-1
APPENDIX F Ozone Production and Its Potential Effects . . . . .	F-1
APPENDIX G Outline of Accident Analyses . . . . .	G-1
APPENDIX H Radiological Impacts of Liquid Effluents . . . . .	H-1
APPENDIX I Radiological Impact of Gaseous Effluents . . . . .	I-1
APPENDIX J Cumulative Radiological Impact on the Tennessee River from the Operation of TVA Nuclear Plants . . . . .	J-1
APPENDIX K Radiological Impact of External Dose From Borated Water and Condensate Storage Tanks . . . . .	K-1
APPENDIX L Nonradiological Environmental Monitoring Program for the Bellefonte Nuclear Plant . . . . .	L-1

## 1.0 INTRODUCTION

TVA is a corporate agency of the United States created by the Tennessee Valley Authority Act of 1933 (48 Stat. 58, as amended, 16 U.S.C. §§ 831-831dd (1970; Supp. II, 1972)). In addition to its programs of flood control, navigation, and regional development, TVA operates a power system supplying the power requirements for an area of approximately 80,000 square miles containing about 6 million people. Except for direct service by TVA to certain industrial customers and Federal installations with large or unusual power requirements, TVA power is supplied to the ultimate consumer by 160 municipalities and rural electric cooperatives which purchase their power requirements from TVA. TVA is interconnected at 26 points with neighboring utility systems.

The TVA generating system consists of 29 hydro generating plants, 12 fossil-fueled steam generating plants, and two gas turbine peaking plants now in operation. In addition, power from Corps of Engineers' dams in the Cumberland River basin and dams owned by the Aluminum Company of America on Tennessee River tributaries is made available to TVA under long-term contracts. Figure 1.0-1 shows the location of TVA's present generating facilities and those under construction. The approximate area served by municipal and cooperative distributors of TVA power is also shown.

Power loads on the TVA system have doubled in the past 10 years and are expected to continue to increase in the future. In order to keep pace with the growing demand, it has been necessary to add substantial capacity to the generating and transmission system on a regular basis. The present system capacity is shown in Table 1.3-1.

This plant is proposed to satisfy in part TVA's obligation to supply an ample amount of electricity to the area which TVA serves. The plant will consist of two units; each having a net electrical generating capacity of 1,221 MW (electrical) when operating at about 3,600 MW (thermal). An application to construct the plant was filed with the Atomic Energy Commission (AEC) in May 1973. The decision by TVA to locate the plant at the Bellefonte site will be made considering the results of this environmental review. After extensive review of the preliminary safety analysis report and other documents by the AEC regulatory staff and the independent Advisory Committee on Reactor Safeguards and after a public hearing before an Atomic Safety and Licensing Board, AEC is expected to grant a construction permit early in calendar year 1975. The final safety analysis report will be submitted to AEC at a later date, along with a request for authorization to operate both units of the plant at the designed power level. Under the current schedule, TVA expects to begin to load the nuclear fuel for unit 1 in June 1979. Full power operation of unit 1 is expected in December 1979; unit 2 is expected to go into operation in September 1980.


As a Federal agency, TVA is subject to the requirements of the National Environmental Policy Act of 1969 (NEPA) which became effective on January 1, 1970. In carrying out its responsibilities under the TVA Act, TVA follows a policy designed to develop and enhance a quality environment. As a result of this policy, TVA has long considered environmental matters in its decision making. Offices and divisions within TVA employ personnel with a wide diversity of experience and academic training which enables TVA to utilize a systematic, interdisciplinary approach to ensure the integrated use of the natural and

social sciences and the environmental design arts in planning and decision making as required by NEPA. This statement on the environmental considerations relating to the Bellefonte Nuclear Plant is being sent to state and Federal agencies for review and comment pursuant to that Act as implemented by guidelines issued by the Council on Environmental Quality (CEQ) and Office of Management and Budget Circular A-95.

It should be noted that although the two units will begin operation at different times, this environmental statement considers the plant as operating with both units, in order to accurately assess the impact of the plant on the environment, and so that consideration of the cumulative effects of the plant can be assured.

The remainder of this statement provides a baseline inventory of environmental information and covers the environmental considerations set out in Section 102(2)(C) of NEPA, as implemented by the CEQ and AEC guidelines.

# TENNESSEE VALLEY REGION



**LEGEND**

- Steam Plants: Coal-Fired (C)
- Nuclear (N)
- Dams: Corps of Engineers Dam (E)
- Aluminum Co. of America Dam (A)
- Under Construction (U)
- Tennessee River Watershed (shaded area)
- Approximate Areas Served by Municipal & Cooperative Distributors of TVA Power (dashed line)

Figure 1.0-1

\*Includes gas turbine installation

1.1 General Information - This section provides a basic knowledge of the existing environment and the important characteristics and values of the Bellefonte site as it now exists in order to establish a basis for consideration of the environmental impact of the facility.

1. Location of the facility - The proposed site is located on a tract of land consisting of approximately 1,500 acres on a peninsula at Tennessee River mile (TRM) 392 on the west shore of Guntersville Lake about 7 miles east-northeast of Scottsboro, Alabama. The site lies on the southeast side of Browns Valley which separates Sand Mountain on the southeast from the rest of the Cumberland Plateau on the northwest. The proximity of the site to local towns, rivers, and state boundaries is indicated on the vicinity map, figure 1.1-1.

2. Physical characteristics of the facility - The plant will have the following principal structures on the site: two reactor containment buildings, turbine building, auxiliary building, service building, condenser circulating water pumping station, two diesel generator buildings, river intake pumping station, natural draft cooling towers, transformer yard, 500-kV and 161-kV switchyards, and sewage treatment facilities. Figure 1.1-2 shows the preliminary arrangement of these facilities. This arrangement may change as design of the plant progresses.

The two reactor containment buildings each house a pressurized water reactor designed and manufactured by Babcock & Wilcox. The 2-unit plant will have a total electrical generator nameplate rating of 2,664 megawatts. Nuclear fuel is contained inside each

reactor pressure vessel. The fuel is in sealed metal tubes and consists of slightly enriched uranium dioxide pellets. The fission process in the fuel produces heat. Water serves as both the moderator of the fission process and the coolant. The primary coolant water is pumped through the reactor from below the fuel and is heated by contact with the fuel element tubes. The reactor power is controlled by control rods, lumped burnable poison rods, and neutron-absorbing boric acid solution. The heated coolant flows in two closed-loop circuits through tubes in steam generators and then is pumped back into the reactor. In each steam generator a separate body of water flows in contact with the outside surfaces of the tubes and absorbs heat from the reactor coolant, producing steam to power the turbine generator. The electrical power thus produced by the turbine generators is fed through the switchyard and transmission line connections into the TVA system to meet system power requirements.

The principal ways in which the plant will interact with the environment, discussed later in detail, are:

1. Releases of minute quantities of radioactivity to the air and water;
2. Release of minor quantities of heat to Gunterville Lake and major quantities of heat and water vapor to the atmosphere; and
3. Change in land use from farming to industrial.




Figure 1.1-1  
BELLEFONTE VICINITY MAP  
(Site location - 85° 55' 35.6" W,  
34° 42' 31.8"N)




Figure 1.1-2  
 PRELIMINARY PLANT LAYOUT  
 BELLEFONTE NUCLEAR PLANT

1.2 Environment in the Area - The following summary description provides a baseline inventory of the important characteristics of the region.

1. History - The Bellefonte site is in Jackson County, Alabama. Located in the northeastern corner of the state, Jackson County is bounded by the Tennessee State Line, the Georgia State Line, and by DeKalb, Marshall, and Madison Counties. The county was created by an Act of the State Legislature on December 13, 1810. It was named for General Andrew Jackson, hero of the Creek Indian War and seventh President of the United States. Upon the formation of the county, Santa Cave was the temporary county seat but in 1821 Bellefonte was chosen. In 1850 the county seat was removed to Scottsboro, where it has remained.<sup>1</sup>

2. Topography - The Bellefonte site is a moderately wooded area with steep hills on the eastern portion of the tract. The plant will be located west of these hills. On the site, the land rises from the water surface (normal maximum level elevation 595 feet above mean sea level) to a hill crest approximately 800 feet above mean sea level. Across the river, the west escarpment of Sand Mountain rises to approximately 1,400 feet above mean sea level. The general topographic features of the site and nearby areas are shown on Figure A-3 (Appendix A).

3. Geology - The site lies on the southeast side of Browns Valley, which separates Sand Mountain on the southeast from the rest of the Cumberland Plateau to the northwest. Browns Valley in Alabama and its northeastward extension in Tennessee - Sequatchie Valley - were formed as the result of erosion of an anticlinal structure which

extends for over 150 miles from Blount Springs, Alabama, northeastward to Crab Orchard, Tennessee. The rock strata exposed by the anticline range from Cambro-Ordovician dolomite in the core up through Ordovician limestone; Silurian limestone, shale, and sandstone; Mississippian limestone and shale; to Pennsylvanian sandstone and shale on Sand Mountain and the Cumberland Plateau. The major portion of the site is in Section 7, Tier 4 South, Range 7 East.

Included as Figures 1.2-1 to Figure 1.2-4 are the regional tectonic map, regional geologic map, geologic and tectonic map of the plant area, and geologic map of the plant site.

Structures at the Bellefonte site would be founded on Chickamauga limestone of Middle Ordovician Age. The limestone of the Chickamauga strata occur along the entire length of the eastern side of the anticlinal valley and along most of the western side. At the site the strike of the strata is N 40°E and the dip is 17° southeast. The Chickamauga is slightly over 1,400 feet thick in the area and is overlain by approximately 150 feet of limestone, shale, and sandstone of the Silurian Red Mountain Formation and is underlain by several thousand feet of Cambro-Ordovician Knox dolomite.

Exploration and construction activities at the site will not destroy outcrop areas of significant geologic value. In fact, cores from exploratory drilling and exposures in foundation excavations will allow detailed geologic studies to be made in an area that otherwise contains few bedrock exposures. Representatives of the Alabama and Tennessee Geological Surveys have studied cores from the preliminary exploratory drilling and will be advised when additional material is available for further study.

No mineral deposits are being worked in the area. Studies of potential iron ore deposits in the Guntersville Reservoir area included investigation of the Red Mountain Formation at Sublett Ferry in the southwest corner of the site area. Detailed stratigraphic measurements of 150 feet of the formation disclosed no commercially mineable iron ore. The Red Mountain Formation is the host rock for iron ore in the Birmingham District where the formation is 300-500 feet thick and contains beds of ore up to 15 feet thick. In the Browns Valley area, the formation is much thinner and has no distinct iron ore beds. Instead, streaks of ferruginous sandy limestone occur intermittently throughout the section, but nowhere do these have high enough iron content or sufficient thickness to be commercially productive.

There is no indicated potential for any oil and gas production in the area. The latest information furnished by the Alabama Geological Survey indicates that only two exploratory holes have been drilled in Jackson County, both in 1913.<sup>2</sup> One was near Stevenson and the other near Bridgeport. Both were nonproductive.

4. Soils - As described in a soil survey report<sup>3</sup> of Jackson County the 1,500-acre site selected for the Bellefonte Nuclear Plant can be described as occurring in two soil association categories:

- (3) - Etowah-Holston-Talbott-Dewey; and
- (5) - Fullerton-Bodine-Ennis.

Soil association 3 consists of generally level to rolling deep, fertile soils on stream terraces and adjacent limestone uplands. Soil association 5, on the other hand is characterized by deep, well drained, rolling to hilly soils on cherty ridges.

The detailed soils map contained in the referenced report reveals that the dominant soil mapping units with this purchase area include:

- (a) Etowah loams and silt loams, level and undulating phases
- (b) Colbert silty clays and silty clay loams, undulating and rolling phases.
- (c) Fullerton cherty silt loam, eroded steep phase
- (d) Armuchee-Tellico complex, silty clay loams, eroded hilly phase
- (e) Dewey silt loam, hilly phase
- (f) Capshaw silt loam, level and undulating phases
- (g) Tupelo silt loam, undulating phase
- (h) Talbott silty clay loam, eroded undulating and rolling phases
- (i) Hermitage cherty silty clay loam, severely eroded hilly phase
- (j) Cumberland silty clay loam, eroded undulating phase

As indicated by this list of soil mapping units, the suitability of soils for agricultural production varies widely within the 1500 acres. The level to rolling, well and moderately well drained terrace soils (Etowah, Capshaw, Tupelo, and Cumberland series) in the western part of the nuclear plant site are very well suited to both cropland and pasture production. On the other hand, the steeper Fullerton, Dewey, Hermitage, and Armuchee-Tellico soils are not well adapted to cropland and pasture uses. These latter soils occur mainly in the forested uplands of the eastern portion of the nuclear plant site, paralleling Gunterville Reservoir.

5. Seismology - The site lies within the borders of the southern Appalachian seismotectonic province. Figure 1.2-5 locates the nearest faults in the region.

The nearest local quake with a Modified Mercalli intensity of V was centered 5 miles west of the site. The nearest known epicenter of a damaging quake (MM VII) was approximately 50 miles south of the site. The maximum intensity felt at the site from the latter quake was probably no higher than MM IV. Accelerations at the site from a recurrence of these shocks would be far less than the assumed seismic event: a MM VIII shock, centered at the site, with an

acceleration of 0.18g. The seismic history of the Bellefonte area is presented in the plant safety analysis report.<sup>4</sup>

6. Climatology and meteorology - The site is located in a temperate latitude about 250 miles north of the Gulf of Mexico. The area is dominated in winter and spring by alternating cool dry continental air from the north and warm moist maritime air from the south. During this period, migratory cyclonic disturbances cause frequent precipitation and moderate wind. Storms, including tornadoes, reach severest intensity in March and April.

In summer and fall the migratory systems are less frequent and less intense, and the area is generally dominated by the western portion of the Azores-Bermuda anticyclonic circulation. In the fall extensive periods of weak wind and stable atmospheric conditions most likely occur and result in the least favorable atmospheric dispersion conditions. Days of high air pollution potential that would likely affect the area should number about 6 days annually.

Tornadoes in the area generally move northeastward up the valley and cover an average surface path 5 miles long and 150 yards wide. However, the probability of a tornado occurring at the site is extremely low, about once in 15,000 years. Severe windstorms may occur several times a year, with wind speeds reaching 45 mi/h and on occasion exceeding 75 mi/h. High wind may accompany moderate-to-strong cold frontal passages 30 to 40 times a year with maximum frequency in March and April. Strong wind may accompany thunderstorms about 60 times a year with maximum frequency in July.

Average monthly temperatures in the area range from about 43°F in January to about 79°F in July. The maximum annual

temperature range, from 109°F in July to -16°F in February, is 125°F. Detailed temperature data for Scottsboro, Alabama are shown in Table 1.2-1.

Approximately 60 percent of the annual average precipitation of about 56 inches, in the plant site area results from migratory cyclonic disturbances from late November through April (Table 1.2-2). Snowfall data are in Table 1.2-3.

No records of the frequency and intensity of fogs are available for the Bellefonte site area. However, Chattanooga records (Table 1.2-4) indicate that heavy fogs (visibility equal or less than 1/4 mile) occur on 36 days annually with a maximum of 6 days in October and a minimum of 2 days from February through July.

Wind patterns in the area should be similar to those near the Widows Creek Steam Plant about 15 miles northeast of the site where data have been collected since 1964. Both plant sites have similar physiographic features. At Widows Creek the mean wind throughout the lower 600 to 800 feet is markedly bimodal (Figure 1.2-6) with northeasterly (NNE-NE) downvalley wind occurring about 22 percent of the time and southwesterly (SSW-SW) upvalley wind occurring about 24 percent of the time. About 70 percent of the downvalley wind is between 1 and 3 mi/h and occurs most frequently in September. One year of monitoring data in the Widows Creek Steam Plant area shows calm conditions occurring about 15 percent of the time and wind speeds, 1 to 3 mi/h, occurring about 58 percent of the time. This excessive frequency of weak wind conditions is due in part to the higher starting threshold (2 to 3 mi/h) of the older model wind speed sensor which has operated

since 1964 at Widows Creek Steam Plant meteorological facility. The newer wind speed sensor which has operated at the Bellefonte temporary offsite meteorological facility since May 12, 1972, has a starting threshold of 0.6 mph.

Wind patterns on Sand Mountain tend to reflect the regional windflow, which is quite dissimilar to that in the lower valley. The directional frequency pattern on Sand Mountain (Figure 1.2-7) shows a rather uniform distribution, with somewhat higher frequencies of southeasterly, southwesterly, and northwesterly winds. Average wind speeds are about 2 to 3 mi/h higher than those in the valley.

Because of the limited record of data from the temporary meteorological facility near the Bellefonte plant site, an extrapolated evaluation of the atmospheric dispersion conditions in the form of a joint frequency distribution of wind direction, wind speed, and stability was developed. The evaluation was based primarily on the (1) comparative wind direction and wind speed data from the Widows Creek Steam Plant and the Sequoyah Nuclear Plant, (2) temperature gradient data from the Sequoyah Nuclear Plant - adjusted to the Bellefonte plant site, and (3) stability percentage of occurrence (Pasquill classes A through G) at the Sequoyah Nuclear Plant - adjusted to the Bellefonte plant site (Table 1.2-5).

It should be pointed out the preliminary review of the first full year of data from the temporary offsite meteorological facility indicates that the frequency of stability classes, F and G, are somewhat less conservative than those based on the extrapolation.

A breakdown of the estimated occurrence of the individual stability categories, A through G, with respect to wind direction and wind speed is shown in Tables 1.2-6 through 1.2-12. Most significant is the percent occurrence of the 0-3.4 mph wind speed range for the F and G

categories which are usually identified with the most adverse onsite atmospheric dispersion conditions. The respective values are about 26 and 11 percent.

The principal effect of the valley-ridge terrain features on the atmospheric dispersion of effluent releases is one of confinement within the valley, particularly during weak and stable downvalley (northeasterly) and, to a lesser extent, upvalley (southwesterly) flow. Also, with the relatively flat and undulating valley floor, there should be minimal discontinuity of the low-level windflow from terrain roughness and irregularity.

The temporary meteorological facility began operation May 12, 1972, at a site about 2 miles north-northeast of the Bellefonte plant site and at or near plant grade. The facility consists of a 130-foot steel tower with an instrument building near the tower base. The data, processed by a pulse-o-matic automatic data logging system, consists of (1) wind speed and wind direction at 130 feet, and (2) temperature at 33 feet (10 meters) and 130 feet. In September 1973, additional wind direction and wind speed sensors were installed at the 33-foot level to obtain further data on the low-level wind conditions. Prior to this installation, the 33-foot wind speed data were extrapolated from the measured 130-foot wind data by use of the common power law relationship. The extrapolated 33-foot wind speeds should be more representative of plant site conditions than the measured 33-foot wind speeds at the offsite meteorological facility because of the minor differences in terrain features and the resultant effects on the low-level wind structure, particularly during weak wind and inversion conditions. No dew point measurement system was installed as none was available to meet the AEC Regulatory Guide 1.23 specification. TVA has now developed a prototype dew point gradient measurement system which will soon be installed at one of the existing nuclear plant permanent meteorological facilities.

On October 3, 1972, another temporary meteorological facility began operation on the immediate plant site. This facility, having continuous analog recording of wind direction and wind speed at 33 feet, was installed to obtain further data on the onsite low-level wind conditions.

In the fall of 1974, about five years in advance of fuel loading for unit 1 and in ample time to collect adequate data for preparing a definitive evaluation of the onsite atmospheric dispersion conditions, the installation of a permanent meteorological facility will begin. The collection of continuous and reliable data should start in late 1974 or early 1975. The facility will be located about 5,000 feet northeast of the reactor building sites and will consist of a 300- or 400-foot tower with instrument building (Environmental Data Station) near the base of the tower. The data collected and processed by high speed digital computer system will include (1) wind direction and wind speed at 33 (10 meters) and 300 (or 400) feet, atmospheric turbulence index ( $\sigma_y$  and  $\sigma_z$ ) at 33 and 300 (or 400) feet, temperature and dew point at 4, 33, 150 (or 200), and 300 (or 400) feet, and solar radiation, atmospheric pressure, and rainfall at 4 feet.

Also, plans are now being made to conduct special field studies before plant construction to identify the representative onsite atmospheric dispersion conditions or, more specifically, to develop reliable diffusion parameters for estimating maximum ground-level concentrations attributable to postulated accident and/or normal effluent releases.

#### 7. Hydrology and water quality -

(1) Ground water - Ground water at the site is derived principally from precipitation, which has averaged about 56 inches per year.

There is no distinct aquifer in the Chickamauga limestone at the Bellefonte site. The majority of the ground water flow moves through the residual soil overlying rock paralleling the topographic surface. Only minor amounts of water

penetrate small fractures and cracks in the argillaceous limestone. Observation of water levels in exploratory holes indicates a piezometric surface slightly above the top of bedrock which slopes with the topography toward the Town Creek embayment of Gunterville Lake north of the site area. Ground water will flow from the site to Town Creek embayment and reservoir. Drilling of more than 80 exploratory holes in the site area has disclosed no indication of major solution channels in the Chickamauga limestone. Pressure testing of these holes has shown them to be tight with no acceptance of water up to pressures of 50 lb/in<sup>2</sup>.

(2) Surface water - Surface water is derived from precipitation remaining after losses. It can be generally classified as local surface runoff or streamflow.

(a) Reservoir description -

The site is located 43 miles upstream of Gunterville Dam. At normal pool elevation of 595 feet, the reservoir is 75.7 miles long with an area of 67,900 acres, a volume of 1,018,000 acre-feet, a shoreline length of 949 miles, and a width which ranges from 900 feet to 2.5 miles. At the site it is about 3,400 feet wide, with depths ranging up to 30 feet at normal pool elevation. Navigation is provided by maintaining a minimum channel depth of 11 feet. Flow is in a general southwesterly direction.

(b) Streamflow - Records

maintained at South Pittsburg, Tennessee, and Hales Bar Dam for the period 1931 through 1970 show an average discharge of 35,300 ft<sup>3</sup>/s at South Pittsburg. The flow at Bellefonte would be about 3 percent greater. During the summer months (May-October) the flow averages 27,100 ft<sup>3</sup>/s and during the winter months (November-April), averages 44,200 ft<sup>3</sup>/s.

Channel velocities at the plant site average 0.9 feet per second under normal winter flow conditions and 0.6 foot per second under normal summer conditions. Reversals of flow into the embayments occur as a result of water management practices.

(c) Water quality - A

detailed water quality study of Gunterville Reservoir was made during the 12-month period from May 1963 through April 1964.<sup>5</sup> This study included an assessment of both the quality conditions and the uses of Gunterville Reservoir waters. The locations of points where water quality data were collected are shown in Figure 1.2-8.

Results of the bacteriological sampling indicate that the 30 miles of the reservoir upstream from the mouth of Mud Creek (about 2 miles upstream from the Bellefonte Plant site) was seriously polluted by the discharge of untreated or partially treated wastes to the Tennessee River at Chattanooga. This section of Gunterville Reservoir was judged unsatisfactory for swimming and other water-contact recreation. Recent improvements in waste treatment facilities at Chattanooga have greatly reduced the discharge of untreated sewage to the Tennessee River. The results of bacteriological studies made during the recreational season of 1971 and 1972 show that the waters of the Tennessee River downstream from the old Hales Bar Dam (TRM 431.1) are now suitable for water-contact recreation.

The sanitary-chemical and mineral quality of Gunterville Reservoir water was found to be high quality. The water is soft to moderately hard and low in organic content, iron, and manganese. The mineral quality of the water is satisfactory for almost any municipal or industrial use. The bacteriological, sanitary-chemical,

and mineral quality data collected during 1963-1964 at Tennessee River mile 385.9 (about 6 miles downstream from the plant site) are shown in Table 1.2-13.

The radiological quality of water was determined by samples collected from two stations at approximately monthly intervals over the one-year survey period. A three-point composited sample (surface, mid-depth, and near the bottom) from Tennessee River mile 350.4, and a surface sample from Tennessee River mile 385.9, were analyzed to determine alpha and beta radioactivities. The results of these analyses are shown in Table 1.2-14. Alpha-particulate activities ranged from 0 to 2 picocuries per liter while beta activity ranged from 7 to 33 picocuries per liter.

(d) Water temperature and dissolved oxygen - The water temperature and dissolved oxygen profiles observed in Gunterville Reservoir in 1963-1964 during typical spring, summer, fall, and winter months are shown in Figure 1.2-9.

Near river mile 380 mild thermal stratification developed during the warmer months, associated with diminishing DO concentrations in the lower levels of the reservoir. Downstream from mile 380 thermal stratification and DO deficits in the lower levels usually became more pronounced. Depressed DO concentrations at the lower elevations in Gunterville Reservoir were attributed principally to (1) inflow of water from Hales Bar Reservoir that was low in DO, (2) poor vertical mixing in the downstream end of the pool of the warmer surface water and the cooler water near the bottom, and (3) decomposing plankton and other organic material that settle in the

downstream end of the pool from the well-aerated surface layers into the cooler waters below.

Since 1960, TVA has been monitoring, on a weekly basis, the water temperatures and dissolved oxygen concentrations in the releases from its hydro projects. The water temperature and DO concentrations of the releases from Hales Bar and Gunterville Dams during calendar years 1963 and 1964 are shown in Figure 1.2-10. These data show that during the summer, water leaving Gunterville Dam was slightly warmer and contained slightly more DO than when it passed through Hales Bar Dam. The addition of unit number 8 at Widows Creek Steam Plant (TRM 408) in 1965 and the closure of Nickajack Dam (replaced Hales Bar Dam located about six miles upstream) in 1967 probably resulted in water temperatures in Gunterville Reservoir slightly warmer than those observed in 1963-1964, although no data are available to document this. The water temperatures of the releases from Nickajack and Gunterville Dams are summarized in Table 1.2-15.

(3) Water use - From its head near Knoxville to Kentucky Dam near its mouth, the Tennessee River is a series of highly controlled multi-purpose reservoirs. This chain of reservoirs provides flood control, navigation, generation of electric power, sport and commercial fishing, industrial and public water supply, recreation and waste disposal.

Water use in the area is not limited to reservoir water, since several public and private water supplies are taken from ground water sources. These withdrawals are small compared with reservoir uses.

There are seven public water supplies taken from Guntersville Reservoir and its tributary embayments. The nearest downstream supplies are Scottsboro and the Sand Mountain Water Authority, 6.2 and 9.9 miles below the site. Thirteen public ground water supplies are within a 20-mile radius of the site (Figure 1.2-11). The ground water supply nearest the site is 3.4 miles west at Hollywood, serving 485 people. In addition, two public water supplies (Bridgeport and Arab, Alabama) use both surface waters of Guntersville Reservoir and ground waters as their source of supply.

There are four industrial water supplies taken from Guntersville Reservoir and its tributary embayments. Only one of these, the TVA Widows Creek Steam Plant, is within 20 miles of the site. The nearest downstream industrial water supply intake is for the Monsanto synthetic fiber plant at TRM 365 (27 miles downstream). Water from this supply is also used for potable water within the plant. All other industries in the vicinity of the site purchase their process and potable water from public systems. Detailed information on public and industrial water use is in Table 1.2-16.

8. Land Use - For many years, relative isolation due to the topography associated with the Cumberland Plateau has kept the towns within the Sequatchie Valley and its extension into North Alabama from the mainstream of industrialization and urbanization occurring in the Great Valley (Chattanooga and Gadsden) and on the Highland Rim (Tullahoma and Huntsville). However, in recent years several urban-industrial nodes have been developing along the Guntersville Reservoir within the Sequatchie Valley extension (Guntersville, Scottsboro, Stevenson, Bridgeport, and South Pittsburg). Better road access, ample labor and

available waterfront sites have all contributed to the gradual extension of urban-industrial development into the valley. Scottsboro, about 7 miles west-southwest of the site, is the nearest and most important emerging center with a 1970 population of 9,324.

Surrounding these urban-industrial nodes in the river bottomland are extensive agricultural areas. On the Cumberland Plateau to the east, very low-density residential development is scattered among farms specializing in high-value cultivated crops. To the west the plateau is more suitable for forestry and forest related activities and has been primarily so utilized.

The 1971 land use in the site area is shown in Figure A-1 (Appendix A). A more complete description of current local land use is provided in Appendix A. Summary discussions of land use categories are given below.

(1) Industrial operations - Several manufacturing plants are located in and around Scottsboro. The two most important are Revere Copper and Brass Corporation and Goodyear Tire and Rubber Company. Revere is located on a peninsula south of Scottsboro, while Goodyear is on a part of a large tract on the southwest edge of the city.

(2) Farming - Jackson County, according to the 1969 Census of Agriculture, had about 44 percent of its land area in farms. The average size of the 2,044 farms was 145 acres, with only 385 being 200 acres or larger. Farm sales were derived principally from livestock, poultry, and their products, with the major farm sales area being poultry and poultry products (about 34.8 percent gross farm sales). Gross sales were about \$13.9 million for an average of about \$6,800 per farm.

(3) Transportation - U.S. Highway 72, connecting Chattanooga, Tennessee, and Huntsville, Alabama, passes about two miles to the northwest of the proposed site. The Alabama State Highway Department is improving U.S. 72 from Huntsville eastward to the Tennessee line to a four-lane divided highway with unlimited access. Interstate Highway 59 is approximately twenty miles to the southeast of the site. The Southern Railway line between Chattanooga and Huntsville passes about three miles northwest of the site. Barge traffic on Guntersville Reservoir is discussed below.

(4) Recreation - Guntersville Reservoir is especially attractive for water-based recreation. With an average annual use level of over 5 million visits, it ranks second in popularity among all TVA reservoirs. Reservoir use is concentrated primarily in the 7-month period from April through October, within which an estimated 85 percent of the annual use occurs.

Recreation developments on the reservoir include a state park, 3 county parks, 5 municipal parks, 3 wildlife management areas, 26 public access areas, 28 commercial docks or resorts, and several private group camps and club sites. TVA and the State of Alabama plan to augment the system of public access areas on the reservoir, and several of the public parks will be expanded over the next few years. Sand Mountain, an attractive wooded ridgeline, parallels the east shore of the reservoir.

Away from Guntersville Reservoir a variety of recreational attractions exist within a 60-mile radius of the Bellefonte site. Included within this area are all or parts of several Federal

or private reservoirs, a portion of the Chattahoochee National Forest, the Wheeler National Wildlife Refuge, Russell Cave National Monument, several state parks and forests, and several commercial recreation attractions.

(5) Wildlife areas - Several wildlife management areas are located in the vicinity of the site. Three, primarily for waterfowl, are located on North Sauty Creek, Mud Creek, and Crow Creek embayments. An upland game area, Skyline Game Management Area, is about thirteen miles north of the site. During hunting seasons, these areas add to recreational activity by attracting hunters.

(6) Population distribution - Jackson County is sparsely settled with a 1970 population of 39,202. Net population growth in the county between 1960 and 1970 totaled 2,521, for a 6.9 percent increase. Scottsboro, the county seat, is the largest city in the area with a 1970 population of 9,324. The remainder of the population is scattered among farms, rural nonfarm residences, and small towns of less than 3,000 people. Figures 1.2-12 and 1.2-13 show the 1970 population distributions within 10 miles and 50 miles respectively of the site. Figures 1.2-14 and 1.2-15 show projected year 2020 population distributions within 10 miles and 50 miles, respectively, of the site.

Population within 60 miles totals 1,313,515. Slightly over 50 percent is in towns with more than 2,500 people and two-thirds of this is located in the three metropolitan areas of Huntsville, Chattanooga, and Gadsden.

(7) Waterways -

(a) Navigation use - For the years 1971 and 1972, barge and recreational use of the Tennessee River

both upstream at Nickajack Lock and downstream at Guntersville Lock are given below:

		<u>Guntersville Lock</u>	<u>Nickajack Lock</u>
Tons	1971	4,955,888	2,808,638
	1972	4,057,000	2,526,000
Number of Barges	1971	7,227	4,701
	1972	6,009	5,253
Number of Tows	1971	1,158	1,057
	1972	1,011	1,261
Number of Recreational Craft	1971	3,127	1,098
	1972	3,847	1,427

The apparent inconsistency between the tonnage and number of barges and tows for the Nickajack Lock results from a change in the composition of the tows traversing this particular lock.

(b) Growth - Total tonnage

for the Tennessee River in 1970 was 25.5 million tons and in 1971 was 27.7 million tons. Estimates indicate that Tennessee River traffic will experience an average growth rate of about 4.8 percent annually to 1980, when it will reach about 40.5 million tons.

(8) Forestry - A TVA field survey

conducted in September 1972 showed that 57 percent of the area around the proposed Bellefonte Nuclear Plant is forested. Average growing stock is 870 cubic feet of merchantable timber per acre with 24 percent softwoods and 76 percent hardwoods. The sawtimber volume is 2,010 board feet per acre, 32 percent of which is softwoods. Current wood volumes on the site are below the averages of 950 cubic feet and 2,670 board feet for Jackson County, Alabama and 900 cubic feet and 3,230 board feet for the entire Tennessee River Valley.

A field survey conducted in 1962 indicated that of the land in Jackson County 60.8 percent was forested, 34.7 percent was nonforested, and 4.5 percent was covered by water. Volume of growing stock was 319.4 million cubic feet, with 93 percent hardwoods and 7 percent softwoods.

(9) Government reservations and installations - The Tennessee Valley Authority's Nickajack Dam, Guntersville Dam, and Widows Creek Steam Plant and the Department of the Interior's Russell Cave National Monument are the only government installations in the general area of the plant. Redstone Arsenal near Huntsville, Alabama, is located approximately 40 miles west of the site.

9. Ecological surveys - The plant site and adjacent waters have been examined and assessed. No rare or endangered species are known or expected to be threatened on the Bellefonte site. Collected data, species lists, sampling areas and procedures, charts, and other detailed information appear in Appendix B. Appendix B has four subsections, B1 through B4, discussed in the paragraphs below.

(1) Fish and aquatic macrophytes - The most current surveys of the fishery resource of Guntersville Reservoir and of the vicinity of the proposed plant site were conducted in 1971 and 1972 and are detailed in Appendix B1. The two surveys yielded 50 species among 27 genera belonging to 14 families of fish. Comparison of the reservoir-wide 1971 survey with recent results from other TVA lower mainstream reservoirs indicates that Guntersville ranks first in numerical standing stock of harvestable sport species and fourth in commercial species.

In the 1972 site survey, the Mud Creek and Town Creek embayments contained greater percentages of young-of-the-year fish than did the mainstream cove; the majority of these in the embayments were game species, primarily centrarchids. Other sampling operations yielded essentially similar information in terms of species importance.

The aquatic habitat in the vicinity of the plant site supports a diverse piscine fauna dominated by three families: Centrarchidae, Clupeidae and Scianidae. Embayments support large numbers of young game fish; the mainstream supports rough and forage species and adult game species. The most important game species identified in the creel census were white crappie, bluegill, redear sunfish and largemouth bass. Cove-rotenone and meter-net data indicate that all four species are utilizing this area as a reproductive and nursery area. Important commercial species of Gunter's Reservoir as identified in a 1971 survey were catfish, buffalo, carp and drum; these species appeared in the collections of the 1972 biological survey, but the role of the embayments with regard to these is not clear. Forage species, primarily gizzard shad, but with substantial numbers of cyprinids contributing, were found in all areas.

A series of rooted aquatic macrophytes periodically appear at the interface between water and land and out into deeper water. These plants develop in relation to site contours and light penetration. They grade from emergent, to floating leaved, to totally submerged. A preliminary survey of the species found is shown in Table 1.2-17.

Two invading aquatic species identified are Eurasian watermilfoil (Myriophyllum spicatum), and Asiatic clams (Corbicula manilensis) each of which is colonizing extensive areas of Gunter'sville Reservoir.

(2) Mammals, birds, herptiles, and rare and endangered animal species - Appendix B2 provides the ecological survey for mammals, birds and herptiles. Also included is a listing of rare and endangered animal species which could possibly inhabit the area. Summary discussion of these items is provided below.

(a) Mammals - A qualitative assessment of the Bellefonte site mammal populations was made based on a comprehensive vegetative analysis (Appendix B3) of the area, knowledge of past land use practices, a review of a list of mammals found on Wheeler National Wildlife Refuge and Burt's A Field Guide to the Mammals, 1952. Species known to occur at Wheeler Refuge and those whose distributional limits include the plant site area are listed in Appendix B2.

There are several of the larger mammals represented on the Bellefonte site such as the white-tailed deer, gray fox and cottontail rabbit. In addition, because of the habitat variety afforded by different plant associations occurring in small intermixed areas, there are expected to be moderate to large populations of a large variety of small mammals.

(b) Birds - The list of birds given in Appendix B2 is a composite listing of species which likely

nest and winter in the Bellefonte area and those that migrate through Jackson County.

The good mixture of forest and open vegetative types and large degree of openness within forest types available at Bellefonte provides an abundance of niches favoring a diverse bird population.

A species commonly seen on large TVA reservoirs is the Osprey, or Fish Hawk. This bird is not listed as rare or endangered by the Department of the Interior at the present time, but is rapidly decreasing in numbers and may well be placed on the list of threatened species within the next few years. Ospreys have been known to nest on channel marker buoys in Watts Bar, Chickamauga, and other TVA mainstream reservoirs.

The Prothonotary Warbler is conspicuously present in late spring and early summer, breeding in the littoral areas in hollow willows and other tree species. Also, numerous Great Blue Herons and Green Herons use the area.

The Wood Duck is the only waterfowl species which nests frequently in the vicinity of the Bellefonte site. The close proximity of state and federal waterfowl management areas, however, attracts a large number of ducks and geese during the winter months. These birds fly considerable distances in their daily feeding excursions and frequent the waters adjacent to the site. The abundance of aquatic and riparian vegetation in and around the shallow waters of the Bellefonte peninsula serve as natural attractants to waterfowl. These plants are listed and rated for cover and food values in Appendix B2.

The State of Alabama operates four different waterfowl management areas in the vicinity of the plant site (North Sauty, Mud Creek, Crow Creek, and Raccoon Creek). The Mud Creek Waterfowl Management Area is operated on TVA land leased to the State of Alabama and is nearest the site. Virtually all development and hunting activity within the Mud Creek Area is more than four miles north of the proposed plant site.

(c) Herptiles - There are no published accounts dealing specifically with the reptiles and amphibians of Jackson County. An account by Penn (1940) provided an annotated list of species and subspecies collected in Mentone, DeKalb County, and vicinity, and this was used for many years as a source of reference to the herpetology of northeastern Alabama. Within recent years, field crews from Auburn University have made a number of trips to Jackson County for the purpose of making comprehensive collections of reptiles and amphibians. Most of the specimens obtained have been placed in the Auburn University Museum. A total of 81 species, representing 20 families, are thought to occur in Jackson County. The wide variety of habitats found on the proposed plant site doubtless harbor diverse herptile populations (See Appendix B2).

(d) Rare and endangered animal species - After careful review of fauna suspected to inhabit or migrate through the Bellefonte site and those animals whose distributional limits encompass the site, it was found that several species listed by the Department of the Interior Office of Rare and Endangered Species as threatened with extinction could conceivably be found in the area at

certain times during the year. The Southern Bald Eagle is commonly seen on Watts Bar and Chickamauga Lakes upstream from Guntersville and these birds are occasionally seen at Wheeler National Wildlife Refuge. Two extremely rare species, American Peregrine Falcon and Red-cockaded Woodpecker, have been seen on Wheeler Refuge. Bachman's Warbler and Kirtland's Warbler could conceivably migrate through the area, but neither have been recorded at Wheeler Refuge. The Indiana bat, another endangered species, is a cave dweller and would be unlikely in the area, since there are no known caves on the Bellefonte site.

The Alabama Department of Conservation and Natural Resources has also published a list of rare and endangered species. Several animal species not included in the Department of Interior list are considered rare or endangered by Alabama. The southeastern shrew, southeastern myotis, and hoary bat are mammals considered to be threatened in Alabama. The Sharpshinned Hawk, Cooper's Hawk, Golden Eagle, Osprey, Peregrine Falcon, Bewick's Wren, and Ruffed Grouse along with the Bald Eagle are also considered threatened. Rare or endangered Alabama herptiles are the red milk snake and the Tennessee cave salamander. Appendix B2 contains a composite listing of rare and endangered animal species.

(3) Vegetation - The vegetation survey, made in September 1972, encompasses an area of 1,090 acres around the proposed Bellefonte Nuclear Plant site. No rare or endangered plant species listed in the U.S. Forest Service listing of southern wildflowers were found during ecological investigations. The state of Alabama has published no official listing of rare or endangered plant species.

The results are contained in Appendix B3. The five major vegetation types and their percentage of the site area are: cultivated land, 21 percent; elm-ash-soft maple, 17 percent; oak-hickory, 15 percent; mixed conifers and hardwoods, 15 percent; and broom sedge-lespedeza, 14 percent. Figure B3-1 indicates the location and distribution of the eight recognized vegetation types.

Recent heavy logging has substantially reduced the timber volume and perhaps changed the species frequency in the wooded types. This disruptive activity has opened the canopy and has encouraged an increase of low growing plant forms. A summary description of vegetation types is given below. Detailed discussions and descriptions of the types of understory species is given in Appendix B3.

(a) Elm-ash-soft maple -

Twenty-nine percent of the forested plots were classified as elm-ash-soft maple. Winged elm, ash, and sweetgum were the remaining dominants in the heavily cut-over stands. Nine percent were in large sawtimber, 36 percent were in small sawtimber, 45 percent were in pole size stands, and 9 percent were classified as seedling and sapling stands. These figures reflect the fact that most of the forested land has been heavily logged.

(b) Mixed conifers and

Hardwoods - Twenty-six percent of all forest stands were grouped as mixed conifers and hardwoods. These stands are found on well-drained soils on all topographic sites. Some stands were dominated by redcedar, some by loblolly or Virginia pine, some by other species. Due to only

minor differences between plots these species were lumped together into a single broad type. (Two small, almost pure stands of pole-size loblolly pine are shown in Figure B3-1. Since the stands are small enough that no plots were located in them, however, they are not included as a separate type.)

In general, logging was much less intense in these mixed stands. Twenty percent were in large sawtimber and 60 percent were in small sawtimber, while only 20 percent were pole size.

(c) Oak-hickory - Twenty-six

percent of the forested land was classified in the oak-hickory type. These stands consist of oaks and hickories with the more common associates including sweetgum, black locust, and sugar maple. Stands are found on moderate to well drained soils on the high terraces and hilly slopes. Twenty percent of the stands were in large sawtimber, 30 percent were in small sawtimber, 40 percent were in pole size timber, and 10 percent were in the seedling and sapling stand size.

(d) Black locust - Eleven

percent of all wooded stands were classified as black locust. These were found on the lower slopes and terraces on well drained soils. Half of the stands were in pole size timber while the remaining half were split equally between small sawtimber and seedling-sapling stand sizes.

(e) Oak-gum - Eight percent of

all sampled forest stands belonged to the oak-gum type. These stands were composed largely of cherrybark oak, water oak, and sweetgum. The stands were confined for the most part to bottomland sites on which drainage was

poor. Two-thirds of the stands were classified as small sawtimber and one-third were pole size stands.

(f) Broom sedge-lespedeza -

Nine plots representing 32 percent of the open land were classified as broom sedge-lespedeza. Broom sedge, sericea lespedeza, and assorted other grasses dominated the communities. The average percent cover for all species was 94 percent.

(g) Ragweed - Eighteen percent

of the open land was placed in the ragweed community type. Average percent cover for all species was 96 percent. Ragweed and grasses dominated the community.

(4) Other aquatic life - The water level

of the reservoir is managed within a narrow fluctuation limit of about 2 feet annually. Due to gradual slopes, extensive shallows are dewatered during periods of drawdown. These areas provide good habitat for species with short life cycles such as midges. These areas are not readily utilized by long lived species such as mussels; but snails may move in and out of these areas with the fluctuation in water levels.

When a stable pool is maintained, the natural river flow passes through the reservoir rapidly so that suspended or drifting organisms are retained in the reservoir for only a short time. Embayments and overbank areas protected by islands provide good aquatic environments throughout the year. The most stable shoreline habitat and environment is in the zones of embayments or along channels and islands with steep slopes.

The organisms found in the vicinity of the Bellefonte site are listed and described in Appendix B4.

10. Historical and archeological significance of the site - Adjacent to the plant site is the location of the former Jackson County seat of Bellefonte. It is listed in the Alabama Statewide Plan of Historic Preservation and the site is being processed for nomination to the National Register of Historical Places. An old tavern, dating back to 1845, is still standing but is in a deteriorated condition, as are some other remaining, but undated, structures. Part of the old stagecoach road is still in evidence, as is the old courthouse cistern.

It is planned to have initial construction access to the site over the county road which passes through the old town site. Thus, TVA has consulted with the Alabama State Historical Commission staff regarding this as an access alternative and found it to be preferred, providing that there be no destruction of structures, remains, or important sites. Should this route be chosen, TVA will use all available information to assure that this condition is met.

To assist in determining the physical extent of old town Bellefonte, an investigation of the historical significance of the town site has been proposed. A research proposal has been submitted to TVA by the University of Alabama at Birmingham. It proposes the undertaking of an archeological investigation of building sites and research of historical records and documents. It is expected that information obtained would make possible a better evaluation and assessment of the historical importance of Bellefonte to the region. Arrangements for carrying out this research investigation are being completed. Also, TVA

has agreed to evaluate, in consultation with the Alabama State Historical Commission, the appropriate ways by which the historical aspects of the area could be accentuated.

An archeological investigation of the Bellefonte site was conducted during the summer of 1972. The investigative survey was directed by Mr. Carey B. Oakley, Research Associate in Archeology, Department of Anthropology, University of Alabama. The survey methods, sites, and results are given in Appendix C. The survey indicated that the Bellefonte site was never extensively utilized by the prehistoric Indian. However, two survey sites, 1 Ja 300 and 1 Ja 302, were identified as sites that should be investigated.

REFERENCES FOR SECTION 1.2

1. Volume I, Alabama Encyclopedia, Jesse M. Richardson, Copyright 1965
2. Oil and Gas Wells in Alabama, Geological Survey of Alabama, Circular 43, January 1966.
3. Soil Survey Report of Jackson County, Alabama, Series 1941, No. 8, issued March 1954. Published cooperatively by: U.S.D.A. Soil Conservation Service Alabama Dept. of Agriculture and Industries; Alabama Agricultural Experiment Station; and Tennessee Valley Authority. 222 p and maps.
4. Section 2.5. Geology and Seismology, Bellefonte Nuclear Plant Preliminary Safety Analysis Report.
5. "Quality of Water in Guntersville Reservoir," TVA Division of Environmental Research and Development, Water Quality Branch, December 1970.

Table 1.2-1

AIR TEMPERATURE DATA\*

Scottsboro, Alabama

Month	Mean Monthly (° F)	Mean		Highest Temp. (° F)	Lowest Temp. (° F)	Mean No. Days	
		Daily Maximum (° F)	Daily Minimum (° F)			90° F and Above	32° F and Below
December	43.2	53.7	32.5	80	4	0	16
January	42.7	53.4	32.2	81	-10	0	17
February	43.9	55.1	33.1	80	-16	0	13
Winter	43.3	54.1	32.6	81	-16	0	46
March	52.2	64.0	40.3	90	5	0	11
April	60.4	72.9	47.6	92	23	1	2
May	68.4	81.0	55.8	98	31	6	0
Spring	60.3	72.6	47.9	98	5	7	13
June	75.6	87.8	63.9	107	39	16	0
July	78.5	89.8	67.0	109	49	23	0
August	77.7	89.2	66.3	105	49	23	0
Summer	77.3	88.9	65.7	109	39	62	0
September	72.7	84.9	60.3	108	34	10	0
October	61.5	74.8	48.3	96	23	1	2
November	50.3	62.9	37.6	84	1	0	13
Fall	61.5	74.2	48.7	108	1	11	15
Annual	60.6	72.5	48.7	109	-16	80	74

\*Climatography of the United States No. 86-1; Decennial Census of the United States Climate; Climatic Summary of the United States - Supplement for 1951 through 1960, Alabama. Period of Record, 76 Years (1885-1960).

Table 1.2-2

PRECIPITATION DATA \*

Scottsboro, Alabama \*\*

<u>Month</u>	<u>Monthly Average (Inches)</u>	<u>Extreme Monthly Maximum (Inches)</u>	<u>Extreme Monthly Minimum (Inches)</u>	<u>Maximum in 24 Hrs. (Inches)</u>	<u>Average No. of Days With 0.01 Inch or More</u>
December	5.16	13.67	1.06	5.75	9
January	6.01	13.80	1.99	4.12	11
February	6.07	13.50	1.02	4.10	10
Winter	17.24				30
March	6.32	12.78	1.63	4.60	10
April	5.13	11.12	1.38	3.73	10
May	4.05	8.20	0.57	3.50	9
Spring	15.50				29
June	4.12	8.11	0.81	3.72	9
July	5.22	11.18	1.16	3.43	10
August	3.44	9.65	0.05	3.20	9
Summer	12.78				28
September	3.67	10.13	0.40	3.10	7
October	2.69	10.37	0.00	3.65	6
November	4.19	15.49	1.08	3.50	8
Fall	10.55				21
Annual	56.07				108

\*Precipitation in the Tennessee River Basin, TVA, Division of Water Control Planning, Hydraulic Data Branch; period of record, monthly data for 35 years (1935-1969).

\*\*National Weather Service Cooperative Station.

Table 1.2-3

SNOWFALL DATA\*

Scottsboro, Alabama

<u>Month</u>	<u>Monthly Average (Inches)</u> (1)	<u>Monthly Average (Inches)</u> (2)	<u>Monthly Maximum (Inches)</u> (1)
January	T	1.1	T
February	1.9	1.1	10.0
March	0.3	0.1	3.0
April	0	0	0
May	0	0	0
June	0	0	0
July	0	0	0
August	0	0	0
September	0	0	0
October	0	0	0
November	T	0.1	T
December	T	0.4	T
Annual	2.2	2.8	

\* Climatology of the United States No. 86-1; Decennial Census of the United States Climate; Climatic Summary of the United States - Supplement for 1951 through 1960, Alabama. (1) Period of record, 10 years (1951-1960); (2) Period of record, 68 years (1893-1960).

Table 1.2-4

HEAVY FOG\*

Chattanooga, Tennessee

1931-1972

<u>Month</u>		<u>Mean No. of Days With Heavy Fog**</u>
Dec.		4
Jan.		3
Feb.		2
	Winter	9
Mar.		2
April		2
May		2
	Spring	6
June		2
July		2
Aug.		3
	Summer	7
Sept.		4
Oct.		6
Nov.		4
	Fall	14
	Annual	36

\*Local Climatological Data with Comparative Data, 1972, Chattanooga, Tennessee, U.S. Department of Commerce, National Weather Service.

\*\*Heavy fog is defined as fog reducing the visibility to 1/4 mile or less.

Table 1.2-5

PERCENT OCCURRENCE OF ATMOSPHERIC STABILITY\*

Bellefonte Site		
<u>Pasquill Stability Class</u>	<u>Vertical Temperature</u>	<u>Percent Occurrence</u>
A	$\Delta T < 1.9^{\circ}\text{C}/100\text{m}$	2.50
B	$-1.9 < \Delta T \leq -1.7^{\circ}\text{C}/100\text{m}$	2.80
C	$-1.7 < \Delta T \leq -1.5^{\circ}\text{C}/100\text{m}$	4.07
D	$-1.5 < \Delta T \leq -0.5^{\circ}\text{C}/100\text{m}$	19.47
E	$-0.5 < \Delta T \leq 1.5^{\circ}\text{C}/100\text{m}$	33.08
F	$1.5 < \Delta T \leq 4.0^{\circ}\text{C}/100\text{m}$	26.39
G	$\Delta T > 4^{\circ}\text{C}/100\text{m}$	<u>11.67</u>
Total		100.00

## \*Extrapolated from:

1. Widows Creek annual wind direction and wind speed frequency data (1968-70) from the Valley meteorological station.
2. Sequoyah wind direction and wind speed frequency data (April 2, 1971-March 31, 1972).
3. Sequoyah joint frequency distribution data (April 2, 1971-March 31, 1972) for wind direction, wind speed, and Pasquill stability classes A-G.
4. Joint frequency distribution data (May 12-July 31, 1972) for wind direction, wind speed, and Pasquill stability classes A-G from the temporary meteorological facility, Bellefonte site.

Table 1.2-6

PERCENT OCCURRENCE OF WIND SPEED  
FOR ALL WIND DIRECTIONS\*

STABILITY CATEGORY A

Bellefonte Site

Wind Direction	Wind Speed (mi/h)					Total
	0.0-0.5	0.6-3.4	3.5-7.4	7.5-12.4	≥12.5	
N	0.05	0.26				0.31
NNE	0.04	0.31	0.05			0.40
NE	0.05	0.31	0.08			0.44
ENE						
E						
ESE			0.32			0.32
SE			0.13			0.13
SSE						
S		0.08	0.05			0.13
SSW				0.13		0.13
SW		0.08	0.13			0.21
WSW						
W		0.05				0.05
WNW				0.05	0.05	0.10
NW		0.05		0.13		0.18
NNW		0.10				0.10
Total	0.14	1.24	0.76	0.31	0.05	2.50

\*Extrapolated from:

1. Widows Creek annual wind direction and wind speed frequency data (1968-70) from the Valley meteorological station.
2. Sequoyah wind direction and wind speed frequency data (April 2, 1971-March 31, 1972).
3. Sequoyah joint frequency distribution data (April 2, 1971-March 31, 1972) for wind direction, wind speed, and Pasquill stability classes A-G.
4. Bellefonte joint frequency distribution data (May 12-July 31, 1972) for wind direction, wind speed, and Pasquill stability classes A-G from the temporary meteorological facility.

Table 1.2-7

PERCENT OCCURRENCE OF WIND SPEED  
FOR ALL WIND DIRECTIONS\*

STABILITY CATEGORY B

Bellefonte Site

Wind Direction	Wind Speed (mi/h)					Total
	0.0-0.5	0.6-3.4	3.5-7.4	7.5-12.4	≥12.5	
N			0.21	0.35		0.56
NNE		0.14	0.07			0.21
NE	0.07	0.46	0.28	0.07		0.88
ENE						
E		0.14				0.14
ESE						
SE						
SSE						
S						
SSW			0.7	0.16		0.23
SW		0.09	0.16	0.14		0.39
WSW			0.09			0.09
W						
WNW						
NW			0.16			0.16
NNW		0.07			0.07	0.14
Total	0.07	0.90	1.04	0.72	0.07	2.80

\*Extrapolated from:

1. Widows Creek annual wind direction and wind speed frequency data (1968-70) from the Valley meteorological station.
2. Sequoyah wind direction and wind speed frequency data (April 2, 1971-March 31, 1972).
3. Sequoyah joint frequency distribution data (April 2, 1971-March 31, 1972) for wind direction, wind speed, and Pasquill stability classes A-G.
4. Bellefonte joint frequency distribution data (May 12-July 31, 1972) for wind direction, wind speed, and Pasquill stability classes A-G from the temporary meteorological facility.

Table 1.2-8

PERCENT OCCURRENCE OF WIND SPEED  
FOR ALL WIND DIRECTIONS\*

Stability Category C

Bellefonte Site

Wind Direction	Wind Speed (mph)					Total
	<u>0.0-0.5</u>	<u>0.6-3.4</u>	<u>3.5-7.4</u>	<u>7.5-12.4</u>	<u>≥12.5</u>	
N		0.03	0.12	0.15		0.30
NNE	0.03	0.19	0.18			0.40
NE	0.03	0.37	0.25	0.09		0.74
ENE		0.06	0.03			0.09
E			0.15			0.15
ESE						
SE		0.06	0.22			0.28
SSE			0.06			0.06
S		0.03	0.03	0.03	0.03	0.12
SSW		0.10		0.19		0.29
SW		0.06	0.15	0.31		0.52
WSW			0.06	0.21		0.27
W			0.10	0.19		0.29
WNW						
NW			0.06	0.09	0.03	0.18
NNW			0.03	0.31	0.04	0.38
Total	0.06	0.90	1.44	1.57	0.10	4.07

\*Extrapolated from:

1. Widows Creek annual wind direction and wind speed frequency data (1968-70) from the Valley meteorological station.
2. Sequoyah wind direction and wind speed frequency data (April 2, 1971-March 31, 1972).
3. Sequoyah joint frequency distribution data (April 2, 1971-March 31, 1972) for wind direction, wind speed, and Pasquill stability classes A-G.
4. Bellefonte joint frequency distribution data (May 12-July 31, 1972) for wind direction, wind speed, and Pasquill stability classes A-G from the temporary meteorological facility.

Table 1.2-9

PERCENT OCCURRENCE OF WIND SPEED  
FOR ALL WIND DIRECTIONS\*

STABILITY CATEGORY D

Bellefonte Site

Wind Direction	Wind Speed (mi/h)					Total
	0.0-0.5	0.6-3.4	3.5-7.4	7.5-12.4	≥12.5	
N	0.04	0.38	0.73	0.23		1.38
NNE	0.12	1.32	0.80			2.24
NE	0.24	2.28	0.88	0.19		3.59
ENE	0.04	0.53	0.13			0.70
E	0.01	0.11	0.09			0.21
ESE	0.01	0.22	0.13			0.36
SE	0.02	0.25	0.22			0.49
SSE	0.03	0.42	0.14	0.01		0.60
S	0.01	0.25	0.15	0.04	0.08	0.53
SSW	0.07	0.80	0.52	0.43	0.03	1.85
SW	0.09	0.90	0.73	0.58	0.07	2.37
WSW	0.01	0.29	0.33	0.36		0.99
W		0.12	1.38	0.31	0.13	1.94
WNW	0.01	0.07	0.21	0.25	0.01	0.55
NW	0.01	0.17	0.19	0.36	0.02	0.75
NNW	0.01	0.18	0.30	0.40	0.03	0.92
Total	0.72	8.29	6.93	3.16	0.37	19.47

\*Extrapolated from:

1. Widows Creek annual wind direction and wind speed frequency data (1968-70) from the Valley meteorological station.
2. Sequoyah wind direction and wind speed frequency data (April 2, 1971-March 31, 1972).
3. Sequoyah joint frequency distribution data (April 2, 1971-March 31, 1972) for wind direction, wind speed, and Pasquill stability classes A-G.
4. Bellefonte joint frequency distribution data (May 12-July 31, 1972) for wind direction, wind speed, and Pasquill stability classes A-G from the temporary meteorological facility.

1.2-40

Table 1.2-10

PERCENT OCCURRENCE OF WIND SPEED  
FOR ALL WIND DIRECTIONS\*

STABILITY CATEGORY E

Bellefonte Site

Wind Direction	Wind Speed (mi/h)					Total
	0.0-0.5	0.6-3.4	3.5-7.4	7.5-12.4	≥12.5	
N	0.01	1.55	0.38	0.05		1.99
NNE	0.37	3.69	0.32			4.38
NE	0.27	2.30	0.25			2.82
ENE	0.07	0.69	0.05			0.81
E	0.03	0.43				0.46
ESE	0.06	0.58	0.05			0.69
SE	0.05	0.53	0.07			0.65
SSE	0.09	1.14	0.30	0.02		1.55
S	0.09	1.06	0.32	0.10		1.57
SSW	0.25	2.44	0.73	0.44	0.03	3.89
SW	0.29	2.89	0.81	0.64	0.10	4.73
WSW	0.15	1.82	0.40	0.25		2.62
W	0.06	0.76	0.86	0.13		1.81
WNW	0.05	0.68	0.36	0.83		1.92
NW	0.05	0.68	0.37	0.14	0.01	1.25
NNW	0.10	1.14	0.46	0.23	0.01	1.94
Total	1.99	22.38	5.73	2.83	0.15	33.08

\*Extrapolated from:

1. Widows Creek annual wind direction and wind speed frequency data (1968-70) from the Valley meteorological station.
2. Sequoyah wind direction and wind speed frequency data (April 2, 1971-March 31, 1972).
3. Sequoyah joint frequency distribution data (April 2, 1971-March 31, 1972) for wind direction, wind speed, and Pasquill stability classes A-G.
4. Bellefonte joint frequency distribution data (May 12-July 31, 1972) for wind direction, wind speed, and Pasquill stability classes A-G from the temporary meteorological facility.

Table 1.2-11

PERCENT OCCURRENCE OF WIND SPEED  
FOR ALL WIND DIRECTIONS\*

STABILITY CATEGORY F

Bellefonte Site

Wind Direction	Wind Speed (mi/h)					Total
	0.0-0.5	0.6-3.4	3.5-7.4	7.5-12.4	≥12.5	
N	0.21	2.21	0.15			2.57
NNE	0.46	5.20	0.04			5.70
NE	0.34	3.40	0.01			3.75
ENE	0.18	1.74	0.01			1.93
E	0.02	0.39				0.41
ESE	0.05	0.65	0.09			0.79
SE	0.05	0.65				0.70
SSE	0.07	0.92				0.99
S	0.05	0.75	0.04			0.84
SSW	0.18	2.23	0.12			2.53
SW	0.18	2.23	0.49	0.04		2.94
WSW	0.05	0.67	0.15			0.87
W	0.01	0.29	0.35			0.65
WNW	0.01	0.29	0.07	0.32		0.69
NW	0.01	0.14	0.05	0.01		0.21
NNW	0.05	0.68	0.09			0.82
Total	1.92	22.44	1.66	0.37		26.39

\*Extrapolated from:

1. Widows Creek annual wind direction and wind speed frequency data (1968-70) from the Valley meteorological station.
2. Sequoyah wind direction and wind speed frequency data (April 2, 1971-March 31, 1972).
3. Sequoyah joint frequency distribution data (April 2, 1971-March 31, 1972) for wind direction, wind speed, and Pasquill stability classes A-G.
4. Bellefonte joint frequency distribution data (May 12-July 31, 1972) for wind direction, wind speed, and Pasquill stability classes A-G from the temporary meteorological facility.

Table 1.2-12

PERCENT OCCURRENCE OF WIND SPEED  
FOR ALL WIND DIRECTIONS\*

STABILITY CATEGORY G

Bellefonte Site

Wind Direction	Wind Speed (mi/h)					Total
	0.0-0.5	0.6-3.4	3.5-7.4	7.5-12.4	≥12.5	
N	0.03	0.31	0.01			0.35
NNE	0.11	1.51				1.62
NE	0.16	1.61				1.77
ENE	0.15	1.55				1.70
E	0.04	0.60				0.64
ESE	0.01	0.18				0.19
SE	0.01	0.24		0.30		0.55
SSE	0.01	0.28				0.29
S	0.03	0.40	0.01			0.44
SSW	0.10	1.32	0.01			1.43
SW	0.13	1.77	0.09			1.99
WSW	0.01	0.45	0.03			0.49
W	0.01	0.09				0.10
WNW		0.06				0.06
NW		0.01				0.01
NNW		0.04				0.04
Total	0.80	10.42	0.15	0.30		11.67

\* Extrapolated from:

1. Widows Creek annual wind direction and wind speed frequency data (1968-70) from the Valley meteorological station.
2. Sequoyah wind direction and wind speed frequency data (April 2, 1971-March 31, 1972).
3. Sequoyah joint frequency distribution data (April 2, 1971-March 31, 1972) for wind direction, wind speed, and Pasquill stability classes A-G.
4. Bellefonte joint frequency distribution data (May 12-July 31, 1972) for wind direction, wind speed, and Pasquill stability classes A-G from the temporary meteorological facility.



Station 1Tennessee River Mile 350.4Station 4Tennessee River Mile 385.9

Date	Alpha (pc/l)			Beta (pc/l)			Alpha (pc/l)			Beta (pc/l)		
	Diss.	Susp.	Total	Diss.	Susp.	Total	Diss.	Susp.	Total	Diss.	Susp.	Total
5-19-63	0 ± 0	0 ± 0	0 ± 0	8 ± 1	5 ± 1	13 ± 1	1 ± 0	1 ± 0	2 ± 0	13 ± 1	2 ± 1	15 ± 1
6-12-63	0 ± 0	1 ± 0	1 ± 0	9 ± 1	2 ± 1	11 ± 1	0 ± 0	0 ± 0	0 ± 0	11 ± 1	2 ± 0	13 ± 1
7-14-63	0 ± 0	0 ± 0	0 ± 0	11 ± 1	4 ± 1	15 ± 1	0 ± 0	0 ± 0	0 ± 0	12 ± 1	2 ± 0	14 ± 1
8-31-63	0 ± 0	0 ± 0	0 ± 0	12 ± 1	1 ± 0	13 ± 1	0 ± 0	0 ± 0	0 ± 0	15 ± 1	1 ± 0	16 ± 1
9-24-63	0 ± 0	0 ± 0	0 ± 0	13 ± 1	0 ± 0	13 ± 1	0 ± 0	0 ± 0	0 ± 0	10 ± 1	0 ± 0	10 ± 1
10-24-63	0 ± 0	0 ± 0	0 ± 0	11 ± 1	6 ± 1	17 ± 1	0 ± 0	0 ± 0	0 ± 0	7 ± 1	1 ± 0	8 ± 1
11-26-63	0 ± 0	0 ± 0	0 ± 0	7 ± 1	0 ± 0	7 ± 1	0 ± 0	0 ± 0	0 ± 0	13 ± 2	1 ± 0	14 ± 2
12-18-63	0 ± 0	0 ± 0	0 ± 0	7 ± 1	1 ± 0	8 ± 1	0 ± 0	0 ± 0	0 ± 0	10 ± 1	1 ± 0	11 ± 1
1-16-64	0 ± 0	1 ± 0	1 ± 0	4 ± 1	7 ± 1	11 ± 1	0 ± 0	0 ± 0	0 ± 0	11 ± 1	2 ± 0	13 ± 1
2-17-64	0 ± 0	0 ± 0	0 ± 0	16 ± 1	7 ± 1	23 ± 1	0 ± 0	0 ± 0	0 ± 0	13 ± 1	8 ± 1	21 ± 1
3-17-64	0 ± 0	0 ± 0	0 ± 0	11 ± 1	12 ± 1	23 ± 1	0 ± 0	1 ± 0	1 ± 0	9 ± 1	24 ± 2	33 ± 2
4-22-64	0 ± 0	0 ± 0	0 ± 0	11 ± 1	5 ± 1	16 ± 1	0 ± 0	0 ± 0	0 ± 0	12 ± 1	5 ± 1	17 ± 1

1.2-14

Table 1.2-14  
SUMMARY OF GUNTERVILLE  
RESERVIOR RADIOACTIVITY LEVELS  
1963-1964

Table 1.2-15

SUMMARY OF OBSERVED TAILRACE WATER TEMPERATURE DATA

(Weekly Observations)

Week Number	Nickajack Dam 1968-71 Records		Guntersville Dam 1967-71 Records	
	Maximum of the Four Weekly Temperatures OF	Average of the Four Weekly Temperatures OF	Maximum of the Five Weekly Temperatures OF	Average of the Five Weekly Temperatures OF
1	50.0	45.2	46.4	44.6
2	44.6	42.2	44.6	42.1
3	44.6	42.8	46.4	43.0
4	44.6	42.5	46.4	44.4
5	48.2	44.6	48.2	45.1
6	44.6	42.8	46.4	44.6
7	43.7	42.1	46.0	44.5
8	44.6	43.3	50.0	46.2
9	50.0	45.5	48.2	45.5
10	48.2	45.5	51.8	47.7
11	50.0	48.2	51.8	48.9
12	50.0	50.0	53.6	51.3
13	53.6	51.4	57.0	53.4
14	57.2	54.7	60.8	59.7
15	59.9	58.1	64.4	62.1
16	64.4	61.3	68.0	64.6
17	64.4	63.5	68.0	65.8
18	66.2	64.4	68.0	66.9
19	68.0	66.7	68.0	67.3
20	69.8	67.6	71.6	69.8
21	73.4	70.7	71.6	69.8
22	77.9	73.9	73.4	71.6
23	75.2	73.6	77.9	73.9
24	77.0	76.1	80.6	77.2
25	78.8	77.7	81.5	79.5
26	80.6	79.0	86.0	83.0
27	82.4	80.4	85.1	83.8
28	82.4	80.6	88.7	83.3
29	82.4	80.8	86.0	84.2
30	82.4	80.6	84.2	81.7
31	82.4	78.4	84.2	82.6
32	82.4	80.2	84.2	82.4
33	80.6	80.2	85.1	81.7
34	81.5	79.9	84.2	81.1
35	80.6	78.8	82.4	80.0
36	80.6	78.8	84.2	79.5
37	80.6	78.4	86.0	79.9
38	80.6	76.1	83.3	77.2
39	78.8	76.1	80.6	72.3
40	78.8	74.8	78.8	72.9
41	75.2	71.6	74.3	72.7
42	71.6	69.4	72.5	69.1
43	69.8	66.8	66.2	64.0
44	69.8	64.4	71.6	64.8
45	60.8	59.4	62.6	59.5
46	59.0	57.4	61.7	57.5
47	57.0	54.0	58.1	54.5
48	52.7	51.6	53.6	52.9
49	51.8	49.1	51.8	50.0
50	51.8	48.7	54.5	50.0
51	51.8	47.8	53.6	49.8
52	51.8	50.2	53.6	48.0

Table 1.2-16

WATER SUPPLIES WITHIN 20-MILE RADIUS OF PROPOSED PLANT SITE AND  
SUPPLIES TAKEN FROM TENNESSEE RIVER BETWEEN NICKAJACK AND GUNTERSVILLE DAMS

Water Supply	Approximate Distance From Site*	Estimated Population Served	Average Daily Use	Source
<u>Public Supplies</u>	<u>Miles</u>		<u>Gallons</u>	
1. Albertville	33.6	23,045	3,250,000	Surface (TRM 360.8) Short Creek embay- ment (mile 2.4)
2. Arab	36.8	12,620	750,700	Surface (TRM 356.0) Browns Creek embay- ment (mile 0.8) and Ground, Wells
3. Bridgeport	21.6	3,132	310,000	Surface (TRM 413.6) and Ground, Spring
4. Camp Maranatha	14.3	68	6,000	Ground, Wells
5. Christian Youth Camp	23.8	125	6,200	Surface (TRM 368.2)
6. Flat Rock Elementary School	12.6	280	7,000	Ground, Wells
7. Grant	45.3	3,116	174,000	Surface (TRM 351.8) Honeycomb Creek embayment (mile 5.1)

1.2-46

\*Radial distance to all supplies except those that take water directly from the Tennessee River which are shown as river mile distance from 392.0.

Table 1.2-16 (continued)

Water Supply	Approximate Distance From Site*	Estimated Population Served	Average Daily Use	Source
<u>Public Supplies</u>	<u>Miles</u>		<u>Gallons</u>	
8. Grove Oak Junior High School	19.7	165	4,100	Ground, Wells
9. Guntersville	34.0 38.2	6,580	1,249,000	Surface (TRM 358.0) and Surface (TRM 356.0) - Browns Creek embayment (mile 2.2)
10. Hollywood	3.4	485	40,000	Ground, Wells
11. Ider High School	13.5	1,044	26,100	Ground, Wells
12. Limrock Junior High School	15.7	70	1,800	Ground, Wells
13. New Prospect Elementary School	18.4	100	2,500	Ground, Wells
14. North Jackson Hospital	16.3	87	14,500	Ground, Wells
15. North Sand Mountain High School	19.5	508	12,700	Ground, Wells
16. Pisgah	4.2	385	35,000	Ground, Wells
17. Sand Mountain Water Authority	9.9	8,174	546,000	Surface (TRM 382.1)
18. Scottsboro	6.2 16.6	11,000	3,500,000	Surface (TRM 385.8) and Surface (TRM 377.4), North Sauty Creek embayment (mile 2.0)
19. Skyline Elementary School	14.2	370	9,200	Ground, Wells

\*Radial distance to all supplies except those that take water directly from the Tennessee River which are shown as river mile distance from 392.0.

Table 1.2-16 (continued)

Water Supply	Approximate Distance From Site*	Estimated Population Served	Average Daily Use	Source
<u>Public Supplies</u>	<u>Miles</u>		<u>Gallons</u>	
20. Stevenson	11.7	1,600	117,000	Ground, Wells
21. South Pittsburg	26.0	4,820	528,000	Surface (TRM 418.0)
22. Ten Broeck Junior High School	19.8	131	3,300	Ground, Wells
<u>Industrial Supplies</u>				
1-I. Butler Rubber Co., Inc.	33.2	-	250,000	Surface (TRM 358.8) Big Spring Creek embayment (mile 1.7)
2-I. O. K. Tire and Rubber Co.	33.5	-	300,000	Surface (TRM 358.5) Polecat Creek embayment (mile 1.0)
3-I. Monsanto** (Under construction)	27.0	-	-	Surface (TRM 365)
4-I. Widows Creek Steam Plant**	15.6	465	1,573X10 <sup>6</sup>	Surface (TRM 407.6)

\* Radial distance to all supplies except those that take water directly from the Tennessee River which are shown as river mile distance from 392.0.


\*\*Water supply is also used for potable water within the plant.

Table 1.2-17



\*PARTIAL LIST OF AQUATIC MACROPHYTES NEAR THE PROPOSED BELLEFONTENUCLEAR PLANT SITE, GUNTERSVILLE RESERVOIR

<u>Scientific Name</u>	<u>Common Name</u>	<u>Growth Form</u>
<u>Myriophyllum spicatum</u>	Eurasian watermilfoil	Submersed
<u>Ceratophyllum demersum</u>	Coontail	Submersed
<u>Potamogeton crispus</u>	Crispyleaf pondweed	Submersed
<u>Potamogeton nodosus</u>	American pondweed	Submersed
<u>Najas minor</u>	Spinyleaf naiad	Submersed
<u>Najas guadalupensis</u>	Southern naiad	Submersed
<u>Egeria densa</u>	Egeria	Submersed
<u>Elodea canadensis</u>	Elodca	Submersed
<u>Heteranthera dubia</u>	Waterstargrass	Submersed
<u>Chara sp.</u>	Muskgrass	Submersed
<u>Saururus cernuus</u>	Lizardtail	Emergent
<u>Alternanthera philoxeroides</u>	Alligatorweed	Emergent, Floating Mat
<u>Nelumbo lutea</u>	American lotus	Emergent, Floating Mat
<u>Justicia americana</u>	Waterwillow weed	Emergent
<u>Eleocharis quadrangulata</u>	Spikerush	Emergent
<u>Eleocharis acicularis</u>	Midget spikerush	Emergent
<u>Ludwigia palustris</u>	Waterpurslane	Emergent
<u>Scirpus cyperinus</u>	Woolgrass	Emergent
<u>Scirpus validus</u>	Softstem bulrush	Emergent
<u>Scirpus americanus</u>	Three-square	Emergent
<u>Juncus effusus</u>	Common bulrush	Emergent
<u>Hibiscus militaris</u>	Marshmallow	Emergent
<u>Zizaniopsis miliacea</u>	Giant cutgrass	Emergent
<u>Polygonum sagittatum</u>	Tear-thumb	Emergent
<u>Polygonum hydropiperoides</u>	Smartweed	Emergent
<u>Polygonum pennsylvanicum</u>	Smartweed	Emergent
<u>Echinodorus cordifolius</u>	Burhead	Emergent
<u>Carex sp.</u>	Sedge	Emergent
<u>Cyperus psuedovegetus</u>	Sedge	Emergent
<u>Cyperus sp.</u>	Sedge	Emergent
<u>Typha latifolia</u>	Cattail	Emergent
<u>Lemna perpusilla</u>	Duckweed	Floating
<u>Spirodela polyrhiza</u>	Giant duckweed	Floating
<u>Azolla caroliniana</u>	Mosquito fern	Floating

\*The list of aquatic macrophytes was compiled from a boat survey conducted on September 26, 1972, near the proposed Bellefonte Nuclear Plant site. The survey included portions of lower Raccoon, Mud, and Town Creek embayments with additional shoreline inspection from Sublett Ferry (TRM 390) to Raccoon Creek (TRM 396). This listing includes the more common emergent submersed, and floating aquatic macrophytes but does not include a complete floristic listing.




CRUSTAL MOVEMENT MAP SHOWING PROBABLE VERTICAL MOVEMENTS OF THE EARTH'S SURFACE



NOTE:  
 I. Taken from Tectonic Map of United States by U.S. Geological Survey, 1962.


Figure 1.2-1

GEOLOGIC INVESTIGATIONS		
REGIONAL TECTONIC MAP		
BELLFONTE NUCLEAR PLANT TENNESSEE VALLEY AUTHORITY DIVISION OF WATER CONTROL PLANNING		
SUBMITTED	RECOMMENDED	APPROVED
	<i>[Signature]</i>	<i>[Signature]</i>
KNOXVILLE	I-26-7388GE	822BI964



Scale 2500000

Approximately 1 inch to 40 miles



**NOTE:**  
 Taken from GEOLOGIC MAP OF THE UNITED STATES by the United States Geological Survey 1932.

Figure 1.2-2

REV NO.	DATE	MADE	CHKD	SUPV	INSP
1		COMPUTED			
		ENGINEER			

GEOLOGIC INVESTIGATION		
REGIONAL GEOLOGIC MAP		
BELLFONTE NUCLEAR PLANT TENNESSEE VALLEY AUTHORITY DIVISION OF WATER CONTROL PLANNING		
SUBMITTED	RECOMMENDED	APPROVED
	<i>R. W. Allen</i>	<i>J. M. Kelley</i>
KNOXVILLE	1-26-73	88GE 1 822BI963






Figure 1.2-3



**LEGEND:**

- |                            |  |                   |  |                          |  |                            |
|----------------------------|--|-------------------|--|--------------------------|--|----------------------------|
| <b>Pennsylvanian</b>       | <b>Mb</b> — Bangor Limestone             | <b>Silurian</b>   | <b>Sm</b> — Red Mountain Formation—Shale and siltstone with thin Chattanooga Shale at top. | <b>Combro-Ordovician</b> | <b>Och</b> — Knox Dolomite and Limestone | <b>Major thrust fault.</b> |
| <b>Mississippian</b>       | <b>P</b> — Sandstone and Shale           | <b>Ordovician</b> | <b>Och</b> — Chickamauga Formation   |                          |  | <b>Formation contact.</b>  |
| <b>Pennington</b>          | <b>Mfp</b> — Fort Payne Cherty Limestone |                   |  |                          |  |                            |
| <b>Shale and Limestone</b> |  |                   |  |                          |  |                            |


11-22-71	
Check if Section A-A'	
REV NO	DATE MADE
DRWN	SUPV
CHKD	INSP
TRCD	ENGINEER
COMP	

**GEOLOGIC INVESTIGATIONS**

**GEOLOGIC AND TECTONIC MAP OF PLANT AREA**

**BELLEFONTE NUCLEAR PLANT**  
**TENNESSEE VALLEY AUTHORITY**  
 DIVISION OF WATER CONTROL PLANNING

SUBMITTED <i>Harold C. Doolittle</i>	RECOMMENDED <i>R. W. Allen</i>	APPROVED <i>John M. Kelley</i>
KNOXVILLE	7-1-71	W GE I 822N836 RI




**LEGEND:**

- Mfp Fort Payne Limestone
- Srm Red Mountain Formation  
Including Chattanooga Shale  
At Top.
- Och Chickamauga Group
- Ok Knox Group
- — Permanent groundwater station

Figure 1.2-4

**SCALE:**



**NOTES:**

1. Contour interval two feet;  
dashed lines one foot.
2. Top of rock contours are  
not shown.

11-22-72 PCII					
ADD GROUNDWATER STATIONS					
REV NO.	DATE	MADE	CHD	SUPV	INSP
DRWN	COMPUTED				
TRCD	ENGINEER				
CHD					

FOUNDATION INVESTIGATIONS		
GEOLOGIC MAP OF PLANT SITE		
BELLEFONTE NUCLEAR PLANT TENNESSEE VALLEY AUTHORITY DIVISION OF WATER CONTROL PLANNING		
SUBMITTED <i>Forest L. Cox</i>	RECOMMENDED <i>R.W. Allan</i>	APPROVED <i>John M. Kellogg</i>
KNOXVILLE	4-7-72	W GE I 822N1929RI







Figure 1.2-5  
FAULT MAP  
BELLEFONTE SITE




Station located 19 miles NE of Bellefonte Site; Elevation 630 feet MSL; Wind instrument 44 feet above ground.

Figure 1.2-6  
WIND ROSE  
Annual 1971  
WIDOWS CREEK POWER PLANT  
VALLEY METEOROLOGICAL STATION



Lost Record = 1.63



Wind Speed (mph)

Station located 15 miles NE of Bellefonte Site; Elevation 1450 feet MSL; Wind instrument 54 feet above ground.

Figure 1.2-7  
WIND ROSE  
Annual 1971  
WIDOWS CREEK POWER PLANT  
SAND MOUNTAIN METEOROLOGICAL STATION

-LEGEND-	
TYPE OF SAMPLE	FREQUENCY OF COLLECTION
■	BACTERIOLOGICAL 8-DAY INTERVAL, MAY-SEPTEMBER 1963
□	BACTERIOLOGICAL 8-DAY INTERVAL AS ABOVE, PLUS MONTHLY, OCTOBER 1963-APRIL 1964
○	SANITARY-CHEMICAL MONTHLY, MAY 1963-APRIL 1964
△	MINERAL MONTHLY, MAY 1963-APRIL 1964
◇	RADIOLOGICAL MONTHLY, MAY 1963-APRIL 1964






Figure 1.2-8  
 GUNTERSVILLE RESERVOIR  
 WATER QUALITY  
 SAMPLING STATIONS  
 1963-1964



LEGEND  
 - - - (6) - - - DISSOLVED OXYGEN, MG/L  
 - - - 24 - - - TEMPERATURE °C

Figure 1.2-9  
**DISSOLVED OXYGEN  
 AND TEMPERATURE PROFILES  
 GUNTERSVILLE RESERVOIR  
 1963-1964**



LEGEND

- △ -HALES BAR DAM
- -GUNTERSVILLE DAM





Figure 1.2-10  
DISSOLVED OXYGEN AND TEMPERATURE  
AT GUNTERSVILLE AND HALES BAR DAMS



LEGEND

- △-HALES BAR DAM
- GUNTERSVILLE DAM




Figure 1.2-10  
DISSOLVED OXYGEN AND TEMPERATURE  
AT GUNTERSVILLE AND HALES BAR DAMS




Figure 1.2-12  
 POPULATION DISTRIBUTION  
 WITHIN 10 MILES  
 YEAR 1970




Figure 1.2-13  
 POPULATION DISTRIBUTION  
 WITHIN 50 MILES  
 YEAR 1970

1.2-63




Figure 1.2-14  
POPULATION DISTRIBUTION  
WITHIN 10 MILES  
YEAR 2020

1.2-64




Figure 1.2- 15  
POPULATION DISTRIBUTION  
WITHIN 50 MILES  
YEAR 2020

1.3 Electric Power Supply and Demand - TVA is the power supplier for an area of approximately 80,000 square miles containing about six million people. TVA generates, transmits, and sells power to 160 municipalities and rural electric cooperatives which in turn retail power to their own customers. The approximate areas served by these distributors are shown in figure 1.0-1. These distribution systems, which purchase their power requirements from TVA, serve more than 2 million electric customers, including homes, farms, businesses, and most of the region's industries. TVA also supplies power directly to 46 industries which have large or unusual power requirements and to 11 Federal installations, including the Atomic Energy Commission plants at Oak Ridge, Tennessee, and Paducah, Kentucky.

The importance of an adequate supply of power on the TVA system is by no means limited to electric consumers in the area which TVA supplies directly. This system, which with 23.3 million kilowatts of presently installed generating capacity is the Nation's largest, is interconnected at 26 points with neighboring systems with which TVA exchanges power. The TVA system is, in effect, part of a huge power network. In a time of power emergency, operation of the TVA power system could have a definite impact on power supply conditions from the Great Lakes to the Gulf of Mexico, and from New England to Oklahoma and Texas.

During the past 20 years, loads on the TVA power system have increased approximately 7 percent per year. This rate of growth in power requirements has meant that the capacity of the generating and transmission system has been doubled every 10 years. Until the end of World War II,

most of TVA's generating capacity was hydroelectric. By that time, however, most of the suitable hydroelectric sites had been developed, and beginning in 1949 substantially all of the capacity increases were met by the construction of fossil-fueled plants. In the middle 1960's large-scale nuclear plants had become feasible, and TVA began to take steps to add nuclear capacity to its system. TVA has also begun providing pumped-storage and gas turbine capacity to meet system peak loads. Table 1.3-1 shows the TVA system capacity makeup as of December 31, 1973.

The amount of electricity generated in 1965 to meet customer requirements for power exceeded 74.4 billion kilowatt-hours. By 1970, annual electric generation for customer needs had reached 92.7 billion kilowatt-hours. Generating needs are expected to reach 135 billion kilowatt-hours by 1975. TVA presently must add an average of 1,500 megawatts or more of new generating capacity each year to keep up with the rapid increase in electric power usage in this region.

Estimates of future TVA loads are prepared by extending trends of the past while taking into account changes in factors affecting use. Loads are forecast by a number of geographic and class of service categories. Redundant methods are used, where possible, to increase forecast accuracy. Forecasting is preceded by analysis and adjustment of historical data and background preparation including a review of industry conditions, a review of current appliance sales and housing trends, a study of possible new loads, and other factors such as the outlook for the national and regional economy.

Residential uses are forecast by utilizing published forecasts of national household trends and historical trends for regional share of national households and number of customers per household. Average use is forecast by estimating the regional saturation of appliances and annual uses of appliances.

Peak load energy forecasts of large commercial and industrial loads served by municipalities and cooperatives are individually prepared on the basis of factors such as past history, stated plans for operating levels, type of product, and contract demand.

Large industrial and Federal loads which are directly served by TVA are also forecast on an individual basis. Industrial loads are grouped according to industry type, and known expansion and allowance for growth are considered.

1. Power needs - The TVA power system is a winter and summer peaking system with the highest annual peak loads in the TVA service area usually occurring between November and March. Due to seasonal exchange arrangements with other power systems, however, the loads which the TVA generating capacity must actually serve during the remainder of this decade will be greater in the summer than in the preceding winter. The following tabulation indicates TVA's expected power supply outlook during the 1979-82 peak load seasons based on the current capacity installation schedules:

Period	Estimated Peak Demand TVA System-MW	Interchange		Dependable Capacity-MW	Margin	
		Delivered or Received-MW	Load Served by TVA-MW		MW	%
Winter 1979-80	29,300	-2,060	27,240	32,033	4,793	17.6
Summer 1980	25,720	+2,060	27,780	32,204	4,424	15.9
Winter 1980-81	30,900	-2,060	28,840	34,403	5,563	19.3
Summer 1981	27,050	+2,060	29,110	35,774	6,664	22.9
Winter 1981-82	32,650	-2,060	30,590	36,803	6,213	20.3

The above power supply projection is based on a dependable capacity of 1,170 MW for each Bellefonte unit and on assumed commercial operating dates of December 1979 and September 1980.

The power supply situation for the winter peak periods in the interim from January 1980 through January 1982 and the summer 1980 period are expected to be extremely tight, even if the current projected schedules of capacity additions are achieved. These deficiencies are indicated in the following tabulation:

Periods	Margins					
	Desired		Available		Deficiency	
	MW	%	MW	%	MW	
Winter 1979-80	6,876	25.2	4,793	17.6	2,083	
Summer 1980	6,295	22.7	4,424	15.9	1,871	
Winter 1980-81	7,306	25.3	5,563	19.3	1,743	
Winter 1981-82	7,758	25.4	6,213	20.3	1,545	

TVA's desired reserve margins are determined by utilization of the loss of load probability method which has been adapted to the characteristics of the TVA system. TVA's planning criteria requires maintaining a desired reserve margin within a reliability risk level of one day in ten years and any reduction below these margins greatly increases the risk to serve firm load.

2. Consequences of delays - Any delay in operation of the Bellefonte units could result in the inability of the TVA system to adequately meet its obligations during the 1979-80 and 1980-81 winter peak periods and the 1980 summer peak period with the now-scheduled generating capacity. The total consequences of such delays of the Bellefonte Nuclear Plant would be determined by the extent of these delays and the date when such delays were identified.

The following tabulation indicates the amounts by which reserves on the TVA system will be inadequate during various peak load seasons between 1979 and 1981, postulating a delay of 6 months for each of the Bellefonte units from their current schedule. (A delay of unit 1 results in an equal delay in unit 2.)

The deficiencies shown are based on the assumption that the winter peak occurs in January and the summer peak occurs in August since these are the months having the higher probability of the peaks occurring. The winter peak has occurred as early as November and the summer peak as early as June.

TVA System Megawatt Reserve  
Deficiencies from Desired Margins  
Due to Unit Delays of 6 Months

Winter 1979-80	3,296
Summer 1980	1,871 <sup>a</sup>
Winter 1980-81	2,878

- a. Any Bellefonte unit delays would result in a serious deficiency of margins available for scheduled maintenance for all TVA generating units during the period of delay.

The following tabulation indicates the expected reserve deficiencies on the TVA system during various peak load seasons between 1979 and 1981, postulating a delay of 12 months for each of the Bellefonte units from their current schedule.

TVA System Megawatt Deficiencies  
from Desired Margins Due to  
Unit Delays of 12 Months

Winter 1979-80	3,206
Summer 1980	3,000
Winter 1980-81	2,878
Summer 1981	1,122

With the 12-month delay in Bellefonte units and the resulting deficiencies identified above, TVA would be unable to maintain a reliable supply of bulk power to serve firm load during the 1979-81 period. The magnitudes of the deficiencies for this period are more than could be covered by assistance from neighboring utilities, particularly the summer 1980 peak period since neighboring utilities are summer peaking systems.

In addition to jeopardizing the ability to serve firm load which would be caused by the 12-month delay of both units, a serious deficiency of margin available for scheduled maintenance for all of TVA's generating units would result for the entire period.

Deficiencies of the magnitude caused by delays of the Bellefonte units must be replaced either by installing alternative capacity on the TVA system or importing power from other utility systems; otherwise, the reliability of power supply to TVA's customers will be drastically reduced. By the time delays in the Bellefonte nuclear units would be confirmed, it is unlikely that additional capacity other than short lead time generating capacity could be installed to meet these deficiencies. Power in the magnitude being considered is not expected to be available from other utilities when it is needed on the TVA system.

The economic costs of any Bellefonte delays (which must ultimately be borne by the consumer) would consist of two parts: (1) cost of replacement capacity, and (2) increased production expense during the delay period because of unavailability of low-cost nuclear energy.

The estimated investment cost of 1,000 MW of replacement capacity which could be installed for the 1979-80 period is approximately \$130 million (based on 1972 dollars). Annual fixed charges of about \$13 million on such an investment must be borne by consumers in the form of higher rates until the effect of these additions can be absorbed in later years by system growth. The value of these fixed charges (assuming an 8 percent discount rate and a discount period of 4 years) would be about \$43 million.

Fuel, operating, and maintenance expense for the Bellefonte nuclear units is estimated to cost about 2.6 to 2.8 mills per kWh during the 1979-80 period, while replacement energy which would be used in lieu of this nuclear energy in the event of delays would cost from 5.0 to 7.0 mills per kWh for coal and 28 to 32 mills per kWh for oil. Studies of the effects of Bellefonte unit delays indicate that each month's delay on these units would result in increased production expenses on the TVA system of approximately \$5.6 million.

In addition to these economic costs, each month's delay on the two Bellefonte nuclear units could require that approximately 545,000 tons of additional coal and 7.3 million gallons of oil be burned in plants on the TVA system or other systems to replace the

lost nuclear energy. This could have an adverse environmental impact in terms of increased emissions of particulates, sulfur dioxide, and other materials to the atmosphere.

In summary, delays of the Bellefonte Nuclear Plant will have a twofold effect on the TVA power system:

1. Costs to TVA's customers would be increased by at least \$5.6 million for each month of delay, assuming the delay did not require the installation of combustion turbines or combined-cycle units. If additional generating capacity were required to offset deficiencies due to Bellefonte delays, costs to TVA's consumers over and above those shown above could be increased by \$43 million. These costs could total about \$86 million for a 12-month delay.
2. Increased operation of TVA's older, less efficient fossil-fired units would be required during the period of further Bellefonte delays. Such operation would result in the increased emission of particulates, sulfur dioxide, and other materials into the atmosphere.

The analysis shown on page 1.3-4 shows that TVA cannot carry out its statutory obligation of providing an ample supply of electricity for the TVA region without the Bellefonte Nuclear Plant. Even with the Bellefonte plant the reliability risk level will be below that which TVA considers desirable. Without the plant, the reliability risk level would be increased to a loss of load probability of over 2 days per year, which is clearly unacceptable.

Table 1.3-1

TVA SYSTEM CAPACITY  
(as of December 31, 1973)

Plant	Number of Units	Nameplate Capacity-kW	
		Units	Total
<u>TVA Thermal</u>			
Thomas H. Allen <sup>a</sup>	3		990,000
Thomas H. Allen (Gas Turbines)	20	16 @	620,800
		4 @	
			59,600
Bull Run	1		950,000
Colbert	5	2 @	1,396,500
		2 @	
		1 @	223,250
			550,000
Colbert (Gas Turbines)	8		476,000
Cumberland	2		1,300,000
Gallatin	4	2 @	1,255,200
		2 @	
			327,600
John Sevier	4	2 @	846,500
		2 @	
			200,000
Johnsonville	10	4 @	1,485,200
		2 @	
		4 @	147,000
			172,800
Kingston	9	4 @	1,700,000
		5 @	
			200,000
Paradise	3	2 @	2,558,200
		1 @	
			1,150,200
Shawnee	10		1,750,000
Watts Bar	4		240,000
Widows Creek	8	5 @	1,977,985
		1 @	
		1 @	149,850
		1 @	575,010
		1 @	550,000
<u>TVA Hydro</u>			
Appalachia	2		78,900
Blue Ridge	1		20,000
Boone	3		75,000
Chatuge	1		10,000
Cherokee	4		120,000
Chickamauga	4		108,000
Douglas	4		115,000
Fontana	3		225,000
Fort Loudoun	4		135,590
Fort Patrick Henry	2		36,000
Great Falls	2		31,860
Guntersville	4		97,200

a. Leased January 1, 1965, from Memphis Tennessee, Light, Gas and Water Division

Table 1.3-1  
(continued)TVA SYSTEM CAPACITY  
(as of December 31, 1973)

<u>Plant</u>	<u>Number of Units</u>	<u>Nameplate Capacity-kW</u>	
		<u>Units</u>	<u>Total</u>
<u>TVA Hydro (cont.)</u>			
Hiwassee	2		117,100
Kentucky	5		175,000
Melton Hill	2		72,000
Nickajack	4		97,200
Norris	2		100,800
Nottely	1		15,000
Ocoee #1	5		18,000
Ocoee #2	2		21,000
Ocoee #3	1		27,000
Pickwick	6		220,040
South Holston	1		35,000
Tims Ford	1		45,000
Watauga	2		50,000
Watts Bar	5		150,000
Wheeler	11		356,400
Wilbur	4		10,700
Wilson	21		629,840
<u>Alcoa Hydro*</u>			
Bear Creek	1		9,000
Calderwood	3		121,500
Cedar Cliff	1		6,375
Cheoah	5		110,000
Chilhowee	3		50,000
Nantahala	1		43,200
Santeetlah	2		45,000
Tennessee Creek	1		10,800
Thorpe	1		21,600
<u>Corps of Engineers Hydro</u>			
Barkley	4		130,000
Center Hill	3		135,000
Cheatham	3		36,000
Dale Hollow	3		54,000
Old Hickory	4		100,000
J. Percy Priest	1		28,000
Wolf Creek	6		270,000
Cordell Hull	2		66,666

\*Minor Alcoa Plants

6,240

1.4 Environmental Approvals and Consultations - In addition to its own standards, TVA as a Federal agency is subject to comprehensive and broad-scale environmental procedures and Federal and state consultation and coordination requirements of the National Environmental Policy Act of 1969, 42 U.S.C. §§ 4321-4347 (1970) (as implemented by Executive Order 11514 (35 Fed. Reg. 4247)). In addition, TVA is subject to Executive Order 11752 (38 Fed. Reg. 34793), and Office of Management and Budget Circulars A-78 and A-81, relating to the prevention, control, and abatement of air and water pollution in Federal facilities, as well as certain provisions of the Clean Air Act, as amended, 42 U.S.C. §§ 1857-1857k (1970; Supp. 1971), and the Federal Water Pollution Control Act Amendments of 1972, 33 U.S.C. §§ 1251-1376 (Supp. II, 1972) which relate to the applicability of various Federal, state, interstate, or local air and water quality standards. In addition, TVA is subject to the requirements of Office of Management and Budget Circular A-95, (38 Fed. Reg. 32874) which ensure that major generating and transmission projects are coordinated from the point of view of community impact and land use planning with state and local agencies.

TVA has been consulting with state and regional organizations since January 1971 about the possibility of a nuclear plant at the Bellefonte site and its implications on the development of the area.

On January 19, 1971, TVA's Regional Planning Staff met with the Top of Alabama Regional Council of Governments (TARCOG) staff to discuss the sites in north Alabama which might be the location for a nuclear plant. TARCOG is the regional clearinghouse agency. The historical significance of Bellefonte was first brought up at this meeting.

A short time later on January 22, 1971, the Regional Planning Staff met with key officials in the Alabama Development Office (ADO) which is the state clearinghouse agency. The meeting covered TVA's studies of all potential nuclear plant sites in Alabama, which included Bellefonte. The ADO officials were the Director and the State Clearinghouse Officer.

On March 8, 1971, Regional Planning Staff, Alabama Historical Commission, and TARCOG staffs made a field investigation to locate significant historic structures and sites. Location of a stagecoach inn and evidence of the courthouse cistern were determined.

The Regional Planning Staff reviewed TVA's plans with the Alabama State Historical Commission staff in light of the historical aspects of land adjacent to the site. This meeting was held on May 17, 1971, and culminated in a number of suggestions by the Commission's staff as to how the historical site might be improved by TVA.

The Regional Planning Staff met with TARCOG on May 18, 1971, to discuss the relationship of the proposed plant to regional and local development objectives. In addition to general support for the proposal, TARCOG staff made some specific suggestions as to how the necessary rail and highway access to the plant site might be constructed to enhance the development potential of other nearby sites.

On May 21, 1971, the State Clearinghouse Office was apprised of TVA's meetings with the Historical Commission and TARCOG and was requested to provide any comments it felt appropriate at that time.

The Regional Planning Staff was notified by the Alabama Historical Commission on August 6, 1971, that Bellefonte would be

nominated to the National Register of Historic Places. The Commission also made specific recommendations as to how TVA might participate in preservation of the site. Shortly thereafter, TARCOG notified TVA that they concurred with the Historical Commission's recommendations.

TVA has consulted with the Alabama Historical Commission about investigating the historical significance of the Bellefonte town-site. Further consultations will determine the appropriate state agencies that should contract to carry out the investigation.

The acceptability of using a lake as a cooling facility was explored with the Alabama Water Improvement Commission. On October 18, 1972, the Acting Chief Administrative Officer, AWIC, notified TVA that the Commission had previously approved a cooling pond for another power generating facility located in Alabama and that AWIC would not be opposed to evaluating such a system for the Bellefonte site should studies show the cooling pond to be the most feasible cooling alternative.

The Birmingham National Weather Service, Birmingham, Alabama, was consulted in gathering climatological information to discuss severe weather conditions in the Bellefonte area.

The Environmental Data Service state climatologists in Montgomery, Alabama, were consulted for information on frequency and severity of tornadoes in the Bellefonte area.

At the request of Scottsboro's Mayor, TVA met with him on October 3, 1973, to discuss the relationship between the proposed plant and future development in the area between Scottsboro, Hollywood, the site, and Gunter'sville Reservoir. An outgrowth of that meeting has been the initiation of studies to evaluate potential development in that area. During this process, several followup meetings have taken place.

Since TVA published the Bellefonte Draft Environmental Statement in March 1973, there have been several meetings with the AEC and Argonne National Laboratory staffs as part of AEC's environmental review and assessment of the Bellefonte project.

1.5        Emergency Planning - TVA has developed a Radiological Emergency Plan (REP) which sets forth the policies, purposes, delegations, standards, guidelines, and, where feasible, specific instructions necessary for TVA to discharge its responsibilities during a radiological emergency in order to comply with pertinent directives applicable to the protection of the health and safety of the public and TVA personnel, plants, and properties.

The REP consists of the basic document and annexes. The basic document contains program delegations and broad guides, which apply generally to all TVA nuclear operations. Annexes to the basic document will include detailed radiological emergency plans for each TVA nuclear plant. In addition, the annexes will contain a Radiological Emergency Medical Assistance Plan for dealing with employees who might be injured during an accident. A site radiological emergency plan annex will be prepared for the Bellefonte Nuclear Plant.

TVA is coordinating all aspects of the REP with the appropriate state agencies, such as the Departments of Public Health and Public Safety. The TVA Radiological Emergency Plan defines the details of authority and responsibility of all offsite agencies involved in an emergency situation. Responsibilities such as evacuation, housing, and feeding evacuees are defined so that the responsible agencies may take the initiative in expeditiously executing their phases of the plan. The standards and procedures used are consistent with regulatory programs of state and other Federal agencies. To ensure that their latest recommendations are considered, TVA maintains liaison with these agencies.

In developing the Radiological Emergency Plan, meetings have been held with the State Health Departments of Alabama, Georgia, South Carolina, and Tennessee to ensure workability of the plan and delegation of responsibility, authority, and emergency assignments. In addition, the State Health Department of Kentucky has been contacted and arrangements made for participation in the event of a transportation accident involving radioactive materials.

Each state through which radioactive material from a TVA plant is to be transported either has or will have a radiological assistance plan for use in the event of a transportation accident within its jurisdiction. These plans have been or will be obtained and incorporated in the REP as they are available. The plans will be completed prior to shipment of radioactive material from the factory.

Contacts have also been made with the appropriate Atomic Energy Commission Operations Offices to ensure that assistance can be obtained through the Interagency Radiological Assistance Plan, if necessary.

The Eastern Environmental Radiation Laboratory, EPA, has agreed to provide additional analytical laboratory services in the event of an accident if these services are not available within TVA.

Written agreement among participating state and Federal agencies and TVA will be obtained outlining each agency's responsibilities. The individual states' health department radiological assistance plans will be incorporated in the annexes to the TVA Radiological Emergency Plan.

1. Meetings with outside agencies - Representatives of TVA will meet with appropriate representatives of the following states to discuss the plans for radiological emergencies which might result as a consequence of the operation of the Bellefonte Nuclear Plant: Alabama, Georgia, South Carolina, Tennessee, Kentucky, and Illinois. Other agencies, such as the Environmental Protection Agency and Atomic Energy Commission, will also be contacted where necessary.

2. Responsible agencies to be notified in case of accident - Appropriate TVA personnel receiving notice of a transportation accident shall notify the TVA load dispatcher who notifies the Central Emergency Control Center director who shall notify as appropriate key persons in the states involved, as well as EPA and AEC.

## 2.0 ENVIRONMENTAL IMPACT OF THE PROPOSED FACILITY

The Bellefonte Nuclear Plant will interact with the environment as a result of its construction, connection with TVA's power transmission system, and subsequent operation. Construction will result in a physical alteration of a portion of the site area and will result in some erosion, noise, dust, and smoke during various phases of construction. Connection of the plant to TVA's power transmission system will result in easement restrictions on new transmission line rights of way and minor construction effects. Operation of the plant will result in minor releases of heated water, chemicals, and radioactive liquids and gases. These interactions and resulting impacts have been evaluated considering the environment in the area as described in Section 1.2. Environment in the Area.

Since many of the details of the environmental monitoring programs are closely related to the final plant design, the monitoring program described in Appendix L of this statement is tentative. As details of the final plant design are completed, the environmental monitoring program will be reevaluated and modified as needed to ensure an adequate environmental monitoring program. When this is completed, the resulting proposed monitoring program will then be reviewed and coordinated with the appropriate Federal, state, and local agencies as required by Executive Order 11514.

The interactions and impacts discussed in the following sections have been examined for their potential effects on land, water, and air uses, including industrial operations, transportation, farming, forestry, recreation, wildlife preserves, waterways, government reservations, and

water supplies. No adverse impacts on these uses other than those identified in the following sections are anticipated, and no other loss of use of land, water, and air is expected to occur.

2.1 Transportation of Nuclear Fuel and Radioactive Wastes - While specific details of TVA's transportation plans for shipment of radioactive materials for the Bellefonte Nuclear Plant are not available at this stage, the following discussion is appropriate to the environmental review.

About 100 tons of nuclear fuel will be shipped annually to and from the plant, and packaged radioactive waste totaling about 120 tons will be shipped annually from the plant to AEC-licensed disposal areas. These two types of radioactive materials will be shipped in accordance with applicable Federal and state regulations. Packaging and transport of radioactive materials are regulated at the Federal level by both the Atomic Energy Commission (AEC) and the Department of Transportation (DOT). In addition, certain aspects, such as limitations on gross weight of trucks, are regulated by the states.

The protection of the public from radiation during the shipment of nuclear fuel and radioactive waste depends on the limitations on the contents, the package design, the external radiation levels as well as the method, routing, and safeguards to be followed in transport. These factors are discussed below in regard to the shipment of new fuel, spent fuel, and radioactive wastes.

1. New fuel shipment - Fuel elements for the plant require an annual commitment of about 200 tons of natural uranium in the form of  $U_3O_8$  for each reactor. However, some of this uranium may come from reprocessed spent fuel.

New fuel for the plant is made of slightly enriched uranium dioxide pellets which have been sintered and compacted to form very dense pellets having high strength and high melting points. The

pellets are approximately .3 inch in diameter by .75 inch long and are stacked inside zircaloy tubing with space left at the end of the tubing to provide for collection of gas generated during the fission process. These tubes are welded shut at both ends, forming a fuel rod, and are subjected to rigorous quality control to ensure their integrity. These rods are included in a 17 rod by 17 rod array to form a fuel assembly. A more detailed description of the fuel assemblies is in the safety analysis report which has been filed in support of the construction permit application.

TVA will apply for a special nuclear material license to provide for receipt, possession, and storage of fuel elements before the initial core of the reactor is shipped to the plant. In addition, all fuel assemblies will be delivered to the TVA plant site in accordance with shipping procedures and arrangements authorized for use by the fuel fabricator under special nuclear material license in accordance with AEC regulations.<sup>1</sup> Fuel will be shipped in shipping containers which will have been demonstrated to provide safety from criticality under both normal and accident conditions.

(1) Method and frequency of shipment -

The Babcock & Wilcox Company (B&W) is the fabricator of the initial core fuel assemblies and is responsible for shipment of these fuel assemblies to the reactor site. B&W presently has a fuel fabrication plant at Lynchburg, Virginia. This fuel will most likely be shipped by truck trailers in quantities up to six shipping containers per load, each containing two fuel assemblies, thereby providing a maximum of twelve fuel assemblies per truck shipment. About twelve such shipments by truck will

be received at the plant annually (about 18 shipments in the initial core for each unit).

(a) Shipping routes - It is assumed that B&W will ship the initial core fuel assemblies by truck from its fabrication plant in Lynchburg, Virginia, to the plant. The major population centers encountered over an assumed 375-mile route include the following:

<u>City</u>	<u>1970 Population</u>	<u>Density Persons/mile<sup>2</sup></u>
1. Lynchburg, VA--by way of U.S. 460 to	54,083	2,153
2. Roanoke, VA--by way of U.S. 220, I-81, and I-40 to	92,115	3,412
3. Knoxville, TN--by way of I-75 to	174,587	2,267
4. Chattanooga, TN--by way of I-24 and U.S. 72 to	119,082	2,267
5. Bellefonte Plant Site		

(b) Shipment activity - Relatively low levels of radiation are emitted from unirradiated new fuel assemblies. Because the type of radiation emitted by uranium is reduced by even thin layers of metal and the self-shielding properties of the fuel reduce the cumulative effect, no additional gamma or beta shielding is required in shipping packages for new fuel. The following properties of the fabricated new fuel limit the radiological impact on the environment to negligible levels:

- . No radioactive fission products.
- . No radioactive gases.
- . High melting point.

- . Insoluble solid.
- . Zircaloy clad.
- . Fuel assemblies will not disruptively react or decompose under expected or postulated thermal conditions.

(2) Environmental effects - The population exposure resulting from the normal shipments of new fuel has been evaluated for the people who reside on either side of the transport route. The radiation dose as a function of distance from a shipping container drops off quite rapidly. Because the container will be stationary for only brief intervals and because of the low activity level of new fuel, the total exposure to an individual living along the transport route will be an insignificant fraction of the exposure from natural background radiation.

(a) Normal shipments - Because of the estimated low dose rates due to new fuel at the time of shipment ( $<0.1$  mrem/h at 6 feet from the container), the only exposure from routine shipments of new fuel is to persons along the transport route during the brief period such a shipment is in direct view and to the individual truck drivers driving the trucks. For example, a member of the general public who spends 3 minutes at an average distance of 6 feet from the container would receive a dose not exceeding 0.005 mrem. If 10 persons were so exposed per shipment, the total annual dose for the 12 shipments of new fuel would be about 0.0006 man-rem.

Based on an estimated radiation level in the cab of the truck of  $<0.1$  mrem/h, exposure to transportation personnel is estimated to be less than 1 mrem per shipment. A total dose to all drivers for a given year, assuming two drivers per vehicle, would not exceed 0.02 man-rem.

It is concluded that there are no environmental risks from radiation associated with the normal shipment of new fuel.

(b) Accident occurrences - The problems which might result from a transportation accident equivalent to that specified in 10 CFR Part 71 would consist of the physical damage of the impact and the interference associated with having to send the fuel back to the fabricator for inspection. A subsequent determination would then be made to determine whether there had been damage which would affect the operation of the fuel in the reactor. There would be no release of radioactive materials and no increase in radiation dose rates over those from normal shipment. Thus, it is concluded that there would be no significant environmental risks from radiation resulting from an accident involving a shipment of new fuel.

2. Spent fuel shipment - Spent fuel removed from the two reactors during the annual refuelings is expected to contain on a weight basis in excess of 99 percent of the fission products formed inside the fuel. The water in the pool serves as both a radiation shield and coolant while the short-lived fission products decay. At the end of a storage period of about 3 to 4 months, the spent fuel is loaded into ruggedly built shielded containers for shipment to a fuel

reprocessing plant. There the spent fuel is chemically reprocessed to recover its unused fuel content, uranium and plutonium, for future use. It is possible to ship spent fuel by rail, truck, or barge.

(1) Method and frequency of shipment -

All the equipment and services for spent fuel transportation and reprocessing are to be provided to TVA by contract. This includes transport vehicles, special shielded containers, services associated with container loading, and all transport arrangements. Even though TVA contracts these services, it will specify the scope, terms, scheduling, transportation, and reporting of shipments as appropriate and in accordance with AEC and the Department of Transportation regulations. Presently, there are fuel reprocessing plants in operation or under construction in Morris, Illinois; West Valley, New York; and Barnwell, South Carolina.

There are several possible shipping methods for irradiated fuel. These range from truck shipments with cask capacities from 0.4 to 1.2 metric tons of uranium to rail shipments with cask capacities from 3.2 to 5.0 metric tons of uranium at a time. Water transportation of spent fuel with about 5 metric tons of uranium could also be used.

Truck shipment of spent fuel from Bellefonte would require about 140 legal-weight shipments (73,280 pounds) over a period of about 4 to 6 months each year or about 70 shipments if a 90,000-pound truck load limit is permitted.

Rail shipments originating from the plant would require about 10 to 14 shipments annually. The shipments would be in a special rail cask holding from about 10 to 15 fuel assemblies. If necessary, fuel assemblies which have identified clad perforations will

be sealed in special containers before being loaded into the spent fuel cask.

Since it will not be necessary to ship spent fuel from Bellefonte to a reprocessing plant until approximately 1980, TVA has not entered at this time into a contract for shipment of spent fuel from this plant. Even though the exact mode of transportation and other details related to spent fuel shipments have not yet been defined, rail shipments have been assumed for purposes of routing and estimating the environmental effects.

(a) Shipping routes - It is assumed that the spent fuel from Bellefonte would be shipped about 425 miles by rail to the closest fuel reprocessing plant which is at Barnwell, South Carolina. The major population centers encountered along the assumed route are:

<u>City</u>	<u>1970 Population</u>	<u>Density Persons/mile<sup>2</sup></u>
1. Bellefonte Site--by way of Southern to	--	--
2. Chattanooga, TN--by way of Southern to	119,082	2,267
3. Atlanta, GA--by way of Seaboard Coast to	496,973	3,779
4. Barnwell, SC (AGNS site)	4,439	562

(b) Shipment activity - Fuel elements which are removed from the reactor will be essentially unchanged in outward appearance. However, in addition to a portion of the original useful uranium fuel, these fuel elements will contain some reactor-generated plutonium and an accumulation of fission products. This

irradiated spent fuel is subsequently shipped to a reprocessing plant for recovery of its unused fuel content (fissionable uranium and plutonium).

The estimated inventory of fission product activity and decay heat of the Bellefonte spent fuel at the time of shipment is given in Table 2.1-1. It should be noted that effectively all of this contained radioactivity is tightly bound within the insoluble, high-melting-point uranium dioxide pellets. Therefore, even if the shipping cask should be breached in an accident and the fuel cladding should be ruptured, there is still no ready mechanism for dispersing any substantial fraction of the total contained radioactivity.

(2) Environmental effects - Prior to shipment, the fuel will be allowed to radioactively decay for about 3 to 4 months. Then all noble gases with the exception of krypton-85 will have decayed to insignificant levels and iodine-131 will have decayed to low levels. Further, the rate of decay heat generation by the spent fuel will have decreased. Of the iodine isotopes, only iodine-131 is present in significant amounts. Fission products other than a portion of the noble gases and iodine are strongly held within the uranium dioxide fuel pellets. Hence, only noble gases and iodine which have escaped from the fuel could escape through a penetration in fuel clad to the shipping cask cavity.

(a) Normal shipment - The principal normal environmental effect from spent fuel shipments would be the direct radiation dose from the fuel as it moves from the reactor to the reprocessing plant. The population exposure resulting from normal shipments of radioactive materials has been evaluated based on

the assumption that there would be about 42,500 people living in the area within 1/2 mile of both sides of the transport route along the estimated 425-mile route. It has also been assumed that the shipments are made at the maximum permitted level of 10 mrem/h at 6 feet from the nearest accessible surface.<sup>2</sup> Figures D-1 and D-2 of Appendix D show the location of the shipping container relative to people living adjacent to the transport route and the rapid decrease in radiation exposures as a function of distance from the shipping container. The calculation does not include reductions of exposures due to shielding from structures, topographic features, or other radiation-attenuating materials.

Assuming a maximum of 14 shipments per year, each moving at only 20 mi/h, the maximum exposure received by any individual residing 100 feet from the center of the transport route would be about 0.004 mrem per year. The average exposure for these 14 shipments to an individual living along the transport route would be about 0.0002 mrem per year. On the basis that there would be a total of about 42,500 people living within 1/2 mile on either side of the transport route between the fuel reprocessing plant at Barnwell, South Carolina, these people would receive an annual dose of about 0.009 man-rem per year. Train brakemen or a member of the general public might spend a few minutes in the vicinity of the car, at an average distance of 6 feet, for an average exposure of about 0.5 mrem per shipment. With 10 different brakemen and 10 members of the general public so involved along the route, the total dose for 14 shipments during the year is estimated to be about 0.14 man-rem.

Since the exposure to the people who reside along the route and to each person who might come within 6 feet of the railcar for a short period is only 0.0002 and 0.4 percent respectively of the exposure these same people receive from natural background radiation, it is concluded that no adverse environmental effects will result from the normal transportation of spent fuel from Bellefonte to the fuel reprocessing plant.

(b) Accident occurrences - The principal potential environmental effects from an accident are those from direct radiation resulting from increased radiation levels, from gaseous release of noble gases and iodine, and from release of contaminated coolant.

Evaluation of exposure from direct radiation assumes that the radiation exposure rate is the maximum permitted by regulations, 1,000 mrem/h at 3 feet from the surface of the container, and that people have surrounded the container beginning at about 50 feet from the container.<sup>3</sup> Figure D-3 of Appendix D shows the exposure rate for accident conditions as a function of distance from the container. The exposure rate at 50 feet would be about 17 mrem/h. Assuming a tightly packed crowd, there would be 154 people in the front row, and as shown on figure D-4, these people would provide shielding such that people in subsequent rows would receive greatly reduced radiation exposure. If a person remained in the front row for 2 hours, his exposure would be about 34 mrem. Further, the increased radiation level would most likely be from only a localized area on the container, and thus only a small number of people in even the front row of a crowd would be exposed to these radiation levels.

Calculations for a probable shipping container indicate that there would be no gaseous releases unless there were a substantial quantity of decay heat in the shipping container and some additional external heat such as from a fire. Thus, it is assumed that the heated air currents surrounding the container would carry any released fission gases to a height of 10 meters before they are dispersed in the environment. Assuming a person stands in the plume during the entire accident, the resulting whole-body exposure would be 2 mrem, the skin dose would be about 86 mrem, and the thyroid dose would be about 5 rem. For the noble gas release, assuming an average population density of 100 people per square mile, the total whole-body population dose from the accident would be 0.07 man-rem. TVA considers the average population to be a realistic number for analyzing transportation accidents because of the small fraction of the total distance travelled in high population density areas and because accidents in such areas generally occur at lower speeds and thus could be expected to be less severe.

The contaminated coolant in the shipping container is basically low specific activity material. In the event the coolant were drained from the container in an accident, emergency plans for containing the contaminated liquid and preventing a radiation hazard to the public and the environment will be initiated.

The principal environmental risk resulting from an accident would be the potential whole-body radiation exposure due to direct radiation and the noble gases released and potential thyroid dose due to the iodines released. Because of the

dose reduction with distance and the mitigating effect of proposed emergency actions, it can be concluded that the whole-body radiation exposure to the public will be negligible. Because of the unlikely combination of circumstances which must be present to result in a significant dose due to the release of iodine, the probability of significant doses due to this occurrence is considered extremely small.

3. Radioactive waste shipment - The radioactive wastes to be shipped for disposal will be concentrates from the waste evaporator, spent demineralizer resins, miscellaneous dry solid wastes, irradiated or contaminated equipment components, and tritiated water.

The radwaste packaging facility at Bellefonte will be equipped to use standard DOT17H<sup>4</sup> drums. The waste evaporator bottoms and spent demineralizer resins will be solidified before shipment to a disposal site regulated by AEC and the state.

(1) Method and frequency of shipment - Waste evaporator concentrates and spent demineralizer resins are collected in the plant and may be stored for decay of short-lived isotopes. After up to 120 days' decay, the only significant radioactive isotopes present will be long-lived corrosion products such as cobalt-60.

Based on the estimated quantities and activities, there will be about 16 shipments of waste evaporator concentrates and 8 shipments of spent demineralizer resins each year. Waste evaporator concentrates are drummed and placed in an approved container for shipment to an AEC-licensed disposal area. The resins may be shipped in specially constructed lead-steel containers similar to the LL-60-150 cask planned to be used for shipping the higher activity

radioactive material from the Browns Ferry Nuclear Plant. The casks will be decontaminated if necessary at the disposal area and returned to the plant.

Appropriately packaged compressible wastes will generally be shipped to the disposal area on flatbed trucks. There will be approximately one shipment per year of such compressible wastes.

Radioactive equipment components will generally have low volumes. No shipments are expected during the first years of operation. Radioactive components will be stored in the spent fuel pit until sufficient quantities are available for a shipment.

Tritiated water may be shipped offsite as low specific activity waste. If shipped as a liquid, about 50,000 gallons of tritiated water must be shipped annually once disposal of tritiated water becomes necessary. If the tritiated water is mixed with cement and shipped as a solid, the total volume to be shipped would be about 10,720 cubic feet. Liquid shipment would require about 13 tank truck loads each containing approximately 35 Ci of tritium. Exact packaging methods for solidified tritium shipment are very tentative at present but it is estimated that shipment of solidified material would require about 60 shipments per year each containing 8 Ci or less.

(a) Shipping routes - It is assumed that radwaste shipments from Bellefonte would be by truck about 400 miles to the closest AEC-approved disposal area at Morehead, Kentucky. The major population centers encountered over the assumed route are:

<u>City</u>	<u>1970 Population</u>	<u>Density Persons/mile<sup>2</sup></u>
1. Bellefonte site--by way of U.S. 72 and I-24 to	--	--
2. Chattanooga, TN--by way of I-75 to	119,082	2,267
3. Knoxville, TN--by way of I-75 to	174,587	2,267
4. Lexington, KY--by way of I-64 to	108,137	4,702
5. Morehead, KY	7,191	4,494

(b) Shipment activity - The

estimated activity and quantities of the radioactive wastes to be shipped from Bellefonte are summarized as follows:

<u>Type Waste</u>	<u>Annual Amount</u>	<u>Expected Activity @ Shipment</u>
1. Waste evaporator concentrates	1,750 ft <sup>3</sup>	0.03 Ci/ft <sup>3</sup>
2. Spent demineralizer resins	710 ft <sup>3</sup>	0.5 Ci/ft <sup>3</sup>
3. Miscellaneous dry solids	900 ft <sup>3</sup>	0.01 Ci/ft <sup>3</sup>
4. Radioactive equipment components	*	--
5. Tritiated water**		
Liquid shipment mode	50,000 gal.	2.5 µCi/cc
Solid shipment mode	10,720 ft <sup>3</sup>	1.5 µCi/cc

\*Low volume, no shipments during early years of operation.

\*\*No shipments assumed for first 7 years' operation. In the event tritiated water shipment is selected as the method of disposal, one of the two indicated modes will be used.

(2) Environmental effects - The environ-

mental effects for these radioactive wastes for normal shipments and during accident occurrences are evaluated for the potential exposure to transport workers and the general public. It is assumed for purposes of calculating the environmental effects that radioactive wastes are shipped by truck at the regulatory radiation level limit of 10 mrem/h

at 6 feet from the nearest surface.<sup>2</sup> It is also assumed that the exposure rate to transportation personnel is not greater than the regulatory level limit of 2 mrem/h in occupied positions of vehicles.<sup>2</sup>

(a) Normal shipment - The estimated 25 shipments of solid waste containers between the reactor site and a disposal location will be done periodically. Regulations pertaining to such shipments, packaging, and shipping safeguards will be adhered to in all cases.

Under normal conditions, the truck driver might receive as much as 15 mrem per shipment. A total dose to all drivers for a given year, assuming two drivers per vehicle, would not exceed 0.75 man-rem.

Because of the low dose rates permitted at the time of shipment (10 mrem/h at 6 feet from the nearest surface), the only exposure to people from routine shipments is for the brief period such a shipment is in direct view. For example, a member of the general public who spends 3 minutes at an average distance of 6 feet from the vehicle would receive a dose not exceeding 0.5 mrem. If 10 persons were so exposed per shipment, the total annual dose for the 25 shipments of solid radioactive waste would be about 0.125 man-rem.

Figure D-1 of Appendix D shows the location of the shipping container relative to people living adjacent to the transport route that was used to calculate radiation exposures. The radiation dose as a function of distance from a stationary shipping container is shown in figure D-2 of the same appendix. On the basis that there would be a total of about 40,000 people living along the assumed

400-mile transport route between Bellefonte and the waste burial facility at Morehead, Kentucky, these people would receive an annual dose of about 0.016 man-rem per year. A summary of these effects is given in Table 2.1-2.

The shipments of compressible wastes would not contribute significant radiation exposure to the public. The low energy radiation from tritium will be shielded by the shipping vessel (tank truck) and will not be a source of radiation exposure during transport.

Since the exposures to the people who reside along the route, to each truck driver per shipment, and to each person who might come within 6 feet of the vehicle for a short period are only 0.0003, 11, and 0.4 percent, respectively, of the exposure these same people receive from natural background radiation and since compressible waste and tritiated water shipments contribute no radiation exposure, it is concluded that no adverse environmental effects will result from the transportation of radioactive waste from Bellefonte to the disposal facilities.

(b) Accident occurrences -

Although transportation accidents involving radioactive material from the Bellefonte plant may be expected to occur about once every 22 years based on the national truck accident statistics for 1969,<sup>5</sup> it is highly unlikely that a shipment of new fuel or solid radioactive waste will be involved in a severe accident during the life of the plant. This is based on data on accidents involving TVA trucks during the past 10 years which show a rate of 4.06 accidents per million miles travelled. Based on these data and using the estimated annual shipment miles of

new fuel and radioactive waste for the Bellefonte plant, truck accidents may be expected to occur about once every 17 years. However, about 90 percent of the accidents included in the TVA data are of a minor nature, and since radioactive shipments will be made in accordance with the stringent conditions imposed by AEC and DOT procedures and regulations, the probability of an accident of a severity which would result in release of significant quantities of radioactive materials to the environment would not be likely during the life of the plant.

If a shipment of compressible wastes in appropriate containers becomes involved in a severe accident, some release of waste might occur, but the specific activity of the waste will be so low that the exposure of personnel or the public would not be expected to be significant. Waste evaporator bottoms and spent demineralizer resins which have been solidified will be shipped in Type A or Type B packages as appropriate.<sup>6</sup> The allowable contents of Type A packages and the probability of release from a Type B package in a severe accident is sufficiently small that, considering the form of the waste and the very low probability of the severe accident occurrences, the likelihood of significant exposure would be extremely small.

Consideration has been given to the radiological impact of the shipment of tritiated water. The low energy radiation from tritium will be shielded by the shipping container and will not be a source of radiation exposure during normal transportation. Calculations have been performed for an accidental release of the entire contents of a 3,700-gallon container of tritiated water with a tritium concentration of 2.5  $\mu\text{Ci}/\text{cc}$ . A conservative upper limit for the resulting

radiation dose is computed by assuming that all of the tritiated water evaporates into the atmosphere and is blown directly to an individual who remains at the maximum dose point for the entire period of release to the atmosphere. With these assumptions the maximum whole-body dose is computed to be 440 mrem. This dose decreases rapidly with distance, as shown in figure D-5, and at 600 feet is about 17 mrem. Assuming a uniform average population density, the population dose within 50 miles is less than 0.08 man-rem.

4. Shipping safeguards - The protection of the public from radiation during shipment of nuclear fuel and radioactive waste is achieved by a combination of limitations on the contents of the package according to the quantities and types of radioactivity, the package design, and the external radiation levels. In addition to these shipping safeguards, transportation accident procedures will provide for rapid and orderly use of personnel and equipment in the event an accident occurs in the shipment of radioactive materials by TVA.

The Department of Transportation (DOT) has regulatory responsibility for safety in the transport of radioactive materials by all modes of transport in interstate or foreign commerce (rail, road, air, and water), except postal shipments.<sup>7</sup> Those shipments not in interstate or foreign commerce are subject to control by a state agency in most cases. The Atomic Energy Commission (AEC) also has responsibility for safety in the possession and use, including transport, of radioactive materials.<sup>8</sup> Both Title 10 and Title 49 of the Code of Federal Regulations set forth the limitations and classifications of the contents, design, and external radiation levels of transport packages.

(1) Governing regulations - This section identifies and summarizes the governing regulations affecting the transport of nuclear fuel and radioactive material. The major aspects of package design and the technical bases of the regulations and the control of the radiation emitted from individual packages are also discussed. In addition, the external radiation levels permitted for low specific activity (LSA) are listed.

Package classification depends on the type, form, and quantity of radioactive material being shipped in the individual container. Small quantities and certain materials of low specific activity are exempted from specification packaging, marking, and labeling when transported on a sole-use vehicle. All other types and quantities of radioactive materials are divided into two broad classes as either "special form" or "normal form." "Special form" radioactive materials means those which, if released from a package, might present some direct radiation exposure but would present little hazard due to radiotoxicity and little possibility of contamination. This may be the result of inherent properties of the material (such as metals or alloys) or acquired characteristics (such as through encapsulation). "Normal form" materials which do not meet these criteria are classified into one of seven transport groups and listed in a table of individual radionuclides.<sup>9</sup>

Varying quantities of special form and normal form radioactive materials are specified for Type A packaging, larger quantities for Type B packaging, and in excess of Type B quantities for "large quantity" radioactive materials. The Type A packaging standards are for normal conditions of transport. Type B and large quantity packaging

standards are for accident conditions. The large quantity standards, in addition to considering both normal and hypothetical accident test conditions, must take into account other factors such as radioactive decay heat produced by the contents. Fissile radioactive materials also require consideration of the potential for accidental criticality.

Low specific activity packages must not have any significant removable surface contamination, and the external radiation levels must not exceed the following dose rates when transported in a sole-use vehicle:

- (a) 1,000 mrem/h at 3 feet from the external surface of the package (closed transport vehicle only);
- (b) 200 mrem/h at any point on the external surface of the car or vehicle (closed transport vehicle only);
- (c) 10 mrem/h at 6 feet from the surface of the car or vehicle;  
and
- (d) 2 mrem/h in any normally occupied position in the car or vehicle.

The shipment of radioactive material from Bellefonte will be in full accordance with these and other regulations governing such shipments.

(2) Package design - The following discussion relates the new fuel, spent fuel, and radwaste container designs to AEC and DOT regulations for both normal and accident conditions. Radioactive material packaging is evaluated in light of these conditions to assure that packages have the requisite integrity to be safely transported.

(a) New fuel container description

and licensing - Babcock & Wilcox (B&W) is the new fuel fabricator for the initial core fuel assemblies. An AEC special nuclear material license<sup>10</sup> authorizes B&W to deliver special nuclear material to a carrier for transport. Authorization to transport new fuel assemblies has also been obtained by B&W from the Department of Transportation under Special Permit No. 6206.

New fuel assemblies are enclosed in polyethylene wrappers and placed in metal containers which support the fuel assemblies along the entire length during transportation. This container also provides necessary impact protection to meet the hypothetical accident test requirements of the AEC and DOT regulations.<sup>11,12</sup> The metal container is gasketed and bolted shut and has provisions for pressurization and humidity control. The characteristics of a typical new fuel shipping container are given below.

- . All metal reinforced cylindrical outer shell divided longitudinally into two parts
- . Reinforced steel beam fuel assembly supports
- . Capacity of two fuel assemblies
- . Weights
  - Empty - about 3,940 lb
  - Loaded - about 7,300 lb
- . Type B packaging requirements met
- . Package design meets requirements for Fissile Class II and III shipments

(b) Spent fuel container

description and licensing - Spent fuel shipping casks generally have heavy gauge stainless steel inside and outside shells separated by some dense shielding material, such as lead or depleted uranium.

Normal shipping conditions require that the package be able to withstand temperatures ranging from  $-40^{\circ}\text{F}$  to  $130^{\circ}\text{F}$  and to withstand the normal vibrations, shocks, and moisture that could be expected during normal transport.

In addition, casks must withstand specified accident conditions with the release of no radioactivity other than slightly contaminated cask coolant and no more than 1,000 curies of radioactive noble gases. The cask design accident conditions include a 30-foot free fall onto a completely unyielding surface, followed by a 40-inch drop onto a 6-inch diameter metal pin, followed by 30 minutes in fire at a temperature of at least  $1,475^{\circ}\text{F}$ , followed by 8 hours' immersion under at least 3 feet of water. Appendix E of this statement indicates how these 10 CFR Part 71 accident conditions compare to conditions the container might experience as a result of a transportation accident.

It should be noted that there is a wide margin of safety in container designs. For example, the General Electric IF-300 spent fuel shipping cask which will be used at Browns Ferry and may be used at Bellefonte is designed with energy-absorbing fins which absorb the total impact of a 30-foot free fall onto an essentially unyielding surface with only outer fin deformation.<sup>13</sup> As a result of these energy-absorbing fins, there is a wide margin between the damage that would be experienced by the cask in absorbing

the energy of the 30-foot free fall and that which would be required to breach the container. It is estimated that a significant container breach would require from five to ten times the energy which the cask absorbs in the 30-foot free fall. Thus, in the unlikely event that the cask does experience conditions as severe as those imposed by the 10 CFR Part 71 requirements, no container breach is expected.

The accident conditions are judged to be representative of conditions at least as severe as those which would be experienced by containers in transport accidents. Since the tests are applied to the containers in sequence, the cumulative severity of these tests in all probability far exceeds the severity of an accident in transportation. It is highly improbable that a container would be subjected to conditions as severe as one of these conditions, let alone all three in the sequence provided for in the test.

The permissible radiation levels and releases under normal and accident shipping conditions are shown below.

NORMAL AND ACCIDENT SHIPPING REQUIREMENTS

	<u>Normal Conditions</u>	<u>Accident Conditions</u>
<b>External Radiation Levels</b>		
Surface of vehicle	200 mrem/h	NA
3 feet from surface of container	NA	1,000 mrem/h
6 feet from external surface of vehicle	10 mrem/h	NA
<b>Permitted Releases</b>		
		0.1% of total package radioactivity
Noble gases	none	1,000 Ci
Contaminated coolant	none	0.01 Ci alpha, 0.5 Ci mixed fission products 10 Ci iodine
Other	none	none
<b>Contamination Levels</b>		
Beta and gamma	2,200 dpm/100 cm <sup>2</sup>	NA
Alpha	220 dpm/100 cm <sup>2</sup>	NA

In most cases the containers should have radiation levels and releases during accidents somewhat less than those permitted by the regulations because the fuels and materials which will be handled are not expected to be at the cask design activity levels.

Since spent fuel will not be shipped until about 1980, contracts have not been made for the equipment and services for spent fuel shipments. Thus, the exact details of cask design and safety analysis in support of a specific licensing effort are not available at this time. However, TVA will ensure that the AEC, DOT, and any other applicable criteria for spent fuel casks become conditions of the contract for these services.

(c) Radwaste container description

and licensing - The design of the solid waste packaging station permits the use of several different types of containers or packages. The exact type of container to be used for shipments of the higher activity low level wastes from the plant has not been determined at this time. However, for purposes of evaluating the environmental risks associated with shipment of radioactive wastes from this plant, TVA has used the design and safety analyses made under contract with ATCOR, Inc., for the Browns Ferry Nuclear Plant shipping cask. The container designed under this contract (LL-60-150) has been licensed (41-08165-06) for shipping the higher activity low level wastes from Browns Ferry.

The LL-60-150 cask is designed to meet or exceed the requirements established by AEC and the Department of Transportation for the shipment of large quantities of radioactive material. The evaluation made by ATCOR, Inc., in support of licensing for this cask considers both normal and accident conditions of transport.<sup>14</sup> An analysis was performed to demonstrate that the cask provides adequate shielding to satisfy dose rate levels in the vicinity of the cask as required for normal conditions of transport. A shielding analysis was also performed in order to assure that the cask meets the dose rate requirements after a shielding loss has occurred due to a hypothetical accident occurrence.

Accident analysis showed that the lead may slump towards the bottom of the cask as a result of the hypothetical 30-foot drop accident. The level of the lead falls 1.6 inches which will not remove the lead shielding from the top of the solid waste source. At 3 feet from the surface of the cask, the dose rate is estimated

to be less than 500 mrem/h (assuming 4.02 mrem/h at 6 feet before the accident), which is less than half the limit of 1,000 mrem/h at 3 feet stated in 10 CFR Section 71.36(a)(1).

The analysis for puncture resistance was performed and it was found that when considering any point along the 1-1/2-inch thick outer shell, failure in this mode will not occur and no release of radioactive material to the exterior or dose rates in excess of 10 CFR Section 71.36 limits will occur. An analysis has been performed of the hypothetical fire accident. The thermal conductivity across the outer and inner steel shells plus the air gap is sufficiently low to keep the temperature of the lead about 150°F below its melting point. It was also shown that the cask is capable of holding the vapor pressure resulting from the elevated temperatures.

Immersion of the cask under 3 feet of water for more than 24 hours will not cause any detrimental effect since the cask was established in the analysis to be leaktight following the preceding accident conditions.

For lower activity level wastes (activities of 0.5 Ci/ft<sup>3</sup> or less), an all steel cask holding about 183 ft<sup>3</sup> has also been designed and is being constructed by ATCOR, Inc., for use at Browns Ferry and could be used at Bellefonte.

Low activity compressible wastes will be packaged for shipment in appropriate containers. Radioactive equipment components will be shipped by contract with a specialist who will provide the necessary containers, such as modified spent fuel casks.

(3) Transportation procedures - Elements

of the procedures to be followed by TVA for handling radioactive materials for transportation and while in shipment are given below. These procedures will cover the normal and accident conditions which might be encountered.

(a) Onsite procedures - The

administrative control of radioactive materials intended for offsite shipment will include the following:

- a. Certify container contents.
- b. Assure performance of all tests on loaded containers as required by 10 CFR Section 71.35, 49 CFR Section 173.393(j), and 49 CFR Section 173.397(a).
- c. Ensure that container and vehicle meet the applicable requirements of regulatory bodies for movement offsite.
- d. Qualified personnel with appropriate equipment to be available to make routine determinations as required by (b) above.
- e. Provide estimated time of arrival (ETA) at destination.
- f. Provide approximate routing, mode of transport, estimated entry and exit times to various states as appropriate.

(b) Offsite procedures - The

driver of the vehicle will be responsible for control of shipments en route and for following the transportation procedures delivered to him before leaving the site.

The state requirements for notification and responsible party to notify when radioactive materials are scheduled to be shipped through various states are given in Table 2.1-3.

(c) Accident occurrences during transport - Each state through which these materials pass will have developed emergency plans for radioactive transportation accidents. These plans, in conjunction with TVA transportation accident procedures, will provide for rapid and orderly use of state facilities and personnel, augmented as necessary by TVA, carrier, and municipal emergency personnel and AEC radiological assistance teams in the event an accident occurs in the shipment of radioactive materials by TVA. In the event of an accident, emergency plans will be initiated to minimize a radiation hazard to the public and the environment.

Accident procedures regarding transportation of radioactive material are described in TVA's nuclear plant procedure manual<sup>15</sup> and the TVA Radiological Emergency Plan.<sup>16</sup> Elements of the procedures for handling transportation accidents for which TVA has responsibility will include, but are not limited to, the following:

1. Vehicular Accidents - General
  - a. In the event of vehicular accident involving radioactive material, establish a restricted area [10 CFR Section 20.203(b) and (c)].
  - b. Use radiation survey meter to establish the perimeter of the restricted area.
  - c. If survey meter is inoperable, calculate from experience and training a very conservative perimeter.
  - d. If survey meter is operable and no radiation hazard exists and the vehicle is in safe operating condition,

the driver may continue en route if not detained by other accident-related conditions.

- e. In any case, immediately after establishing a restricted area or before proceeding on way, TVA shall be notified.

2. Notification and Reports of Incident

- a. Appropriate TVA personnel receiving notice of a transportation accident shall notify the TVA load dispatcher who notifies the Central Emergency Control Center (CECC) director.
- b. The CECC director notifies as appropriate the AEC Operations Office, the State Department of Public Health, the state police, and the AEC Division of Compliance.
- c. The CECC director will provide assistance for cleanup and recovery operations as needed.

TVA has consulted and will consult further with appropriate state agencies regarding the necessary emergency planning for shipments of radioactive material through the state and to seek the state's agreement with TVA's Radiological Emergency Plan.

5. Conclusion - Due to the integrity of the containers used for shipping new fuel elements, spent fuel elements, and low-level radioactive wastes; the emergency plans for vehicular accidents; the administrative control exercised over transportation; and coordination with appropriate state agencies; it is concluded that an insignificant environmental risk will result from the transportation of fuel elements from the fuel fabrication plant to the reactor, or spent fuel elements to the fuel reprocessing plant, and of low-level waste to offsite disposal grounds.

REFERENCES FOR SECTION 2.1

1. Atomic Energy Commission Regulations. Title 10 Code of Federal Regulations Part 70 (10 CFR 70).
2. Department of Transportation Regulations. 49 CFR Section 173.393.
3. Department of Transportation Regulations. 49 CFR Section 173.398.
4. Department of Transportation Regulations. Shipping Container Specifications, Title 49 Code of Federal Regulations Part 178 (49 CFR 178).
5. Department of Transportation. "1969 Accidents of Large Motor Carriers of Property," December 1970.
6. Department of Transportation Regulations. 49 CFR Sections 173.24; 173.389 through 173.399.
7. Department of Transportation. Transportation of Hazardous Materials, Title 49 Code of Federal Regulations Part 171 through Part 179 (49 CFR 171-179).
8. Atomic Energy Commission. Packaging of Radioactive Materials for Transport, Title 10 Code of Federal Regulations Part 71 (10 CFR 71).
9. Atomic Energy Commission Regulations. 10 CFR Part 71, Appendix C.
10. Atomic Energy Commission. License for Delivery of Radioactive Material to a Carrier for Transport, Special Nuclear Material License--SNM-1168, Docket No. 70-1201, Amendments 71-1, Babcock & Wilcox.
11. Atomic Energy Commission Regulations. 10 CFR Section 71.36.
12. Department of Transportation Regulations. 49 CFR Section 173.398.
13. Design and Analysis Report, submitted to AEC in support of licensing of IF-300 Shipping Cask - Docket No. 50-268, Amendment 71-1 - General Electric Company.
14. Safety Analysis Report for the Shipment of Radioactive Solid Waste in the LL-60-150 Cask from the Tennessee Valley Authority Browns Ferry Nuclear Plant Units 1 and 2 - ATCOR, Inc.
15. Tennessee Valley Authority, Division Procedures Manual, Division of Power Production, August 11, 1972.
16. Tennessee Valley Authority, TVA Radiological Emergency Plan.

Table 2.1-1

RADIOACTIVITY OF IRRADIATED FUEL<sup>a</sup>(Ci/MTU)<sup>b</sup>

	<u>Cooling Period (in days)</u>		
	<u>90</u>	<u>150</u>	<u>365</u>
Fission Products	$6.19 \times 10^6$	$4.39 \times 10^6$	$2.22 \times 10^6$
Actinides (Pu,Cm,Am, etc.)	$1.42 \times 10^5$	$1.36 \times 10^5$	$1.24 \times 10^5$
Total	$6.33 \times 10^6$	$4.53 \times 10^6$	$2.34 \times 10^6$

PREDOMINANT FISSION PRODUCTS IN GASEOUS FORM  
INCLUDED IN RADIOACTIVITY OF IRRADIATED FUEL

(Ci/MTU)

	<u>Cooling Period (in days)</u>		
	<u>90</u>	<u>150</u>	<u>365</u>
Krypton-85	$1.13 \times 10^4$	$1.12 \times 10^4$	$1.08 \times 10^4$
Xenon-131m	$1.06 \times 10^2$	3.27	$1.08 \times 10^{-5}$
Iodine-131	$3.81 \times 10^2$	2.17	$1.98 \times 10^{-8}$

THERMAL ENERGY IN IRRADIATED FUEL

(Watts per metric ton of uranium)

	<u>Cooling Period (in days)</u>		
	<u>90</u>	<u>150</u>	<u>365</u>
Thermal Energy	$2.71 \times 10^4$	$2.01 \times 10^4$	$1.04 \times 10^4$

- a. Estimated burnup 33,000 MWD/MTU - Siting of Fuel Reprocessing Plants and Waste Management Facilities - ORNL - 4451, July 1970.
- b. Approximately two assemblies per MTU.

Table 2.1-2

RADIOACTIVE MATERIALS TRANSPORTATION - SUMMARY OF EFFECTS

(Normal Conditions)

Type	Transportation		Stationary Cask Radiation Exposure (mrem/h)		Cask Moving at 20 mi/h Individual Exposure (mrem/trip)		Population Exposure (man-rem/yr)
	Mode	Frequency (Shipments/yr)	at 6 ft	at 100 ft	Maximum	Average	
Spent Fuel	Rail ( 5 MTU/ shipment)	14	10	~ 0.1	0.00029	0.000016	0.009
Waste							
Low Level	Truck	25 <sup>a</sup>	10	~ 0.1	0.00029	0.000016	0.016
							Total 0.025 <sup>b</sup>

(10 CFR Part 71 Accident Conditions)

Type Shipment	Transportation		Direct Radiation		Fission Gas Release		Thyroid Dose (rem)	
	Mode	(Shipments/yr)	Dose Rate (mrem/h)		External Dose (mrem)			Whole Body Population Dose (man-rem)
			at 3 ft	at 50 ft	Whole body	Skin		
Spent Fuel	Rail ( 5 MTU/ shipment)	14	1,000	17	2	86	0.07	5
Waste								
Low Level	Truck	25 <sup>a</sup>	500					

a. Design conditions.

b. This population group receives about 11,500 man-rem/yr exposure from natural background radiation (140 mrem/yr).

NOTIFICATION REQUIREMENTS OF STATES  
FOR SHIPMENT OF RADIOACTIVE MATERIAL

Alabama

Requirements:

Telephone or telegraph  
Route, mode of transportation,  
time of arrival in state

Notify:

Director  
Division of Radiological Health  
Room 311, State Office Building  
Montgomery, AL 36104  
Telephone: 205-269-7634

Georgia

Requirements:

Letter, telephone or telegraph  
Approximate route and mode of  
transportation

Notify:

Chief  
Radioactive Materials Control Section  
Division of Radiological Health  
535 Milam Avenue, SW  
Atlanta, GA 30314  
Telephone: 404-762-6111

Illinois

Requirements:

Letter, telephone or telegraph  
Route, estimated arrival time  
in state

Notify:

Director  
Department of Public Health  
535 West Jefferson  
Springfield, IL 62706  
Telephone: 217-525-6550

Indiana

Requirements:

No notification required

Notify:

Director  
Division of Radiological Health  
1330 West Michigan  
Indianapolis, IN 46206  
Telephone: 317-633-6340

Kentucky

Requirements:

Letter, telephone or telegraph  
Route, estimated entry and  
exit times in state

Additional:

Identify carrier and approxi-  
mate activity of each shipment

Notify:

Director  
Radiological Health Program  
Kentucky State Department of Health  
275 East Main Street  
Frankfort, KY 40601  
Telephone: 502-564-3700

Table 2.1-3 (continued)

Missouri

## Requirements:

Letter, telephone or telegraph  
Route, mode of transportation,  
entry and exit times in state

## Additional:

Truck shipments - license number and/or other identifying numbers, color of truck, entry and exit points in state, highway patrol will meet truck at border and provide protective following as a safety feature

Rail shipments - name of railroad, shipment car number and its location within the train, notification in transit if other cars are added or deleted from train, thus changing relative location of shipment within train, highway patrol will provide surveillance at locations where possible

## Notify:

Director,  
Radiological Health Division  
Broadway State Office Building  
Jefferson, MO 65101  
Telephone: 314-635-4111

North Carolina

## Requirements:

Letter or telegraph  
Route, mode of transportation

## Comment:

- \* Notification for each individual shipment may not be necessary if specific time interval when several shipments may be made can be scheduled. State is now in the process of formulating emergency planning with regard to shipments of this sort, and requirements have not been formalized.

## Notify:

Director  
Division of Radiation Protection  
North Carolina State Board of Health  
P.O. Box 2091  
220 North Dawson  
Raleigh, NC 27607  
Telephone: 919-829-4283

South Carolina

## Requirements:

No notification required

## Notify:

Director  
Division of Radiological Health  
South Carolina State Board of Health  
2600 Bull Street  
Columbia, SC 29201  
Telephone: 803-758-5548

Tennessee

## Requirements:

Letter or telephone  
Approximate route and mode  
of transportation

## Notify:

Director  
Division of Radiological Health  
727 Cordell Hull Building  
Nashville, TN 37219  
Telephone: 615-741-3161

2.2 Environmental Aspects of Transmission Lines - Transmission lines for the Bellefonte Nuclear Plant will be constructed in four steps which are coincident with (1) providing a temporary line for construction power at the Bellefonte plant site, (2) the early construction of two separate Bellefonte transmission line sections which will be used in the interim to meet other power system needs, (3) the initial operation of generator Unit 1, and (4) initial operation of generator Unit 2. The following table summarizes these line connections:

STEP I

<u>Line Name</u>	<u>Voltage (kV)</u>	<u>Approximate Length of New Construction (Miles)</u>	<u>Approximate Date Required</u>
Hollywood- Scottsboro Tap to Bellefonte (Temporary)	46	2.7	August 1974 (Assuming grant of limited work authorization)

STEP II

Bellefonte- Widows Creek No. 2*	500	16.8	June 1976
Bellefonte- Guntersville*	500	22.9	June 1976

\*(Excluding Bellefonte River Crossing section)

STEP III

Widows Creek- Madison, Loop into Bellefonte Nuclear Plant	500	24.6	June 1979
Widows Creek- Scottsboro, Loop into Bellefonte Nuclear Plant	161	2.4	June 1979

STEP IV

<u>Line Name</u>	<u>Voltage (kV)</u>	<u>Approximate Length of New Construction (Miles)</u>	<u>Approximate Date Required</u>
Bellefonte- Widows Creek No. 2*	500	3.1	March 1980
Bellefonte- Guntersville*	500	3.1	March 1980

\*(River Crossing Section)

Under Step I, electrical power for construction activities at the Bellefonte Nuclear Plant will be provided by building a temporary 2.7-mile wood-pole supply line from the Hollywood-Scottsboro 46-kV Transmission Line to a 46-kV substation to be established on the Bellefonte site. The exact location of the substation will be determined by later field studies.

In the summer of 1976 and coincident with the establishment of a separately proposed intersystem 500-kV tie line between TVA and the Alabama Power Company, (i.e., Guntersville to West Jefferson near Birmingham, Alabama), it is proposed to advance construction of the Bellefonte-Widows Creek No. 2 and Bellefonte-Guntersville 500-kV Lines. This construction activity, identified as Step II, will temporarily exclude the river crossing sections for these lines to the Bellefonte Switchyard (3.1 miles each). The resulting line sections will be temporarily tied together in the vicinity of Bellefonte and will become a link of the Widows Creek-Guntersville-West Jefferson intersystem tie line.

In the Bellefonte Draft Environmental Statement, it was originally proposed to extend the Bellefonte-Guntersville 500-kV Line an additional

36 miles to the Madison Substation near Huntsville, Alabama. However, subsequent studies jointly conducted between TVA, Southern Services Corporation and Alabama Power Company show that a multi-purpose 500-kV interconnection between the TVA system at Guntersville and the Alabama Power Company at West Jefferson will provide significant benefits to both systems. This interconnection working in conjunction with the Bellefonte-Guntersville No. 2 500-kV Line will provide sufficient power system access for stable operation of the second Bellefonte generator unit. These connections therefore eliminate the need for the previously proposed Guntersville-Madison Line section.

Under Step III, two 500-kV transmission lines will provide system connections for the Bellefonte Nuclear Plant Unit 1. These connections will be established by opening the existing Widows Creek-Madison 500-kV Transmission Line and extending the resulting line sections approximately 12.3 miles each to the nuclear plant switchyard. This will provide 500-kV transmission lines to Widows Creek Steam Plant and Madison Substation.

Off-site station service power to the nuclear plant will be provided by opening the existing Widows Creek-Scottsboro 161-kV Transmission Line in the vicinity of Bellefonte and constructing two line sections to the nuclear plant switchyard. Approximately 1.2 miles of new construction will be required for each 161-kV line.

Under Step IV, two additional 500-kV transmission lines will be required when the second Bellefonte generator unit is placed in service. These lines are the Bellefonte-Widows Creek No. 2 and the Bellefonte-Guntersville 500-kV Lines. While major segments of these lines will have

been provided under Step II above, it will be necessary to open these lines where they will have been temporarily connected together and to extend the resulting line section across the Tennessee River to the Bellefonte switchyard a distance of approximately 3.1 miles. These short line sections will be provided on double circuit towers.

The transmission line routes as shown on figure 2.2-2 will require approximately 72.9 miles of new transmission line construction and necessitate the purchase of 1,550 acres of new right of way easements. Approximately 50 percent of the required rights of way is presently in woodland, 25 percent is used for farming with the remainder being farmland lying idle. Approximately 69 miles of existing rights of way will be utilized for the line connections to Bellefonte. New transmission lines will be constructed on 16.6 miles of common rights of way.

1. General considerations - As a first step in the transmission line location process, topographic maps were examined in the office to determine the best apparent route. In some cases these maps were supplemented with aerial photographs to assure that the most up-to-date knowledge of land use developments was available. Then a field reconnaissance was made using these maps and photographs.

In the field, engineers first looked for the best places to cross major highways and secondary roads, at the same time avoiding, to the extent possible, residential, commercial and industrial areas; recreational areas and other developments; and areas of historical, cultural or scenic significance. Locations on crests of mountains and ridges were generally avoided to minimize visual impacts.

Route selection will be coordinated with municipal, county and state planning boards and with municipal, state and Federal authorities when crossing of public lands is involved. At the same time, care will be taken to minimize the visual and physical impact of transmission facilities on residential properties. Locations along property lines and away from homes and barns will be chosen where feasible.

In general, final route selection will be made in keeping with the Environmental Criteria for Electric Transmission Systems.<sup>1</sup>

In selecting routes for transmission lines, TVA attempts to locate the lines so that family or business relocations are not required. This policy is being followed in the selection of routes for the lines from the Bellefonte Nuclear Plant and no relocations are anticipated. However, in the event relocations are required, assistance will be provided in accordance with "Uniform Relocation and Real Property Acquisition Policies Act of 1970" (Public Law 91-646).

To the extent possible, TVA avoids routing its lines through residential areas. However, such areas frequently develop adjacent to the cleared areas created by the construction of transmission lines. When residential areas cannot be avoided, environmental impacts are minimized by following property lines as much as practicable, preserving natural vegetation and avoiding the splitting of land use zones.

Open land that is not being cultivated is generally preferred to timbered land for line locations, and routes are chosen to minimize conflicts with existing land uses. However, routes which result in substantial increases in length are generally avoided.

It is frequently necessary in the construction of transmission lines to cross rivers or other bodies of water. Three transmission lines that connect to the Bellefonte Nuclear Plant will cross the Tennessee River (Guntersville Reservoir). The three lines will be constructed on two sets of common structures, thereby reducing the number of separate crossings. In selecting locations for these crossings, conflicts with residential, commercial and industrial developments, game sanctuaries, and scenic and recreational areas have been avoided.

In crossing streams under the jurisdiction of state agencies, on-site inspections have been made with agency representatives to assure agreement on the location. All river crossings are coordinated with the appropriate local, regional and state planning agencies.

When a navigable stream or reservoir is crossed, the work will be coordinated with the United States Corps of Engineers. Crossings of streams and drainage areas having water conservation projects planned by the United States Department of Agriculture's Soil Conservation Service are coordinated with that agency.

The new transmission line routes are being closely coordinated with the Top of Alabama Regional Council of Governments; the Section, Alabama Planning Commission; the Scottsboro, Alabama Planning Commission; The Alabama Conservation Department; the Alabama Highway Department; and the United States Department of Agriculture, Soil Conservation Service.

Within TVA the line routes will be closely coordinated with the Division of Navigation Development and Regional Studies, the Division of Reservoir Properties, the Office of Tributary Area Development,

the Division of Environmental Planning, the Division of Forestry, Fisheries, and Wildlife Development, and the Division of Water Control Planning.

The transmission line structures for these lines will be self-supporting steel towers. This self-supporting aspect of the structures eliminates the need for guys. The small amount of land occupied by the structures is the only part of the right of way which cannot be used for other purposes. The balance of the rights of way remain clear of obstructions and are available for a variety of other uses.

2. Impacts of transmission line rights of way clearing and control practices -

(1) Shear clearing - In constructing transmission lines through wooded areas, the right of way is generally shear cleared (clearing of trees and other vegetation to the ground level) except where outcropping of rocks, in proximity to streams and road crossings, or steep slopes make it impractical. Where these exceptions are encountered, hand clearing or spanning of vegetation is utilized. Of the 1,550 acres of right of way required by this project only 750 acres are wooded.

While the removal of vegetation from the right of way by shear clearing constitutes an impact on terrestrial plant and animal communities existing in the corridor area, the impact of shear clearing will be localized because the land pattern traversed by these proposed routes is alternately open farmland, pasture land, and wooded areas. The longest continuously wooded area traversed by the proposed lines is three miles. The impact is further reduced by TVA's practice of reseeding the right of way with pasture type grasses and also by the natural invasion by weeds and plants during subsequent growing seasons.

In lieu of shear clearing, several major wooded test tracts will be selectively cleared for the Step II transmission line connections for this project. Cost estimates and other related benefits of the selective clearing method will be obtained on these test sections. Evaluations will then be made using data obtained from these test areas and other TVA research projects on right of way clearing methods to form a basis for specific clearing practices to be used for the balance of the transmission lines to be constructed under Steps III and IV of the Bellefonte project.

To further reduce the need for controlling brush growth and to minimize the environmental impact of a cleared right of way, an intensive effort is made to encourage the landowner to maintain an appropriate grass or wildlife food and cover or to utilize the area for row crops when consistent with his use of adjoining land. Such uses enhance the appearance of the right of way and at the same time provide agricultural production and wildlife benefits.

(a) Impact on flora - The major impact to flora will result from the clearing of brushland and forested areas. These land cover types will be altered to brushland which can be termed a short rotation brush community situation where plant succession continues for 3 to 5 years until further maintenance of the right of way is required.

While some economic loss of timber productivity will result from the clearing of the proposed right of way, it is possible that this loss can be offset by converting the cleared land into uses that would provide an equal or higher return than timber production. Examples of these uses are delineated under Multiple use of rights of way on page 2.2-14.

Transmission line maintenance requires that vegetation be controlled so it will not interfere with the safe and reliable operation of the line nor impede restoration of service when outages occur. Growth of vegetation will be controlled by mechanical or hand cutting, replacement planting, and limited use of herbicides. In wooded areas brush mowing (bushhogging) will be combined with hand- or power-saw felling of larger timber. For heavier stands, dozer-blade clearing will be employed, and a brush rake will be used to windrow the felled brush along the edge of the right of way. Vegetation will not be removed where there is no danger of trees interfering with line operation such as in ravines and deep hollows.

(b) Impact on fauna - The construction of these transmission line facilities will have an impact on certain fauna, owing to habitat disturbance during initial construction and subsequent maintenance work. Species inhabiting open areas where vegetation removal will not take place (pasture, cropland, etc.) will not be significantly affected by construction, operation, and maintenance procedures (e.g., lark, sparrow, meadow lark, cotton rat). In areas where major vegetation removal will take place such as old fields and second growth deciduous and coniferous forests, significant impacts to certain faunal species will occur (e.g., flying squirrels, pine mouse, wood rat, pine warbler, worm-eating warbler and wood thrush). These impacts will be short-term or temporary for species preferring early plant successional habitats such as brushland (e.g., yellow breasted chat, prairie warbler, cottontail

rabbit, skunks, and numerous reptiles), but permanent or long-term displacement will occur for others (e.g., wood thrush, summer tanager, red-eyed vireo, wood rat, flying squirrel).

Operation of the proposed lines should have no significant impact on wildlife, but maintenance activities will cause periodic changes in animal communities by removal of woody vegetation every 3 to 5 years. These maintenance clearing activities will cause changes in bird, mammal, reptile, and amphibian populations. TVA is presently in the process of establishing research projects which will enable quantification of the changes and shifts in populations due to power line construction and maintenance activities.

In summary, adverse impacts to vertebrates will be most pronounced to species dependent on second growth pine and hardwood forest types for their livelihood. Species favoring open and brushy situations as well as edge areas will be benefited.

(c) Impact on waterfowl - Except where the proposed line corridors cross Guntersville Reservoir and related, river-front lands, they will generally pass through upland areas that are seldom if ever utilized by waterfowl. In the vicinity of Coon Creek, however, construction work is scheduled to avoid the waterfowl hunting season (approximately November 20 through January 31).

Location of the Bellefonte-Widows Creek No. 2 500-kV Transmission Line in the Raccoon Creek Waterfowl Management Area has been discussed with the Alabama Division of Game and Fish. Construction activities will be timed so that they do not occur during the waterfowl hunting season. Precautions will be taken to minimize

habitat disturbance. As soon as the exact location of the corridor is marked on the ground, the Alabama Division of Game and Fish will be notified so arrangements can be made with their contractual crop producers. As agreed, the cleared right of way areas within the Raccoon Creek Waterfowl Management Area will be seeded with Kentucky 31 Fescue and White Clover, fertilized and maintained in sod cover except where in row crops and/or rented to cooperative farmers.

(d) The "Edge Effect"<sup>(2,3)</sup> and wildlife benefits - Utility line rights of way can rarely go longer than 5 years without mechanical maintenance of some type. Early stages of plant succession on cleared rights of way, particularly the first 6 to 8 years, are the most productive for many wildlife food and cover plants. In addition, the low herbaceous plant growth supports insects which provide the high protein content necessary in the diet of many young vertebrates (game and nongame).

Power line rights of way have potential as habitat for certain species because of the "edge effect" that results where low herbaceous and woody plant growth meets the forest or where adjacent cropland and weedy or "brushy" rights of way merge. The junction of the brushland community right of way and the adjacent forest is referred to as "edge" which is generally defined as the interface or junction zone of two or more habitat types. The zone or edge where two communities meet and overlap commonly contains species from both communities in addition to other species which are indigenous to the edge area. In many cases the number and density of some species is greater in the edge than in the vegetation communities adjacent to it.

A common wildlife management practice in large sections of unbroken forest land is to develop relatively small, evenly spaced clearings. Rationale for this practice is to provide the diversity in the forest environment necessary to attract greater numbers of species. Power line rights of way essentially create long linear forest openings. The sunlight penetrating the forest edge through the rights of way stimulates understory growth adjacent to the power line. Periodic power line maintenance then perpetuates these habitat conditions. Specific management practices geared toward wildlife production can significantly enhance the wildlife potential already present along transmission lines. TVA attempts to implement such management practices jointly with the agency controlling public lands crossed and with the landowner on private lands when consistent with his own land use desires.

Rights of way in wooded areas are planted to grasses or low-growing vegetation except along the outer edges where taller growing plants such as autumn olive may be used. Maintenance is then geared to the continuation of improved habitat conditions for selected wildlife species.

TVA, in cooperation with the Tennessee Game and Fish Commission, has published a booklet for distribution to landowners within the service area describing practices they can employ to benefit various wildlife species on rights of way.<sup>(4)</sup>

(e) Chemical maintenance of right of way -

Growth of vegetation on the proposed line rights of way is a special problem because of the relatively long growing season in the north Alabama area and will be controlled by mechanical or hand cutting and the limited

application of herbicides. During the fiscal year ending June 30, 1971, a transition was made in TVA's right of way maintenance program from essentially complete herbicidal control to primarily mechanical maintenance. Chemical maintenance is now limited to those areas which are both remote and inaccessible. It is estimated that less than 5 percent (approximately 28 acres) of the forested right of way acreage for the proposed transmission lines will be maintained with herbicides on a 3 to 5 year cycle. This will include herbicidal stump treatment to be used in conjunction with select clearing methods being evaluated on portions of the lines proposed under Step II.

When herbicides are used, their application is carefully controlled to ensure on-target placement and avoid drift off the right of way or contamination of watercourses. Watercourses are identified by ground or air reconnaissance prior to spraying, and no chemicals are applied within 100 feet of these areas. The herbicides used are Tandex, Tordon 101, Tordon 10K pellets, and/or Hychlor, all of which are approved for this use by the Federal Working Group on Pest Management (FWG on PM). From transmission line right of way inspections, TVA determines each year where chemical control of brush is to be used, the chemicals to be employed, and the method and rate of application. The entire annual program is then submitted for approval to the FWG on PM, and no herbicides are applied until approval is received.

In addition to information about program objectives, chemicals used, and mode of application, the program annual report summarizes precautions taken by TVA in applying the chemicals and specifies areas of the environment that are to be avoided or treated with

caution. Field observations have revealed no significant adverse environmental effects from the use of chemicals in the right of way maintenance program. In addition, formal studies are planned to quantitatively document these observations.

TVA employees responsible for right of way maintenance work closely with wildlife biologists and foresters of TVA's Division of Forestry, Fisheries, and Wildlife Development. The combined expertise of these TVA employees and other TVA specialists ensures that biologically sound and economically feasible recommendations are made to improve wildlife habitat on the rights of way.

(2) Multiple use of rights of way - As a general rule, where transmission line rights of way cross wooded areas, TVA is willing to perform the necessary clearing or invest as its part of a cooperative arrangement an amount which approximates the average cost to clear or later reclear the area as dictated by maintenance requirements. TVA negotiates with county agents, state, and Federal park commissions, soil conservation agencies, sportsmen groups, and other interested agencies that propose compatible uses for wooded land within easement areas that will meet the goals of the interested parties. Under such an arrangement, forest development interests can be implemented which allow growing of small trees such as Christmas trees and nursery stock. Also, buckwheat, Korean and Kobe Lespedeza, and other low-growing grasses and seed crops can be planted which are beneficial to small game.

It is recognized that many additional multiple right of way uses can be identified. Agricultural uses other than the growing

of timber may be continued. The easement area may be fenced and cross fenced. Roads and driveways may be installed provided fills do not interfere with proper clearances of the transmission line, and utilities such as water lines, telephone lines, electrical distribution lines, sewer lines and gas lines may be installed. Stock ponds or lakes may be built provided tower foundations are not jeopardized. Lawns, flower or vegetable gardens and other domestic uses may continue. The landowners involved may also establish playgrounds, athletic fields, golf courses, parks, picnic areas, hiking trails and horseback riding trails. In short, all multiple uses are permitted under the terms of TVA's easement other than those which would interfere with the safe operation and maintenance of the transmission line.

3. Solid waste disposal - TVA contracts most right of way clearing for the construction of transmission lines. Where practical, merchantable timber is marketed. Open burning, normally employed for disposal of the remaining forest slash cleared from rights of way, will be used for the proposed Bellefonte transmission line connections and will be performed in compliance with local, state, and Federal air pollution guidelines and ordinances. This will result in the release of some particulates and gases into the atmosphere. However, these minor effects will be localized and generally short lived. In locations where disposal by burning is not desirable, slash will be piled in windrows along the edge of the right of way.

In general, other solid waste that may be generated by constructing these transmission lines will be very small. These minor construction

waste items will consist of protective wood cribbing attached to conductor reels, cardboard shipping cartons and steel bands used to bind tower structural items and other line hardware. This waste will be returned to staging areas for disposal.

At staging or material assembly points, relatively large quantities of the used packing material which accumulates will be transported to state-approved sanitary landfills or dumps. However, in localized areas, smaller quantities of wood and paper will be disposed of by controlled burning.

4. Erosion control practices - Construction of these transmission lines will involve the use of heavy equipment for tower erection and stringing of conductor. Although this equipment may cause temporary rutting along the rights of way, precautionary measures will be taken so that the effects of soil erosion on local water quality is not significant. The erosion of local areas will be controlled to a significant degree by:

- (1) using special construction procedures which limit the use of heavy equipment in areas of high erosion potential, directing runoff from exposed land to settling ponds, and keeping vegetation on the land as long as possible before construction; and
- (2) scheduling construction activities in swampy or wet areas to coincide with favorable dry weather conditions.

When line construction activity is completed, the rights of way will be contoured and seeded with pasture-type grasses or planted in wildlife food and cover to control soil erosion and provide wildlife habitat. Road routes will be selected to minimize damage to existing

growth and drainage ditches, water breaks, terracing, and ground cover will be provided in order to minimize soil erosion.

5. Miscellaneous impacts -

(1) Ozone - Ozone can be produced from corona discharges (ionization of the air) in the operation of transmission lines and substations, particularly at the higher voltages. It can be harmful if breathed in sufficient concentrations over prolonged periods. However, it is not considered to be injurious to vegetation, animals, and humans unless concentrations exceed about 0.05 ppm.

Corona discharges can result from abrasions, foreign particles or sharp points on electric conductors and electric equipment, or incorrect design which produce excessively high potential gradients.

Extensive field tests to detect ozone in the vicinity of 765-kV lines were recently completed by the Battelle Memorial Institute under a variety of meteorological conditions. From these tests it was concluded that no significant adverse effects on vegetation, animals, or humans are to be expected from levels of ozone that may be produced in the operation of transmission facilities at voltages up to 765-kV. Consequently, any levels of ozone that can reasonably be expected to be generated by TVA's transmission facilities (500-kV nominal voltage) would be environmentally inconsequential.

TVA gives careful attention to the design and construction of its transmission facilities to minimize corona discharges. TVA specifications require that transmission line hardware and electrical equipment for operation at 500,000 volts be factory tested to assure corona-free

performance up to maximum operating voltage levels. A more detailed report of ozone characteristics, sources, and a discussion of tests and reference material can be found in Appendix F.

(2) Compatibility with communications equipment -

High-voltage power lines operating in close proximity to telephone and signalling equipment can produce undesirable effects on the communication circuit through inductive coupling. However, it is TVA's normal practice to send transmission line vicinity maps to railroad and telephone companies having tracks or communication lines in the general area of proposed power lines for the purpose of making inductive coordination studies. If corrective action is indicated, the problem will be jointly studied and any required changes will be mutually resolved. This procedure will be followed for the proposed transmission line connections for Bellefonte Nuclear Plant.

No inductive coordination problems have been experienced on the Widows Creek-Madison 500-kV Transmission Line which has been in operation for several years. It is expected that no new problems will be encountered when this line is altered in the vicinity of Bellefonte Nuclear Plant to form the Bellefonte-Widows Creek and Bellefonte-Madison 500-kV lines. For the proposed routes, we do not anticipate any inductive coupling problems for the other proposed transmission lines.

(3) Historical and archaeological compatibility -

In developing routes for the proposed transmission lines, the National Register of Historic Places, published by the National Park Service, and other state and local inventories were consulted to determine if the proposed lines would conflict with any previously identified historical or

archaeologically significant site. These reviews, although not all conclusive, failed to reveal any conflicts which would necessitate a route adjustment. However, following completion of an engineering survey to define specific routes for the proposed lines, a detailed professional field reconnaissance of the routes will be made by qualified historians and archaeologists. Should this survey reveal the presence of any significant site on or in close proximity to the lines, an evaluation will be made to determine if the transmission line route or specific towers should be relocated. For archaeological sites, the possibility of recovering the artifacts will be studied. In the event a structure or other prominent historical property is identified, a determination will be made in conjunction with state and Federal historical agencies as to its eligibility for nomination to the National Register. In the event such a property is identified, the proposed transmission line route will be reevaluated and made compatible with the National Register Property as appropriate.

(4) Impacts on aviation - Tall towers normally are required to accommodate long spans associated with major river crossings or to provide electrical clearance over unusual topographic features or man-made objects. When these towers exceed a height of 200 feet above local terrain or invade upon air traffic patterns, a permit must be obtained from the Federal Aviation Administration prior to construction.

The proposed transmission lines included in this project will cross the Tennessee River at the Widows Creek Steam Plant and at the proposed Bellefonte Nuclear Plant site. When sufficient design

information is available, application for FAA permits will be made. Appropriate markings and warning lights will be installed on these towers.

(5) Impact of support facilities - In defining the scope of this environmental statement, all identified major power system support facilities have been included. Although not specifically described, terminal structures and switching equipment will be required at the Bellefonte Nuclear Plant site and Widows Creek Steam Plant. These items do not require separate facilities but rather are part of the total facilities at each of these locations.

At this time no transmission line construction other than that described in the proposed action has been specifically identified to introduce the Bellefonte generation into the TVA system. It is assumed that in the future, as in the past, generation plant siting studies will consider existing plant expansion as well as new plant site development. On this premise, it is possible that transmission system needs may someday warrant additional line connections at Bellefonte Nuclear Plant. However, the same rigid environmental evaluations and tests will be applied to these facilities as early as possible in the planning process.

(6) General impacts - During normal operations no adverse environmental impact is expected to occur on either 500- or 161-kV transmission lines. During inclement weather and unusual atmospheric conditions a light humming may be heard directly under 500-kV lines, but this noise is rarely heard off the rights of way. Transmission lines can, under certain conditions, cause mild static charges to develop on fence wires and other ungrounded objects under the lines. These charges are

similar to the common static charges people experience when walking on certain types of indoor carpeting in dry weather.

The landowner retains all mineral rights to his land, and he may use the land for whatever purposes he wishes so long as such uses do not conflict with the terms of the easement. In many instances the existing land uses--particularly agricultural uses--may continue. However, such things as buildings, signboards, stored personal property, or other obstructions which create fire hazards and/or interfere with the operation and maintenance of the line may not be located on the rights of way. Except in very unusual situations, the transmission lines will have no effect on aerial crop dusting.

Damage to fences, gates, bridges, and other structures will be paid for or repaired by TVA following construction, and landowners are reimbursed by TVA for the value of crops damaged by construction or later maintenance activity.

6. Tentative transmission line route selections - Based on the above considerations, the tentative line routes and alternate routes for connecting the Bellefonte Nuclear Plant were investigated. The routes shown on figure 2.2-2 are feasible at present. However, changes within the next few years may require that these routes be shifted to avoid new development.

The enlarged insert shown on figures 2.2-1 and 2.2-2 shows the Bellefonte Nuclear Plant site, the 500-kV and 161-kV switchyards and land adjacent to the nuclear plant site which has been designated for various purposes. The community of Bellefonte, which may have historical importance,

is located at the southwest end of Town Creek inlet of Gunter'sville Reservoir. Considering these factors, route selections in the vicinity of the proposed nuclear plant were quite limited.

To provide electrical power for construction of the Bellefonte Nuclear Plant, a 2.7-mile temporary section of line will be constructed from the Hollywood-Scottsboro 46-kV Transmission Line to the Bellefonte Construction Substation. The line will be designed for 46-kV operation, using single-circuit, wood-pole construction, with post-type insulators, vertical-line configuration, and requiring a 50-foot-wide right of way. The line route is shown on figure 2.2-3. A tap structure will be installed at the point where the Hollywood-Scottsboro Transmission Line crosses an existing dirt road near U. S. Highway 72, approximately 2.8 miles northeast of Hollywood. From this point, the line will extend approximately 400 feet southeastward before crossing Highway 72. The line crossing will be at a 90-degree angle to the highway, and tree cover on the south side of the road will provide a visual shielding effect to highway traffic. The line will then continue in a southeastward direction across open and partially wooded land toward the Town Creek embayment a distance of 4,500 feet. The line will cross the Town Creek embayment stepping to a wooded island and then on to the Bellefonte property. Utilizing this island as an intermediate pole location will avoid the need for relatively tall structures to accomplish the otherwise long span. Because of the height of the line, clearing on the island will be limited to trimming and topping of some tall trees. Turning southward on the Bellefonte site, the line route traverses open land and will require very little clearing, but will be visually shielded from the river by a buffer of trees to the southeast.

For identification purposes the remaining line connections to Bellefonte Nuclear Plant which are shown on figures 2.2-1 and 2.2-2 are numbered as follows:

1. Bellefonte-Widows Creek No. 1 500-kV Transmission Line
2. Bellefonte-Madison 500-kV Transmission Line
3. Bellefonte-Widows Creek 161-kV Transmission Line
4. Bellefonte-Scottsboro 161-kV Transmission Line
5. Bellefonte-Widows Creek No. 2 500-kV Transmission Line
6. Bellefonte-Guntersville 500-kV Transmission Line

(1) Bellefonte-Madison 500-kV and Bellefonte-Widows Creek No. 1 500-kV Transmission Lines - The existing Widows Creek-Madison 500-kV Transmission Line will be looped into the Bellefonte Nuclear Plant to form the Bellefonte-Madison 500-kV and Bellefonte-Widows Creek No. 1 500-kV Lines. As seen from figure 2.2-2, the existing line is located to the west of Guntersville Reservoir; therefore, a routing from the nuclear plant site in a northwestward direction is desirable. The proposed routes are shown schematically on figure 2.2-2 and are designated Routes 1 and 2. They leave the substation switchyard generally in a northwestward direction crossing the Town Creek inlet of Guntersville Reservoir to the north of the community of Bellefonte. This route will pass south of a small residential area located on the north bank of Town Creek embayment. In the vicinity of U. S. Highway 72, the proposed route swings westward, threading its way between the developed area at Hollywood, Alabama, to the south and Poorhouse Mountain to the north.

Skirting the southwest side of Poorhouse Mountain, the line turns northward traversing mostly low undeveloped terrain along Pegues Branch before crossing Robinson and Mud Creeks. Continuing on this projection, the line passes the rural community of Kyles before ascending to the flat area on the top of Crow Mountain and thence to an intersection with the existing Widows Creek-Madison 500-kV Line. The last four miles of this route are remote and sparsely populated.

From the vicinity of U. S. Highway 72, alternate Routes 1a and 2a were investigated. These alternate routes, shown on figure 2.2-1, would skirt the lower slopes of Poorhouse Mountain along its northeast side before entering the marsh land drained by several tributaries of Mud Creek. From the Mud Creek area, the routes would swing north following the bottom land through Carns Cove before ascending Crow Mountain to intersect with the existing Widows Creek-Madison 500-kV Transmission Line.

The length of right of way required for the preferred route and alternate route is approximately the same. The alternate routes, however, were found to be less desirable because the land between Poorhouse Mountain and the Mud Creek Embayment has significant residential and second home development potential. Although located south of the Mud Creek Wildlife Management Area proper, transmission lines along the alternate routes could potentially be a conflict with wildlife along the upper reaches of the creek not specifically included in the managed area.

Each leg of 500-kV loop connection shown as Route 1 and 2 respectively is approximately 12.3 miles long with 11.1 miles being constructed on 350-foot-wide right of way. The remaining 1.2-mile section

is constructed on right of way 450 feet wide common with the 161-kV connections to Bellefonte described below.

(2) Bellefonte-Widows Creek and Bellefonte-Scottsboro 161-kV Transmission Lines - Off-site station service power for Bellefonte Nuclear Plant will be provided by looping the Widows Creek-Scottsboro 161-kV Transmission Line into the nuclear plant to form the Bellefonte-Widows Creek and Bellefonte-Scottsboro 161-kV Transmission Lines. These line routes which are shown schematically as Routes 3 and 4 respectively will leave the Bellefonte switchyard in a northwestward direction until they intersect with the existing 161-kV line, a distance of about 1.2 miles. These lines will be constructed parallel to and on opposite sides of the Widows Creek-Madison 500-kV loop connection previously described. This will provide sufficient 161-kV line separation to comply with the safety criteria<sup>5</sup> set forth by the Atomic Energy Commission.

(3) Bellefonte-Widows Creek No. 2 500-kV Transmission Line - Coincidental with the installation of the second generator unit at Bellefonte Nuclear Plant will be the need for two additional transmission connections. One of these transmission line connections will be made by constructing a 500-kV line from the Bellefonte Nuclear Plant to the Widows Creek Steam Plant. Several route locations were investigated for this connection and the one causing the least environmental impact is proposed. The proposed route is shown schematically as Route 5 on figure 2.2-2 and is described below.

At Widows Creek Steam Plant, the route for the proposed transmission line will exit the 500-kV switchyard in a southeasterly

direction and immediately cross the Tennessee River on towers common with the Widows Creek-Raccoon Mountain 500-kV Line. This will avoid the development of an additional and separate crossing elsewhere along the river. After crossing the river, the line turns southwestward paralleling the Tennessee River for some 12 miles at a distance of 2,000 to 3,000 feet from the river. The relatively flat land located between the line route and the river is controlled by the State of Alabama and is managed as the Raccoon Creek Waterfowl Management Area. In conjunction with the State of Alabama Department of Conservation - Division of Game and Fish, a mutually acceptable line route has been developed. This 12-mile section of line will be screened from view from the river as it traverses scattered woodland, open pasture, and some open land under cultivation. At the crossing of Alabama State Highway 117, heavy tree growth on each side of the road will be retained to screen the transmission line structures from public view along the highway. Approximately two miles southwest of Highway 117, the proposed route has been carefully located to avoid interference with TVA's Crow Island Yellow Poplar Fertilizer Study Test Area.

From the end of this 12-mile section, the line crosses a narrow point at the mouth of Coon Creek and ascends to the top of Sand Mountain. At the Coon Creek crossing, the only land development in the area consists of a small group of summer cottages which are located approximately one mile east of the proposed route. Heavy woodlands will be traversed in ascending the mountain; however, tower placement near the escarpment will be strategically located to minimize visibility.

After reaching the top of Sand Mountain, the line generally parallels the river southwestward to a point opposite the Bellefonte Plant site. Along this route alternately open farmland, pasture and wooded farm lots are traversed. The line projection was selected to avoid intrusion on the Pisgah community. There are no known recreational areas located along this line route. In the vicinity of the proposed Bellefonte Plant site, at TR-mile 390.6, the line turns northwestward crossing the Tennessee River on common towers with the Bellefonte-Guntersville 500-kV Line. West of the river, the proposed line will follow the route shown on the enlarged insert on figure 2.2-2. No formal recreational or wildlife management areas exist for several miles on either side of the river at this location. Route 5 is approximately 19.9 miles long, and requires a 200-foot right of way. About 1.5 miles of this route will be located on the proposed Bellefonte Nuclear Plant site property.

Since the Bellefonte Nuclear Plant and the Widows Creek Steam Plant are both located west of the Tennessee River, a route west of the river was investigated. The location shown as Route 5a on figure 2.2-1 was considered. The route would have paralleled the new section of the Bellefonte-Widows Creek 161-kV Transmission Line over the Town Creek inlet and then have turned northeastward paralleling the existing portion of the Bellefonte-Widows Creek 161-kV Line to the Widows Creek Steam Plant Switchyard. This proposed route would have crossed U.S. Highway 72 twice and the Mud Creek and Little Crow Creek Wildlife Game Refuges. The land adjacent to U.S. Highway 72 is rapidly developing, and some of the land along Mud Creek and Little Crow Creek

inlets has residential development potential. The arrangement of the 161-kV and 500-kV switchyards at Widows Creek Steam Plant would require a 500-kV transmission route from this direction to cross over 13 existing 161-kV transmission lines.

Present developments along Route 5a would not totally eliminate it from consideration at the present time; however, future developments along U.S. Highway 72 probably will make rights of way unavailable for line construction when required in 1976. Therefore, Route 5 previously described was selected as the preferred route for this connection over 5a.

Another route location which was investigated for the Bellefonte-Widows Creek No. 2 500-kV Transmission Line is shown as Route 5b on figure 2.2-1. This alternate would exit the Widows Creek 500-kV Switchyard along the same route described for Route 5 until it intersects with the existing Widows Creek-Ft. Payne 161-kV Transmission Line. From this intersection, the route would parallel the Widows Creek-Ft. Payne 161-kV Line on adjacent right of way. This parallel routing would proceed southeastward to the top of Sand Mountain and continue for approximately six miles before turning southward to circumvent coal mining operations on top of the mountain. To avoid several road crossings and farmland in active use along these roads, the route then turns westward through wooded terrain to a point south of Coon Creek and about 1.75 miles east of the Tennessee River. From this point, the line again follows the same location proposed for Route 5 to the Bellefonte site.

This alternate route would traverse rugged, heavily forested terrain and would be approximately 40 percent longer than the preferred route. Although avoiding known land use conflicts and utilizing parallel line construction to minimize rights of way requirements, the alternate line section would require approximately 72 acres more in total rights of way and 147 acres of additional wooded land clearing. Therefore, Route 5 is preferred over 5b.

(4) Bellefonte-Guntersville 500-kV Transmission

Line - The fourth 500-kV connection to the Bellefonte Nuclear Plant will be provided by constructing the Bellefonte-Guntersville 500-kV Transmission Line. A major part of this transmission line will be required under Step II of this project, and the balance of the line will be completed as Step IV. Two routes were investigated for this line, the first of which is shown as Route 6 on figure 2.2-2. This route leaves the Bellefonte 500-kV switchyard in a northwestward direction for one or two spans, then turns southwestward until it intersects with the southern property line of the Bellefonte Nuclear Plant site. The route then turns southeastward and follows the property line, crossing the Tennessee River at river mile 390.6. From the switchyard to the river crossing, Route 6 parallels Route 5 and both lines cross the Tennessee River and ascend Sand Mountain on double-circuit transmission line towers, thereby minimizing right of way and the number of separate river crossings.

After clearing the Sand Mountain escarpment, the line diverges from the river in a southerly direction to avoid crossing the inlet of Jones Creek which has good water base recreational potential.

From the Jones Creek inlet, the route proceeds generally southward passing east of Dutton, Alabama, to avoid the residential developments surrounding this small community. This projection locates the proposed line close to an area north of Dutton which has been identified for potential industrial park development. After clearing existing and proposed land developments adjacent to Dutton, the line turns southwestward to avoid productive farmland south of town and to establish a more direct projection toward Guntersville.

Continuing in a general southwesterly direction, the line parallels the Tennessee River at a varying distance of 2 to 3 miles. The line will be routed south of existing and proposed developments near Section, Alabama, including two potential industrial park areas. One industrial park site is located northeast of Section on State Highway 71 and a second site is southeast of Section and adjacent to State Highway 35.

The route then skirts the western edge of Davistown, Alabama, but remains sufficiently westward to avoid conflicts with identifiable land use commitments in this area. The major portion of this line traverses sparsely populated areas, woodlands, and scattered farmland. Only two roads, Alabama State Highway 35 southeast of Section, Alabama, and State Highway 71 northeast of Dutton are crossed by this line. Both crossings were carefully selected to utilize existing woodlands to screen or provide a background to minimize visual awareness of the line. Conflicts with scattered rural homes along the highway were avoided.

Approaching the South Sauty Creek inlet of Guntersville Reservoir, the route has been aligned to effect a crossing of the inlet

at a narrow point. This crossing is located downstream from the Buck's Pocket State Park and sufficiently upstream to avoid conflict with developable recreation areas. It is anticipated that a single-span crossing of the inlet can be accomplished which will greatly reduce the right of way clearing requirements in the embayment area. From this crossing, the line turns westward through heavily wooded terrain for three miles to the Guntersville 500-kV Substation site where it will connect to a separately proposed intersystem tie line to be jointly constructed by the Alabama Power Company and TVA.

An alternate route which was investigated for this line is shown schematically as 6a on figure 2.2-1. This route leaves the Bellefonte 500-kV switchyard in a northwestward direction until it intersects the existing Widows Creek-Scottsboro 161-kV Transmission Line. The route then turns southwestward and parallels the above mentioned line for about 2.5 miles. The next 2.5-mile section then turns generally southward and crosses the Tennessee River north of Alabama State Highway 35. Approximately one mile of this section adjacent to Dry Creek has marginal developmental potential and is aligned to provide a 90° crossing of the Tennessee River. About one-half mile east of the river, the route heads southwestward to the future Guntersville, Alabama, 500-kV Substation site. The land on the northwest bank of the river and adjacent to the proposed river crossing is rapidly being developed. The river crossing is south of the Boy Scouts of America Campground and north of the Section Bluff Cabin Site Area. Route 6a is about 29 miles long of which 4.5 miles is parallel to either proposed or existing transmission lines.


The land northeast of Scottsboro, Alabama, has good industrial development potential because of the accessibility of rail, road, and river transportation in the area. Future industrial developments in this area probably will make this part of Route 6a unavailable for line construction when required. Route 6a would necessitate the construction of additional crossings of the Tennessee River and the Town Creek inlet.

Another alternate route location which was investigated for a section of the Bellefonte-Guntersville 500-kV Line is shown as Route 6b on figure 2.2-1. This alternate was considered to provide a more remote passage of both Dutton and the Jones Creek embayment. However, in avoiding the Pisgah, Alabama, community, this route produced an unacceptable conflict with the air traffic pattern at Griffith Airfield which is located southwest of Pisgah. Although the line distance of this alternate route is approximately equal to the preferred route, an additional five miles of transmission line construction would be required at a later date to connect the line to TVA's proposed Bellefonte Nuclear Plant.

After considering the advantages and disadvantages of all locations, Route 6 was selected as the preferred route.

REFERENCES FOR SECTION 2.2


1. U.S. Department of the Interior and U.S. Department of Agriculture, Environmental Criteria for Electric Transmission Systems, Washington, D.C., U.S. Government Printing Office, 1970, O-404-932.
2. Leopold, Aldo., Game Management: Charles Scribners Sons, New York, 1933, p. 131.
3. Odum, E. P., Fundamentals of Ecology: W. B. Saunders Company, 1959, pp. 278-281.
4. Tennessee Valley Authority, Division of Forestry, Fisheries, and Wildlife Development and Tennessee Game and Fish Commission, What Can You Do To Benefit Wildlife on Your Land?, 1969.
5. General Design Criteria 17, Electric Power Systems, Appendix A to Title 10 Code of Federal Regulations, Part 50.



**LEGEND**

- Alt. Route 
- Existing or Separately Proposed 
- Generating Plt. 
- Substation 

Figure 2.2-1  
**TRANSMISSION FACILITIES**  
 Bellefonte Area



**LEGEND**

- Proposed Route
- Existing or Separately Proposed
- Generating Plt.
- Substation

Figure 2.2-2  
**TRANSMISSION FACILITIES**  
 Bellefonte Area

2.2-35




Figure 2.2-3  
CONSTRUCTION POWER FACILITIES  
Bellefonte Site

2.3 Radiological Effects of Accidents - To aid in developing the overall balancing of environmental costs and benefits of the Bellefonte Nuclear Plant, an assessment has been made of the consequences that might result from the occurrence of postulated accidents. In order to appraise realistically the environmental risks of postulated radiological accidents, parameters, physical characteristics, and phenomena which reflect the present state of the art have been used in the analyses. Best estimates are used where experimental evidence is not sufficient to describe a situation. This approach to the analyses is therefore different from that used in safety analysis reports where conservative values are used to establish limits for design bases.

In accordance with AEC requirements, TVA submitted with its application for permits to construct units 1 and 2 a safety analysis report which describes the technical features of the plant and the provisions for ensuring the health and safety of the public. The analyses presented in this safety analysis report demonstrates that even for postulated accidents of great severity analyzed using highly conservative assumptions, the radiological consequences would be within the reference values of 10 CFR Part 100.

Those postulated accidents having the potential for uncontrolled release of radioactive material to the environment have been divided by the Atomic Energy Commission into nine classes based on the systems involved and the type and potential consequences of the release. These classes are shown in Table 2.3-1. The accident analyses presented in Appendix G are based on the guidance given by AEC in the proposed annex to Appendix D, 10 CFR 50.<sup>1</sup> This approach will allow comparison between reactors of different types at different sites.

In order to assess risk, some measure of probability is required. In general, TVA believes that certain "accidents" may reasonably be expected to occur during the lifetime of the plant. These (accident subclasses 1.0, 2.0, and 5.1) are included in the estimates of routine radioactive discharges. The accidents in classes 3.0 and 5.0 are not expected to occur during the 40-year lifetime of the plant. Accidents in classes 6 and 7 are relatively less probable but still are possible. The probability of occurrence of class 8 accidents is very small. The postulated occurrences in class 9 involve sequences of successive failures more severe than those required to be considered in the design basis of protection systems and engineered safety features. Their consequences could be severe. However, the probability of their occurrence is so low that their environmental risk is extremely small. Defense in depth (multiple physical barriers), quality assurance for design, manufacture and operation, continued surveillance and testing, and conservative design are all applied to provide and maintain the required high degree of assurance that potential accidents in this class are, and will remain, sufficiently low in probability that the environmental risk is extremely small.

Appendix G of this statement, "Outline of Accident Analyses," describes the accidents analyzed and the more important assumptions. In general, coolant activities are based on 0.5 percent failed fuel (as indicated by Reference 1), and on fuel element fission product inventories calculated using the model given in TID-14844.<sup>2</sup> Atmospheric dispersion values are shown in Figure G-1 and Safety Guide No. 4.<sup>3</sup> Doses to hypothetical individuals at the minimum exclusion distance (1,085 meters) and the dose commitment to the population within 50 miles

of the plant are presented in Table 2.3-2. A more detailed discussion is given in Appendix G. Reasonable assumptions other than those given in Reference 1 can be used to calculate releases, but the conclusions as to the environmental risks due to postulated radiological accidents will be similar.

Table 2.3-2 shows that the estimated integrated exposure of the population within 50 miles of the plant from each postulated accident would be orders of magnitude smaller than that from naturally occurring radioactivity, which corresponds to approximately 240,000 man-rem/yr based on a natural background level of 0.145 rem/yr. When multiplied by the probability of occurrence, the annual potential radiation exposure of the population from all the postulated accidents is an even smaller fraction of the exposure from natural background radiation and, in fact, is well within naturally occurring variations in the background. It is concluded from the results of the analysis that the environmental risks due to postulated radiological accidents are exceedingly small.

REFERENCES FOR SECTION 2.3

1. "Consideration of Accidents in Implementation of the National Environmental Policy Act of 1969," Federal Register, Vol. 36, No. 231 (December 1971), p. 22851.
2. Di Nunno, et al. "Calculation of Distance Factors for Power and Test Reactor Sites," TID-14844.
3. Atomic Energy Commission. "Assumptions Used for Evaluating the Potential Radiological Consequences of a Loss-of-Coolant Accident for Pressurized Water Reactors," AEC Safety Guide No. 4.

TABLE 2.3-1

CLASSIFICATION OF POSTULATED ACCIDENTS AND OCCURRENCES

<u>No. of Class</u>	<u>Description</u>	<u>Example(s)</u>
1	Trivial incidents	Small spills Small leaks inside containment
2	Miscellaneous small releases outside containment	Spills Leaks and pipe breaks
3	Radwaste system failures	Equipment failure Serious malfunction or human error
4	Events that release radioactivity into the primary system	Fuel failures during normal operation; transients outside expected range of variables
5	Events that release radioactivity into the secondary system	Class 4 & heat exchanger leak
6	Refueling accidents inside containment	Drop fuel element Drop heavy object onto fuel Mechanical malfunction or loss of cooling in transfer tube
7	Accidents to spent fuel outside containment	Drop fuel element Drop heavy object onto fuel Drop shielding cask--loss of cooling to cask Transportation incident <u>onsite</u>
8	Accident initiation events considered in design-basis evaluation in the Safety Analysis Report	Reactivity transient Rupture of primary piping Flow decrease--steamline break
9	Hypothetical sequences of failures more severe than Class 8	Successive failures of multiple barriers normally provided and maintained

Table 2.3-2

## SUMMARY OF RADIOLOGICAL CONSEQUENCES OF POSTULATED ACCIDENTS

<u>Class</u>	<u>Event</u>	<u>Individual Doses At the Exclusion Distance (Fraction of 10 CFR 20 Limit)</u>	<u>Dose Commitment To Population (Man-Rem)</u>
1.0	Trivial incidents	*	*
2.0	Small releases outside contain- ment	*	*
3.0	Radwaste system failures		
3.1	Equipment leakage or malfunction	$4.2 \times 10^{-1}$	$4.1 \times 10^1$
3.2	Release of waste gas storage tank contents	1.6	$1.6 \times 10^2$
3.3	Release of liquid waste storage tank contents	$4.1 \times 10^{-2}$	7.3
4.0	Fission products to primary system (BWR)	NA	NA
5.0	Fission products to primary and second- ary systems (PWR)		
5.1	Fuel cladding defects and steam generator leaks	*	*
5.2	Offdesign transients that induce fuel failure above those expected and steam generator leak	$2.3 \times 10^{-3}$	$3.0 \times 10^{-1}$
5.3	Steam generator tube rupture	$2.3 \times 10^{-1}$	$2.6 \times 10^1$
6.0	Refueling accidents		
6.1	Fuel bundle drop	$8.8 \times 10^{-3}$	$9.8 \times 10^{-1}$
6.2	Heavy object drop onto fuel in core	$1.8 \times 10^{-1}$	$2.0 \times 10^1$

\*Evaluated as routine release in section 2.4.

Table 2.3-2  
(Continued)

SUMMARY OF RADIOLOGICAL CONSEQUENCES OF POSTULATED ACCIDENTS

<u>Class</u>	<u>Event</u>	<u>Individual Doses At the Exclusion Distance (Fraction of 10 CFR 20 Limit)</u>	<u>Dose Commitment To Population (Man-Rem)</u>
7.0	Spent fuel handling accident		
7.1	Fuel assembly drop in fuel storage pool	$8.8 \times 10^{-3}$	$9.8 \times 10^{-1}$
7.2	Heavy object drop onto fuel rack	$7.8 \times 10^{-3}$	$9.6 \times 10^{-1}$
7.3	Fuel cask drop	$1.2 \times 10^{-3}$	$1.2 \times 10^{-1}$
8.0	Accident initiation events considered in design basis evaluation in safety analysis report		
8.1	Small loss-of-coolant	$7.5 \times 10^{-5}$	$1.4 \times 10^{-2}$
8.1	Large loss-of-coolant	$3.2 \times 10^{-1}$	$5.4 \times 10^1$
8.1a	Instrument line break	NA	NA
8.2(a)	Rod ejection accident	$3.3 \times 10^{-2}$	5.7
8.3(a)	Small MSIR	$6.5 \times 10^{-7}$	$2.0 \times 10^{-4}$
8.3(a)	Large MSIR	$3.4 \times 10^{-6}$	$1.0 \times 10^{-3}$

2.4 Radioactive Discharges -

1. Waste management policy - TVA's policy is to keep the discharge of all wastes from its facilities, including nuclear plants, at the lowest practicable level by using the best and highest degree of waste treatment available under existing technology within reasonable economic limits.

All equipment installed by TVA to reduce radioactive effluents to the minimum practical level will be maintained in good operating order and will be operated to the maximum extent practicable. The waste treatment facilities can be modified or supplemented if a higher degree of treatment should be required in the future.

The radioactive waste disposal system provided under TVA's contract with Babcock & Wilcox afforded a high degree of waste treatment. As the design progressed, several changes were made to further reduce radioactivity releases. Under the original system all liquid wastes were treated and discharged. With the proposed system tritium-containing liquids are to be segregated from those low in tritium and the tritium-containing water is treated and recycled. Since most of the radioactivity is associated with the tritium-containing liquid, this change significantly reduces the amounts of tritium and other radioactive materials to be discharged from the plant.

Another change was the addition of an auxiliary waste evaporator to process so-called nontritiated liquids as well as spent regenerant solutions from the condensate demineralizers. The original system did not provide for the spent regenerants, which, in the event of steam generator leakage, would contain radioactive materials.

The installation of additional equipment for extended treatment of radwaste to reduce exposure of the general public may

cause increased exposure of plant personnel. The majority of the exposure will be received during maintenance of processing equipment. Consideration is being given to location, operational requirements, and maintenance schedules in order to minimize unnecessary exposure to personnel during work involving the additional equipment. The protection provided the employee during the time he is working in the plant is addressed in detail in the Bellefonte Nuclear Plant Preliminary Safety Analysis Report.

Evaluation of the gaseous waste system showed that gas decay tanks, originally designed for 45-day storage, have adequate capacity to store gas for 60 days. TVA will operate the tanks with a minimum storage time of 60 days.

Additional changes include the provision of high-efficiency particulate filters and charcoal iodine-removal filters to reduce radioactivity emission at several points of gaseous release.

2. Origins of radioactivity released - Radioactivity released from the plant results from the deliberate removal of liquid from the reactor coolant system or by leakage of this liquid. Radioactive materials present in the reactor coolant are produced in the following ways:

1. Fissioning creates radioactive fission products in the fuel which leak out through perforations in the fuel clad.
2. Corrosion products are derived from metallic components in the reactor coolant system which are made radioactive by neutron interaction as the corrosion products circulate with the reactor coolant through the reactor core.
3. Oxygen combined as water in the reactor coolant interacts with neutrons to produce the radioactive isotopes nitrogen-13,

nitrogen-16, and oxygen-19.

Radioactive materials produced by these methods are either dissolved or suspended in the reactor coolant. The dissolved materials include the radioactive noble gases, xenon and krypton.

Radioactive tritium is an isotope of hydrogen. While it may originate in elemental form, it is normally found in the coolant combined as HTO. The separation of HTO from H<sub>2</sub>O cannot be accomplished by ordinary chemical means. Complex and expensive multi-stage processes are required, and it is not now feasible to carry out the separation at a nuclear power station. Tritium is formed by the following methods:

1. Tritium is formed as one of the fission products. Approximately 1 percent of the tritium so formed escapes from the fuel through perforations in the clad or by diffusion through the clad.
2. Boron and lithium, which are normal constituents of the reactor coolant, interact with neutrons to produce tritium.
3. Deuterium, an isotope of hydrogen present in small amounts in water, can absorb a neutron to become tritium.

If boron carbide were used as the neutron absorber in the reactor control rods, this would be an additional and major source of tritium. The Bellefonte reactors, however, will use silver-indium-cadmium in the control rods instead of boron carbide, thereby avoiding this mode of tritium production.

The estimated concentrations of radioactive materials in the reactor coolant liquid are given in Table 2.4-1. Table 2.4-2 gives escape rate coefficients used in estimating the reactor coolant activity, and Table 2.4-3 lists the bases for the determination of coolant activity.

3. Radioactive waste disposal system - The radioactive waste disposal system includes facilities for the treatment of liquid, gaseous, and solid wastes.

(1) Makeup and purification, chemical addition and boron recovery systems - These systems, while technically not a part of the waste disposal system, are discussed here because they treat for recycle large quantities of liquid that would otherwise be waste and because they constitute the principal pathway by which radioactive gases enter the gaseous waste disposal system. The basic portions of these systems are shown schematically in figure 2.4-1. Each reactor unit has a separate makeup and purification system. Each also has a chemical addition and boron recovery system with crossties to the corresponding system of the other reactor.

The makeup and purification system is in continuous use during reactor operation. It may also be used during shutdowns, including refueling outages.

Reactor coolant is withdrawn from the reactor coolant system at a rate of 50 gal/min, is reduced in pressure, and is cooled by passage through a heat exchanger. The cooled liquid is filtered and is passed through purification demineralizers. The liquid then passes through another filter before entering the makeup tank. A hydrogen atmosphere is provided in the makeup tank to maintain a dissolved hydrogen content of about 30 cc H<sub>2</sub>/kg in the coolant. The dissolved hydrogen suppresses the radiolysis of water in the reactor and combines with any free oxygen that may be present. Liquid is pumped back to the reactor coolant system from the makeup tank.

During shutdown of the reactor, gas released from the coolant as it cools is vented from the makeup tank to the gaseous waste disposal system.

In order to change the boron concentration in the reactor coolant, a quantity of coolant is transferred to the chemical addition and boron recovery system via the makeup and purification system. A corresponding quantity of boric acid and distillate is supplied to the reactor coolant system through the makeup tank. Boron concentration changes are made during base-load operation for chemical shim adjustment and are made each time a significant change in reactor power is made. Concentration changes are made also at each startup and shutdown.

These functions are carried out by the chemical addition and boron recovery system. Liquid is transferred from the makeup and purification system at a point downstream of the demineralizers and is collected in a 120,000-gallon reactor coolant bleed tank. Letdown of the coolant to a pressure slightly above atmospheric in the bleed tank releases much of the dissolved hydrogen, xenon, and krypton from the liquid to the gas space in the tank, from which it is transferred to the gaseous waste disposal system. Liquid is pumped from the bleed tank through a mixed-bed demineralizer and a filter to a 30-gal/min reactor coolant bleed evaporator. Distillate from the evaporator is collected in one of a pair of test tanks, from which it is pumped through a demineralizer to a 120,000-gallon distillate storage tank. The evaporator concentrate, containing from 5 to 7 percent boric acid, is pumped to one of two 31,000-gallon boric acid storage tanks. Recovered distillate and boric acid are supplied to the reactor coolant system via the makeup and purification system in the proportions and amounts required.

The evaporation process removes substantially all of the hydrogen and noble gases from the liquid. The gases vented from the evaporator are sent to the gaseous waste disposal system.

Recovered distillate will be low enough in radioactivity content to permit storage in tanks without shielding. Shielding will be provided for the boric acid tanks, but it too is expected to be low in radioactivity content.

(2) Liquid waste disposal system - The sources of radioactive wastes, the estimated amounts, and the bases for these amounts are given in Table 2.4-4. A portion of the waste is relatively high in tritium content, while the remainder contains little tritium. Drains which normally carry tritiated liquid are segregated from those which normally carry nontritiated liquid. In a few instances, where a waste source may be of either category (e.g., reactor building floor drain collector tank contents), provision is made to route the liquid either way. It is necessary to have a dividing line between tritiated and nontritiated liquid. TVA has decided to treat liquid which has a tritium concentration equal to 10 percent or more of the reactor water tritium concentration as tritiated water. Although the dividing line varies from day to day, this particular formula permits operating practices to remain fairly constant throughout plant life.

(a) Tritiated liquid waste -

The essential features of the system for treating tritiated liquid waste is shown in figure 2.4-2.

Leakage from the reactor coolant system is collected in equipment drains and routed to reactor coolant drain tanks.

Normally, this liquid is then pumped to the reactor coolant bleed tank for processing in the chemical addition and boron recovery system. It may, however, be transferred to the tritiated waste holdup tank.

Tritiated liquids from the sources shown in Table 2.4-4 are collected in the tritiated waste holdup tank. Periodically, a batch of liquid is processed by filtering and evaporating. The concentrates from the 2-gal/min waste evaporator are sent to solid waste disposal for packaging. The distillate is collected in one of two test tanks. The distillate is then passed through a demineralizer to the distillate storage tank, which is a part of the chemical addition and boron recovery system. From there, the liquid is recycled to the reactor coolant system.

TVA intends to recycle tritiated water back into the primary system until the primary coolant tritium concentration reaches a maximum desirable level. The exact concentration which will be considered the maximum level will be determined largely by doses which could be received by plant personnel during refueling operations. Tentatively, this concentration has been set at 2.5  $\mu\text{Ci/ml}$  for analysis purposes, and based on the assumptions used for estimating routine releases, this level would be reached about 7 years after startup. Tritiated water will be periodically extracted from the primary system to maintain the maximum level.

TVA has studied several alternate methods of disposal of tritiated water. TVA will continue its investigations into the questions posed by tritium recycle including the transfer of tritiated water to an AEC-approved disposal area. If future developments indicate that it is desirable to permit controlled releases of tritium, TVA will modify its operations accordingly.

Figure 2.4-3 shows the buildup of tritium in the primary system and in the refueling water volume for each unit, based on maintaining an upper limit of 2.5  $\mu\text{Ci/ml}$  in the primary system. The upper curve describes the tritium concentration in the primary system as a function of time. The tritium concentration of the refueling water is given by the bottom of each vertical line. For example, during the refueling outage at year 5, the tritium concentration in the refueling volume (not including the spent fuel pool) is 0.5  $\mu\text{Ci/ml}$ . The water returned to the refueling water tank after the refueling is at this same concentration. The concentration in the primary system following refueling is 1.7  $\mu\text{Ci/ml}$  and increases to 2.3  $\mu\text{Ci/ml}$  during the subsequent fuel cycle.

At any time except during refueling, the volume of water in the primary system is approximately 165,000 gallons. This includes water in the reactor coolant system, the primary makeup water storage tank, the CVCS holdup tank, the CVCS monitor tank, and the tritiated waste holdup tank. The tanks are assumed to be partly full at normal operating levels. The refueling water volume is approximately 600,000 gallons. Amounts of water that must be removed to maintain a maximum tritium concentration of 2.5  $\mu\text{Ci/ml}$  are noted on the curve.

The maximum amount of tritium in storage at any time is about 8,600 Ci (both units).

It is impossible to totally prevent release of tritium from a nuclear power plant by reasonable means. Vaporization from the refueling canal and spent fuel pit carries off significant amounts of tritium. In addition, some secondary liquids

and vapors must be released from the plant, and at times these will contain small amounts of tritium which have leaked into the secondary system from the primary system. Expected sources of tritium release include purging of the containment and fuel storage areas, condenser vacuum pump effluent during periods of steam generator leaks, and any leakage which is at a tritium concentration too low to be recycled.

The amount of tritium discharged will vary depending on the concentration of tritium in the primary coolant, the primary to secondary leakage rate, and the period of operation with a primary to secondary leak. Assuming tritium recycle, if each reactor had a primary to secondary leak of 20 gallons per day which persisted for a year, the total tritium release from the secondary system would be about 140 curies.

(b) Nontritiated liquid waste -

The essential features of the nontritiated liquid waste system are shown on figure 2.4-4. These wastes are treated for recycle to the secondary system or for discharge to Gunterville Reservoir after dilution by the cooling tower blowdown stream.

The degree of treatment given a particular batch of a liquid depends on its radioactivity concentration. As shown in figure 2.4-4, the contents of the nontritiated waste holdup tank can be treated by filtration or by evaporation. If the gross radioactivity concentration (other than tritium) of this liquid is greater than  $10^{-4}$   $\mu\text{Ci/ml}$ , it will be treated by evaporation to reduce the concentration in the distillate to below  $10^{-4}$   $\mu\text{Ci/ml}$ . If the gross radioactivity concentration is less than  $10^{-4}$   $\mu\text{Ci/ml}$ , the liquid will be treated by filtration prior to discharge. The same

radioactivity guideline will be applied to spent regenerants and chemical drains. Laundry, hot shower, and cask decontamination drains are not expected to exceed  $10^{-4}$   $\mu\text{Ci/ml}$ , but they will be monitored and if they do exceed this value they can be transferred to the nontritiated waste holdup tank for processing by evaporation.

Nontritiated liquids from floor and equipment drains are collected in the nontritiated waste holdup tank. If analysis shows the radioactivity concentration to be below  $10^{-4}$   $\mu\text{Ci/ml}$ , the liquid is pumped through a filter to the plant discharge. If above  $10^{-4}$   $\mu\text{Ci/ml}$ , the liquid is pumped to the auxiliary waste evaporator. The concentrates from the evaporator are sent to solid waste disposal for packaging. The distillate is collected in one of two test tanks for determination of radioactivity and chemical content. It is then either pumped through a demineralizer to one of the condenser hotwells for reuse in the secondary system or it is pumped to the plant discharge. In the event that the distillate meets neither recycle or discharge standards, it is pumped to the nontritiated waste holdup tank for reprocessing.

The treatment given the liquids in the chemical drain tank depends on their chemical and radioactivity contents. If it contains chemicals that cannot be discharged or would be harmful to the evaporator, the liquid is sent to solid waste disposal for packaging. If free of harmful chemicals and below  $10^{-4}$   $\mu\text{Ci/ml}$  in radioactivity, the liquid is discharged after filtration. If free of chemicals that would be harmful to the evaporator and above  $10^{-4}$   $\mu\text{Ci/ml}$ , the liquid is processed in the auxiliary waste evaporator. The distillate is recycled to the secondary system or is discharged.

Laundry and hot shower drains, after sampling and analysis, are filtered prior to discharge. In the unlikely event that the radioactivity concentration exceeds  $10^{-4}$   $\mu\text{Ci/ml}$ , the liquid is transferred to the nontritiated waste holdup tank for further treatment. Spent fuel cask decontamination drains are handled in a similar manner.

The Bellefonte plant uses once-through-type steam generators, which operate without blowdown. Condensate demineralizers are employed to provide water of adequate quality for the steam generators. These demineralizers are regenerated periodically with sulfuric acid, sodium hydroxide, and ammonium hydroxide. In the event of a primary to secondary leak in a steam generator, the secondary system will become contaminated with constituents of the primary system, including radioactive materials. Radioactive gases separated in the condenser will be released via the vacuum pump exhaust. Radioactive dissolved and suspended materials will accumulate in the condensate demineralizers. When the demineralizers are regenerated, these materials will be contained in the spent regenerant solutions. The solutions are collected in the spent regenerants tank, where sulfuric acid is added to neutralize excess alkali. If the solution contains less than  $10^{-4}$   $\mu\text{Ci/ml}$ , it will be discharged. If above  $10^{-4}$   $\mu\text{Ci/ml}$ , it will be processed. At a time when the auxiliary waste evaporator is not in use with other wastes, the contaminated spent regenerant solutions are fed to the evaporator. The distillate and concentrates will be handled as in the case of liquids from the nontritiated waste holdup tank.

The condensate demineralizers are located in the turbine building. Liquid leaks in the demineralizer area are collected in a sump and are pumped into the spent regenerants tank. Liquid leaks in the remainder of the turbine building, including those from condensate and feedwater lines, are collected in the turbine building sump. Sump liquid is sampled and analyzed for radioactivity prior to discharge. The amount of radioactivity associated with this liquid will be small, and no provision is made for processing it.

(c) Discharge of radioactive liquids - Any batch of potentially radioactive liquid released from the plant is first sampled and analyzed. Liquids from the waste disposal system are discharged through the waste discharge line which connects into the cooling tower blowdown line. The waste discharge line includes a flowmeter, a locked-closed valve, a radiation-controlled valve, and in-line radiation monitor, and a valve controlled by flow in the cooling tower blowdown line. The radiation-controlled valve is automatically closed when the monitor detects a concentration in excess of  $10^{-4}$   $\mu\text{Ci/ml}$ . The flow rate in the cooling tower blowdown line will range from zero to about 33,000 gal/min. A flowmeter in the blowdown line is interlocked with the flow-controlled valve in the waste discharge line such that the valve is closed when the blowdown flow rate is less than 15,000 gal/min.

Waste can only be pumped into the waste discharge line; flow by gravity does not take place. The radwaste operator controls the waste discharge rate to keep the concentration in the tower blowdown line below  $10^{-7}$   $\mu\text{Ci/ml}$  at all times. On an annual average basis the concentrations will not exceed the limits proposed in Appendix I to 10 CFR Part 50.

(3) Gaseous waste disposal system - The radioactive noble gases krypton and xenon are dissolved in the reactor coolant. When the reactor coolant pressure is reduced to near-atmospheric pressure, the gases tend to come out of solution, along with hydrogen and some radioactive iodine. This occurs when reactor coolant is let down to the reactor coolant bleed tanks. It also occurs when reactor coolant leaks from the system.

Most of the radioactive gas released from the reactor coolant system is handled in the gas decay system. Gases from the following sources are handled:

Reactor coolant bleed holdup tank

Reactor coolant bleed evaporators

Makeup tanks

Vents from pumps, filters, demineralizers, coolers in reactor coolant, makeup and purification, and chemical addition and boron recovery systems

Relief valves

Reactor coolant drain tanks

Tritiated waste holdup tank

Tritiated auxiliary building sump tank

Waste evaporator feed tank

Waste evaporator

Waste evaporator distillate test tanks

Spent resin tank

Distillate storage tanks

Boric acid storage tanks

Reactor coolant bleed evaporator feed tanks

Reactor coolant bleed evaporator test tanks

Vents from each of these sources are connected to a compressor suction header as shown on figure 2.4-5. Two gas compressors are connected to this header. The compressors discharge to one of two 3,000-cubic-foot gas decay tanks. A recycle line between the compressor discharge and suction has a pressure-controlled valve which responds to pressure in the suction header.

One compressor is normally in operation, with the other in standby. When the pressure in the suction header reaches 2.0 lb/in<sup>2</sup> gauge, the compressor starts and runs until the header pressure drops to 0.5 lb/in<sup>2</sup> gauge. When the header pressure drops below 0.5 lb/in<sup>2</sup> gauge, the pressure-controlled valve in the recycle line opens, recycling gas from the storage tank to the header. Typically, when a tank such as a reactor coolant bleed tank is being filled with liquid, gas above the liquid is transferred by the compressors to the gas decay tanks. When the liquid level in the tank is lowered, gas is returned from the decay tank to the holdup tank via the recycle line. This arrangement allows a maximum decay time while minimizing gas consumption.

When the decay tank in service approaches a pressure of 100 lb/in<sup>2</sup> gauge, the contents of the other tank are released. The tank vent line includes a radiation-controlled valve, a flow-controlled valve, a prefilter, high-efficiency particulate filter, a charcoal filter (for iodine removal), and a radiation monitor. The monitor closes the valve when a concentration of 5  $\mu$ Ci/ml is exceeded. Downstream of the monitor, the line branches into two lines, each of which terminates at the top of a reactor shield building. Releases are made at a time when meteorological conditions are favorable and from the vent that will provide the best dispersion for the gases.

Other gaseous releases occur for which decay storage is not provided. Tanks and equipment in the radioactive liquid waste disposal system, other than those listed above, are vented to the auxiliary building ventilation exhaust system. Radioactive gases and airborne particulates resulting from liquid leaks and spills in the auxiliary building are also picked up by the exhaust system. The exhaust is passed through HEPA and charcoal filters for particulate and iodine removal prior to discharge at the shield building vent.

During operation with primary to secondary leakage, gases from the primary system are transported with the steam to the turbine and condenser. The gases, along with air that leaks into the condenser, are removed from the condenser by vacuum pump exhausters. The vacuum pump exhaust is passed through a blower, a heater, a HEPA filter, and two charcoal filters in series before being discharged to the turbine building roof as shown on figure 2.4-5. This path is in operation except when vacuum pump flows in excess of 50 ft<sup>3</sup>/min occur, as during unit startup. A high-flow bypass is provided which automatically opens on a high-pressure drop signal across the HEPA filter.

Radioactive gases and particulates accumulate in the containment atmosphere during normal operation as a result of small leaks in the reactor coolant system. The containment atmosphere is continuously monitored for radioactivity during operation. The containment atmosphere is purged prior to entry of personnel or in order to equalize the containment pressure with the outside atmosphere. A containment auxiliary charcoal system is operated for about 8 hours prior to purging. This system consists of three fan-filter units, each

located on a separate level of the building and arranged to enhance mixing of the total containment volume. HEPA and charcoal filters are provided in each unit for reduction of airborne particulates and iodine. The three units can circulate the containment atmosphere about two times during an 8-hour period. During purging, outside air is supplied to the containment. Purged air is exhausted through two 50 percent capacity fans and filter networks in parallel (high-efficiency particulate air filter and charcoal filters) to the plant vent where it is monitored during release to the atmosphere. The containment purge system has a capacity of approximately 1.5 complete changes of air per hour. Venting capacity is controlled by variable dampers.

In addition to purge of the full containment, the instrument room is purged separately for entries made about once per 2 weeks. The air from this room is exhausted through the containment purge exhaust system.

Leakage of steam and feedwater during periods of operation with primary to secondary leakage introduces some radioactivity into the turbine building atmosphere. Airborne radioactivity is exhausted, without treatment, at the turbine building roof.

(4) Solid waste disposal system - The sources of solid wastes are spent demineralizer resins; waste and auxiliary waste evaporator concentrates; and miscellaneous solids such as filter elements, paper, rags, plastic sheeting, laboratory ware, and contaminated equipment and parts.

Spent resins are collected and stored in a spent resin tank. Periodically the spent resins are sluiced to the

packaging system, where they are mixed with a solidification agent (e.g., cement or methyl methacrylate) and packaged in containers. Evaporator concentrates are also mixed with a solidification agent and packaged. Compressible wastes are packaged in drums using a baling machine. Filter elements from liquid filters are placed in drums and concrete is poured into the drums. Spent HEPA and charcoal filter elements are packaged in the containers in which new elements are received.

The quantities and shipment of solid rad-waste are discussed in section 2.1.

4. Radioactivity releases - The radioactive discharges have been estimated for the principal routes of release or removal which are the liquid releases, gaseous releases, and solid rad-waste disposal. For this analysis it is assumed that the reactor operates at full load for 292 days out of the year. It is assumed that fuel which produces 0.25 percent of the core power contains small defects, allowing fission products to escape the coolant. The escape rate coefficients used to estimate this release are given in Table 2.4-2.

TVA has investigated the predicted level of failed fuel for the Bellefonte plant and has concluded (based on operation experience and predictions of fuel failure rates) that the assumption that the presence of clad defects in the fuel pins which produce 0.25 percent of the core power is a reasonable and achievable level of fuel performance over the life of the plant. Good fuel performance is enhanced by proper fuel design, good fabrication techniques, and a comprehensive quality assurance program. Inspections and tests by TVA or its consultant, as well as by the fuel fabricator, will ensure that the

fuel is fabricated as designed. The design of the Bellefonte fuel will be similar to that in plants now operating or about to be operating but will have the benefit of the experience gained in operation of these plants. The radwaste systems and shielding in the plant will be designed to handle the radwaste from operation with 1 percent failed fuel in both units.

(1) Liquid releases - Table 2.4-4 summarizes the estimated annual quantities of liquid wastes from the various sources within the plant. Table 2.4-5 shows the radioactivity releases from the liquid waste disposal system, from processing condensate demineralizer regenerants and from secondary system feedwater leakage. Table 2.4-6 gives the estimated isotopic distribution of these releases.

In estimating the release from the waste disposal system, it was assumed that 20 gallons per day per unit of reactor coolant leaked into the waste disposal system, was processed by the auxiliary waste evaporator and was discharged. A decontamination factor of 1,000 was assumed for the evaporator. In addition, it was assumed that 1 gallon per day of reactor coolant was released without processing, other than by decay and filtration, in the form of nontritiated wastes, including laundry and shower wastes, cask decontamination drains, floor drains, etc.

The estimated release from the condensate demineralizer regeneration system assumes 20 gallons per day per unit of primary to secondary leakage. It is assumed that the demineralizers remove 90 percent per pass of the nongaseous radioactivity from the condensate, that the individual demineralizers are regenerated at 30-day

intervals, that the spent regenerants are decayed for 3 days and processed by evaporation with a decontamination factor of 100, and that the distillate is discharged.

In estimating the secondary system feed-water leakage, it was assumed that 100 pounds per day per unit of feed-water enters the turbine building floor drain system and is discharged. It was assumed that primary to secondary leakage exists (20 gallons per day per unit), that 46 percent of the feedwater does not pass through the condensate demineralizers, and that the demineralizers remove 90 percent of the radioactivity from the remainder.

(2) Gaseous releases - Table 2.4-7 gives the estimated gaseous releases of iodines and noble gases. Table 2.4-6 gives the calculated isotopic distribution in the combined releases.

All releases are based on the reactor coolant composition given in Table 2.4-3. Other assumptions used in estimating these releases are discussed below.

(a) Containment purge - It is assumed that 50 pounds per day per unit of hot reactor coolant escapes into containment. Purges are carried out as discussed previously. Releases of radioactivity to the atmosphere are based on: (1) twelve complete containment purges per unit per year, (2) operation of the containment auxiliary charcoal filter system for 8 hours prior to purge, (3) an iodine decontamination factor (DF) of 10 in the auxiliary charcoal filters for all radioisotopes except noble gases, and (4) an iodine DF of 100 in the charcoal filters in the purge exhaust system.

(b) Instrument room purge -

Releases from this source were based on 26 purges per unit. A DF of 100 for iodine in the charcoal filters of the purge exhaust system is assumed.

(c) Releases through the

auxiliary building ventilation system - It is assumed that the radio-activity in 1 gallon per day per unit of reactor coolant plus 19 gallons per day per unit of liquid downstream of the purification demineralizers is released to the building atmosphere. The building atmosphere is exhausted through HEPA and charcoal filters with a DF of 100 for iodine.

It is assumed that liquid leaks from individual components in the building take place at the following rates:

3 grams per hour per valve

30 grams per hour per flange

75 grams per hour per pump seal on transfer pumps

150 grams per hour per makeup pump seal

Gas leak rates are assumed to be:

$10^{-3}$  grams per hour per high-pressure valve or flange

$10^{-4}$  grams per hour per low-pressure valve or flange

Specific activities of liquids are based on reactor coolant of the composition given in Table 2.4-1 and on the following process DF's:

	<u>Purification Demineralizers</u>	<u>Evaporator Distillate</u>	<u>Evaporator Concentrates</u>
Xe and Kr	1	$10^4$	infinite
Cs, Y, Mo	1.22	$10^2$	0.1
Tritium	1	1	1
Others	10	$10^2$	0.1

The specific activity of gases is based on an average dissolved hydrogen concentration of  $27.5 \text{ ccH}_2/\text{kg}$  and a one-to-one dilution with nitrogen. The release process at the source of the leak is assumed to provide the following DF's:

Xe and Kr	DF = 1
Br and I	DF = $10^3$
Tritium	DF = 1
Others	DF = $10^5$

(d) Waste gas decay tank

venting - These estimates are based on the following:

1. Load-following (push-pull) operation of both units with daily load swings from 100 percent power to 50 percent power to 100 percent power for the first 254 days of a 292-day equilibrium cycle, and baseloaded thereafter.
2. A load factor, including refueling outages, of 84 percent which results in 1.05 equilibrium (292 EFPD) cycles per unit per year.
3. Coolant activities, as shown in Table 2.4-3.
4. Waste gas decay tanks operated on a 120-day cycle--60 days to fill and 60 days for decay.

5. The iodine release based on a total DF of  $10^5$  ( $10^2$  for the purification demineralizer,  $10^2$  for vapor-liquid partitioning, and  $10^1$  for charcoal filters in vent line).
6. Particulate activity from primarily Sr-89 and Cs-137 resulting from the decay of Kr-89 and Xe-137, respectively. Particulate activity receives a DF of 100 due to HEPA filters in the vent line.

(e) Steam leakages - Radioactivity in steam assumes that 20 gallons per day of reactor coolant (Table 2.4-3) leaks to the secondary side of the steam generators and that all radioactivity leaves with the steam or deposits in the system. Steam leakage of 100 pounds per day per unit is assumed. All noble gas in the leaked steam is assumed to be released. It is assumed that 90 percent of the iodine deposits in the system before reaching the leak points.

(f) Turbine gland sealing system leakage - It is assumed that 9,000 pounds per hour per unit of steam goes to the gland seals. Primary to secondary leakage of 20 gallons per day per unit is assumed. All noble gases in the steam are assumed to be released. A decontamination factor of 2,000 across the gland seal condenser is assumed for iodine.

(g) Condenser offgas - Condenser offgas release estimates are based on 20 gallons per day per unit of primary to secondary leakage (reactor coolant composition as in Table 2.4-3). It is assumed that all of the noble gases leaked to the secondary side are released as condenser offgas. Iodine releases assume a steam

generator internal partition factor of 1 (once-through steam generator), a condenser air ejector partition factor of 2,000 and a decontamination factor of 100 across the air ejector after-condenser and charcoal filter.

(h) Feedwater leakage - The feedwater leakage release estimates are based on a leakage rate of 100 pounds per day per unit during operation with 20 gallons per day per unit primary to secondary leakage. For the portion of condensate that passes through the condensate demineralizers (54 percent), a decontamination factor of 10 is assumed. For all except noble gases, a decontamination factor of 10,000 is assumed from puddle to air.

5. Alternative waste treatment -

(1) Liquid waste disposal alternatives -

The liquid waste disposal system, as now designed, provides treatment which reduces releases to a level which is as low as practicable. Segregation of drains to permit recycle of tritiated liquids removes this potentially major source from the plant effluent. The added auxiliary waste evaporator provides for nontritiated liquids and makes possible the recycle of a significant fraction of such liquids.

The present design permits the treatment of detergent wastes in the event that radioactivity concentrations exceed  $10^{-4}$   $\mu\text{Ci/ml}$ . However, treatment of such wastes in an evaporator could give rise to operational problems, such as foaming. Although it is understood that detergent waste treatment systems are under development, they are not commercially available at present. TVA will consider the feasibility of installing such a system if one is perfected, taking into account effectiveness, space requirements, and cost.

The present design reduces radioactive liquid discharges to a level which is considered as low as practicable.

(2) Gaseous waste disposal alternatives -

A gas decay system which provides a minimum storage time of 60 days following a 60-day filling time has been selected to handle gases released from the reactor coolant.

The following alternatives to the gas decay system have been considered:

1. Addition of a recombiner to the gas decay system to remove hydrogen by reaction with added oxygen, thereby increasing the effective storage capacity of the gas decay system.
2. Addition of a cryogenic distillation or solvent absorption system to remove noble gases from the decay tank effluent.

(a) Addition of recombiner -

The first alternative would use a recombiner installed in the gas decay system as shown in figure 2.4-6. The recombiner would remove hydrogen from the gas by reacting it with added oxygen. Since hydrogen comprises a large fraction of the total gas, the effective decay time for the noble gases would be increased from 60 days to a year or more.

Table 2.4-8 shows the effect of the added decay time on the estimated release from the gas decay system. The additional decay time has little effect on the total release because the dominant isotope, krypton-85, has a long half-life. The system would not reduce gas releases due to leakage.

The installed cost of a recombiner system would be approximately \$400,000. Annual operating costs,

not including depreciation, maintenance, or operating labor, could run from about \$1,000 to more than \$5,000, depending primarily on catalyst life, which is not known at present. A system of the type considered is not now in operation at a nuclear power station.

(b) Addition of noble gas

removal system - The second alternative would add a noble gas removal system which would treat gas released from the gas decay tanks. The noble gas removal system would be a cryogenic distillation system or a solvent absorption system. Figure 2.4-7 illustrates the modification. These systems would be capable of removing more than 99 percent of the noble gases and of collecting them in containers for long-term storage. The resulting emissions from the gas decay system would be reduced to about 1 percent of the values shown in Table 2.4-8 in the 60-day decay column. Gas releases due to leakage would not be reduced.

The cryogenic distillation process is based on the differences in boiling points of the gases involved (principally nitrogen, hydrogen, xenon, and krypton). The process is now available for pressurized water reactor application from several vendors with air-liquifaction experience. Among its advantages, the equipment gives a high decontamination factor and is compact in size. On the debit side, the system is subject to mechanical failure. Care must also be taken to avoid contamination by oxygen, carbon dioxide, nitrogen oxides, and hydrocarbons, since these materials could cause operational difficulties or explosion hazards. The installed cost would be approximately \$600,000. Annual operating cost, not including depreciation, maintenance, and operating labor, would be about \$3,000.

The solvent absorption process utilizes the changes in gas solubilities with temperature and pressure and the differing solubilities of the gases. The process has been demonstrated on a pilot-plant scale at the Oak Ridge Gaseous Diffusion Plant. Among its advantages are the high decontamination factors obtained and the small size of the equipment. The major problems are associated with high-pressure operation and degradation of the fluorocarbon solvent. As compared to cryogenic distillation, the process does not have the benefit of long experience with comparable nonradioactive systems. The installed cost of a solvent absorption system would be about \$400,000. The principal operating cost, other than for depreciation, maintenance, and operating labor, would be for solvent makeup. This is not expected to exceed a few thousand dollars per year.

(3) Conclusions - TVA considers that the liquid waste disposal system, as it is now being designed, will reduce liquid emissions to a level which is as low as practicable. The addition of facilities to process detergent wastes will be considered if operating experience shows them to be necessary.

TVA considers that the gaseous waste disposal system, as it is now being designed, will reduce gaseous emissions to a level which is as low as practicable. Alternate systems offer but minor reductions in offsite doses which with the present system are acceptably low. The amount of dose reduction offered by the alternates does not justify their cost.

6. Environmental radiological monitoring program -

(1) General - The preoperational environmental radiological monitoring program has the objective of establishing a baseline of data on the distribution of natural and manmade radioactivity in the environment near the plant site. With this background information, it will then be possible to determine, when the plant becomes operational, the earliest possible indications of the accumulation or buildup of radionuclides. The impact of accumulation will be minor even though trace accumulation may occur during the life of the plant.

Field staffs in TVA's Division of Environmental Planning and Division of Forestry, Fisheries, and Wildlife Development will carry out the sampling program outlined in Tables 2.4-9 and 2.4-10. Sampling locations are shown in figures 2.4-8 and 2.4-9. All of the radiochemical and instrumental analyses will be conducted in a central laboratory at Muscle Shoals, Alabama. Alpha and beta analyses will be performed on a Beckman Low Beta II low-background proportional counter. A Nuclear Data Model 2200 multichannel system will be used to analyze the samples for specific gamma-emitting isotopes. Data will be coded and punched on IBM cards or automatically punched into paper tape for computer processing specific to the analysis conducted. A digital computer will be used to solve multimatrix problems associated with identification of gamma-emitting isotopes.

A study of environmental radiation levels will be initiated approximately two years before startup and will continue through low-power testing and operation of the plant.

The environmental monitoring program outlined herein is subject to change based on continued evaluation of the program now being conducted at the Browns Ferry and Sequoyah Nuclear Plant sites. The program will be coordinated closely with other agencies' programs, such as the nationwide fallout sampling and water quality networks and the radiological health program of the State of Alabama.

The program will include measurements of direct gamma radiation and sampling of airborne radioactivity, fallout particulate matter, rainfall, surface water, well and public water supplies, soil, vegetation, milk, fish, clams, bottom sediment, plankton, aquatic macrophytes, and river water. The extent to which various aspects of the program will be carried out takes into account data available from other sources; however, the program as outlined is self-sufficient. It will be continually evaluated to determine that the most sensitive vectors are being sampled to properly evaluate exposure of the population. Continual evaluation also allows planning an effective system with respect to sampling frequencies, locations, and laboratory analyses.

(2) Atmospheric monitoring - Ten atmospheric monitoring stations have been planned for Bellefonte Nuclear Plant. Two of these monitors will be located on the plant site in the two quadrants of greatest wind frequency. One additional station will be placed at the point of maximum predicted offsite concentration of radionuclides if this point varies significantly from present proposed locations. Six other stations will be located at perimeter areas out to 10 miles. These stations will be instrumented and data will be telemetered into the control room. Generally these stations will be located in or near the more densely populated areas within 10 miles of the plant

in those quadrants having the greatest wind frequency on an annual basis (see figure 2.4-8). Two other monitors will be located at distances out to 20 miles. These remote monitors will be used as control or base-line stations. Samples of air, rainwater, and heavy particle fallout will be collected routinely as indicated in Table 2.4-9.

The atmosphere will be sampled for tritium at the Bellefonte Nuclear Plant. TVA has recently tested sampling methods, and plans have been made to incorporate the sampling apparatus into both the local and one of the remote monitoring stations.

(3) Terrestrial monitoring - Samples of milk, vegetation, soil, private well water, and public water supplies will be collected within a 20-mile radius of the plant. Environmental gamma radiation levels will be measured utilizing thermoluminescent dosimeters on a 500-foot grid within the plant boundaries and at each offsite air monitoring station. At least two dosimeters will be placed at the locations of highest predicted ground level concentrations. All dosimeters will be left in the field for three months.

Milk will be collected monthly from selected dairy farms, immediately surrounding the plant, and from public supplies by purchasing quantities from food stores in the area. The samples will be analyzed for specific gamma-emitting radio-nuclides and, radiochemically, for Sr-89 and Sr-90. After the plant begins operation, during the seasons that animals producing milk for human consumption are on pasture, samples of fresh milk will be obtained weekly and analyzed for I-131 content. During periods of monthly milk sampling, if an increase in I-131 content is detected in other critical vectors such as vegetation, the frequency of milk sampling will be increased.

## Vegetation (grass, weeds, leaves, etc.)

and soil samples will be collected quarterly from the vicinity of the atmospheric monitoring stations. The same rationale for locating the atmospheric monitors is applicable to this program. In addition, pasturage grass will be collected monthly from the farms mentioned in the preceding paragraph. The sampling and analysis schedule is shown in Table 2.4-9.

Consideration has been given to sampling animals such as cattle raised in the vicinity of the nuclear plant. Pasturage grass will be collected monthly from the dairy farms. This vector would be the first indicator in the food chain to man through animal. If a statistically significant increase above the natural background established during the preoperational monitoring program is detected, the program will be expanded to include other vectors in the food chain such as beef cattle. Food crops grown by subsistence farmers in the area will be sampled during the growing season.

(4) Reservoir monitoring - Biological sampling for radiological analyses will be carried out quarterly at three river stations in Gunterville Reservoir. Reservoir water samples will be collected continuously at three stations and analyzed monthly for radioactivity content. The stations will be located as indicated in figure 2.4-9 at Tennessee River miles (TRM) 396.8, 388.0, and at a station which will be located 500 feet below the plant discharge (approximate location TRM 391.2).

Aquatic macrophytes, bottom fauna, plankton, and sediment will be sampled at three stations. Further sampling information can be found in Tables 2.4-9 and 2.4-10.

Samples of net plankton, sediment, aquatic macrophytes, Asiatic clams, and three species of fish will be collected quarterly (plankton only during the two quarters of maximum abundance) and analyzed for radioactivity. Gamma, gross alpha, and gross beta activity will be determined in water (dissolved and total), net plankton, aquatic macrophytes, sediment, shells and flesh of clams, flesh of two commercial and one game fish species, and the whole body of one commercial fish species. Reservoir water samples will also be analyzed for tritium. Except in the flesh of clams, white crappie, and channel catfish, Sr-89 and Sr-90 content will be determined in all samples by appropriate radiochemical techniques. The activity of at least ten gamma-emitting radionuclides will be determined with a multichannel gamma spectrometer.

At present TVA feels that it will be sampling those vectors which will give the first indication of increased radioactivity levels in the environment. If radioactivity increases are seen in those vectors being sampled, consideration will then be given to expanding the sampling program to include other biological specimens.

Consideration has been given to sampling waterfowl; however, about 95 percent of ducks hunted in northeast Alabama are migratory, moving great distances in the winter and spring. It would be impossible to make an accurate assessment of any radionuclides found in migratory waterfowl to a particular source such as

Bellefonte Nuclear Plant. Therefore, it seems more logical to sample other vectors in the environment.

(a) Water - Water samples will be collected for determination of total and dissolved radioactivity from the three cross sections. The samples will be collected continuously by sequential-type samplers and analyzed monthly.

Effluent concentrations are determined prior to release of liquid radioactive waste from the plant. The liquid radwaste holdup tanks are sampled prior to release and the concentration of the contents is determined. Knowing the dilution water discharge flow rate and the concentration of the liquid in the radwaste tank, a release rate from the tank will be established which will not exceed applicable standards in the discharge pipe prior to release to the unrestricted area. A set point will be established on a radiation monitor downstream of the tank discharge line which will cause automatic isolation if the concentration in the line exceeds the previously established value. In addition, a sequential-type sampler will continuously sample the effluent and be analyzed periodically to ensure that all other systems are functioning properly. When considering these plant safeguards, the reservoir monitoring frequency is believed to be adequate.

Buildup of radioactivity in Guntersvill Reservoir is not expected; however, if it does occur it will occur slowly over a long period of time. The frequencies established in the present program will be satisfactory to detect this gradual effect. Possible leakages will be detected by the plant effluent monitoring system.

(b) Fish - Radiological

monitoring will be accomplished by analyses of composite samples of adult fish taken from each of three contiguous reservoirs--Nickajack, Gunterville, and Wheeler.

No permanent sampling stations have been established within each reservoir; this reflects the movement of fish species within reservoirs as determined by TVA data from the Browns Ferry Nuclear Plant preoperational monitoring program. Three species, white crappie, channel catfish, and smallmouth buffalo, will be collected as representative commercial and game species. For each of the following composites, sufficient amounts of fish will be collected in each reservoir to yield from 250 to 300 grams oven-dry weight for analytical purposes:

Flesh - white crappie

Flesh - smallmouth buffalo

Flesh - channel catfish

Whole fish - smallmouth buffalo

All samples will be collected quarterly and analyzed for gamma, gross alpha, and gross beta activity. Concentrations of Sr-89 and Sr-90 will be determined on the whole fish and flesh of smallmouth buffalo only. The composite samples will contain approximately the same quantity of flesh from each of the fish. For each composite a subsample of material will be drawn for counting.

(c) Plankton - For radiological

analyses, net plankton samples will be collected at three stations by vertical tows with a one-half-meter net (pore size, 80 microns). For analytical accuracy, at least 50 grams (wet weight) of material is

desirable and collection of such amounts will probably be practical only during the period April through September because of seasonal variability in plankton abundance. Samples will be analyzed for gamma, gross alpha, and gross beta activity, and for Sr-89 and Sr-90 content.

(d) Sediment - Sediment samples will be collected from Ponar dredge hauls. Gamma, gross alpha, and gross beta activity and Sr-89 and Sr-90 content will be determined in samples collected from three stations. Each sample will be a composite obtained by combining equal volumes of sediment from at least three dredge hauls collected at a point from each station.

(e) Aquatic macrophytes - Samples of at least 50 grams (wet weight) of aquatic macrophytes will be collected from both right and left overbanks at each of the three stations. Aquatic macrophytes will be analyzed for gamma, gross alpha, and gross beta activity and for Sr-89 and Sr-90 content.

(f) Bottom fauna - Asiatic clams will be collected from in-place biomonitoring units at three stations and analyzed for gamma, gross alpha, and gross beta activity. The Sr-89 and Sr-90 content will be determined on the shells only. A 50-gram (wet weight) flesh sample should provide sufficient activity for counting.

(5) Domestic water supplies monitoring - Domestic water supplies, such as small surface streams and wells, will be sampled and analyzed. Well water will be obtained from at least four farms located within five miles of the plant, and from one at some greater distance to serve as a control for monthly laboratory analysis. Public water supplies within 10 miles downstream of the plant discharge will

be sampled continuously and analyzed monthly for gross beta, tritium, and at least 10 specific gamma-emitting radionuclides.

(6) Quality Control - The quality control program now in effect with the Alabama Department of Public Health Radiological Laboratory and the Eastern Environmental Radiation Facility, Environmental Protection Agency, Montgomery, Alabama, will be expanded to include samples from Bellefonte Nuclear Plant in order to assure the accuracy of analytical methods. Samples of air, water, milk, vegetation, and soil collected around the plant are forwarded to these laboratories for analysis. Results are exchanged for comparison.

7. Estimated increase in annual environmental radioactivity levels and potential annual radiation doses from principal radionuclides - Environmental radioactivity levels due to releases to unrestricted areas from the Bellefonte Nuclear Plant will be so low that the radiation doses to man will be less than the variations in the natural background radiation dose. However, TVA has calculated the expected increase in radioactivity levels and potential radiation doses to the population as a result of these low-level releases.

(1) Radionuclides in liquid effluents - The following doses are calculated for exposures to radionuclides routinely released in liquid effluents:

1. Doses to man
  - a. From the ingestion of water
  - b. From the consumption of fish
  - c. From water sports
2. Doses to terrestrial vertebrates from the consumption of aquatic plants
3. Doses to aquatic plants, aquatic invertebrates, and fish

The organisms and pathways that are considered in this report are those that are judged to be the most significant because of species, habitat, diet, or patterns of living. Conservative assumptions are applied in these analyses which should result in overestimation of the doses.

Internal doses are calculated using methods outlined by the International Commission on Radiological Protection which describe international retention of radionuclides with a single-exponential model. This model is used for estimating the doses to the bone, G.I. tract, thyroid and total body of man from ingestion of water and consumption of fish and for estimating the doses to terrestrial vertebrates from the consumption of green algae. For calculating the internal doses to aquatic organisms it is assumed that an equilibrium exists between the activity concentrations in the water and those inside the organisms.

External doses are estimated using either an infinite or a semi-infinite, homogeneous-medium approximation depending on whether the organism is considered to be immersed in or floating on the water.

A more detailed discussion of the analytical methods used in calculating these doses and a detailed listing of the results are given in Appendix H.

(2) Radionuclides in gaseous effluents -

The following doses to humans living in the vicinity of the Bellefonte Nuclear Plant are calculated for routine releases of radioactive gases:

1. External beta doses
2. External gamma doses

3. Thyroid doses due to inhalation of radioactive iodine
4. Thyroid doses due to concentration of radioactive iodine in milk produced near the site

The external beta and gamma doses to terrestrial plants and animals are considered to be of the same magnitude as the doses estimated for humans.

The gaseous effluents are released from vents located near the top of the plant buildings. Dilution of the gaseous effluents will take place due to diffusion and turbulent mixing as the gases travel downwind from the point of release. The downwind, ground-level concentrations of radionuclides are determined using a sector-averaged diffusion equation and meteorological data estimated for the Bellefonte site.

External beta and gamma doses are computed using semi-infinite cloud, immersion dose models. Iodine inhalation doses are calculated by assuming that these doses are proportional to the ground-level concentration and the receptor breathing rate. Iodine ingestion doses are calculated by assuming that they are proportional to the rate of iodine deposition on pasturage, the concentration of iodine in milk, and the milk consumption rate of the receptor. Studies<sup>1</sup> show that the iodine milk pathway is the principal food chain pathway for halogen and particulate releases.

A more detailed description of the analytical methods used in calculating these doses and a detailed listing of results are given in Appendix I.

(3) Summary of radiological impact -

Table 2.4-13 summarizes the radiation doses calculated for releases of

radionuclides in gaseous and liquid effluents during normal operation of the Bellefonte Nuclear Plant. The predicted cumulative radiological impact on the Tennessee River from operation of the Watts Bar, Sequoyah, and Bellefonte Nuclear Plants and Oak Ridge National Laboratory is discussed in Appendix J. The external radiation dose from outside liquid storage tanks is also shown and is discussed in Appendix K.

A comparison of doses resulting from the operation of the Bellefonte Nuclear Plant to those occurring from natural radioactivity assists in placing the doses from Bellefonte in perspective. Near the plant site the average annual dose from naturally occurring external sources of radiation is 125 mrem (Table 2.4-14). An individual receives an additional dose of approximately 20 mrem per year from naturally occurring internal sources. Therefore, the average total dose from natural radioactivity in the vicinity of the Bellefonte plant is approximately 145 mrem per year. Individual doses vary widely around this average value because of local differences in the concentrations of terrestrial radioactivity and because of variations in dose rates within different types of buildings. Large variations are also observed between different areas within the United States because of the dependence of cosmic ray dose rates on altitude and geomagnetic latitude. Due to these variations, the annual total-body doses to individuals in the United States from natural radioactivity range from approximately 110 mrem to 240 mrem.

A hypothetical individual at the site boundary would receive a maximum annual dose of about 2 mrem from the normal operation of the Bellefonte Nuclear Plant. It is assumed that

this individual stands in the open at the highest dose point on the site boundary for 24 hours a day, 365 days per year. The maximum dose to the hypothetical individual is about 1 percent of the dose from natural background radiation. The maximum dose to an actual individual should be significantly less than the dose to the hypothetical individual.

The population dose within 50 miles of the Bellefonte site from naturally occurring radioactivity is estimated to be approximately 240,000 man-rem in the year 2020 (Table 2.4-14). The population dose in the year 2020 due to normal operation of the Bellefonte Nuclear Plant is calculated to be 12 man-rem (Table 2.4-13), which is less than 0.005 percent of the dose to the population within 50 miles from natural background radiation. Because population groups beyond 50 miles were considered in dose estimates for radionuclides in liquid effluents the population dose due to operation of the Bellefonte Nuclear Plant is actually less than 0.005 percent of the dose to the same population due to natural background radiation.

TVA has evaluated the potential radiation dose from a broad spectrum of possible pathways of exposure. It should be emphasized that it is possible to theoretically calculate an environmental radioactivity level or potential radiation dose that is minutely small. The dose calculated in this evaluation is only a small fraction of the dose from the natural background radiation and is, in fact, much less than the variations in natural background radiation doses. It is concluded that the Bellefonte Nuclear Plant will operate with no significant risk to the health and safety of the public.

REFERENCE

1. Atomic Energy Commission, Final Environmental Statement Related to the Operation of Oconee Units 1, 2, and 3, Duke Power Company, March 1972.

Table 2.4-1

BELLEFONTE AVERAGE REACTOR COOLANT ACTIVITY

(Based on Table 2.4-3 Assumptions)

<u>Isotope</u>	<u>Average Activity (<math>\mu\text{Ci}/\text{gm}</math>)</u>
Br-84	$0.841 \times 10^{-2}$
Br-85	$0.111 \times 10^{-2}$
Kr-85m	$0.444 \times 10^0$
Kr-85	$0.571 \times 10^{-1}$
Kr-87	$0.260 \times 10^0$
Kr-88	$0.809 \times 10^0$
Rb-88	$0.807 \times 10^0$
Sr-89	$0.9638 \times 10^{-3}$
Sr-90	$0.281 \times 10^{-4}$
Sr-91	$0.788 \times 10^{-2}$
Sr-92	$0.264 \times 10^{-2}$
Y-90	$0.172 \times 10^{-4}$
Y-91	$0.528 \times 10^{-3}$
Mo-93	$0.412 \times 10^0$
Ru-106	$0.373 \times 10^{-1}$
Xe-131m	$0.128 \times 10^0$
Xe-133m	$0.414 \times 10^{+2}$
Xe-133	$0.248 \times 10^0$
Xe-135m	$0.203 \times 10^0$
Xe-135	$0.964 \times 10^{-8}$
I-129	$0.936 \times 10^{-8}$
I-131	$0.730 \times 10^0$
I-132	$0.393 \times 10^0$
I-133	$0.979 \times 10^0$
I-134	$0.122 \times 10^0$
I-135	$0.544 \times 10^0$
Cs-134	$0.392 \times 10^{-1}$
Cs-136	$0.238 \times 10^{-1}$
Cs-137	$0.903 \times 10^{-1}$
Cs-138	$0.217 \times 10^0$
Ba-137m	$0.252 \times 10^{-1}$
Ba-139	$0.234 \times 10^{-1}$
Ba-140	$0.126 \times 10^{-2}$
La-140	$0.435 \times 10^{-3}$
Ce-144	$0.101 \times 10^{-3}$

Table 2.4-2

ESCAPE RATE COEFFICIENT UTILIZED IN ESTIMATING  
REACTOR COOLANT ACTIVITY OF THE BELLEFONTE NUCLEAR PLANT

<u>Isotope</u>	<u>Escape Rate Coefficient (sec<sup>-1</sup>)</u>
Kr	$6.5 \times 10^{-8}$
Xe	$6.5 \times 10^{-8}$
Br	$1.3 \times 10^{-8}$
Rb	$1.3 \times 10^{-8}$
I	$1.3 \times 10^{-8}$
Cs	$1.3 \times 10^{-8}$
Mo	$2.0 \times 10^{-9}$
Te	$2.0 \times 10^{-9}$
Ru	$2.0 \times 10^{-9}$
Se	$1.0 \times 10^{-9}$
Te	$1.0 \times 10^{-9}$
Sr	$1.0 \times 10^{-11}$
Ba	$1.0 \times 10^{-11}$
All Others	$1.6 \times 10^{-12}$

Table 2.4-3

BASES FOR THE DETERMINATION OF REACTOR COOLANT ACTIVITY

- (1) Fuel which represents 0.25 percent of the core power is assumed to be defective.
- (2) The activity of the core is determined by way of the model and equation presented in TID-14844.
- (3) The activity is based on a load-following operation of both units with daily load swings from 100 percent power to 50 percent power to 100 percent power for the first 254 days of a 292-day equilibrium cycle, and base-loaded thereafter.
- (4) A load factor of 84 percent is utilized that includes a refueling outage which results in 1.05 equilibrium cycles per unit per year.
- (5) The tritium release is based on the reactor coolant concentration being limited to a maximum of 2.5  $\mu\text{Ci/cc}$  (assuming density = 1  $\text{gn/cc}$ ). The tritium release is essentially all HT and is based on bw equilibrium constant of 2.13 for the reaction  $\text{H}_2\text{O} + \text{HT} > \text{HTO} + \text{H}_2$ .
- (6) The escape rate coefficients of the isotopes contained in the defective fuel are those presented in Table 2.4-2. These coefficients apply to the total activity of the isotope in the fuel pin (fuel and gap).

Table 2.4-4

RADIOACTIVE WASTE QUANTITIES

<u>Waste Source</u>	<u>Quantity (dual plant), ft<sup>3</sup>/yr</u>	<u>Assumptions and Comments</u>
<u>Liquid Wastes</u>		
<u>Tritiated Waste</u>		
Miscellaneous system leakage	5,800	5 gal/h leakage
Sluicing of ion exchange resins	2,800	14 transfers/yr at 200 ft <sup>3</sup> each
Regeneration of deborating demineralizers	18,200	14 regenerations/yr at 1,300 ft <sup>3</sup> each
Sampling and laboratory drains	4,700	20 samples/day at 5 gal/sample
Filter backwash	1,200	20 backwashes/yr at 30 ft <sup>3</sup> each
Subtotal	32,700	All tritiated waste recycled
<u>Nontritiated Waste</u>		
Miscellaneous system leakage	5,800	5 gal/h leakage
Spent fuel cask decontamination	50,000	30 decontaminations/yr at 1,600 ft <sup>3</sup> each
Sample drains	1,100	4 samples/day at 5 gal/sample
Subtotal	56,900	
<u>Chemical Waste</u>		
Laboratory drains	5,800	
Decontamination drains	1,000	500 items at 2 ft <sup>3</sup> each
Subtotal	6,800	
<u>Detergent Wastes</u>		
Laundry drains	28,800	600 gal/day
Shower and sink drains	28,800	20 showers/day at 30 gal each
Subtotal	57,600	
Total Liquid Discharged	121,300	(sum of nontritiated, chemical, and detergent wastes)

Table 2.4-4  
(continued)RADIOACTIVE WASTE QUANTITIES

<u>Waste Source</u>	<u>Quantity (dual plant), ft<sup>3</sup>/yr</u>	<u>Assumptions and Comments</u>
<u>Gaseous Wastes</u>		
Reactor coolant degassing		Degas at 30 std cc H <sub>2</sub> per kg water
Startup expansion and dilution	2,700	4 cold startups per fuel cycle
Lifetime shim bleed and transient xenon control	66,000	Daily load swings of 50% through 90% of fuel cycle
End of fuel cycle	4,000	Degas H <sub>2</sub> from reactor coolant before refueling
Start of fuel cycle	1,400	N <sub>2</sub> displaced with H <sub>2</sub> in makeup tank
Pressurizer venting	6,000	Vent once per week (primarily H <sub>2</sub> )
System venting following refueling	12,500	N <sub>2</sub> displaced as system refined after refueling
Miscellaneous	1,800	Degas misc liquids such as laboratory samples or system leakage
<b>Total Gaseous Wastes</b>	<b>94,400</b>	
<u>Solid Wastes</u>		
Spent purification and other demineralizer resins	670	Change twice yearly and as required
Spent deborating demineralizer resin	40	Change as required
Evaporator bottoms	1,750	Liquid wastes concentrated to 20 wt % solids
Miscellaneous	900	1-1/2 55-gal drums per week plus 300 ft <sup>3</sup> per refueling period
<b>Total Solid Wastes</b>	<b>3,360</b>	

Table 2.4-5

ESTIMATED AMOUNTS OF RADIOACTIVITY IN LIQUID RELEASES

<u>Origin of Release</u>	<u>Release, Curies/yr</u>
Liquid waste disposal system	0.670(0)*
Processing condensate demineralizer spent regenerants	0.260(0)
Secondary system liquid leakage	0.200(-4)

---

\*0.670 x 10<sup>0</sup>

Table 2.4-6

ESTIMATED SOURCES OF RADIOACTIVITY RELEASED TO THE ENVIRONMENT  
DURING ONE YEAR'S OPERATION OF TWO UNITS

<u>Isotope</u>	<u>Liquid Releases (Curies)</u>	<u>Gaseous Releases (Curies)</u>
Br-84	0.69(-7)	0.97(-5)
Br-85	0.62(-8)	0.20(-7)
Kr-85m	0.0	0.33(+2)
Kr-85	0.0	0.156(+4)
Kr-87	0.0	0.197(+2)
Kr-88	0.0	0.60(+2)
Rb-88	0.45(-6)	0.57(-4)
Sr-89	0.88(-3)	0.12(-3)
Sr-90	0.92(-4)	0.82(-9)
Sr-91	0.27(-6)	0.13(-6)
Sr-92	0.26(-7)	0.42(-7)
Y-90	0.82(-5)	0.28(-9)
Y-91	0.58(-3)	0.16(-7)
Mo-99	0.31(-1)	0.12(-4)
Ru-106	0.10(+0)	0.62(-5)
Xe-131m	0.0	0.646(+2)
Xe-133m	0.0	0.326(+2)
Xe-133	0.0	0.1971(+4)
Xe-135m	0.0	0.90(+1)
Xe-135	0.0	0.762(+2)
I-129	0.31(-7)	0.44(-8)
I-131	0.11(+0)	0.13(-2)
I-132	0.39(-5)	0.49(-3)
I-133	0.30(-1)	0.12(-2)
I-134	0.11(-5)	0.19(-3)
I-135	0.32(-4)	0.64(-3)
Cs-134	0.11(+0)	0.11(-5)
Cs-136	0.49(-2)	0.73(-6)
Cs-137	0.28(+0)	0.63(-5)
Cs-138	0.11(-5)	0.50(-5)
Ba-137m	0.25(+0)	0.62(-5)
Ba-139	0.39(-7)	0.35(-6)
Ba-140	0.91(-4)	0.36(-7)
La-140	0.20(-3)	0.13(-7)
Ce-144	0.25(-3)	0.29(-8)
Cr-51	0.58(-3)	0.49(-7)
Mn-54	0.97(-4)	0.56(-8)
Fe-59	0.78(-4)	0.56(-8)
Co-58	0.45(-2)	0.29(-6)
Co-60	0.29(-2)	0.16(-6)
Zr-95	0.58(-2)	0.39(-6)
Total	0.93(+0)	0.38(+4)
Tritium	0.2800(+3)	0.300(+3)

Table 2.4-7

ESTIMATED AMOUNTS OF RADIOACTIVITY IN GASEOUS RELEASES

<u>Sources</u>	<u>Curies/year</u>	
	<u>Iodine-131</u>	<u>Noble Gases*</u>
Containment purge	0.10 (-4)	0.865(+2)
Instrument room purge	0.375(-6)	0.714(-1)
Purification and makeup system gases vented to ABVS	0.880(-3)	0.123(+4)
Waste gas decay tank venting	0.420(-3)	0.167(+4)
Steam leakages	0.14 (-5)	0.451(-3)
Turbine gland sealing system leakage	0.121(-4)	0.839(-0)
Condenser offgases	0.121(-4)	0.839(+3)
Feedwater leakage	0.204(-8)	0.128(-8)

---

\*Noble gases include: Kr-85m, Kr-85, Kr-87, Kr-88, Xe-131m, Xe-133m, Xe-133, Xe-135m, Xe-135

Table 2.4-8

ESTIMATED ANNUAL GASEOUS RELEASE FROM THE WASTE GAS DECAY TANKS

<u>Isotope</u>	<u>Half-Life</u>	<u>Annual Release, Curies</u>	
		<u>60-Day Decay</u>	<u>1-Year Decay</u>
Krypton-85	10.57 y	1,554	1,470
Xenon-131m	12 d	54	$1.3 \times 10^{-6}$
Xenon-133	5.27 d	64	$2.3 \times 10^{-13}$
Iodine-129	$1.7 \times 10^7$ y	4.4(-9)	$4.4 \times 10^{-9}$
Iodine-131	8 d	4.2(-4)	$1.5 \times 10^{-15}$
Strontium-89	53 d	1.2(-4)	$2.3 \times 10^{-6}$
Cesium-137	37 y	3.7(-6)	$3.6 \times 10^{-6}$
Tritium	12.33 y	47	45

Table 2.4-9

Environmental Radiological Surveillance ProgramBellefonte Nuclear Plant

	<u>Criteria and Sampling Locations</u>	<u>Collection Frequency</u>	<u>Analysis/Counting</u>
<b>I. Atmospheric</b>			
<b>A. Air</b>			
1. Particulate	Filter paper at 10 locations	Weekly	Gross beta (gamma scan monthly) I-131
2. Radioiodine	Charcoal filter at 10 locations	Weekly	
B. Fallout	Gummed acetate at 10 locations	Monthly	Gross beta
C. Rainwater	Same as locations indicated in I.A.1	Monthly	Gross beta, gamma scan, <sup>a</sup> Sr-89, Sr-90, H-3
<b>II. Reservoir</b>			
<b>A. Water</b>			
1. Municipal (public supplies)	All public water supply intakes within 10 miles upstream and downstream of the plant	Monthly Quarterly	Gross beta, gamma scan, H-3
2. Reservoir (dissolved and total)	Continuous samples from three locations; one above, one below, and one at plant site	Analyzed Monthly	Gross beta, gamma scan, Sr-89, Sr-90, H-3
<b>B. Aquatic Biota</b>			
1. Fish (buffalo, crappie, and catfish)	Nickajack, Guntersville, and Wheeler reservoirs	Quarterly	Gross beta, gross alpha, <sup>b</sup> gamma scan, Sr-89, Sr-90
2. Shellfish (Asiatic clams)	Three locations	Quarterly	Gross beta, gross alpha, gamma scan, (Sr-89, Sr-90 shells only)
3. Aquatic Macrophytes	Three locations	Quarterly	Gross beta, gross alpha, gamma scan, Sr-89, Sr-90
4. Plankton	Three locations	Quarterly	Gross beta, gross alpha, gamma scan, Sr-89, Sr-90
C. Sediment	Three locations	Quarterly	Gross beta, gross alpha, gamma scan, Sr-89, Sr-90
<b>III. Terrestrial</b>			
A. Soil <sup>c</sup>	Atmospheric monitoring locations	Quarterly	Gross beta, gamma scan
<b>B. Vegetation<sup>d</sup></b>			
1. Pasturage and grass	Selected dairy farms within 10-mile radius of plant	Monthly	Gross beta, gamma scan, Sr-89, Sr-90
	10 atmospheric monitoring stations	Quarterly	Gross beta, total alpha, <sup>e</sup> gamma scan, Sr-89, Sr-90
2. Food crops	Within 10-mile radius of plant	Semiannually	Gross beta, total alpha, gamma scan, Sr-89, Sr-90
C. Milk	Selected dairy farms within 10-mile radius of plant	Monthly <sup>f</sup>	Gamma scan, Sr-89, Sr-90, I-131
D. Well water	Selected farms within 5 miles of plant	Monthly Quarterly	Gross beta, gamma scan
E. Direct radiation	TLD's at remote and perimeter monitors	Quarterly	Dose determination

a. The gamma scan will include specific analyses of a least 10 gamma-emitting isotopes except for milk samples which will be analyzed for four isotopes.

b. Aliquot of prepared sample counted directly for alpha.

c. Soil is collected over a two-square-foot area one inch in depth.

d. Vegetation samples are collected such that there are sufficient quantities for appropriate analysis after necessary preparation.

e. Heavy metals separated as a part of the Sr-89, Sr-90 separation process are precipitated, filtered, and counted for alpha.

f. After the plant begins operation milk samples will be taken weekly when cows are on pasture.

Table 2.4-10

TYPES AND LOCATIONS OF BIOLOGICAL SAMPLES COLLECTED  
FOR PREOPERATIONAL AND OPERATIONAL RAD ANALYSIS  
IN GUNTERSVILLE RESERVOIR IN RELATION  
TO THE BELLEFONTE NUCLEAR PLANT

<u>TRM Station</u>	<u>Plankton</u> <sup>a, b</sup>	<u>Benthic Fauna</u> <sup>c</sup>	<u>Aquatic Macrophytes</u> <sup>d</sup>	<u>Sediment</u>	<u>Fish</u> <sup>e</sup>
396.8	2	2	2	2	
391.2	2	2	2	2	
388.0	2	2	2	2	

- a. Vertical tows.  
b. Replicate samples.  
c. Replicate samples of Asiatic clam flesh taken from inplace biomonitoring units.  
d. Aquatic macrophytes will be collected on both overbanks.  
e. Samples will be collected from Nickajack, Gunterville, and Wheeler reservoirs.

Table 2.4-11

RESERVOIR WATER SAMPLES COLLECTED TO MONITOR PREOPERATIONAL  
AND OPERATIONAL RADIOLOGICAL CONDITIONS IN GUNTERSVILLE  
RESERVIOR IN RELATION TO THE BELLEFONTE NUCLEAR PLANT

<u>TRM Station</u>	<u>Distance from Left Bank (Normal Full Pool Elev.)</u>		<u>Depths for Water</u>
	<u>Feet</u>	<u>Percent</u>	<u>meters</u>
396.8	2,000	71	1
	2,400	86	1, 8
392 <sup>+</sup> a	(To be determined)		4, 8
397.5	1,300	34	1, 4, 8
	3,400	88	1
380.4	500	12	1
	2,900	72	1, 9
365.5	4,400	50	1, 11

---

a. This station will be located 500 feet downstream from the point of release.

Table 2.4-12

RESERVOIR MONITORING RADIOLOGICAL ANALYSES

<u>Type Sample</u>	<u>Analyses<sup>a</sup></u>
Fish	Gamma scan, gross alpha, gross beta, Sr <sup>89</sup> and Sr <sup>90</sup> <sup>b</sup>
Sediment	Gamma scan, gross alpha, gross beta, Sr <sup>89</sup> and Sr <sup>90</sup>
Water	Gamma scan, gross alpha, gross beta, Sr <sup>89</sup> and Sr <sup>90</sup> , and tritium
Plankton	Gamma scan, gross alpha, gross beta, Sr <sup>89</sup> and Sr <sup>90</sup> <sup>c</sup>
Macrophytes	Gamma scan, gross alpha, gross beta, Sr <sup>89</sup> and Sr <sup>90</sup>
Benthos	Gamma scan, gross alpha, gross beta, Sr <sup>89</sup> and Sr <sup>90</sup> will be determined on shells only

---

All samples will be collected and analyzed on a quarterly frequency.

- a. The activity of 13 gamma-emitting radionuclides will be determined with a multichannel gamma spectrometer. Sr<sup>89</sup> and Sr<sup>90</sup> will be determined by appropriate radiochemical techniques.
- b. Sr<sup>89</sup> and Sr<sup>90</sup> concentrations will be determined on the whole fish and flesh of smallmouth buffalo only, which will be composed of individuals as nearly equal in size as possible. The composite samples will contain an equal quantity (approximately) of flesh from each of the six fish of the species. From each composite a subsample of at least 50 to 100 grams (net weight) will be drawn for counting.
- c. Sr<sup>89</sup> and Sr<sup>90</sup> will be determined if there is adequate sample. At least 50 grams must be obtained for analytical accuracy. Samples will be collected twice annually during periods of greatest abundance.

Table 2.4-13

SUMMARY OF RADIOLOGICAL IMPACT ON ANNUAL BASIS<sup>a,b</sup>

	<u>Normal Operation</u>	<u>Proposed 10 CFR 50 Appendix I Guides</u>
<b>A. <u>Liquid Effluents</u></b>		
Activity released	0.93 Ci	10 Ci
Average concentration before dilution in the Tennessee River	1.5 (-8) <sup>c</sup> $\mu\text{Ci}/\text{cm}^3$	2.0 (-8) $\mu\text{Ci}/\text{cm}^3$
Maximum human organ doses		
1. bone	2.1 (-2) mrem	5 mrem
2. G.I. tract	1.4 (-2) mrem	5 mrem
3. thyroid	3.3 (-2) mrem	5 mrem
4. skin	4.3 (-2) mrem	5 mrem
5. total body	3.9 (-2) mrem	5 mrem
Human population doses within the Tennessee Valley region		
1. bone	6.6 man-rem	
2. G.I. tract	4.7 man-rem	
3. thyroid	7.4 man-rem	
4. skin	5.2 man-rem	
5. total body	5.0 man-rem	
Maximum dose to terrestrial vertebrates	160 mrad	
Maximum doses to aquatic organisms		
1. plants	8.5 mrad	
2. invertebrates	3.5 mrad suspended 120 mrad benthic	
3. fish	0.4 mrad	

a. Table excludes tritium. Doses due to release of tritium in liquid effluents are  $3.0 \times 10^{-3}$  mrem and 0.68 man-rem. Doses due to releases of tritium in gaseous effluents are 0.16 mrem and 1.0 man-rem.

b. Releases for two units operating at full power with 0.25 percent failed fuel.

c.  $1.5 \times 10^{-8}$ .

Table 2.4-13 (continued)

	<u>Normal Operation</u>	<u>Proposed 10 CFR 50 Appendix I Guides</u>
<b>B. <u>Gaseous Effluents</u></b>		
I-131 concentration at site boundary	4.4 (-16) $\frac{\mu\text{Ci}}{\text{cc}}$	1.0 (-15) $\frac{\mu\text{Ci}}{\text{cc}}$
Maximum individual doses		
1. inhalation at site boundary (thyroid)	1.7 (-2) mrem	5 mrem
2. consumption of milk from nearest dairy farm (thyroid)	4.5 (-2) mrem	5 mrem
3. external exposure at site boundary ( $\beta\delta\gamma$ )	1.7 mrem	10 mrem
Population doses within a 50-mile radius		
1. inhalation (thyroid)	4.2 (-2) man-rem	
2. consumption of milk (thyroid)	3.3 (-1) man-rem	
3. external exposure ( $\beta\delta\gamma$ )	7.9 man-rem	
<b>C. Direct Gamma Radiation from Liquid Storage Tanks</b>	2.8 (-2) mrem	
<b>D. Maximum Annual Dose to<sup>d</sup> Any Individual</b>	1.7 mrem	
<b>E. Maximum Population Dose<sup>d</sup></b>	1.2 (+1) man-rem	

---

d. Skin dose. Thyroid dose is of about the same magnitude as skin dose.

Table 2.4-14

DOSES FROM NATURALLY-OCCURRING BACKGROUND RADIATION


## Individual Doses (mrem)

External <sup>a</sup>	125
Internal <sup>b</sup>	<u>20</u>
Total	145 mrem

## Population Dose (man-rem)

$$0.145 \text{ rem} \times 1,650,000^c \text{ people} = 240,000 \text{ man-rem}$$

- 
- a. Measured by TVA personnel  
b. Principles of Radiation Protection. K. Z. Morgan and J. E. Turner, eds.  
New York: John Wiley and Sons, Inc., 1967, p. 10.  
c. Estimated population within a 50-mile radius of the Bellefonte Nuclear  
Plant in the year 2020.



2.4-57

Figure 2.4-1  
 MAKEUP AND PURIFICATION; CHEMICAL  
 ADDITION AND BORON  
 RECOVERY SYSTEMS




Figure 2.4-2  
TRITIATED LIQUID WASTE  
TREATMENT SYSTEM






Figure 2.4-3  
 TRITIUM BUILDUP IN PRIMARY AND  
 REFUELING VOLUMES WITH 2.5  
 $\mu\text{Ci}/\text{CC}$  LIMIT IN PRIMARY VOLUME





2.4-61

Figure 2.4-5  
GASEOUS EXHAUST SYSTEMS

Gas Vented from  
Tanks and Released  
from Gas Strippers

Gas  
Compressors

Gas  
Storage  
Tanks

Radiation  
Monitor

Plant  
Vent

Oxygen

Hydrogen  
Recombiner

Figure 2.4-6  
GASEOUS RADWASTE  
ALTERNATIVE 1  
ADDITION OF A  
HYDROGEN RECOMBINER

2.4-62

Gas Vented from  
Tanks and  
Released from  
Gas Strippers

Gas  
Compressors

Gas  
Storage  
Tanks

Noble Gas  
Removal


Radiation  
Monitor

Vent

Noble  
Gases

Storage  
Cylinders

Figure 2.4-7  
GASEOUS RADWASTE  
ALTERNATIVE 2  
ADDITION OF  
NOBLE GAS REMOVAL SYSTEM



Note: The following samples are collected from each station:

- |                        |            |
|------------------------|------------|
| Air Particulates       | Rainwater  |
| Radioiodine            | Soil       |
| Heavy Particle Fallout | Vegetation |

Figure 2.4-8  
ATMOSPHERIC AND TERRESTRIAL  
MONITORING NETWORK




Figure 2.4-9  
RESERVOIR MONITORING NETWORK

2.5 Nonradioactive Discharges - It is TVA's policy to keep the discharge of all wastes from its facilities at the lowest practicable level by using the best and highest degree of waste treatment available with existing technology, within reasonable economic limits.

A description of the potential sources and amounts of non-radioactive discharges which have been identified is given in this section, along with a description of the specific treatment of these potential sources.

1. Chemical discharges - The Bellefonte Nuclear Plant chemical discharge system is shown in schematic representation in figure 2.5-1. The sources of these chemicals and the maximum expected quantity of resulting chemical end products that could be discharged are summarized in Table 2.5-1. The proposed blowdown diffuser will be designed to mix the blowdown with 9 equal parts of reservoir water. On this basis the average and maximum expected chemical concentrations in the discharge pipe and in the reservoir after initial jet mixing are shown in Table 2.5-2. The tables were generated using conservative assumptions for chemical usage and solids concentrations in the cooling towers. The computations show that even under adverse conditions and using conservative assumptions, chemical discharges to the environment will be very small.

(1) Cooling tower blowdown and drift - The normal blowdown rate from the cooling towers will be approximately  $74 \text{ ft}^3/\text{s}$  during periods of high evaporation. This will maintain a condenser cooling system solids concentration of about twice the reservoir solids concentration. Blowdown will be returned to the river through a diffuser system designed to (1) provide good diffusion and (2) to minimize environmental impacts due to disturbance of aquatic life during construction and operation of the plant.

As described in Section 2.6, Heat Dissipation, short periods of no flow at the Bellefonte site occur rather often, but the duration of no flow is relatively short. As also discussed in section 2.6, the blowdown diffuser will continue to entrain river water for some portion of this low flow period and cooling tower blowdown will be discontinued when there is insufficient riverflow to provide proper dilution of the blowdown. If the blowdown is discontinued during a 5-hour period, dissolved solids concentrations in the cooling water circuit will rise, but are not expected to exceed three times their reservoir concentrations.

If blowdown is discontinued for about 5 hours, the chemical concentration factor of the cooling system would increase from about 2 to 3. Resumption of blowdown at  $74 \text{ ft}^3/\text{s}$  will gradually reduce the concentration factor back to about 2. The trace metal concentrations calculated to occur in (1) the cooling tower blowdown and (2) in Gunter'sville Reservoir at the edge of the jet mixing zone are presented in Table 2.5-5. Also shown in the table are the applicable effluent guidelines.

In the trace metal analysis, no distinction has been made of element state or form. For conservatism, all forms are considered as being available to the biota which would not be the case in nature as discriminatory limits are determined by the state or form of the element as presented to an organism. Data on trace metals are limited. Water quality data from EPA for 1962 to 1967 are shown in Table 2.5-5. Data on trace metals in sediment for

1972 are shown in Appendix B as part of the sediment analyses for ecological baseline information on fish and other aquatic life.

These trace metal concentrations, or higher concentrations in the future, are not expected to have more than a local impact that may or may not be reflected in the biota. The degree of impact will depend on the organic content, the suspended solids concentration, and the turbidity of the water. It also depends on the type of sediment the organisms inhabit.

It is anticipated that a biological control method might have to be used at the plant to control growth of fauna or flora in the main condenser cooling system. The selected method of treatment would be injection of chlorine. If chlorine is used, it will be fed for one hour per day to maintain a maximum of 0.5 mg/l residual at the condenser outlet during feed periods.

The National Water Quality Laboratory has stated that intermittent (2 hours per day) discharges not exceeding a concentration of 0.05 mg/l residual chlorine in the receiving water "should not result in significant kills of aquatic organisms nor adversely affect the aquatic ecology."<sup>1</sup> With the diffuser system at Bellefonte, a 9 to 1 dilution will insure that the residual chlorine concentration will not exceed 0.05 mg/l.

Cooling tower drift is not expected to exceed .25 ft<sup>3</sup>/s. This amount of drift would result in an average discharge of solids of about 230 lb/d. Essentially all of the drift

is expected to fall within 1,000 yards of the towers.<sup>2</sup> No significant environmental impacts will occur since no area outside the plant area would receive significant quantities of drift.

(2) Cooling tower makeup and essential raw cooling water systems - If faunal or floral populations develop in either the condenser cooling system or the essential raw cooling water system a biocide will probably be used. The upstream Widows Creek Steam Plant, however, has had no fouling problems with any biological forms and does not treat its cooling systems. Acrolein, an unsaturated aldehyde, would probably be fed into the cooling tower makeup stream and into the essential raw cooling water system should a problem exist.

The principal organism that creates fouling problems in cooling systems in the Tennessee Valley is the invasion species, Corbicula manilensis, the Asiatic clam. Experience at operating plants indicates a maximum annual problem period of about 120 days in the spring and summer when the veliger larvae are in the water. If a problem develops, acrolein will be fed into the cooling tower makeup and into the essential raw cooling water system one-half hour each day to maintain a concentration within the influent streams of approximately 0.2 to 0.3 mg/l during feed periods. The two systems' flows will be added as makeup water to the main condenser cooling system upstream of the condensers.

An acrolein demand of the main condenser cooling water of only 0.1 mg/l in one hour<sup>3</sup> would be sufficient to deplete all the residual acrolein contained in the cooling tower makeup and essential raw cooling systems. Since acrolein is volatile, much of it

would also be readily scrubbed from the cooling system water during its first pass through the cooling tower fill.

Considering only dilution, the maximum concentration that would be expected in the main condenser system during periods when acrolein is fed simultaneously to both the cooling tower makeup and essential raw cooling water systems, would be about 0.02 mg/l. This concentration in the cooling tower blowdown discharged through the diffuser would result in an acrolein concentration in the river, at the edge of the jet mixing zone, of 0.002 mg/l. The 96-hour TLM for fathead minnows is reported to be 0.06 mg/l<sup>4</sup>; for juvenile top minnows the 48-hour TLM was 0.24 mg/l<sup>5</sup>. The concentration in the river resulting from dilution alone (within the main condenser cooling system and by the diffuser) is about 3 percent of the 96-hour TLM for fathead minnows.

An anticipated acrolein demand in the main condenser cooling water and the probability of acrolein scrubbing in the cooling towers would add to the conservativeness of the described dilution; thus the use of acrolein or an equivalent biocide should have no significant wide area adverse impact on the reservoir.

(3) Water filtration plant - Raw water will be processed through a filtration plant for providing water to the steam systems makeup demineralizers and other plant uses. The plant will have a maximum capacity of 502 gallons per minute for a daily net output of 635,000 gallons. This rate will be utilized only prior to unit startup and at times of unit outage which will be for a period of about 12 weeks annually. Annual operational requirements will be about 40 percent of the maximum capacity.

Operation of the water filtration plant will require the use of alum, soda ash, and chlorine. Chlorine will be fed only to meet the initial raw water demand. The resultant chlorides will be removed by the steam systems makeup demineralizers and will be retained as combined chlorides in the demineralizer regenerant solutions. Filter backwash water and clarifier sludge will contain aluminum hydroxide floc and settled solids. These wastes will be diverted to a settling area which will consist of two basins for use at alternate times for storage and settling. Each basin will be sized for maximum plant output to allow a settling time of 2 days for normal backwash rates and four weeks storage of anticipated sludge. The supernatant water from the lagoon area will be decanted and returned to the inlet of the water filtration plant. As necessary, the sludge will be removed and disposed of by burial in compliance with applicable standards. Burial or landfill is a commonly accepted method of ultimate disposal of waste sludge used by municipal or other industrial plants. All disposal will be done in such a manner that environmental impacts will be minimal.

The addition of a coagulation aid may be necessary for more efficient operation of the filter plant. Any coagulation aid used will be chosen from those approved by the Environmental Protection Agency<sup>6</sup> and will be used in accordance with manufacturer's recommendations. Since a coagulation aid is used to improve the efficiency of the sedimentation, its use should result in less use of alum and soda ash with an overall result of less environmental impact.


(4) Steam systems makeup demineralizers - Two demineralizer trains, each with a capacity of 150 gallons per minute, will be installed for the purpose of supplying demineralized water for primary and secondary steam systems makeup and other minor plant uses such as

equipment decontamination, etc. The two trains will be operated only prior to unit startup and at times of unit outage which will be for a period of about 12 weeks annually. Normal annual operational requirements should be about 25 percent of maximum treatment capability. Based on maximum capacity operation for 12 weeks during refueling and reduced capacity operation for the remaining 40 weeks, the expected annual chemical additives would be approximately 126,200 pounds of sulfuric acid and 103,100 pounds of sodium hydroxide.

Normal procedure for treatment of demineralizer wastes is to hold the acid and caustic wastes in a tank, monitor pH, and adjust pH by addition of acid or caustic as required, and when neutralized the waste is discharged from the plant. At Bellefonte the regeneration waste will be passed through a weak cation-anion exchanger which will neutralize the waste. It will then be collected in a sump and, after pH monitoring and any further pH adjustment required, will be pumped to the cooling tower blowdown stream.

The weak cation-anion exchanger is charged initially with a weakly acidic cation resin which has a negligible salt splitting capacity. The neutral salts present do not consume ion exchange capacity, but pass through the column unchanged. Typical chemical reactions with the weakly acid cation exchanger are as follows:

Reactions with acid:



Reactions with alkali:



The unit is self-regenerating as long as the process is in balance.

Backwash for the demineralizer and neutralizer will be diverted to the filter plant backwash settling area.

(5) Main steam system - The main steam system utilizes once-through steam generators. Condensate polishing demineralizers are employed to control secondary system solids concentrations. There will be no steam generator blowdown. Currently it is expected that the condensate polishing demineralizers will utilize an ammonium-form cation resin. Regeneration of the condensate demineralizers will require the use of sulfuric acid, sodium hydroxide, and ammonium hydroxide. Regenerant wastes will normally be given the same treatment as the steam systems makeup demineralizers regeneration wastes. However, during periods of operation with steam generator leaks the condensate demineralizers may be radioactive. Under these circumstances, the condensate demineralizer regeneration wastes will be treated by evaporation and the evaporator distillate recycled for use in the secondary system (See section 2.4). The evaporator bottoms will be treated as solid radwaste.

Only hydrazine and ammonia are expected to be added to the steam generator feedwater. Feed concentrations will be about 15 µg/l hydrazine and 100 µg/l ammonia. (Feedwater pH will be maintained near 9.4 for system corrosion protection.) The only releases of ammonia or hydrazine will be trace amounts by way of the condenser vacuum pump air ejectors. These releases will not constitute a significant environmental impact.

(6) Alternative Treatment of Wastes from Makeup and Condensate Demineralizers - The spent regenerant solutions from the makeup and condensate demineralizers are the source of more than 90 percent of the "added" nonradioactive inorganic chemical wastes which will originate from the plant. The proposed method for disposing of these

wastes is to neutralize the regenerant solutions and then discharge them to the reservoir through the cooling tower blowdown. This is an accepted and widely used method of handling nonradioactive inorganic chemical wastes of this type. The expected chemical concentrations in the cooling tower blowdown and in the reservoir after mixing are summarized in Table 2.5-2. Discharge in this manner will not significantly alter the chemical quality of the river nor have significant environmental impacts that would affect other water uses.

As part of its environmental review, TVA investigated alternative methods of treating these wastes to determine if there were feasible and economically available methods to further reduce the already insignificant environmental impact of the proposed method of treatment and discharge of these wastes. Basically the alternatives considered would treat the spent regenerant solutions from the makeup and/or condensate demineralizers by evaporation. The evaporator distillate would be recycled within the plant and the evaporator bottoms would be disposed of by burial. The alternatives considered would achieve two different levels of reduction in discharges. However, because two different disposal methods were considered for each level of reduction, there were four alternatives considered. The alternatives considered are as follows:

1. The spent makeup demineralizer regenerants, after neutralization, would be released through the cooling tower blowdown in the same manner as the proposed method. The spent condensate demineralizer regenerants would be neutralized then evaporated. The evaporator bottoms would be disposed of with radioactive wastes in a licensed repository.

2. Both the spent makeup and condensate demineralizer regenerants would be neutralized, then evaporated. The evaporator bottoms would be disposed of with radioactive wastes in a licensed repository.
3. The spent makeup demineralizer regenerants, after neutralization, would be released through the cooling tower blowdown in the same manner as the proposed method. The spent condensate demineralizer regenerants would be neutralized then evaporated. The evaporator bottoms would be disposed of by burial in accordance with applicable standards.
4. Both the spent makeup and condensate demineralizers regenerants would be neutralized, then evaporated. The evaporator bottoms would be disposed of by burial in accordance with applicable standards.

The performance of alternatives 1 and 3 and of alternatives 2 and 4 are the same in regard to their impact on the aquatic environment. The performance of these two alternative groups are summarized and compared with the proposed method of treating and discharging these wastes in Table 2.5-3. Alternatives 2 and 4 when compared with the proposed method would result in the maximum reduction in discharge of the water quality parameters that would be affected by the implementation of the alternatives. The resulting reductions, in all cases, are less than the variations between the average and maximum concentrations observed to naturally occur at TRM 385.9. When compared with the proposed method of treatment and discharge of these wastes, no beneficial impacts on the aquatic environment can be identified as

resulting from the implementation of either of the alternative treatment methods. In addition, there would be increased impacts in other areas; such as land use, transportation, and resource commitments.

The economic costs of adding the treatment alternatives are summarized in Table 2.5-4. These costs include only the costs of evaporator operation, bottoms solidifications (as required), transportation, and burial. No capital costs for evaporators and related equipment were included in these economic evaluations. Assuming all evaporator bottoms to be nonradioactive, then Alternative No. 4 having an added annual cost of about \$81,000 is the lowest cost alternative considered that would provide the maximum reduction in the discharge of these wastes. Correspondingly, if all the bottoms were assumed to be radioactive, then Alternative No. 2 having an added annual cost of \$342,000 would be the lowest cost alternative. The actual annual cost that would be expected with the implementation of either alternative 2 or 4 would be somewhere between \$81,000 and \$342,000 depending on the relative portion of the bottoms that would be disposed of as either nonradioactive or radioactive wastes.

Since there are no environmental benefits that can be identified with the addition of either of the alternatives considered, it is concluded that the additional economic costs associated with the implementation of any of the alternatives considered cannot be justified.

(7) Component cooling water system - The cooling water system, used to cool the components of the primary reactor system during reactor shutdown, is closed forming a double barrier between the radioactive primary cooling system and the raw water cooling system. Corrosion inhibitors must be used in this intermediate cooling

system. Tentative plans are to use an amine form inhibitor such as ammonia, morpholine, or cyclohexylamine. The concentration within the component cooling water system is expected to be about 5 ppm ammonia or an equivalent concentration of morpholine or cyclohexylamine. Hydrazine will be used as an oxygen scavenger. Its concentration will be about 5-10 ppm.

When necessary for maintenance purposes, the component cooling water will be drained from portions of the system. If possible, the water will be returned to the component cooling water system. Otherwise, the water will be processed through the radwaste system for recycle or discharge.

(8) Reactor coolant system - Boric acid, lithium hydroxide, and hydrazine will be used in the reactor coolant system. Hydrazine will be used only during startup. Letdown from this system will be processed as tritium-containing waste and recycled for reuse in the plant.

(9) Auxiliary steam generator blowdown - Two 100,000-pound-per-hour oil-fired steam generators will be supplied. One steam generator will operate continuously and one will operate during the heating season and intermittently during the remainder of the year. Hydrazine will be added continuously to the feedwater as a dissolved oxygen scavenger. The hydrazine concentration in the feedwater will be about 10-15  $\mu\text{g/l}$  and within the system is expected to be at less than detectable concentrations. Ammonia will be intermittently added to the feedwater for pH control. Blowdown rate will vary from about 5,000 to about 11,000 gallons per day for both steam generators and will result in an annual discharge of ammonia of only about 33 pounds. The blowdown, which will have a residual ammonia concentration of about

0.3 mg/l, will be discharged to the sewage system subsurface filter dosing tank which discharges to the condenser cooling system makeup supply. Much of the ammonia will be scrubbed from the cooling water in the cooling towers.

(10) Chemical cleaning during construction -

Chemical cleaning operations prior to unit startup will be conducted in such a way as to minimize releases to the reservoir and to ensure that any chemicals released have been neutralized and diluted to meet applicable standards. These operations are described in Section 2.7, Construction Effects.

(11) Miscellaneous - Most equipment cleaning and decontamination operations will be performed with high-pressure water and with detergent solutions. A minimum amount of detergent will also be used for laundry and similar uses. Treatment will be provided to meet the applicable effluent limitations. Treatment and discharge of these detergent solutions in this manner are not anticipated to result in any significant environmental impacts.

Some decontamination operations will involve the use of chemicals such as sodium phosphate, sodium permanganate, ammonium citrate, alkaline potassium permanganate, and nitric, citric, oxalic, acetic, and hydrofluoric acids. Although the amounts of such chemicals have not been determined at this time, they will not be discharged to the reservoir but will be drained to the chemical tank in the radwaste system. The solutions will be neutralized and either drummed directly or processed by evaporation and the concentrates drummed.

Inputs to the chemical drain tank in the radwaste system will consist of laboratory drains and decontamination

wastes. The principal chemical reagents used in the laboratory will include sodium and ammonium hydroxides; hydrochloric, nitric, and sulfuric acids; ammonium acetate; and sodium carbonate.

Before the chemical drain tank is emptied, its contents will be analyzed. If the liquid does not contain chemicals that would be harmful to evaporator equipment (principally, chlorides and sulfides) it will be processed by evaporation. The concentrates will be drummed and the distillate discharged to the reservoir. If the chemical drain tank should contain chemicals that would be harmful to the evaporator, the contents will be drummed without further processing. The contents of the tank will be released to the reservoir only when analysis shows that chemical and/or radioactivity levels are within acceptable limits. It is expected that release would be an infrequent event.

2. Yard drainage system - An area of approximately 10 acres will be diked to provide a yard drainage pond. Any debris or oil which may be spilled and enter the yard drainage system will flow to this pond. A deep-level skimming type outflow will be provided so that floating debris and oil cannot escape from the pond. This material will be periodically removed from the pond for disposal. Depending on the character of the wastes, disposal will be by such methods as reclamation, burial, landfill, or burning. Oil will be reclaimed for reuse when practicable. If not suitable for reuse, it will be drummed and held onsite for later disposal. One possible disposal method under consideration is for fuel in one of TVA's fossil-fueled plants.

3. Transformers and electrical machinery - Some oil leakage may occur from bearings and other parts of certain machinery inside buildings. The oil will be drained to an oil sump that will have adequate capacity to contain all spillage which will be recovered for reclamation or disposal.

In the event of an outside oil spill from the main stepup transformer or insulating oil storage tank, the oil spillage will be routed to the storm drains and then to the drainage pond. At the drainage pond the oil will be recovered for reclamation or disposal.

Diesel fuel oil for auxiliary boilers and lube oil will be stored in tanks in an area which will be depressed below the surrounding ground to form a basin of sufficient capacity to retain the contents of the enclosed tanks. During periods of rainfall, some runoff water may accumulate in the basin. A valved low-level discharge pipe will be provided for periodic removal of precipitation collected within this area and basin contents will be inspected prior to discharge to assure that oil will not be released by this mechanism. The valve will be maintained in a closed position at all other times to provide for retention of oil should the tanks rupture.

In the interest of fire prevention, indoor transformer installations will be either Askarel-filled or dry-type transformers. When the former is used, the transformer will be located within a concrete basin to contain any possible spillage of this liquid. This will isolate this liquid (which contains polychlorinated biphenyls) from the common floor drainage system. Either a separate drain will be provided for routing any spillage to a separate storage sump or else the basin will be made high enough to hold the entire liquid content of the transformer. In either case, spilled liquid will subsequently be drummed for proper disposal if not suitable for reuse. Plans are to return the liquid to the manufacturer for ultimate disposal.

4. Sanitary wastes - Extended aeration sewage treatment facilities will be provided during the construction period to treat the domestic wastes from a peak construction force of approximately 2,500

persons. Effluent from the plant will be chlorinated before discharge to the river. These treatment facilities will be complemented during construction by portable-type chemical toilets for use in isolated or remote areas of the project site. At the end of construction, these initially installed facilities will be removed.

Secondary treatment facilities with provision for chlorination will be provided for the permanent plant. The treatment facility will be designed to handle the sewage load for approximately 300 persons which should be satisfactory for the 170 permanent employees, temporary employees, and visitors. During periods when a large temporary maintenance force is working at the plant, the permanent waste treatment system will be supplemented by portable-type chemical toilets.

Both construction and permanent sewage systems will be operated to prevent untreated effluents from entering the river. The effluent from the permanent plant will be discharged to the cooling tower makeup system. The design will be in accordance with approved sanitation standards applicable to TVA facilities and the waste treatment regulations of the Alabama Water Improvement Commission.

TVA routinely sends plans of its sanitary waste treatment facilities to the appropriate state pollution control organization for their information and files.

5. Gaseous emissions - The oil-fired auxiliary steam generators are expected to burn a total of about  $4.8 \times 10^6$  gallons per year of No. 2 fuel oil, having a maximum sulfur content of 0.5 percent.

The boilers are each rated at 100,000 lb/h steamflow with an input rating of about  $145 \times 10^6$  Btu/h.

Emissions resulting from boiler operation were used to calculate the annual average ambient pollutant concentrations. For shorter averaging times (24 hours and less) both units were assumed to operate at full capacity, which results in burning 1,815 gallons/h of fuel.

The following emission rates were used to calculate ambient pollutant concentrations:

Particulates	14.6 lb/h
Sulfur Oxides	143.0 lb/h
Carbon Monoxide	0.073 lb/h
Hydrocarbons	3.68 lb/h
Nitrogen Oxides	251.98 ton/yr

The emission will be released through a stack which is approximately 125 feet above ground level.

Calculated maximum ambient pollutant concentrations resulting from these emissions, together with the applicable ambient standards, are given below.

<u>Pollutant</u>	<u>Averaging Time</u>	<u>Calculated Concentrations</u>	<u>Secondary Ambient Standards</u>
Particulates	24-hour	0.57 ug/m <sup>3</sup>	150 ug/m <sup>3</sup>
Sulfur Oxides	24-hour	2.23 x 10 <sup>-3</sup> ppm	0.14 ppm
Carbon Monoxide	1-hour	1.27 x 10 <sup>-5</sup> ppm	35 ppm
Hydrocarbons	3-hour	7.43 x 10 <sup>-4</sup> ppm	0.24 ppm
Nitrogen Oxides	1-year	7.13 x 10 <sup>-5</sup> ppm	0.05 ppm

This evaluation of the emissions from the auxiliary boilers indicates that these emissions will cause a negligible environmental impact.

6. Normal Solid Waste Disposal - The nonradioactive solid waste, including sludge from the water treatment plant filters and demineralizers, generated at Bellefonte Nuclear Plant will be disposed of in a sanitary landfill located on TVA land and operated by TVA in

accordance with EPA guidelines or in a state-approved sanitary landfill on non-TVA land and operated by a municipality, county, or private contractor.

The characteristics of the nonradioactive solid waste generated at this installation will be paper, soft-drink cans, glass, wood, and garbage. The garbage portion will be relatively small in comparison to the quantity of paper present; thus, the moisture content of the solid waste will be low. The sludge from the filter plant and demineralizers will contain aluminum hydroxide which may be toxic to some plants if spread over land; therefore, the sludge will be dewatered, mixed with the other nonradioactive solid waste, and disposed of in a sanitary landfill. It is estimated that the quantity of nonradioactive solid waste will be 30 cubic yards per week plus about an additional 20 cubic yards of sludge per year. EPA's draft guidelines permit the disposal of sludge in a sanitary landfill provided it has been dewatered. The scrap metals (other than cans) will be salvaged and sold. Scrap lumber will be salvaged for reuse and made available to scavengers when it no longer can be used by TVA. Residue from the scavenged scrap lumber will be mixed with the other solid waste for disposal in a sanitary landfill. This system will be used during construction and operation of the completed plant. Used oil will be collected and transported to the nearest fossil-fueled plant for disposal.

Private contractual service for handling solid waste is available and some installations on Gunter'sville Reservoir are being served by a private contractor. Economics will determine whether TVA or a private contractor operates the collection and disposal systems. Adequate storage facilities, based on a minimum collection frequency of twice a week, will be provided and transport

will be in a closed vehicle or container regardless of which method is utilized. The service provided will be continually monitored by TVA to assure conformance to applicable Federal and state regulations.

REFERENCES FOR SECTION 2.5

1. Water Quality Criteria Recommendations for Residual Chlorine in Receiving Waters for the Protection of Aquatic Life. Letter to Francis T. Mayo from W. A. Brungs. EPA National Water Quality Laboratory, Duluth, Minnesota, dated December 30, 1971.
2. McKelvey, K. K. and Maxey Brooke, The Industrial Cooling Tower. Elsevier Publishing Company, Amsterdam, London, New York, Princeton, 1959 pp. 206.
3. Walko, J. F., J. M. Donohue, B. F. Shema, "Biological Control in Cooling Systems--New Developments and Pollution Considerations," presented at the International Water Conference, 32nd Annual Meeting, Pittsburg, Pennsylvania, November 2, 1971.
4. Butler, P. A. 1965 "Effects of Herbicides on Estuarine Fauna," Proceedings of Southern Weed Conference, 18:576-580.
5. Oberton, A. C. F. and V. T. Stack. 1957 "Biochemical Oxygen Demand of Organic Chemicals," Sewage Industrial Wastes 29 (11): 1267-1272.
6. "Coagulant Aids for Water Treatment," Journal of American Water Works Association, Volume 63, pp. 388-389.

Table 2.5-1

## SUMMARY OF "ADDED" CHEMICALS AND RESULTING END PRODUCTS

System	Chemical Treatment Source Chemical	Maximum Annual Use lbs	Waste End Product Chemical	Resulting End Product - lbs		
				Maximum Annual	Mean Daily	Maximum Daily
Steam System Water Filtration Plant <sup>a</sup>	Alum	43,232	Al(OH) <sub>3</sub> <sup>b</sup>	9,860	27	60
	Al <sub>2</sub> (SO <sub>4</sub> ) <sub>3</sub> · 18 H <sub>2</sub> O		SO <sub>4</sub> <sup>--</sup>	18,700	51	110
	Soda Ash Na <sub>2</sub> CO <sub>3</sub>	15,596	Na <sup>+</sup>	6,800	19	42
	Chlorine Cl <sub>2</sub>	5,250	Settled Solids <sup>b,c</sup>	21,800	60	151
Steam System Makeup Water Demineralizers <sup>a</sup>			OCl <sup>-</sup> and Cl <sup>-</sup>	5,250	14	30
	Sulfuric Acid H <sub>2</sub> SO <sub>4</sub> (100%)	126,200	SO <sub>4</sub> <sup>--</sup>	123,600	339	1,410
Natural Minerals Removed by Demineralizers <sup>a,c</sup>	Sodium Hydroxide NaOH (100%)	103,087	Na <sup>+</sup>	59,300	162	1,150
	Sodium Na <sup>+</sup>	2,500	Na <sup>+</sup>	2,500	7	28
	Chloride Cl <sup>-</sup>	4,810	Cl <sup>-</sup>	4,810	13	55
	Sulfate SO <sub>4</sub> <sup>--</sup>	5,760	SO <sub>4</sub> <sup>--</sup>	5,760	16	65
	Total Dissolved Solids	30,900	Total Dissolved Solids	30,900	85	340
Main Steam System Condensate Polishing Demineralizers <sup>d</sup>	Sulfuric Acid H <sub>2</sub> SO <sub>4</sub> (100%)	160,000	SO <sub>4</sub> <sup>--</sup>	157,000	430	1,602
	Sodium Hydroxide NaOH (100%)	52,500	Na <sup>+</sup>	30,200	83	308
	Ammonia Hydroxide NH <sub>4</sub> OH (100%)	33,000	NH <sub>3</sub>	17,000	47	173
	Ammonia NH <sub>3</sub> <sup>e</sup>	13,000	NH <sub>3</sub> <sup>f</sup>	13,000	36	36
Main Steam Generator System <sup>d</sup>	Hydrazine H <sub>2</sub> NNH <sub>2</sub> <sup>g</sup>	1,900	NH <sub>3</sub> <sup>f</sup>	1,900	5	5
	Auxiliary Steam Generator System <sup>d</sup>	Ammonia NH <sub>3</sub> <sup>e</sup>	175	NH <sub>3</sub>	175	0.5
RCW and ERCW <sup>d</sup>	Hydrazine H <sub>2</sub> NNH <sub>2</sub> <sup>g</sup>	26	NH <sub>3</sub>	26	0.1	0.1
	Acrolein (CH <sub>2</sub> = CHCHO) <sup>h</sup>	600	Acrolein	-	-	-
Main Condenser Cooling H <sub>2</sub> O <sup>d</sup>	Chlorine (Cl <sub>2</sub> ) <sup>i</sup>	149,800	OCl <sup>-</sup> and Cl <sup>-</sup>	149,800	410	410

a. Based on operation at rated capacity 12 weeks per year and less than rated capacity 40 weeks per year.

b. Precipitated material that will make up the water treatment sludge on a dry weight basis.

c. Estimates based on mean water quality data observed at TRM 385.9.

d. Based on 24-hour operation 365 days per year at rated capacity.

e. Ammonia will be added as needed to maintain a pH of approximately 9.4 in the system.

f. Ammonia will be released to the atmosphere through the air vapor outlet.

g. Hydrazine will be added as needed as a "DO" scavenger. Hydrazine assumed to decompose to ammonia.

h. Acrolein will be added to the system for 120 days for one-half hour each day. The acrolein demand of the main condenser water system and cooling tower stripping will prevent acrolein from being discharged to the aquatic environment.

i. Chlorine will be added to maintain a 0.5 mg/l chlorine residual at condenser outlet for one hour each day.

Table 2.5-2

SUMMARY OF "ADDED" INORGANIC CHEMICAL DISCHARGES TO GUNTERSVILLE RESERVOIR  
USING THE PROPOSED METHOD OF TREATMENT<sup>a</sup> AND DISCHARGE

BELLEFONTE NUCLEAR PLANT

Waste Product Chemical	Maximum Daily Discharge of Product Chemical - lbs	Maximum Daily <sup>b</sup> Contribution to Cooling Tower Blowdown - mg/l	Observed Chemical Concentrations in Reservoir Water at TRM 385.9 mg/l		Blowdown <sup>c</sup> Concentration Factor	Concentration During Period of Added Chemical Discharge				Allowable <sup>f</sup> Concentration in Reservoir mg/l
			Average	Maximum		Blowdown <sup>d</sup> mg/l		River After <sup>e</sup> Jet Mixing mg/l		
						Average	Maximum	Average	Maximum	
Sulfates (SO <sub>4</sub> <sup>2-</sup> )	3,187	47.9	17.7	23.0	2 3	83.3 101.0	93.9 116.9	24.3 26.0	30.1 32.4	250
Sodium (Na <sup>+</sup> )	1,528	23.0	7.7	12.4	2 3	38.4 46.1	47.8 60.2	10.8 11.5	15.9 17.2	8
Chlorides <sup>h</sup> (Cl <sup>-</sup> )	495	7.4	14.8	22.0	2 3	37.0 51.8	51.4 73.4	17.0 18.5	24.9 27.1	250
Ammonia <sup>i</sup> (NH <sub>3</sub> )	0.6	.009	0.026	0.09	2 3	.061 .087	.189 .279	.031 .032	0.10 0.11	8
Total Dissolved Solids	5,402	81.1	95.0	140.0	2 3	271.1 366.1	361.1 501.1	112.6 122.1	162.1 176.1	500

- a. Assume all maximum daily waste streams are retained in a holding tank and discharged within a 4-hour period each day. The makeup demineralizer spent regenerants and condensate demineralizer spent regenerants will be retained in separate tanks. However, when discharged to blowdown, the tanks could be emptied simultaneously. This will constitute the maximum discharge during a specific 4-hour period.
- b. Based on maximum daily contributions in blowdown stream for a 2-unit plant with a 74 ft<sup>3</sup>/s continuous blowdown rate.
- c. Normal blowdown concentration factor = 2; blowdown concentration factor = 3 following periods when blowdown was discontinued.
- d. Based on concentrations occurring only when the cooling tower blowdown is being released.
- e. Assumes jet mixing diffuser will be provided to mix 9 volumes reservoir water with one volume of blowdown.
- f. Alabama Water Improvement Commission, Water Quality Criteria for Waters of Alabama, July 17, 1972. Note: TVA code requires observance of 150 mg/l for SO<sub>4</sub><sup>2-</sup> instead of the given 250 mg/l.
- g. No specific standard has been identified, but contribution to dissolved solids is included.
- h. Computation is for chlorides.
- i. Ammonia and hydrazine added to the auxiliary steam system for pH control and dissolved oxygen control, respectively. Hydrazine assumed to decompose to ammonia.

Table 2.5-3

PERFORMANCE SUMMARY OF ALTERNATIVES FOR THE TREATMENT OF  
 "ADDED" INORGANIC CHEMICAL WASTES AND COMPARISON WITH THE PROPOSED METHOD

Parameter	Observed Chemical Concentrations in Reservoir Water at TRM 385.9 mg/l		Blowdown Concentration Factor	Alternates 1 and 3 <sup>a</sup>								Alternates 2 and 4 <sup>b</sup>							
				Maximum Daily Contribution to Cooling Tower Blowdown mg/l	Total Chemical Concentrations During Periods of Chemical Release				Reduction in Concentration as Compared to Proposed Method <sup>d</sup>		Maximum Daily Contribution to Cooling Tower Blowdown mg/l	Total Chemical Concentrations During Periods of Chemical Release				Reduction in Concentration as Compared to Proposed Method <sup>d</sup>			
					Blowdown mg/l		River After <sup>c</sup> Jet Mixing mg/l		Blowdown mg/l	River After <sup>c</sup> Jet Mixing mg/l		Blowdown mg/l		River After <sup>c</sup> Jet Mixing mg/l		Blowdown mg/l	River After <sup>c</sup> Jet Mixing mg/l		
					Average	Maximum	Average	Maximum				Average	Maximum	Average	Maximum				
Sulfates SO <sub>4</sub> <sup>---</sup>	17.7	23.0	2 3	23.8	59.2 76.9	69.8 92.8	21.9 23.6	27.7 30.0	24.1	2.4	0	35.4 53.1	46.0 69.0	19.5 21.2	25.3 27.6	47.9	4.8		
Sodium Na <sup>+</sup>	7.7	12.4	2 3	18.4	33.8 41.5	43.2 55.6	10.3 11.0	15.4 16.7	4.6	0.5	0	15.4 23.1	24.8 37.2	8.5 9.2	13.6 14.9	23.0	2.3		
Chlorides Cl <sup>-</sup> , OCl <sup>-</sup>	14.8	22.0	2 3	7.4	37.0 51.8	51.4 73.4	17.0 18.5	24.9 27.1	0	0	6.1	35.7 50.5	50.1 72.1	16.0 18.4	24.8 27.0	1.3	0.1		
Ammonia NH <sub>3</sub>	0.026	0.09	2 3	.009	.061 .087	.189 .279	.031 .032	0.10 0.11	0	0	.009	.061 .087	.189 .279	.031 .032	0.10 0.11	0	0		
Total Dissolved Solids	95	140	2 3	52.4	242.4 337.4	332.4 472.4	109.7 119.2	159.2 173.2	28.7	2.9	6.1	196.1 291.1	286.1 426.1	105.1 114.6	154.6 168.6	75	7.5		

- a. Neutralization and discharge of spent makeup demineralizer wastes on the same manner as the proposed method with evaporation of the condensate demineralizer spent regenerant wastes.  
 b. Neutralization and evaporation of both the makeup and condensate demineralizer spent regenerant wastes.  
 c. Assumes jet diffuser will be designed to mix nine volumes of river water with one volume of blowdown.  
 d. Reduction for average and maximum reservoir conditions are the same.

2.5-24  
Table 2.5-4

SUMMARY OF ADDITIONAL AVERAGE ANNUAL COSTS  
OF ALTERNATIVE METHODS OF TREATING INORGANIC CHEMICAL  
DISCHARGES AS COMPARED TO THE PROPOSED METHOD

	Additional Annual <sup>a</sup> Cost
Proposed System Neutralization of spent makeup and condensate polishing demineralizer wastes followed by discharge to the cooling tower blowdown.	Base
Alternative No. 1 The spent makeup demineralizer regenerants, after neutralization, would be released through the cooling tower blowdown in the same manner as the proposed method. The spent condensate demineralizer regenerants would be neutralized, then evaporated. The evaporator bottoms would be disposed of with radioactive wastes in a licensed repository.	\$197,000
Alternative No. 2 Both the spent makeup and condensate demineralizer regenerants would be neutralized, then evaporated. The evaporator bottoms would be disposed of with radioactive wastes in a licensed repository.	\$342,000
Alternative No. 3 The spent makeup demineralizer regenerants, after neutralization, would be released through the cooling towers blowdown in the same manner as the proposed method. The spent condensate demineralizer regenerants would be neutralized, then evaporated. The evaporator bottoms would be disposed of by burial in accordance with applicable standards.	\$ 50,000
Alternative No. 4 Both the spent makeup and condensate demineralizers regenerants would be neutralized, then evaporated. The evaporator bottoms would be disposed of by burial in accordance with applicable standards.	\$ 81,000

a. Includes evaporator operation, bottoms solidification (as required), transportation, and burial. Does not include capital cost of evaporators and related equipment.

Table 2.5-5

SUMMARY OF OBSERVED TRACE METAL CONCENTRATIONS AND EXPECTED MAXIMUM TRACE METAL CONCENTRATIONS  
IN THE DISCHARGE STRAM AND AT THE EDGE OF THE JET MIXING ZONE  
BELLEFONTE NUCLEAR PLANT

Parameter (Dissolved)	Number of Times Observed in Nine Samples <sup>a</sup>	Statistics for Observed Values <sup>a</sup>			Concentration <sup>b</sup> Factor	Maximum Expected Trace Metal Concentrations Closed-Cycle Cooling Operation <sup>c</sup>		Effluent Guidelines <sup>e</sup> ug/l
		ug/l				ug/l		
		Minimum	Maximum	Mean		In Blowdown	Edge of Jet Mixing Zone <sup>d</sup>	
Zinc	5	6	23	12	2	46	25.3	800 (Zn)
					3	69	27.6	
Boron	9	7	45	24	2	90	49.5	
					3	135	54.0	
Iron	9	4	52	21	2	104	57.2	3,000 (Fe)
					3	156	62.4	
Manganese	3	0.6	1.9	1.4	2	3.8	2.1	
					3	5.7	2.3	
Copper	9	2	9	4	2	18	9.9	500 (Cu)
					3	27	10.8	
Barium	9	11	36	24	2	72	39.6	
					3	108	43.2	
Strontium	9	20	118	54	2	236	129.8	
					3	354	141.6	
Aluminum	6	16	53	28	2	106	58.3	
					3	159	63.6	
Chromium	3	3	13	6	2	26	14.3	500 (Cr)
					3	39	15.6	
Lead	2	11	14	12.5	2	28	15.4	
					3	42	16.8	
Molybdenum	1	12	12	12	2	24	13.2	
					3	36	14.4	
Cadmium <sup>f</sup>	0	-	-	-				<100 (Cd)
Arsenic <sup>f</sup>	0	-	-	-				
Beryllium <sup>f</sup>	0	-	-	-				
Silver <sup>f</sup>	0	-	-	-				
Nickel <sup>f</sup>	0	-	-	-				500 (Ni)

- a. From Trace Metals in Waters of the United States: A Five Year Summary of Trace Metals in Rivers and Lakes of the United States, (October 1, 1962 through September 30, 1967), U.S. Department of the Interior, FWPCA, Division of Pollution Surveillance, Cincinnati, Ohio. Weekly samples were composited for 3-month periods twice a year during the period. Data collected at Widows Creek Steam Plant TRM 408.
- b. Normal blowdown concentration factor = 2; blowdown concentration factor = 3 when blowdown is resumed following periods when blowdown had been discontinued for up to 5 hours because of low streamflows.
- c. Assumes maximum observed concentrations occur.
- d. Assumes jet diffuser will be designed to mix nine volumes of river water with one volume of blowdown.
- e. Alabama Water Improvement Commission, Tentative Guidelines for Heavy Metal Effluent Limitations, received by letter, October 30, 1972.
- f. Not detected in any sample.

2.6 Heat Dissipation - All steam-electric generating plants must release heat to the environment. A portion of the thermal energy produced in the reactor will be converted to electrical energy through the turbine and generator, while the remainder is absorbed by cooling water flowing through the condenser. In the current state of technological development in nuclear plants, approximately two-thirds of the heat produced in the reactor is released to the environment.

1. Water temperature standards - The applicable water temperature standards within the State of Alabama for the protection of fish and wildlife are as follows:

The maximum temperature rise above natural temperatures before the addition of artificial heat shall not exceed 5°F. in streams, lakes, and reservoirs nor shall the maximum water temperature exceed 90°F., except that in the Tennessee and Cahaba River Basins and portions of the Tallapoosa River Basin which have been designated by the Alabama Department of Conservation as supporting smallmouth bass, sauger, and walleye, the temperature shall not exceed 86°F. In lakes and reservoirs, there shall be no withdrawals from or discharge of heated waters to the hypolimnion unless it can be shown that such discharge will be beneficial to water quality. In all waters the normal daily and seasonal temperature variations that were present before the addition of artificial heat shall be maintained.

These standards were adopted by the Alabama Water Improvement Commission on July 17, 1972, and approved by EPA on September 19, 1972.

2. Thermal regime of Guntersville Reservoir - Guntersville Reservoir exhibits weak thermal stratification during the summer months due primarily to the relatively short detention time within the reservoir and the fact that the power intakes at Nickajack withdraw water from the entire depth of the reservoir. The dissolved oxygen and temperature profiles of Guntersville Reservoir observed in 1963-64 and the dissolved oxygen and temperature observed in the releases from

Guntersville Dam and Hales Bar Dam (replaced in 1967 by Nickajack Dam) for calendar years 1963 and 1964 have been previously discussed in Section 1.2, General Information, and are shown in figures 1.2-9 and 1.2-10, respectively.

Temperature data collected in the tailrace of Guntersville Dam for the period 1960 through 1971 show a maximum temperature of 88.7°F and also show that temperatures exceeding 82°F occurred frequently during the summer months. Similar data collected at Nickajack for the period 1968 through 1971 show a maximum water temperature of 82.4°F. These data show that the outflow temperature from Nickajack (inflow to Guntersville) is slightly cooler than the outflow from Guntersville. The temperatures of the releases from Guntersville and Nickajack Dams are summarized in Table 1.2-15.

3. Description of the cooling system - To meet cooling requirements at Bellefonte Nuclear Plant and at the same time provide environmental protection for the waters of Guntersville Reservoir, TVA proposes to install closed-cycle natural draft hyperbolic cooling towers. This type of condenser cooling water system would enable the plant to operate with a minimum thermal effect on the Tennessee River since the condenser cooling water system will cycle cool water from the cooling towers through the condensers and discharge the warmed water back to the cooling towers in a closed system rather than discharging to the river.

The plant will be designed for two towers which will be approximately 500 feet in diameter and 500 feet high. Figure 2.6-1 shows the tower arrangement. The use of natural draft towers will not require additional land.

For each unit approximately 436,000 gal/min of cooling water from the cooling towers would circulate through the condensers. The temperature of the water flowing through the condensers will be raised by approximately 36°F in removing  $7.8 \times 10^9$  Btu/h from each unit when operating at normal full load. In the operation of cooling towers a certain portion of the circulating water is continuously lost as a result of evaporation, small leaks, drift, and blowdown. Therefore, makeup water must be continuously added to the system. To provide this makeup, an estimated maximum of 66,600 gal/min, or 148.5 ft<sup>3</sup>/s, will be withdrawn at the head of the channel feeding from the Guntersville Reservoir at TRM 392.25. Normally about 26,000 gal/min, or 57.9 ft<sup>3</sup>/s, of this withdrawal will supply water for the essential raw cooling water system. This flow, which may be warmed as much as 13°F in passing through the heat exchangers, will be discharged to the cold water channel of the towers, thus supplying a portion of the water required for use as cooling tower makeup. Since the normal flow from the essential raw cooling water system will not meet cooling tower makeup requirements in all cases, which at a maximum are about 148.5 ft<sup>3</sup>/s, additional (supplemental) intake pumps will be provided. The raw cooling water for the plant will be taken from and returned to the cooling tower system.

Normal water surface of the Guntersville Reservoir varies between elevations about 595 (summer) and 593 (winter). The water intake pump structure will be located at the end of an intake channel in which the maximum water velocity of the cross section will be less than 0.2 foot per second even for a water surface elevation of

593. The intake structure will have four openings slightly over 8 feet wide and 15 feet high. The top of the opening will be at elevation 572 and the bottom at elevation 557. The maximum velocity of flow will be less than 0.42 foot per second through each of the openings. The openings will be followed by vertical traveling screens which have 3/8-inch opening mesh. The maximum velocities through clean screens are estimated to be about 0.24 foot per second during summer high-water level and about 0.25 foot per second during winter low-water level. All intake water taken from the river will pass through 1/8-inch strainers after passing through the traveling screens.

The intake channel which connects the intake structure to the reservoir will have side slopes 4 feet horizontally to 1 foot vertically with the side slopes intersecting the surface of rock. The distance between the toes of the slopes at the rock surface will be 40 feet. To provide assurance that water will always be available to the essential raw cooling water system, a 20-foot-wide trench will be excavated 20.5 feet below the surface of the rock to connect to the original river channel. The depth of water in the intake channel will vary from 10 to 12 feet measured to the surface of the rock and 30.5 feet to 32.5 feet to the bottom of the trench. The intake structure will be located some 1,200 feet from the existing shoreline (at elevation 595).

TVA concluded that the proposed intake resulted in no significant adverse environmental impacts and that detailed studies of alternatives was not warranted. In the process of its review of the draft environmental statement, the AEC Regulatory Staff on several occasions requested TVA to examine alternate intake designs. In response to the

AEC request, TVA has examined several alternatives to the proposed intake arrangement and has concluded, on balance, that the originally proposed shoreline intake structure is the best alternative available. Alternative intake designs are discussed in subsection 2.6.6 (9).

Normal blowdown from the natural draft towers will be discharged into Gunterville Reservoir at a rate of about  $74 \text{ ft}^3/\text{s}$ . Studies will be made to determine the proper type and the best location for a blowdown diffuser to provide good dilution with the streamflow, consistent with the need to protect the aquatic biota of the reservoir. The temperature of the blowdown will be the same as the cooling tower effluent which will vary with the meteorological conditions. It is now believed that a nozzle-type diffuser will be the best diffuser design for this site and that it can be designed to mix the blowdown with 9 equal parts of reservoir water and thus limit the temperature rise after mixing to less than  $5^\circ\text{F}$ . For cost estimating purposes such a design was assumed to consist of an approach pipe approximately 4 feet in diameter. Mixing would be achieved by means of two 2-foot diameter nozzles spaced approximately 50 feet apart and oriented to discharge perpendicular to the reservoir current. The blowdown diffuser will continue to entrain ambient river water even during periods of zero or low flow. The length of time that the blowdown diffuser can operate in these low-flow situations without exceeding a  $5^\circ\text{F}$  rise after mixing will depend on the final design of the diffuser.

The diffuser will be designed and located in the stream so as to minimize the disturbance of the aquatic organisms on

the bottom of the reservoir, and it will be located to take advantage of flow in the reservoir to provide mixing to reduce the thermal impact.

An exact estimate of the mixing zone for the heated discharge can only be determined after the design of the diffuser is finalized.

Alternatives to the multiple-nozzle jet diffuser include a multiport diffuser, an open pipe with headwall, and a single buoyant jet. The least costly alternative to construct and operate would be the open-end pipe to discharge back to the reservoir. However, the open-pipe discharge and the buoyant jet would not achieve the required degree of mixing to meet the State water quality standards. Thus TVA proposes to use some type of diffuser system for discharging the blowdown to the reservoir.

A multiport diffuser could be designed to achieve the required dilution, but preliminary investigations indicate that there would be no economic or environmental advantage over the jet diffuser.

4. Impact of heat dissipation facilities - After considering several alternative heat dissipation facilities, including once-through cooling, mechanical draft and natural draft cooling towers, spray canal, and a cooling lake (the details of which are discussed in section 2.6.6), TVA proposes to install closed-cycle natural draft hyperbolic cooling towers. This section describes the environmental impacts which are anticipated as a result of installing and operating this system.

(1) Physical and chemical characteristics

of the tower effluent - Tower makeup will be taken from the Tennessee River at the plant site. The quantity of makeup will be dependent on (1) the amount of blowdown necessary, (2) the amount of evaporation, and (3) drift and other small losses. The maximum amount of makeup required for operation with natural draft cooling towers is estimated to be about 148.5 ft<sup>3</sup>/s.

Operation of the two natural draft cooling towers of the condenser circulating water system will evaporate approximately 37 ft<sup>3</sup>/s of the flow for each tower during periods of high evaporation. Since water is continuously evaporated from the towers, the concentrations of dissolved solids in the circulating water of a closed system will increase. To limit the dissolved solids concentrations and water chemistry changes which would result from chemical additives, a certain amount of blowdown from the towers and makeup to the towers must be provided. The amount of blowdown is dependent on the amount of evaporation, the concentration of dissolved solids in the circulating water, and the water quality standards imposed for the receiving waters. This blowdown will be removed from the tower effluent (cold-water side) and normally will be discharged into Gunter'sville Reservoir through a diffuser at a rate of 74 ft<sup>3</sup>/s. The dissolved solids at TRM 385.9 for 1963-64 averaged approximately 95 mg/l with a peak of 140 mg/l. It is expected that concentrations of dissolved solids in the circulating water system will not normally exceed 2 (see section 2.5.1), and the applicable stream standards for dissolved solids will not be exceeded.

Because the plant site is located between the Nickajack and Guntersville Dams, the flows by the site will depend on the releases TVA schedules from these two projects, the primary influence being the release from Nickajack. All cooling tower blowdown will be stopped when there is insufficient water available to provide dilution of the cooling tower blowdown. Short periods of no flow at the site probably occur rather frequently, as shown by the flow frequency curves for Nickajack and Guntersville Dams (see figures 2.6-2 and 2.6-3). However, the duration of no-flow periods is relatively short, as shown by the following table:

DURATION OF ZERO-FLOW PERIODS

AT NICKAJACK DAM FROM MAY 1968 TO OCTOBER 1971

<u>Duration (hours)</u>	<u>No. of Occurrences from 5/68 to 10/71</u>
1	32
2	27
3	41
4	62
5	90
6	112
7	89
8	57
9	33
10	21
11	6
12	4
13	0
14	1
15	0
16	1

There were no occasions during this period when the duration of no releases was 24 hours or more. These shutdowns were controlled by TVA and were planned operations. After Bellefonte Nuclear Plant becomes

operational, the blowdown requirements of Bellefonte Nuclear Plant will be considered before the releases of the hydro project are restricted.

When streamflows are restored following shutdowns, the normal blowdown rate will be resumed. After some period, depending on the length of time blowdown was withheld, the concentrations of solids will return to normal levels.

The temperature of this blowdown water will be approximately 67°F under average winter conditions, 74°F under average fall and spring conditions, and 84°F under average summer conditions. A peak summer condition could produce temperatures near 90°F for a few hours a day on the hottest summer days.

As shown by the data of Table 1.2-15, there will be times when the water temperatures of Guntersville already equal or exceed the maximum temperature standard of 86°F. During such times TVA will operate Bellefonte so as to hold up blowdown to the extent considered practicable. This holdup capability can be used to restrict heated discharges to the periods of the day when wet-bulb temperature is most favorable. This will result in discharges of blowdown at the lowest possible temperature. Nevertheless, there will be very limited times when the reservoir water temperatures are 86°F or more and blowdown will have to be discharged. The quantity of heat will be small and will be well dispersed within the receiving waters by the mixing device.

A detailed thermal monitoring program for the Bellefonte Nuclear Plant will be available at the operating license stage.

The amount of drift is estimated to be approximately 0.01 percent of the circulating waterflow, or about 0.25 ft<sup>3</sup>/s total for the two towers.

(2) Local fogging and icing -

(a) General conditions -

Potential environmental effects from thermal dissipation alternatives at the Bellefonte Nuclear Plant may include some modification of the local environment by increased frequency of fog formation, increased fog density, reduced visibility, increased precipitation, alteration of ambient moisture content, and icing on nearby surfaces when temperatures are below freezing.

Local atmospheric conditions indicate that dense, naturally occurring fogs (visibility less than or equal to one quarter mile) can be expected about 36 days per year in the vicinity of the Bellefonte Nuclear Plant.

Fogs occurring in the Bellefonte area are mainly radiation and radiation-advection types resulting primarily from nocturnal cooling and subsequent saturation of the air within the lower few hundred feet of the surface. These fogs normally occur during late evening through midmorning hours when weak winds and optimum radiational cooling conditions prevail. On a seasonal basis, heavy natural fogs occur in the Bellefonte area with the highest frequency during the fall and early winter and the lowest frequency during the late winter through midsummer.

(b) Method of analysis -

Evaluations of the potential environmental effects from operation of

mechanical draft and natural draft cooling towers, spray canal, and cooling lake alternatives were based partly on field observations from August 1, 1970, through August 31, 1971, at the TVA Paradise Steam Plant in Kentucky. During this period one or more of the three natural draft cooling towers at the Paradise plant were in operation on 122 days during all seasons in the year. Observations were made by the resident meteorologist\* usually between 0730 and 0900 hours local time. These observations were augmented by data from the Paradise meteorological station, the National Weather Service Upper Air Section (rawinsonde) in Nashville, and the Widows Creek valley and Widows Creek Sand Mountain meteorological stations located 19 and 15 miles, respectively, upvalley from the Bellefonte plant site.

Since the length of the visible vapor plumes depends primarily on the moisture content of the ambient air, observed plume lengths at the Paradise Steam Plant were correlated with the absolute humidity deficit determined from the mean ambient dry-bulb and dew-point temperatures of the layer of air in which the plume was observed. Absolute humidity deficit is defined as the amount of moisture a parcel of air can contain at saturation for a specific dry-bulb temperature, minus the actual amount of moisture present. The observed plume lengths and humidity deficits were fitted by least squares to obtain an expression to estimate plume lengths.

The absolute humidity deficit was determined for the vertical layers, 0 to 1,000 feet and 500 to 3,000 feet, and correlated with corresponding mean wind directions to identify the mean meteorological conditions applicable for mechanical draft and

---

\*On Permanent assignment at the Paradise Steam Plant for support of the plant's SO<sub>2</sub> emission limitation program.

natural draft tower operations, respectively. This information, which is based on the 0600 local time Nashville rawinsonde data, was extrapolated to the Bellefonte area and used to estimate plume lengths for the mechanical draft and natural draft towers. Early morning data from the two Widows Creek Steam Plant meteorological stations were used to evaluate the environmental effects of the proposed spray canal and cooling lake. Data from these stations provided surface information for evaluating the environmental effects of low-level moisture additions from the spray canal and cooling lake.

Since the generating capacity of the Bellefonte Nuclear Plant is larger than that of the Paradise Steam Plant, more moisture would be evaporated into the atmosphere at Bellefonte; therefore, it is necessary to adjust the observed Paradise evaporation rates upward. This adjustment of observations resulted in longer vapor plume estimates for the Bellefonte Nuclear Plant heat dissipation alternatives.

This data analysis was used to construct radial graphs illustrating directional frequency, by compass sector, of the expected plume lengths during the early morning hours, 0600-0900 local time, the time of day when the maximum plume lengths are expected. Two graphs were prepared for each heat dissipation method--one for all days regardless of the early morning average ambient temperature and one for those days when the 0600-0900 average ambient temperature was below freezing. The plume length data from which the graphs were drawn were separated by direction into the sixteen 22-1/2-degree compass point sectors. Radial distances on the graphs represent

plume lengths up to 5 miles; numbers on the lines dividing the compass sectors represent percentages of days when sometime during the period, 0600-0900 local time, the vapor plume will be equal to or greater than the indicated length. It is emphasized that these numbers represent the percentage of days the plume lengths could reach these distances and do not indicate necessarily whether or not the vapor plume would exist at ground level for a particular alternative. These radial graphs were overlaid on a scaled map showing the highways, population centers, and the terrain elevations for the Bellefonte area.

(c) Effects of natural draft

towers - Observations of the natural draft cooling tower plumes at the TVA Paradise Steam Plant indicate that with the average plume rise ranging from 500 to 1,000 feet above the cooling towers, the visible portion of the elevated plumes seldom, if ever, reaches ground level and causes localized surface fogging. However, in the Bellefonte area the nearby Sand Mountain Plateau is approximately 400 feet higher than the natural draft cooling tower. The plateau lies within 1-1/2 to 2-1/2 miles from the plant site in the northeast through south sectors. The radial graph illustrating directional frequency of expected plume lengths, figure 2.6-4, indicates that plumes of sufficient length to reach the plateau will occur as often as 6 percent of the time (22 days per year) in some of these sectors. Subsequently, there may be a fogging potential associated with the roadways on Sand Mountain. The approximate population of this area is 880. Traffic volume data are not available for the county roads of the area where increased fogging could occur. However, Alabama Highway 40 in the south sector could

have the plume reach it 1 percent of the time. The 1970 average daily traffic at this point was 2,200 vehicles.

Review of the daily early morning temperatures indicated that freezing temperatures can normally be expected about 70 days during the 5-month period, November through March. As indicated by figure 2.6-5, plumes of sufficient length to reach the nearby Sand Mountain Plateau during potential icing conditions could occur as often as 2 percent of the time (7 days per year) in some of the sectors. Highway 40 in the south sector could have potential icing conditions about 0.5 percent of the time. Observations at the Paradise Steam Plant indicate that light fallout of freezing precipitation from the bottom of the plume should be no problem.

(3) Aesthetics - The hyperbolic form and concrete materials will be compatible with the architecture of the main plant and should not require any special aesthetics treatment.

The natural draft cooling towers being about 500 feet high will most certainly become a landmark on the surrounding terrain. The vapor plumes will create an aesthetic impact on the towns of Pisgah (population, 519), Hollywood (population, 865), and Scottsboro (population, 9,324), as well as for traffic on U.S. Highway 72, which is within 5 miles of the plant in the north-northeast through west-southwest sectors.

(4) Noise - Based on TVA's experience with the three natural draft towers installed at its Paradise Steam Plant, only slight increases in noise levels at the site boundary would be expected from the natural draft towers.

5. Applicability of water quality certification -

Under the provisions of Section 401(a)(6) of the Federal Water Pollution Control Act Amendments of 1972 [33 U.S.C. § 1341(a)(6) (Supp. II, 1972)], TVA as a Federal agency is not required to obtain the certification of compliance with applicable state water quality standards required by Section 401(a) of that Act. TVA is, however, required by Section 313 to meet state water quality requirements and is subject to Executive Order 11752, "Prevention, Control, and Abatement of Environmental Pollution at Federal Facilities."

The thermal discharge from this plant will not affect the quality of the waters of any other state.

6. Alternative heat dissipation facilities - The

following discussion describes the alternative heat dissipation methods and facilities considered by TVA. The methods investigated were: once-through cooling using a large diffuser system, dry cooling towers, mechanical draft cooling towers (wet), natural draft cooling towers (wet), spray canal system, and cooling lake system.

Analyses were performed using the following factors as a basis: feasibility, environmental considerations, and economic considerations. The analyses were carried to the extent required to determine the acceptability of each alternative when considering these factors and the capability of meeting water quality standards.

(1) Once-through cooling - Once-through cooling utilizing a diffuser discharge to the reservoir has been a practical consideration at other plant sites in order to benefit the plant with cooler water for lower turbine backpressure and attendant increased plant capability. Because of the adopted thermal standards

of 5°F rise and 86°F maximum, the completely open system was not considered feasible for this plant. Assuming the heated effluent is mixed with 75 percent of the riverflow, there would have been insufficient flows available in the reservoir to meet thermal standards about 30 percent of the days based on analysis of the daily flows for 1966-71. In a low-flow year with a relatively hot summer, plant generation might have to be curtailed as much as 43 percent of the days to comply with the thermal standards if the plant utilized once-through cooling only. Therefore, the temperature rise after mixing could not meet the criteria a sufficient amount of time to justify the once-through cooling system. Some form of auxiliary cooling with a combined- or closed-cycle system is therefore required to assure that the thermal criteria are complied with and that a reliable source of power is provided.

(2) Dry cooling towers - The use of dry cooling towers for power plants is a relatively recent development in the United States. The largest unit in the United States employing this type of cooling is less than 50 MW. While European units have used dry cooling towers for years, the largest such unit is believed to be less than 250 MW in size.<sup>1</sup>

Dry cooling tower systems for use in heat dissipation for power plants are today being discussed more and more because of the potential environmental advantages this method has over the once-through and the evaporative (wet) or conventional cooling systems. The dry system requires almost no consumptive use of water, and since there is no evaporation of water, there are no vapor plumes, no drift, and therefore no fogging and icing. Losses to the aquatic

life from impingement and entrainment are limited to the initial filling of the system and to the occasional replacement for leaks and other losses. There is no cooling tower blowdown, and thermal discharges to surface waters are not required.

The dry cooling tower system which would most likely be used for generating units in the size range now installed in the U.S. is the indirect or Heller system.<sup>2</sup> In this system the cool water coming from the tower is sprayed directly into the turbine exhaust steam in a jet-spray condenser. The water from the condenser is collected and a portion is returned to the boiler in the steam cycle; the remainder circulates in a closed system to the cooling tower to be cooled and again sprayed into the condenser. Since the cooling water and the steam are mixed, the cooling water must be of condensate purity. Both mechanical draft and natural draft towers can be used in the dry system to reject the heat to the ambient air by convection rather than evaporation. This is an inherently less efficient process and requires an extensive heat transfer surface area of metal fin tubing within the tower, which could be either mechanical or natural draft. In this system the temperature of the water leaving the tower can only approach the dry-bulb temperature of air which is invariably higher than the wet-bulb temperature approached by the wet towers.

Because of the high circulating water temperatures, expensive supplemental cooling must be provided for plant auxiliaries.<sup>1</sup> Dry cooling systems dictate severe performance requirements on the turbines which may have to operate over a wide range of backpressures with a maximum of from 10 to 14 inches Hg Absolute compared to a maximum backpressure of conventionally cooled plants of about 5 inches of Hg Abs.<sup>1,3</sup>

Turbine manufacturers have recently indicated it should be feasible to develop 700 to 800 MW turbines with backpressures as high as 15 inches Hg Abs. for delivery by 1976. There are, however, substantial associated problems which would have to be resolved before these turbines can be made available. In a June 28, 1971, Marketing Information Letter the General Electric Company stated:

Our studies show that there are substantial turbine design challenges associated with the higher than normal exhaust pressure of dry cooling tower applications. These include: possible overheating of the last-stage bucket; possible flutter damage to the last-stage bucket at high exhaust pressures and low loads; possible water damage due to recirculation from the direct condenser; rapid exhaust temperature changes due to load changes which cause cycling thermal stresses; distortion of the exhaust hood and bearing supports; and difficulties in providing adequate clearance control.

Regarding turbines of the size required for large units as are to be installed at Bellefonte, the GE letter said, "We believe it is premature to speculate on the cost or earliest shipment of any nuclear turbine design suitable for operation at exhaust pressures up to 15 inches Hg absolute."

In a followup letter of November 29, 1971, GE offered a turbine for fossil reheat application suitable for operation at exhaust pressures up to 15 inches Hg Abs. The maximum rating for a 4-flow turbine-generator of this design is approximately 750,000 kW. GE announced that they were proceeding with the design and development of this new turbine in order to support shipment by early 1976.

A report, Plant Design Alternatives for Controlling Thermal Discharge, Chemical Effluents, and Intake Entrapment, which was prepared by Sargent & Lundy Engineers and presented at the Atomic Industrial Forum Seminar, January 23, 1973, stated regarding dry towers:

Dry towers are not feasible on large nuclear units at the present time for many reasons. These include engineering problems, condenser problems, lack of experience, and unfavorable economics.

Indications are that progress is being made in the area of power plant design for dry tower application and that more serious consideration will be given in the future to such towers. However, at present TVA believes that dry cooling towers are not a viable alternative heat dissipation method for nuclear units of the size to be installed at Bellefonte.

(3) Alternative systems of operation -

Two systems of operation were considered for the several heat dissipation alternatives: (1) closed-cycle system, in which the cooling water is circulated in a closed-loop system, and (2) combined-cycle system, in which the system can be operated in any of three modes as required.

The three modes in which the combined-cycle system can operate are:

1. Open mode. Operates as a once-through system with heat dissipated to the river.
2. Helper or topping mode. Heated condenser water is circulated through a supplemental cooling facility for initial cooling and then discharged to the river.
3. Closed mode. Operates in a closed loop with heat dissipated to atmosphere by, for example, a tower.

The closed-cycle system is adaptable to either mechanical or natural draft cooling towers, cooling lake, or spray canal. The only water discharged to Gunter'sville Reservoir would

be the required blowdown from the cooling system. The closed system would essentially exclude the use of Guntersville Reservoir for heat dissipation but would result in reduction of plant net electrical output and therefore reduced plant efficiency. Figure 2.6-6 shows the schematic arrangement for a closed system.

The combined-cycle system provides the flexibility of using the Guntersville Reservoir for heat dissipation. The open mode would utilize diffusers alone, which increases plant efficiency due to lower condenser cooling water temperature. The helper mode also would allow use of the lower temperature condenser cooling water from the reservoir and would divide the heat dissipation between the reservoir and the heat dissipation device. The combined-cycle system would employ cooling facilities designed for less cooling capability than the facilities selected for a closed system since a closed system requires supplemental cooling 100 percent of the time, and therefore higher cost, more efficient heat dissipation facilities can be justified. Figure 2.6-7 shows the schematic arrangement and operation of the various gates required in the cooling water circuit to accomplish the three modes of combined-cycle operation.

The design of the intake as a skimmer wall for combined-cycle system is not considered feasible because of the shallow water depths at the site and the small temperature difference between the upper and lower layer of water which will exist when meeting the 5°F rise standard. With 2-unit open or helper mode operation and a maximum temperature rise in the reservoir of 5°F, the width of the skimmer wall necessary to withdraw water from a 12-foot-deep lower layer (out of a total depth of 20-25 feet) would be at least 2,000 feet.

The location of the intake would be expected to be on the river bank upstream from the discharge which has been shown by model studies for the Browns Ferry plant to result in negligible intake temperature rise as long as the criterion of a 5°F rise in the river is being met by diffuser dilution.

Analysis shows that a diffuser system is feasible for those schemes employing a combined cooling system. Although sufficient design information is not available for a final design, a preliminary design has been developed.

The proposed design consists of two conduits having cross-sectional areas equivalent to a 19-foot diameter circular section. Because of the shallow depths and the large hydrodynamic loading that would act on an exposed diffuser pipe as a result of navigation above it, it is believed that the diffuser would have to be almost completely buried. The length of the upstream conduit would be about 1,100 feet excluding approach pipe. Diffusion would be achieved by means of 43 two-foot diameter nozzles evenly spaced along the last 550 feet of the pipe. The nozzles should be oriented to discharge in the downstream direction, parallel to the reservoir current. The downstream diffuser would be 550 feet long excluding approach pipe and would also have 43 two-foot diameter nozzles evenly spaced along the length of the conduit. Nozzle orientation would be the same as for the upstream diffuser. The nozzle jet velocity would be approximately 10 ft/s. The velocity of the flow over the diffusers which would be induced by the jets would be about 1 ft/s.

Based on available design criteria, it is estimated that this diffuser would be capable of entraining up to 10 times

the condenser flow. The diffuser would occupy about 75-80 percent of the width of the section; hence, at large reservoir flows, the condenser flow may mix with as much as 75-80 percent of the reservoir flow. Based on experience with the Browns Ferry 3-dimensional model, three types of thermal regimes could occur depending on the total reservoir flow.

For reservoir flows less than or equal to 10 times the condenser flow, the diffuser would entrain the entire reservoir flow, and the resulting temperature rise in the reservoir,  $\Delta T_R$ , would be

$$\Delta T_R = \frac{Q_C \Delta T_C}{Q_R}$$

where  $Q_C$  = Condenser flow rate

$Q_R$  = Reservoir flow rate

$\Delta T_C$  = Temperature differential between the reservoir and the condenser water

A second type of thermal regime would occur when the total reservoir flow is greater than 10 times the condenser flow but less than about 12.5-13.5 times the condenser flow. The upper limit on flow for this regime represents the reservoir flow at which the jet entrainment is satisfied without deflecting the stream lines of the upstream flow. For this regime, the temperature rise of the reservoir is given by

$$\Delta T_R = \frac{T_C}{10}$$

Some of the reservoir flow would pass the diffuser without being entrained by the jets. The cooler, unmixed water would flow beneath the heated water forming a 2-layered system downstream. A surface eddy

is expected to form in the area between the end of the diffuser and the left bank. Heated water would move upstream from the diffuser.

A third thermal regime would form at reservoir flows greater than about 12.5-13.5 times the condenser flow. For this regime, the temperature rise of the reservoir is given by:

$$\Delta T_R = \frac{Q_C \Delta T_C}{P Q_R}$$

where: P = the percent of the total reservoir flow passing over the diffuser which would be about 75-80 percent.

The length of the conduits could be decreased and still maintain the same dilution; however, the velocity over the diffusers will be increased and might create a navigation problem. The quantity of flow intercepted by the diffuser would also be reduced below the 75-80 percent used in the preceding discussion.

The cooling tower, spray canal, or cooling lake may be utilized as the supplemental heat dissipation device for a combined-cycle system.

The alternative systems investigated for this plant are the schemes as designated below:

<u>Scheme</u>	<u>Heat Dissipation Device</u>	<u>Type System</u>
1	Cooling lake	Closed
2A	Spray canal	Combined (Intake from reservoir)
2B	Spray canal	Combined (Intake from Town Creek)
3	Spray canal	Closed
4	Mechanical draft towers	Combined
5	Mechanical draft towers	Closed
6	Natural draft towers	Combined
7	Natural draft towers	Closed

Scheme 7 is the proposed system discussed previously and was used as a base case for economic comparison of the alternatives which follows.

(4) Cooling lake (scheme 1) -

(a) Feasibility - The use of a cooling lake as an alternative closed-cycle heat dissipation method would require about 3,900 acres of effective water surface based on a rule of thumb of 1.5 acres per MW of nuclear capacity. The approximate lake size feasible at this site is 5,650 acres, which would be achieved by impounding the Dry Creek basin and flooding it to elevation 630 feet (See figure 2.6-8). This is 35 feet above normal reservoir elevation. The area to be flooded is sparsely populated except for areas near Scottsboro and Hollywood, Alabama, which are moderately populated. Additional land would be required for flood control and other management functions. Some 6,100 acres would have to be cleared. A 29,000

foot-long dike dividing the lake and directing the flow into a circuitous route, a 1,000-foot dike separating the Dry Creek and Evans Creek drainage areas, a 4,000-foot dike separating the Dry Creek and Town Creek drainage areas, and a 6,000-foot dike dividing the impounded lake from the main river channel would be required. The shoreline of the cooling lake would come within 10,000 feet of the plant site, and the water circulated to and from the plant would be through open channels. A lift station with pumps would be required.

The acceptability of this type of cooling facility has been explored with the Alabama Water Improvement Commission. By letter dated October 18, 1972, the Acting Chief Administrative Officer, AWIC, notified TVA that the Commission had previously approved a cooling pond for another power generating facility located in Alabama. However, it was emphasized that prior approval of cooling ponds did not constitute a general policy action by the Commission. If TVA studies showed the cooling lake to be the most feasible cooling alternative at Bellefonte Nuclear Plant, then TVA would need to further explore the possibility with the Commission.

The performance of the proposed cooling lake has been evaluated from the point of view of its hydraulic and heat transfer behavior.

The topography of the lake would promote a slug-type flow from the discharge to the intake without any significant short circuiting. This is particularly important as it reduces the impacts of the discharge and intake design on the performance. It is expected that neither the intake nor the discharge design would

have a significant effect on the lake performance except for a small benefit in the form of slightly lower ( $<.5^{\circ}\text{F}$ ) intake temperatures which might possibly be achieved by designing the intake to withdraw from the lower portion of the lake depth.

The lake depth is estimated to be about 20 feet on the average and would result in the following beneficial heat transfer behavior:

1. Surface layers of water slightly warmer than the underlying waters would move as density currents into the many small coves and embayments along the perimeter of the lake. This would promote highly efficient use of the full surface area for heat transfer.
2. The net heat transfer through the surface of the lake would determine: (1) the average temperature of the lake as a whole and (2) its cooling performance, i.e., the decrease in temperature between the discharge and intake points. The proposed lake would have sufficient depth so that its "thermal inertia" would be large enough to prevent daily variations in the solar and atmospheric radiation inputs from causing significant changes to the average lake temperature. Specifically, the response time of the average lake temperature to changes in natural heat inputs would be on the order of 1 week. The total volume of the lake is such that the 2-unit flow-through time would be about 7 days, thus ensuring that the cooling performance would not be affected by hourly or daily variations in wind speed,

dry-bulb temperature, or wet-bulb temperature. The protection of the intake temperature from short-term excursions of natural meteorological conditions is an important advantage of a cooling lake over mechanical cooling devices.

The thermal loading of the surface area of the lake would be low, about 2.5 acres per MW. Assuming typical heat loss coefficients for summer and winter conditions, the extremes of the cooling lake performance have been evaluated. The intake temperature rise above "ambient" would range from about 0.5° in the summer to 4° in the winter. This is very adequate because the intake temperature rise would be lowest in the summer when the efficiency of the plant is more sensitive to the condenser intake temperature. The average surface temperature rise would range from 7°F to 14°F above "ambient."

A cooling lake is an established method of heat rejection which would be feasible at this site.

(b) Environmental considerations -

Physical and chemical characteristics of lake effluents - Heat dissipation by the cooling lake is largely by evaporation, although a significant portion is by convection and radiation. The forced evaporation caused by the plant heat load plus the natural evaporation due to heat gain from solar radiation causes the average makeup to be approximately 140 ft<sup>3</sup>/s, which is essentially the same as that required for other alternatives. The average inflow to Dry Creek is only 31 ft<sup>3</sup>/s; therefore, additional makeup from Gunterville Reservoir would normally be required. There would be no drift associated with a cooling lake.

Cooling lake makeup water for the closed-loop system would consist of the auxiliary and essential raw cooling water discharges plus natural inflows. Blowdown would be taken from the lake return channel.

The amount of makeup required for continuous operation of the cycle would depend on the amount of blowdown necessary and evaporation. With a blowdown concentration factor of 2, the total makeup required would be approximately 5.8 percent of the circulating flow, or 140 ft<sup>3</sup>/s. The flow required from Gunterville Reservoir would vary since the natural inflow to Dry Creek Basin influences the concentration of the blowdown. Blowdown would vary, but the normal rate is estimated to be 2.9 percent of the circulating waterflow, or 70 ft<sup>3</sup>/s.

Temperature of the blowdown for the closed cooling lake system would be approximately 64°F under average winter conditions, 75°F under average fall and spring conditions, and 88°F under average summer conditions. Peak summer conditions could produce blowdown temperatures near 95°F. During periods of high temperature and no flow by the discharge point (approximately 5 hours maximum) the blowdown could be withheld without significantly affecting the concentrations in the lake due to the large inventory of water in the lake. The cooling lake offers additional time for settling of solids and dilution of plant effluents during periods of high inflow.

#### Ecological considerations -

The cooling lake alternative would represent an initial one-time demand for water. The location of the lake would avoid infringement on existing

embayments. Effects on biota owing to thermal discharges would be avoided. Entrainment would, after the initial filling stage, be limited to that associated with the withdrawal of makeup water. Studies of larval fish at the Browns Ferry Nuclear Plant site (Wheeler Reservoir) in 1971 indicated that at least 90 percent of larval fish produced annually is present in the 91-day period between April 27 and July 27.<sup>4</sup> Estimated maximum entrainment losses of larval fish based on this 91-day period of vulnerability would be  $1.1 \times 10^8$ ; losses of larval and young fish would be irretrievable. A cooling lake would have the potential for providing additional habitat for sport fish or aquaculture, provided the design of the lake and the temperature of the water are favorable.

The change in land use to a limited-use or nearly single-purpose reservoir would constitute a significant effect on aquatic life of impounded streams and terrestrial life of the area. A cooling lake would present to invading aquatic life areas of extreme thermal conditions. The areas of greatest temperature would be within the heated water discharge plume. Some aquatic life forms present in the Guntersville Reservoir, however, can live in high-temperature zones and could pass through the nuclear plant cooling systems into the cooling lake. Such organisms include midges, Asiatic clams, a number of higher aquatic plants, and many algal forms.

A small number of fragments of Eurasian watermilfoil would be expected to pass through the intake screens. Such fragments have been found to have a threshold of damage by short-term high-temperature treatment of  $45^{\circ}\text{C}$  ( $113^{\circ}\text{F}$ ) for 5 minutes. Lower temperature ( $40^{\circ}\text{C}$ ), even for 15 minutes, was barely detrimental; higher temperature ( $50^{\circ}\text{C}$ ) for only 2 minutes was very

detrimental. Some fragments subjected to 45°C for 5 minutes could survive and be able to establish new colonies creating a potential problem in the cooling lake.

The colonization of the lake by Eurasian watermilfoil and possibly by Asiatic clams would require control measures such as herbicides or biocides. Additionally, concentrations of trace metals and scaling elements would increase within the cooling lake, its sediments, and biota.

#### Atmospheric impact -

Evaluations of the atmospheric effects of cooling lakes are very limited to date. A review of the literature and discussions with other investigators<sup>5</sup> indicate that if the cooling lake is of adequate size for the thermal discharge, the effects are limited to within 1/4 mile from the lake border and to bridges over the lake. "Adequate size" is determined using a rule-of-thumb estimation as 1-1/2 acres of cooling lake for one megawatt plant size rating for nuclear power plants and a one-to-one requirement for fossil-fired power plants, i.e., one acre for one megawatt. The cooling lake would affect the local environment in a manner similar to that of any natural body of water. However, some environmental effects would be expected in the area where the thermal discharge enters the lake to include that area where the water temperature is above the temperature of a natural body of water. These effects are expected only out to within 1/4 mile downwind from the lake edge in the areas of warm water.

The affected peripheral area was determined by the annual wind direction frequency distribution

in the plant area. The wind data from the Widows Creek valley meteorological station indicated the area most affected will be south-southwest of the cooling lake, figure 2.6-9. This sector will experience potential fogging about 23 percent of the time (83 days per year). A high percentage, i.e., 23.01 percent, of "calms" is the result of using only early morning, 0600 local time, readings, which is the critical period for potential dense fogging. The south-southwest sector is also more frequently affected during freezing temperatures when rime icing could form on structures and vegetation up to 1/4 mile downwind. As indicated by figure 2.6-10, this sector will be affected during freezing temperatures about 12 percent of the time (43 days per year).

Particularly in the winter months, "steam fogs" would occasionally develop over the lake. This type of fog has been observed on a plant access road over a cooling pond at Commonwealth Edison Company's Dresden Nuclear Power Station. Therefore, it is believed that a cooling lake of this size (figure 2.6-8) at the Bellefonte Nuclear Plant would frequently create a serious hazard to travel on U.S. Highway 72 and the Southern Railroad, both of which would cross the lake, as well as on the proposed plant access road.

Aesthetics - Since the lake would be created by impounding a natural basin, the approaches to the lake would be natural, and the lake would be aesthetically pleasing.

Noise - Noise levels at the plant site would not be increased.

(c) Land - The cooling lake would require about 7,000 acres of land beyond that now proposed for

the plant site. Successful management of the land surrounding the lake to minimize the environmental impact of the lake on wildlife and to control flooding would require the purchase of approximately 1,350 acres in addition to the lake area of 5,650 acres. Approximately 140 occupied structures would have to be removed. The value of the impounded waters may be enhanced by providing a habitat for aquatic species not naturally occurring in that locale.

Dikes between the cooling lake and adjoining drainage areas and between the cooling lake and Gunterville Reservoir would be provided with an impermeable compacted earth-fill to minimize seepage and resist erosion. However, extensive soil sampling and rock core drilling would be required to accurately predict the total seepage from the lake.

Construction excavation and diking would be performed in a manner to minimize land damage.

(d) Economic considerations -

The initial investment required to install a cooling lake system is preliminarily estimated to be \$8,940,000 more than for scheme 7.

The comparative capability and the required present worth cost to provide the replacement capacity for a cooling lake compared to scheme 7 are as follows:

Scheme	<u>7</u>	<u>1</u>
Type system	Closed ND	Closed CL
Comparative capacity loss, kW	Base	(-)6,200
Comparative replacement cost, 10 <sup>6</sup> \$	Base	(-)1.75

The availability of a large cooling lake and the lower cost of circulating water pumping power due to the lower head requirements results in a lower main condenser back pressure for the cooling lake scheme versus scheme 7. As a result the plant utilizing a cooling lake would produce more power and reject less heat than with natural draft towers.

The present worth (1979-80 dollars) comparative operation and maintenance costs of a cooling lake compared to scheme 7 are shown below:

Scheme	<u>7</u>	<u>1</u>
Type system	Closed ND	Closed CL
Heat rate, Btu/kWh	9534.4	9510.0
Efficiency loss, $10^6$ \$	Base	(-) 0.82
Pump power cost, $10^6$ \$	<u>Base</u>	<u>(-) 2.64</u>
Total operation cost, $10^6$ \$	Base	(-) 3.46
Maintenance cost, $10^6$ \$	<u>Base</u>	<u>(-) 0.69</u>
Total operation and maintenance cost, $10^6$ \$	Base	(-) 4.15

(5) Spray canal system (schemes 2A,

2B, and 3) -

(a) Feasibility - The use of a spray canal system as an alternative combined-cycle heat dissipation method would require a canal approximately 12,800 feet in total length and 200 feet wide with 320 power spray modules spaced four abreast in 80 rows. The use of a spray canal system as an alternative heat dissipation method is considered feasible for this site, and three arrangements were evaluated. Figures 2.6-11, 2.6-12, and 2.6-13 show possible locations and arrangements on the plant site.

The use of a spray canal for power plant cooling is a relatively new concept and only in recent months has a large installation been put into operation. Typical among units adopting this method for heat dispersal are:

<u>User</u>	<u>Location</u>	<u>Heat Rejection Millions, Btu/h</u>	<u>Purpose</u>
Commonwealth Edison	Dresden	5,466	Temporary startup, Units 2 and 3
Gulf States Utilities	Beaumont, Texas	-	Salt water test
Detroit Edison	Fermi	261	Testing
Virginia Electric & Power	Chesterfield	2,067	Topping
Public Service of New Hampshire	Merrimack	429	Topping

The largest installation, Dresden, has been in operation for over one year in conjunction with units of 809-MW capacity and a heat rejection rate of 5,466 million Btu/h. By comparison, the heat rejected from the proposed Bellefonte plant is 15,600 million Btu/h.

Spray canal systems have demonstrated heat dispersal capability for the above installations, and as experience is being obtained, this method is being adopted for larger installations.

The performance of the proposed spray canal systems has not been evaluated quantitatively since design details have not been determined. In any case there is a lack of a good general model for spray canal performance, and most designs must proceed on the basis of manufacturers' specifications. It is possible, however, to make some general comments about spray canals.

1. Wind speed has far less effect on heat and mass transfer in a spray pond in comparison with a cooling lake. This helps to reduce the hourly variations in spray pond performance which might otherwise be caused by changing wind speeds.
2. The efficiency of a spray pond is a very strong function of the wet-bulb temperature alone. Heat and mass transfer coefficients may vary as much as 50 percent for wet-bulb variations between 40°F and 80°F. If the spray system is to be used in the winter months, it must be designed large enough to reflect the low wet-bulb temperatures common at that time.
3. The overall heat transfer rate of the spray system is directly proportional to the difference between the average temperature of the spray (the average of the plant condenser intake and discharge temperatures) and the natural wet-bulb temperature. The wet-bulb temperature is known to vary widely on an hourly basis. These variations will be reflected in the condenser intake temperature, and thus in the power production efficiency, because the water in the system has very little thermal inertia and will respond to the hourly wet-bulb behavior.

The preceding discussion on the performance of spray ponds was based on reference number 6.

Location of the intake in Town Creek for scheme 2B would have to be evaluated in light of the possibility that Town Creek may undergo significant diurnal fluctuations in temperature and may be generally warmer than the water in Gunterville Reservoir proper.

(b) Environmental considerations -

Physical and chemical characteristics of canal effluents - Water necessary for operation of the spray canal in the closed mode would be obtained from the Tennessee River at the plant site. With a blowdown concentration factor of 2, the total makeup required would be approximately 5.4 percent of the circulating flow, or 146 ft<sup>3</sup>/s.

The water for makeup for spray canal schemes 2A (combined) and 3 (closed) is taken directly from Gunterville Reservoir; the water for makeup for spray canal scheme 2B (combined) is taken from the Town Creek Embayment of Gunterville Reservoir.

The amount of blowdown and its dissolved solids concentration required for continuous operation with spray canal is estimated to be approximately 2.7 percent of the circulating waterflow, or 73 ft<sup>3</sup>/s. With a concentration factor of 2, the dissolved solids in the blowdown should not exceed acceptable levels.

Temperature of the blowdown for the spray canal closed-cycle system would be approximately 72°F under average winter conditions, 83°F under average fall and spring

conditions, and 91°F under average summer conditions. Peak summer conditions can produce temperatures near 97°F a few hours a day on the hottest summer days. Corresponding temperatures for closed mode of a combined-cycle system are 80°F, 86°F, 93°F, and 98°F, respectively. Holdup time on blowdown would be longer for the spray canal system than for cooling towers due to the larger quantity of water in the system.

Drift, the water blown from the spray canal by wind, is estimated to involve quantities of approximately 0.007 percent of the circulating waterflow, or 0.2 ft<sup>3</sup>/s. Although the water is sprayed into the air by the spraying modules and is subject to being carried away, the droplets are large and should be carried only a short distance. Furthermore, the channel edge would be approximately 20 feet from the side spray modules and the edge would be sloped back to the channel so that a large percentage of water which may be blown by the wind would return to the canal.

#### Ecological considerations -

Under schemes 2A and 2B operation of the spray canal would require more water than other alternatives considered. The location of the canal as indicated on figure 2.6-12 suggests the possibility of some disturbance of the upper end of Town Creek Embayment. Alternative location B appears to have more potential for disturbance of the embayment than does alternative A. Care would have to be taken to avoid disturbance of the shoreline during all phases of site preparation and construction for either of the spray canal alternatives. For combined-cycle systems, thermal effects on biota owing to discharge of heated water would occur; the extent and significance of the impact would be determined primarily by

the design and location of the discharge structure. In this regard, a discharge diffuser located in the channel would be preferable to a shallow-water, point-source discharge. In open-cycle operation, estimated losses of larval and young fish would be  $2.3 \times 10^9$  for a 91-day period of vulnerability; in closed cycle, losses would be  $1.1 \times 10^8$ . Losses under combined-mode operation would vary within this range depending on the operating schedule. Losses of plankton, larval fish, and young fish due to entrainment and condenser passage would be irretrievable under either mode. Assuming that numbers of organisms entrained would be roughly proportional to the amount of water withdrawn, the spray canal alternative under combined-mode operation is the worst alternative in this regard.

The location of the intake in Town Creek and the operation of the cooling system in a helper or open mode would induce a flushing flow in Town Creek many times its natural flow. Water would enter Town Creek from the river upstream from the plant, pass through the creek, and be withdrawn by the intake structure to be discharged eventually back into the river. This constant movement of the water in Town Creek and the introduction of river water may produce changes in the aquatic environment which have not been evaluated.

#### Atmospheric impacts -

Effects from the use of a spray canal system in the Bellefonte area would involve some fogging and icing. These effects are largely dependent on the quantity of evaporation of the spray effluent and the absolute humidity deficit of the atmosphere. Therefore, the expected plume

lengths should be somewhat greater than those estimated for cooling towers because of the usually lower ambient temperature and greater amount of moisture within the near-surface layer where most of the effluent will be dispersed. (Water is sprayed upward at a low level, 15 to 20 feet, as compared to plume release heights of 60 feet and 400 to 500 feet for mechanical and natural draft cooling towers, respectively.)

In many cases visible plumes generated by the spray canals would move downwind near ground level with intensifying effects on natural fogging. Such conditions should occur about 35 days per year with most fogging between 3 a.m. and 8 a.m. Most fogging will probably occur south-southwest of the plant--the highest frequency of plume occurrence. Figure 2.6-14 indicates that for 13 percent of the time (47 days per year) the plume would be 2 miles or more in length in this sector. In the south and south-southwest sectors from 4 to 8 percent of the time fogging could be encountered by traffic on Alabama State Highway 40. Average daily traffic on Highway 40 in 1970 at this point was 2,200 vehicles. U.S. Highway 72 would experience fogging in several sectors, and plume-induced fogging would reach Hollywood (population 865) about 2.5 percent of the time (9 days per year). Average daily traffic on U.S. 72 in 1970 at this point was estimated at 3,660 vehicles.

Periods of potential canal-induced icing when the ambient temperature is below freezing are expected about 70 days per year during the 5-month period, November through March, with the highest frequency in January and February.

Duration of heaviest icing would depend on the persistency of the below-freezing temperatures. Most severe conditions are expected between midnight and 7 a.m. Icing could be experienced on Alabama State Highway 40 about 4 percent of the time (15 days per year), on U.S. Highway 72 about 1 percent of the time (3.5 days per year), and possibly as a very rare occurrence on Alabama Highway 35 (figure 2.6-15).

Aesthetics - Plume-induced fogging would create an aesthetic impact to the Hollywood populace and to travelers of the highways in the area. However, the aesthetic impact from a spray canal system should not be significantly adverse.

Noise - The operation of a spray canal would increase noise levels at the plant site by a small amount. This increase would be due to motors and the falling water. Normally acceptable noise levels would be expected at site boundary.

(c) Land - Based on a preliminary investigation of site conditions, it is estimated that spray canal scheme 2A (combined) would require the acquisition of 480 acres of land in addition to that required for the plant. Spray canal scheme 2B (combined) and scheme 3 (closed) would not require the purchase of additional land.

(d) Economic considerations - The initial investment to install a spray canal system is estimated to require \$16,510,000 more for scheme 2A, \$16,250,000 more for scheme 2B, and \$5,540,000 more for scheme 3 than for the proposed scheme 7.

Due to the location of base rock relatively close to the surface at this site, construction of the 12,800-foot spray canal would be particularly expensive.

The comparative capability and the associated replacement cost of a spray canal versus scheme 7 are as follows:

Scheme	<u>1</u>	<u>2A</u>	<u>2B</u>	<u>3</u>
Type system	Closed ND	Combined SC	Combined SC	Closed SC
Comparative capacity loss, kW	Base	(-)14,880	(-)14,880	4,940
Comparative replacement cost, $10^6$ \$	Base	(-)4.16	(-)4.16	1.39

The savings realized in capability by the combined spray canal scheme over scheme 7 is a result of the lower backpressure caused by operation in the open mode a large portion of the time. The present worth (1979-80 dollars) comparative operation and maintenance costs of a spray canal compared to scheme 7 are as follows:

Scheme	<u>1</u>	<u>2A</u>	<u>2B</u>	<u>3</u>
Type system	Closed ND	Combined SC	Combined SC	Closed SC
Heat rate, Btu/kWh	9534.4	9477.0	9477.0	9553.6
Efficiency loss, $10^6$ \$	Base	(-) 1.94	(-) 1.94	.64
Pump power cost, $10^6$ \$	<u>Base</u>	<u>(-) 2.77</u>	<u>(-) 2.77</u>	<u>2.47</u>
Total operation cost, $10^6$ \$	Base	(-) 4.71	(-) 4.71	3.11
Maintenance cost, $10^6$ \$	<u>Base</u>	<u>.99</u>	<u>.99</u>	<u>.99</u>
Total operation and maintenance cost, $10^6$ \$	Base	(-) 3.72	(-) 3.72	4.10

Since the combined-cycle spray canal system operates in the open or helper mode a large part of the time, the turbine efficiency is better and the required auxiliary power is less than for scheme 7.

(6) Mechanical draft cooling towers

(schemes 4 and 5) - The use of crossflow mechanical draft cooling towers as an alternative cooling method would require four wood-filled cooling tower sections, each approximately 50 feet wide by 60 feet high by 640 feet long with 14 cells per section for the combined-cycle system (scheme 4) and four tower sections, each approximately 50 feet wide by 60 feet high by 720 feet long with 18 cells per section for the closed-cycle system (scheme 5).

(a) Feasibility - Mechanical draft cooling towers are suitable for application to a closed or combined system at the Bellefonte Nuclear Plant site. Figure 2.6-16 and 2.6-17 show possible locations and arrangements of the mechanical draft towers on the plant site.

(b) Environmental considerations -

Physical and chemical characteristics of effluents - For a closed-loop tower system, the main circulating water pumps would circulate water through the condenser and to the towers where the heat is transferred to the air, the flow of which is induced by large fans. Water returning from the towers would flow by gravity back to the circulating water pumps. Tower makeup water and tower blowdown would be the only intake and discharge from and to Guntersville Reservoir.

With a blowdown concentration factor of 2, the total makeup required would be approximately 6 percent of the circulating flow, or 147 ft<sup>3</sup>/s.

The blowdown is estimated to be 3 percent of the circulating waterflow, or 71 ft<sup>3</sup>/s. Concentrations of dissolved solids in the circulating water system of a closed system or closed mode of operation will not normally exceed 2 and blowdown would meet stream standards.

Slightly increasing the quantity of blowdown and makeup would further reduce the dissolved solids concentration. The temperature of this blowdown for the mechanical draft tower closed-cycle system (scheme 5) would be approximately 74°F under average winter conditions, 77°F under average fall and spring conditions, and 84°F under average summer conditions. Peak summer conditions could produce temperatures near 89°F a few hours a day on the hottest summer days. Corresponding temperatures for closed mode on a combined mechanical draft tower system (scheme 4) are 81°F, 85°F, 91°F, and 95°F respectively. Under peak temperature conditions and during periods when there is no flow by the discharge point, blowdown could be withheld. During periods of no flow (approximately 5 hours maximum) the concentrations in the tower system are not expected to exceed 3. Discharge to the reservoir with this concentration would not exceed stream standards.

Drift, which is water that is blown out of the towers, has been estimated by the cooling tower manufacturers to involve quantities of approximately 0.1 percent of the circulating waterflow, or 2.5 ft<sup>3</sup>/s.

Ecological considerations -

Mechanical draft towers rank intermediately in water demand of the

alternatives considered. The principal advantages of this alternative, under either scheme, over the spray canal alternative are the absence of infringement on Town Creek Embayment and reduced entrainment losses; the latter being solely a function of the relatively smaller water demand. Estimated losses of larval and young fish would be  $2.0 \times 10^9$  under open-cycle operation and  $1.1 \times 10^8$  under closed-cycle operation. Losses would be irretrievable under closed-cycle operation; irretrievable losses under open-cycle operation are more difficult to predict but would probably approach 100 percent. Thermal discharge effects would be approximately the same as for the spray canal (scheme 3), given the same considerations regarding design and location of the discharge device.

The closed-cycle scheme would be preferable in terms of avoiding losses due to entrainment. No significant differences in entrainment losses would be expected for mechanical versus natural draft towers.

Thermal discharges under combined cycle would be made in compliance with the applicable thermal standards, and therefore no significant adverse effects would be expected to occur.

#### Atmospheric impacts -

Atmospheric effects from the operation of the mechanical draft cooling towers at the Bellefonte Nuclear Plant would include considerable fogging and possibly some icing within about 4 to 5 miles of the cooling towers. The potential effects will be more significant than those from the higher plumes of the natural draft cooling towers because of their lower emission height. In some cases the visible plumes from the mechanical draft towers should move downwind at near ground level. Of particular

interest would be the intensifying effects of these low-level plumes during periods of natural fog. Such fogging conditions would likely occur on about 35 days per year with optimum conditions for fogging occurring between 3 a.m. and 8 a.m.

Most fogging would probably occur south-southwest of the plant in the direction of the highest frequency of long-plume occurrence (figure 2.6-18). About 17 percent of the time (61 days per year) the plumes will be transported in the south through the southwest sectors with lengths greater than 4 miles. Alabama Highway 40 could experience fogging from 4 to 8 percent of the time. The model used indicated no expected plume lengths beyond 5 miles. However, the trend of results in these sectors indicated that a fogging potential exists a small percentage of the time in the vicinity of Alabama Highway 35 which is about 5.2 miles' distance. Also of significance is potential fogging to the town of Hollywood 2.5 percent of the time (9 days per year) and to U.S. Highway 72 in the north-northeast sector 7 percent of the time (26 days per year).

The data indicate that cooling tower-induced icing could occur on about 70 days per year during the 5-month period, November through March, with the highest frequency expected in January and February. Duration of heaviest icing would depend on persistency of the below-freezing temperatures with the optimum periods from midnight to 7 a.m. The direction with the maximum frequency of plume travel is the south-southwest sector. As indicated in figure 2.6-19, the ice-inducing plume could reach Alabama Highway 40 from 1.5 to 3 percent of the time. It is unlikely that a plume of length sufficient to affect Alabama Highway 35 would occur any more often than

one day per year. Light-to-moderate icing would occasionally occur on any nearby structures located north-northeast through west-southwest of the cooling towers.

Aesthetics - The materials of mechanical draft towers would not be compatible with the architecture of the powerhouse; therefore design features would be incorporated to achieve architectural compatibility with the main plant. The relatively low profile of the mechanical draft towers would not present a very large vertical barrier or landmark on the terrain.

Noise - The use of mechanical draft towers would increase noise levels at the plant site. This increase would be due to (1) the fans, and (2) the falling water with fan noise being dominant. Predicted sound pressure levels from one manufacturer<sup>7</sup> of cooling towers are 62 dB at 250 Hz, 57 dB at 2,000 Hz, and 59 dB at 8,000 Hz--all 200 feet from the louvered face (ref 0.0002 microbar). Predicted noise levels for Browns Ferry plant, at which six 600-foot sections of mechanical draft cooling towers are being installed, were judged to be "normally acceptable." On the basis of these predicted levels, it is expected that mechanical draft towers for the Bellefonte site would also be judged "normally acceptable."

(c) Land - The use of mechanical draft towers as an alternative means of cooling would not require the acquisition of additional land beyond that now required for the plant. The towers would occupy about 50 to 100 acres of the site.

(d) Economic considerations - The initial investment required to adapt and install the mechanical

draft tower system for combined-cycle is estimated to be \$17,390,000 more than the proposed natural draft tower system, and the closed-cycle mechanical draft tower system is estimated to require an investment of \$1,510,000 less than the proposed tower system.

The combined-cycle system dictates lower efficiency, less costly towers; however, the additional return channels, gates, and diffusers make the initial cost greater than the closed-cycle system. Less expensive mechanical draft towers make their initial investment less than a natural draft tower for a closed-cycle system. However, due to the longer conduits and greater excavation required and the more extensive site preparation needed for the mechanical draft towers this difference in cost is narrowed considerably.

The loss in capacity and associated replacement cost to assure the same reliability of power supply as compared to scheme 7 are as follows:

Scheme	<u>7</u>	<u>4</u>	<u>5</u>
Type system	Closed ND	Combined MD	Closed MD
Comparative capacity loss, kW	Base	(-)13,140	120
Comparative replacement cost, 10 <sup>6</sup> \$	Base	(-)3.68	.05

The cooling towers for closed-cycle systems have optimum economic selection points at lower approaches than those for combined-cycle systems. Also, the combined-cycle system would benefit from the lower reservoir temperatures for condenser cooling

water when sufficient flow is available. The loss in capacity and efficiency is therefore less for a combined-cycle system.

The use of mechanical draft cooling towers is estimated to have the following operating and maintenance costs as compared to scheme 7 (costs are present worth differences in 1979-80 dollars):

Scheme	Comparative Costs		
	<u>7</u>	<u>4</u>	<u>5</u>
Type System	Closed ND	Combined MD	Closed MD
Heat rate, Btu/kWh	9534.4	9483.2	9534.9
Efficiency loss, $10^6$ \$	Base	(-) 1.72	.02
Fan and pump, power cost, $10^6$ \$	<u>Base</u>	<u>(-) 1.77</u>	<u>3.69</u>
Total operation cost, $10^6$ \$	Base	(-) 3.49	3.71
Maintenance cost, $10^6$ \$	<u>Base</u>	<u>3.16</u>	<u>3.70</u>
Total operation and maintenance cost, $10^6$ \$	Base	(-) 0.33	7.41

Average efficiency is greater and auxiliary power requirements are less for a combined-cycle tower system than for a closed-cycle system due to the benefit from lower reservoir temperatures when on helper- or open-mode and because the towers are operated less. The mechanical draft tower closed-cycle system, however, requires greater auxiliary power than a closed natural draft tower system due to the additional fan power requirements. Efficiency loss for the closed-cycle mechanical draft tower and for the closed-cycle natural draft tower systems is nearly equal since the optimum selection point was at about the same approach. Maintenance

cost for the mechanical draft tower system is understandably higher due to the additional mechanical equipment involved.

(7) Natural draft cooling towers (schemes 6 and 7) - The use of two closed-cycle natural draft towers is proposed as the method of heat dissipation for the Bellefonte Nuclear Plant. Considerations for this alternative are discussed in detail in sections 2.6.3 and 2.6.4. The discussion in this subsection is limited primarily to the differences in considerations associated with the combined-cycle natural draft system alternative (scheme 6).

The use of natural draft cooling towers as an alternative cooling method would require two impervious-fill towers approximately 480 feet in diameter and 400 feet high for the combined-cycle system and 500 feet in diameter and 500 feet high for the closed-cycle system.

(a) Feasibility - Natural draft cooling towers have been used for many years; however, the first unit in the United States, Big Sandy, commenced operation in 1962. The following counterflow towers, similar to those required for Bellefonte, are under construction or were recently placed in operation:

American Electric Power, Amos Plant - 400' diameter x 492' high

Portland General Electric, Trojan Plant - 385' diameter x 492' high

Toledo Edison and Cleveland Electric, Davis-Besse Plant -

411' diameter x 492' high

Cincinnati Gas & Electric, Zimmer Plant - 383' diameter x 479' high

Natural draft cooling towers are suitable for application to a closed- or combined-cycle system at the Bellefonte Nuclear Plant site.

Figures 2.6-1 and 2.6-20 show possible locations and arrangements of the two towers on the plant site.

(b) Environmental considerations -

Physical and chemical

characteristics of effluents - The temperature of the blowdown for the combined-cycle system operated in the closed mode would be approximately 71°F under average winter conditions, 78°F under average fall and spring conditions, and 88°F under average summer conditions. Peak summer conditions can produce temperatures near 94°F a few hours a day on the hottest summer days; however, blowdown could be withheld under peak temperature conditions and during periods when there is no flow by the discharge point. Drift has been estimated to be 0.01 percent of the circulating waterflow, or 0.25 ft<sup>3</sup>/s.

Ecological considerations -

Combined-cycle natural draft towers have advantages over the mechanical draft towers and spray canals in terms of total water demand and the concomitant entrainment losses. Estimated losses of larval fish would be  $1.8 \times 10^9$  under open-cycle operation and  $1.1 \times 10^8$  under closed-cycle operation. Natural draft towers would also avoid disturbance of Town Creek embayment. Thermal discharge effects would be similar to those of mechanical draft towers. The closed-cycle scheme would be preferable in terms of avoiding losses due to entrainment.

Land disturbance would be less than for any of the other heat dissipation schemes since less total area and excavation would be necessary.

## Thermal discharges

under combined cycle would be made in compliance with the applicable thermal standards, and therefore no significant adverse effects would be expected to occur.

(c) Economic considerations -

The initial investment required to install combined-cycle natural draft towers is estimated to be \$17,140,000 more than closed-cycle natural draft towers, which for the 2-unit plant are estimated to cost about \$58 million, including conduits, condensers, and site preparation.

The combined-cycle tower system dictates lower efficiency, less costly towers; however, the additional channels, gates, and diffusers make the initial cost greater than the closed tower system.

The loss in capability and the associated replacement cost (1979-80 dollars) to assure the same reliability of power supply with scheme 7 as the base are as follows:

Scheme	<u>1</u>	<u>6</u>
Type System	Closed ND	Combined ND
Comparative capacity loss, kW	Base	(-)8,540
Comparative replacement cost, 10 <sup>6</sup> \$	Base	(-) 2.36

As was the case for mechanical draft towers, the natural draft towers for closed-cycle systems have optimum economic selection points at a lower approach than that for combined systems because the combined system benefits from lower condenser cooling water when operating on

helper and open modes. The average loss in capacity and efficiency is therefore less for a combined system.

The use of natural draft cooling towers would have the following operating and maintenance cost differentials (1979-80 dollars) compared with scheme 7 as base:

Scheme	<u>Comparative Costs</u>	
	<u>7</u>	<u>6</u>
System type	Closed ND	Combined ND
Heat rate, Btu/kWh	9534.4	9501.3
Efficiency loss, $10^6$ \$	Base	(-) 1.12
Fan and pump power cost, $10^6$ \$	<u>Base</u>	<u>(-) 2.62</u>
Total operation cost, $10^6$ \$	Base	(-) 3.74
Maintenance cost, $10^6$ \$	<u>Base</u>	<u>(-) .19</u>
Total operation and maintenance cost, $10^6$ \$	Base	(-) 3.93

As was the case for mechanical draft tower systems, average efficiency is greater and auxiliary power requirements are less for a combined-cycle tower system than for a closed-cycle system due to the benefits from lower reservoir temperature when on helper or open mode. Maintenance costs are slightly lower for the combined-cycle systems due to the smaller towers required.

(8) Evaluation of alternative heat dissipation facilities - Table 2.6-1 summarizes the present worth cost comparison in 1979-80 dollars and other differences of the feasible alternatives.

The comparison of feasible alternatives shown in Table 2.6-1 indicates the relative economic differences in present worth evaluated costs (1979-80 dollars) which include the capital cost of installing the facilities and the present worth of the operation and maintenance costs. The natural draft closed-cycle cooling tower scheme is used as the base since it is the scheme with the lowest total evaluated cost. Scheme 1, closed-cycle cooling lake, has the next lowest evaluated cost, and scheme 5, closed-cycle mechanical draft cooling tower system, is the third lowest.

All alternatives are estimated to be compatible with the construction schedule for the remainder of the plant, except the cooling lake which may not be compatible because of possible problems in acquiring needed land.

The mechanical draft closed system (scheme 5), in addition to having an evaluated cost of some \$6 million more than the natural draft towers, would create considerable fogging and icing, the effects of which would be more significant than the potential effects from the higher plumes of the natural draft towers. Mechanical draft towers are also noisier than any of the other alternatives.

The cooling lake system would cost some \$3 million more than the natural draft towers and would require the use of considerably more land and the acquisition of about 7,000 acres of additional land. Ground fogging and icing would also be a problem more frequently with a cooling lake than with the towers.

In conclusion, TVA has investigated numerous feasible alternatives for heat dissipation for the Bellefonte

Nuclear Plant, and each alternative costs more and offers no significant advantages over the natural draft towers. Therefore, due to the economic advantage and the smaller overall potential for environmental impacts, TVA proposes to include the closed-cycle natural draft cooling tower installation for heat dissipation at the Bellefonte Nuclear Plant. The initial investment in facilities for the base natural draft closed-cycle system, including towers, conduits, condensers, site preparation, etc., is estimated at \$58 million for the 2-unit plant.

(9) Alternative intake designs - In response to the AEC, TVA has evaluated several alternative intake designs.

(a) Alternate 1 - This is the proposed intake design which is discussed in section 2.6.3 above and incorporates an intake structure located approximately 1,200 feet from the reservoir shoreline with a 5-foot floating trash boom located at the shoreline to protect the channel from floating debris and Eurasian watermilfoil (figure 2.6-21). The inlet will be constructed utilizing and expanding a natural embayment. The proposed design would have a maximum channel intake velocity of less than 0.2 ft/s.

(b) Alternate 2 - This is the same as the proposed alternate 1 except that a skimmer wall would be used in lieu of the floating trash boom. The depth of withdrawal for the skimmer wall is 22 feet below the minimum reservoir water surface. The maximum intake water velocity under the wall would be 0.36 ft/s. Due to the weak thermal stratification of Gunterville Reservoir, the skimmer wall is not effective in reducing the impact of suspended aquatic life.

(c) Alternate 3 - The intake structure design is the same as for alternates 1 and 2, but the structure would be located at the shoreline of the reservoir. Since the intake provides the water supply for the essential raw cooling water system, the intake is an engineered safety feature and is essential for safe operation and shutdown of the Bellefonte plant. The water supply must be provided even under abnormal conditions such as a probable maximum flood and loss of the downstream dam due to a seismic event. The reservoir shoreline location for the intake structure is not desirable since it would be vulnerable to damage and blockage from runaway barges and to fire resulting from oil spills.

(d) Alternate 4 - This alternate consists of a submerged intake located in the bottom of the original river channel nearest the site shoreline (figure 2.6-22). From the submerged intake, four 60-inch steel pipes extend to and through a permanent earth dike across the embayment at the shoreline. Four pipes are required for compliance with AEC Regulatory Guide 1.27. A valve system is required to permit periodic testing of the pipes. A traveling screen system for the submerged intake to remove trash and debris is not feasible for this system. Therefore, periodic inspection and removal of debris and siltation by underwater divers would be required. At the deepwater intake the pipes would turn downstream into a concrete intake structure which takes water from the downstream face. The pumping structure would be located in the embayment. Trashracks would be fitted on the intake openings and the openings would be sized for a maximum velocity through the racks of 0.5 ft/s. A cofferdam extending into the reservoir would

be required to construct the deepwater intake and would also serve for dewatering the embayment for construction of the pumping structure and the permanent earth dike. The cofferdam would be removed after construction of the intake facilities are completed.

(e) Alternate 5 - This alternate is the same as alternate 4 except that the intake pipes extend to the pumping structure and no permanent earth dike is required.

(f) Alternate 6 - This alternate is the same as alternate 4 except redundant inlet piping is not provided and a 60-acre cooling pond is included as a backup in the event the deepwater intake becomes blocked (see figure 2.6-23). This system would consist of dikes to form the pond and a water conduit with a control valve to pass water from the pond to the intake forebay. Should the deepwater intake become blocked, the control valve under the pumping station would open at a predetermined water level in the intake channel permitting the cooling water to circulate from the intake forebay to the plant, from the plant to the cooling pond, and the cooling pond to the intake forebay.

(g) Evaluations of alternate intake designs - With a flow velocity of less than 0.42 ft/s through the intake openings, the losses of aquatic life due to the proposed intake design will be the result of entrainment of plankton; impingement of healthy fish is expected to be minor. The present state-of-the-art regarding the use of louvers, bypass devices, and bubble screens is such that they have not been demonstrated to be effective in reducing entrainment of suspended aquatic life. This, in addition to the unfavorable economics of such devices preclude the need to conduct a

detailed cost/benefit analysis of these devices since they cannot be considered feasible alternatives.

Following these additional studies and evaluations as requested by AEC, TVA's selection of a proposed design remains as alternate 1, the alternative with the least total evaluated cost as shown in the table below. The costs shown are not the total expected costs as the estimates were carried out to the extent deemed necessary to determine that further evaluations were not warranted. For example, the costs of using underwater divers to inspect and remove debris for alternates 4, 5, and 6 are not included in the table.

<u>Alternate</u>	<u>Estimated Capital Costs (Thousands of Dollars)</u>
1 (Shoreline Intake)	\$4,450
2 (Shoreline Intake)	4,550
3 (Shoreline Intake)	9,300
4 (Deepwater Intake)	8,250
5 (Deepwater Intake)	9,300
6 (Deepwater Intake and Cooling Pond)	8,150

The environmental costs were computed using values per fish as supplied by "Monetary Values of Fish," The Pollution Committee, Southern Division, American Fisheries Society, 1970. Based on sampling at Bellefonte, the number of larval fish in deep water (5 meters) is approximately 6 percent of that near the shoreline in shallow water. On this basis, the environmental costs for the shoreline intake alternates are estimated to be \$2 million more than for the alternatives with a deepwater intake.

The table shows that the capital costs of any of the alternatives with a deepwater intake exceed the proposed alternative 1 by nearly \$4 million, while a conservative estimate of the environmental advantage is only about \$2 million. Therefore, after weighing and balancing the economic and environmental costs along with safety considerations, TVA has concluded that the proposed intake design represents the best balance of cost, feasibility, and environmental impact. TVA will verify this conclusion by conducting more detailed and extensive larval fish studies in the vicinity of the Bellefonte site during the spring of 1974.

REFERENCES FOR SECTION 2.6

1. Rossie, J. P., and W. A. Williams, Jr. "The Cost of Energy from Nuclear Power Plants Equipped with Dry Cooling Systems." ASME. 1972.
2. Leung, P., and R. E. Moore. "Thermal Cycle Arrangements for Power Plants Employing Dry Cooling Towers." ASME. 1970.
3. Leung, P., G. R. Reti, and J. R. Schilling. "Dry Cooling Tower Plant Thermodynamic and Economic Optimization." ASME. 1972.
4. Tennessee Valley Authority. Browns Ferry Nuclear Plant Units 1, 2, and 3 Environmental Statement, Section 2.7, Volume 1. 1972.
5. Communications with James E. Carson, Argonne National Laboratory, 10/1/71, and Donald Portman, University of Michigan, 9/29/71, by W. C. Colbaugh, TVA.
6. Ryan, P. J. "Temperature Prediction and Design of Cooling Ponds," Engineering Aspects of Heat Disposal from Power Generation, (D.R.F. Harleman, Ed.), R. M. Parsons Laboratory for Water Resources and Hydrodynamics. Department of Civil Engineering, M.I.T. June 1972.
7. Letter to R. S. Rainey, TVA, from I. F. Kuharic, Engineering Division, The Marley Company, Mission, Kansas. February 10, 1972.

Table 2.6-1

PRESENT WORTH COST COMPARISONS OF ALTERNATIVE HEAT DISSIPATION FACILITIES<sup>a</sup>  
(1979-80 Dollars)

<u>Scheme</u>	<u>1</u>	<u>2A</u>	<u>2B</u>	<u>3</u>	<u>4</u>	<u>5</u>	<u>6</u>	<u>7</u>
Heat Dissipation Device	Cooling Lake	Spray Canal	Spray Canal	Spray Canal	Mechanical Draft Towers	Mechanical Draft Towers	Natural Draft Towers	Natural Draft Towers
Type	Closed	Combined	Combined	Closed	Combined	Closed	Combined	Closed
Average Annual Net Turbine Heat Rate - Btu/kWh	9510.0	9477.0	9477.0	9553.6	9483.2	9534.9	9501.3	9534.4
Percent of Time Operating in Various Modes								
Open	0	71.6	71.6	0	71.6	0	71.5	0
Helper	0	25.5	25.5	0	24.9	0	25.1	0
Closed	100	2.9	2.9	100	3.6	100	3.4	100
Facilities Cost, \$ Million	8.94	16.51	16.25	5.54	17.39	(-) 1.51	17.14	Base
Capability Cost, \$ Million	(-)1.75	(-) 4.16	(-) 4.16	1.39	(-) 3.68	0.05	(-) 2.36	Base
Operation Cost, \$ Million	(-)3.46	(-) 4.71	(-) 4.71	3.11	(-) 3.49	3.71	(-) 3.74	Base
Maintenance Cost, \$ Million	(-)0.69	<u>0.99</u>	<u>0.99</u>	<u>0.99</u>	<u>3.16</u>	<u>3.70</u>	<u>(-) 0.19</u>	<u>Base</u>
Total, \$ Million	3.04	8.63	8.37	11.03	13.38	5.95	10.85	Base

a. All costs shown are present worth cost differences in 1979-80 dollars using scheme 7 as a base.




Figure 2.6-1  
COOLING WATER SYSTEM ALTERNATIVE  
BELLEFONTE NUCLEAR PLANT SITE  
NATURAL DRAFT TOWERS-CLOSED SYSTEM  
SCHEME 7




Figure 2.6-2

NICKAJACK DAM  
Hourly Flow  
May 1968 - October 1971





Figure 2.6-3  
GUNTERVILLE DAM HOURLY FLOW  
10 YEARS OF RECORD  
1959 - 1968

\* Example: 2 percent of the time (7 days per year)  
 plumes with lengths  $\geq 2.7$  miles  
 occur in the  $22\frac{1}{2}^\circ$  sector north of site

Percent of  
 total days in a year




Based on daily early morning record  
 Aug. 1970 - Aug. 1971

Figure 2.6 - 4 EXPECTED PLUME LENGTH AND FREQUENCY OF OCCURRENCE  
 FOR 16 COMPASS POINT SECTORS  
 (ALL TEMPERATURES)  
 NATURAL DRAFT COOLING TOWERS  
 BELLEFONTE NUCLEAR PLANT SITE

\*Example: .5 percent of the time (2 days per year)  
 plumes with lengths  $\geq 3.2$  miles  
 occur in the  $22\frac{1}{2}^\circ$  sector northwest of site

Percent of  
 total days in a year



Based on daily early morning record  
 Aug. 1970 - Aug. 1971

Figure 2.6 - 5 EXPECTED PLUME LENGTH AND FREQUENCY OF OCCURRENCE  
 FOR 16 COMPASS POINT SECTORS  
 (AMBIENT TEMPERATURE BELOW FREEZING)  
 NATURAL DRAFT COOLING TOWERS  
 BELLEFONTE NUCLEAR PLANT SITE





Figure 2.6-6  
BELLEFONTE NUCLEAR PLANT  
ALTERNATIVE COOLING SYSTEM  
CLOSED-CYCLE SYSTEM  
SCHEMES 1, 3, 5, 7



GATE NO.	1*	2	3
OPEN MODE	0	C	0
CLOSED MODE	C	0	C
HELPER MODE	C	C	0

\*Gate for towers only

Figure 2.6-7  
 BELLEFONTE NUCLEAR PLANT  
 ALTERNATIVE COOLING SYSTEM  
 COMBINED COOLING SYSTEM  
 SCHEMES 2A, 2B, 4, 5



2.6-68

Figure 2.6 - 8  
 COOLING WATER SYSTEM ALTERNATIVE  
 BELLEFONTE NUCLEAR PLANT SITE  
 COOLING LAKE  
 SCHEME 1

1 0 1 Mile








Figure 2.6-11  
COOLING WATER SYSTEM ALTERNATIVE  
BELLEFONTE NUCLEAR PLANT SITE  
SPRAY CANAL-COMBINED SYSTEM  
SCHEME 2A




Figure 2.6-12  
COOLING WATER SYSTEM ALTERNATIVE  
BELLEFONTE NUCLEAR PLANT SITE  
SPRAY CANAL COMBINATION SYSTEM  
SCHEME 2B





Figure 2.6-13  
COOLING WATER SYSTEM ALTERNATIVE  
BELLEFONTE NUCLEAR PLANT SITE  
SPRAY CANAL CLOSED SYSTEM  
SCHEME 3

\* Example: 1.5 percent of the time (5 days per year)  
 plumes with lengths  $\geq 4.0$  miles  
 occur in the  $22\frac{1}{2}^\circ$  sector north of site

Percent of  
 total days in a year




Based on daily early morning record  
 Aug. 1970 - Aug. 1971

Figure 2.6 - 14 EXPECTED PLUME LENGTH AND FREQUENCY OF OCCURRENCE  
 FOR 16 COMPASS POINT SECTORS  
 (ALL TEMPERATURES)  
 SPRAY CANAL  
 BELLEFONTE NUCLEAR PLANT SITE

\* Example: .5 percent of time (2 days per year)  
 plumes with lengths  $\geq 4.3$  miles  
 occur in the  $22\frac{1}{2}^\circ$  sector north-northeast of site

Percent of  
 total days in a year



Based on daily early morning record  
 Aug. 1970 - Aug. 1971

Figure 2.6 - 15 EXPECTED PLUME LENGTH AND FREQUENCY OF OCCURRENCE  
 FOR 16 COMPASS POINT SECTORS  
 (AMBIENT TEMPERATURE BELOW FREEZING)  
 SPRAY CANAL  
 BELLEFONTE NUCLEAR PLANT SITE




Figure 2.6-16  
COOLING WATER SYSTEM ALTERNATIVE  
BELLEFONTE NUCLEAR PLANT SITE  
MECHANICAL DRAFT TOWERS-COMBINED  
SYSTEM SCHEME 4





Figure 2.6-17

COOLING WATER SYSTEM ALTERNATIVE  
BELLEFONTE NUCLEAR PLANT SITE  
MECHANICAL DRAFT TOWERS  
CLOSED SYSTEM SCHEME 5

\*Example: 1 percent of the time (3 days per year)  
plumes with lengths  $\geq 4.2$  miles  
occur in the  $22\frac{1}{2}^\circ$  sector north of site

Percent of  
total days in a year




Based on daily early morning record  
Aug. 1970 — Aug. 1971

Figure 2.6 - 18 EXPECTED PLUME LENGTH AND FREQUENCY OF OCCURRENCE  
FOR 16 COMPASS POINT SECTORS  
(ALL TEMPERATURES)  
MECHANICAL DRAFT COOLING TOWERS  
BELLEFONTE NUCLEAR PLANT SITE

\* Example: .5 percent of the time (2 days per year)  
 plumes with lengths  $\geq 4.1$  miles  
 occur in the  $22\frac{1}{2}^\circ$  sector west-southwest of site

Percent of  
 total days in a year



Based on daily early morning record  
 Aug. 1970 - Aug. 1971

Figure 2.6 - 19 EXPECTED PLUME LENGTH AND FREQUENCY OF OCCURRENCE  
 FOR 16 COMPASS POINT SECTORS  
 (AMBIENT TEMPERATURE BELOW FREEZING)  
 MECHANICAL DRAFT COOLING TOWERS  
 BELLEFONTE NUCLEAR PLANT SITE






Figure 2.6-20  
COOLING WATER SYSTEM ALTERNATIVE  
BELLEFONTE NUCLEAR PLANT SITE —  
NATURAL DRAFT TOWERS  
COMBINED SYSTEM SCHEME 6





2.6-82

Figure 2.6-22  
 ALTERNATE 1  
 Intake Alternative Pumping Station  
 Located in Embayment Modified Channel  
 With Intake in Bottom of Reservoir  
 Channel



2.7 Construction Effects -

1. General construction considerations - Initial construction work will include three main categories of construction activities: (1) general grading of the site; (2) construction of the "Construction Plant Facilities" including various shops, warehousing facilities, utility services, concrete mixing plant, administration buildings, roads, railroads, etc.; and (3) excavation of earth and rock in the area of the main powerhouse complex.

The next principal phase of work will be the permanent concreting program for all structures. This is planned to begin about 4 months after the initial construction activities.

Construction activities at the site will be planned to minimize undesirable effects, such as accumulation of scrap materials, burning of cleared brush and trash, and silting of the reservoir during any required dredging operations associated with intake channel excavation. Since there is very little timber and brush to be cleared from the site, air pollution resulting from the burning of this material will be minimal and of short duration.

Temporary construction buildings will be arranged in a neat and orderly manner to minimize land use requirements, to expedite construction operations, and to facilitate routine grounds-keeping and housekeeping needs. Warehousing operations will be centralized at the project for surveillance and control purposes.

Because of the general cleared condition of the site it is anticipated that a total area of only 75 to 85 acres will be affected by tree cutting and clearing required for the construction

area needs. Merchantable timber, if any, will be sold. No significant impact on forest resources will be caused by construction on the plant site.

Preliminary plans indicate an approximate earth excavation requirement in the main powerhouse complex of 170,000 yd<sup>3</sup>. This material will be used for both construction plant and permanent plant fill requirements. The general methods described for protection against soil erosion and resultant siltation are generally those standardized type construction methods that have been used successfully over the years. However, as new techniques are developed which would give a better balance of reduction of environmental impacts and cost, TVA will use these techniques wherever their use is feasible.

Construction effects associated with offsite transmission facilities are discussed in section 2.2.

Following completion of the plant, the complete temporary construction facilities will be dismantled and all material will be disposed of, either through shipments to other TVA projects or by sale. The total construction area will be well landscaped.

(1) General clearing - TVA plans to acquire approximately 1,500 acres of land for the plant site. The land has been generally cleared by previous owners except for some 830 acres of woodland.

The main powerhouse complex is tentatively centered in a large previously cleared area. This complex, including the switchyard, takes in an area of approximately 90 acres with less than 35 percent of this area covered by trees and underbrush. Following

is a tabulation of the approximate areas from which trees must be cleared for construction needs:

	<u>Approximate Area Required (acres)</u>	<u>Approximate Area to be Cleared (acres)</u>
Powerhouse complex including switchyard	90	31
Cooling towers	10	4
Railroad and access road	25	11
Construction plant shop and administration	50	2
Visitors' overlook	10	10
Parking lots	11	6
Warehouse and storage area	60	15
	—	—
	256	79

The construction plant area is being designed to provide the maximum support assistance to the construction of the project. Clearing requirements were coordinated with the TVA Architectural Branch to avoid indiscriminate clearing and to provide screening of the construction area from public roads. Coordination of the construction project with architectural personnel assures that as many tree stands as possible will be left within the construction plant area for their aesthetic value where these will not create costly and dangerous obstacles to construction equipment and personnel movements.

Much of the wooded area will remain undisturbed unless major design changes create additional clearing requirements. Based on present design data available it is assumed that approximately 755 acres of woodland will remain undisturbed for

the 2-unit installation. This comprises approximately 91 percent of the existing woodland.

(2) General grading and excavation -

Current design information indicates the following grading and excavation quantities will be required in the construction of the Bellefonte Nuclear Plant.

	<u>Grading and Excavation Earth (CY)</u>	<u>Excavation Rock (CY)</u>	<u>Backfill or Embankment (CY)</u>
Main PH complex	170,000	-	385,000
Switchyard	0	-	256,000
General yard	-	-	117,000
Dikes and holding ponds	130,000	-	5,000
Intake channel	100,000	80,000	-
Pumping station	22,000	25,000	50,000
Visitors overlook area	16,000		13,000
Access highway	110,000		175,000
Access railroad	100,000		195,000
Construction plant	*		*

\*Construction plant layout is not complete; however, the layout will be made so as to have a balance of cut and fill material.

Following clearing and removal of stumps, grading operations will be sequenced to remove and store topsoil prior to conducting a general grading and excavation program.

The initial grading operation will be to remove the overburden from the main powerhouse complex and cooling tower area down to final plant grade of elevation 628. Existing ground elevations in these areas range up to about elevation 642, requiring about a 14-foot cut at the maximum to reach plant grade. As can be seen from the above tabulation, earth material must be obtained from a borrow source to provide for the total fill material needed. On

completion of the borrow operation, the borrow area will be graded to fit into the surrounding area and restored to a natural condition by seeding and mulching.

The next major operation will be the excavation of the powerhouse complex. Earth overburden will be removed by large rubber-tired panscraper units with the excavation outlines conforming to design drawing details. Usable material will be stored for future use and spoil material will be wasted in preselected areas where it will be graded to conform with the surrounding landscape, covered with topsoil, and seeded and mulched to avoid erosion.

On completion of the removal of earth overburden, foundation rock will be excavated by the presplit method with excavation outlines as required for the structure foundations. The rock will be broken up by small blasting charges and removed by use of power shovels and trucks.

Concurrent with the above excavation program will be the building of construction plant shop and service facilities for use in the construction of permanent plant features. Those temporary facilities will include the administration building; field offices; craft shops; concrete mixing plant; warehouse and storage yards; raw and treated water systems for fire protection, equipment cooling, drinking water, concrete mixing, etc.; service air systems; construction barge dock; substation and electrical distribution; sewage collection and treatment systems; roadways; railroads; etc. Timing for this work will be to complete the facilities required for service in starting the first permanent concreting operation about 4 months after starting initial onsite work.

Following the above operation, excavation will be conducted for the intake channel and pumping station for the essential raw water cooling and makeup system. A temporary dike will be constructed at the reservoir end of the channel to allow excavation to be conducted in the dry. Following completion of the channel and pumping station, flooding of the channel will be accomplished by pumping into the diked channel from the reservoir. The dike will be removed by panscrapers, draglines and/or clamshells, and by dredging. Breaching of the temporary dike will not occur until the water levels are equalized across the dike to avoid siltation wash into the channel areas.

To maintain an emergency cooling water supply at minimum reservoir water levels, the essential cooling water channel must be dredged to the main river channel. Dredging will be accomplished by a suction dredge with the spoil material being disposed of in an upland area to avoid excessive siltation of the reservoir. Siltation controls are being studied for consideration of use during the dredging program.

Design details at this stage are insufficient to indicate the extent of use of riprapping to control reservoir bank erosion.

2. Siltation control - General grading for both the construction plant area and the permanent plant area will be accomplished in accordance with grading plans developed by design and construction engineering personnel. Following clearing and grubbing, usable topsoil is removed and stored for future use in final landscape work. The topsoil will be stored in a manner to minimize loss due to

erosion. Grading work is accomplished according to the grading plans, which include the construction roadway system, drainage ditches, catch basins, sloping of areas to drain, and filled areas for construction shops and administrative office buildings. These grading operations are conducted to provide and maintain a controlled surface drainage system to minimize erosion and resultant silting of the reservoir. Certain methods of erosion control used in conjunction with a master grading plan include the use of berms, diversion dikes, check dams, sediment basins, fiber mats, netting, gravel, mulches, grasses, special drains, and other control devices.

Since TVA performs most of its own work with force account labor, it very seldom becomes involved with contractor efforts to control erosion. This provides the means for strict control over construction phases which could result in environmental impacts. However, since the bases and support piling for the cooling towers are to be contract erected, TVA will enforce erosion control considerations as a part of the cooling tower contract requirements.

Also, since TVA performs most of its own grading operations, good control is maintained at all times over the amount of erodible material exposed. Inspectors working for the project management organization will control the extent of erodible material uncovered and direct the implementation of erosion control devices as deemed necessary to protect adjacent streams. These inspectors and/or engineers will insure that erosion control practices are reasonably current with the excavation, borrow, and grading operations.

The total project lies within relatively tight confines that will allow good current control by inspectors and engineers.

Some material which has been excavated will be stored in rolled sloped mounds to avoid saturation and erosion and to permit its later use as fill. Temporary construction sumps will be constructed in the powerhouse area for the diversion and control of runoff inside the excavated area. Water will be pumped to the yard construction drainage system and further treatment, such as settling pond use, will be effected, if required, to avoid excessive siltation of the reservoir.

Gravel will be used in the construction areas to provide cover for parking, storage, and work areas. Heavy rock bases are laid for construction roadways to avoid rutting and erosion from the use of heavy equipment. Side ditches are cleaned out periodically for proper drainage and side slopes are protected where deemed feasible by seeding, matting, or mulching.

Present plans indicate that the excavation of the intake channel to the essential cooling water pumping station is the major area of possible dredge or dragline operation which would have an undesirable effect on the quality of the water in the reservoir. As previously described, excavation of a portion of this channel will be conducted behind a dike which must eventually be removed by dredge or dragline and the remainder of the channel will be dredged to the main river channel. Special efforts will be made to minimize silting in the reservoir. However, a certain amount of turbidity and siltation

is an unavoidable consequence of operations such as this, and fine control is very difficult to accomplish.

Appropriate siltation control methods will be utilized during construction of the blowdown diffuser to minimize siltation away from the immediate construction area.

3. Solid waste - Trees which must be removed that have no commercial value and stumps will be cut, piled, and burned. All burning will be performed in compliance with Federal, state, and local air quality regulations. There will be no burning of solid waste containing garbage. Metal, lumber scrap, and other salvable material will be collected for periodic sale and removal from the site. Broken concrete, rock, and residue from burning will be used as landfill material onsite. Other solid waste will be collected and disposed of by a private contractor in a state-approved sanitary landfill. The considerations made for disposing of solid wastes from the plant (section 2.5) will be followed in determining the ultimate disposal of these construction wastes.

4. Sanitary wastes - A temporary sewage treatment plant capable of handling the peak construction force sewage load will be installed and operated to meet applicable standards.

In addition, chemical toilets will be used in isolated or remote areas during the construction period, and the servicing contractor will be required to dispose of raw sewage in a manner which is environmentally acceptable. Generally, these wastes are collected in contractor-owned tank trucks and are hauled to a local community sewage treatment plant for disposal.

5. Chemical cleaning - Chemical cleaning operations

prior to unit startup will be conducted to minimize releases to the reservoir and to ensure that any chemicals released have been neutralized and diluted to concentrations which are acceptable for discharge into the reservoir. Procedures for chemical cleaning are not final, but present plans are to clean piping systems and components before erection. Prior to startup or initial operation, systems will be thoroughly flushed: first with a weak solution of trisodium phosphate to remove grease, oil, or similar contaminants and any loose matter, and then given a final flush with filtered or demineralized water. The flush water will be discharged to holding ponds for further dilution and treatment to reduce any objectionable constituents to concentrations which are acceptable for discharge into the reservoir.

Procedures normally include the use of multiple ponds to allow for monitoring various degrees of treatment so that the final effluent to the receiving waters is within applicable water quality standards. Standard design and construction procedures will be utilized in regard to the pond dike system. All unconsolidated fill material will be removed from the dike foundations and the dikes will be constructed with clean impervious soil placed in layers and compacted with earth-hauling equipment. All pond areas will be stripped of vegetation and unconsolidated materials. No problems with either overflow or pond flooding are foreseen.

Flushing oils used during the cleaning process for transformer insulating oil systems and turbogenerator lube oil systems will be reconditioned for reuse or will be disposed of at some offsite location.

6. Miscellaneous - In addition to those considerations already discussed, the following miscellaneous effects have been identified.

A small river docking facility may be constructed to handle barge traffic into and out of the plant. This facility would be constructed with steel pilings to permit use of the facility throughout the lifetime of the plant if considered desirable. Only minor interference with recreational and navigational features is anticipated and this only when barges might be tied up at the dock. After the plant is constructed, the dock is expected to be used only intermittently, and no significant adverse impact on the use of waterways would be expected to occur.

To minimize effects of dust during construction, the use of tank trucks equipped with sprinkler equipment will be employed.

Excavation activities during construction may temporarily affect ground water movement in the immediate vicinity of the excavations, but the ground water movement should return to normal after construction is completed. No public or private use of ground water is expected to be affected due to construction of the plant.

Complete plans have not been developed at this stage for the furnishing of potable water for both the construction plant and the permanent plant needs. The site is located only about 7 miles from Scottsboro, which has a modern and adequate (3,500,000 gal/d) water supply system. It is anticipated that arrangements can be made to purchase potable water from Scottsboro. Construction needs would vary from a normal daily requirement of 30,000 gal/d (assuming

use in concreting operations) up to a peak use of 250,000 gal/d during startup periods for the plant where high water usage is required in the plant flushing and cleanup cycles. Use of water from Scottsboro would require that 3 miles of 8-inch pipe main be constructed along U.S. Highway 72 north of Scottsboro to a point where TVA would connect. This would also make treated water available along the route of the pipeline to many people who do not now have treated water service.

Raw water for construction needs in fire protection, equipment cooling, and other services will be pumped from the reservoir using a temporary pumping station located slightly offshore near the plant site.

7. Impact of construction traffic - There will be two access roads to the site during most of the construction program, one via existing roads south of the plant site and a new permanent access road from U.S. 72 north of the site. Initially most all traffic will enter the project area via the existing highway which passes through the old townsite of Bellefonte. By the time the construction force reaches 1,000 employees (est. 450 cars) the new access road should be open to traffic. After this occurs employees living north of the plant site will likely use the new road while those living to the south will continue to use existing roads leading to the south entrance. The Division of Construction plans no new road construction or general upgrading of existing roads in the Bellefonte area; however, some repairs may be required due to abnormal use during the construction program. Responsibility will be determined on an individual basis with local highway officials at the appropriate time. At peak of activity

it is estimated that TVA and contractor employees will drive about 1,200 vehicles to work.

Since most of the heavier items of permanent equipment will arrive by rail or barge shipment, numerous equipment deliveries by motor freight are not expected. Approximately one-half of these will enter the project site through the south entrance assuming interchange with a local carrier with terminal facilities in Scottsboro. Concrete aggregates, cement, etc., will require many shipments, and quite likely these also will be by truck.

2.8 Socioeconomic Impact - Population in the area will continue to grow along with the industrial growth in the region. Construction of the Bellefonte Nuclear Plant will have a twofold impact on the surrounding area. First, there will be the temporary impact of construction employees who move into the area to work on the project. Second, permanent employees to supervise, operate, and maintain the plant will also be moving into the area.

This section includes estimated data of the construction employees' impact and the projected schedule for permanent employment.

1. Construction employment impact - One impact of the construction of the Bellefonte Nuclear Plant will be attracting workers who will move into the area of the plant site, thereby providing a temporary stimulus to the economic growth of the area. The two main concerns are housing and schools, although other public and private facilities will be affected.

Workers moving into the area are estimated to comprise between 25 and 30 percent of the total construction work force. In general, the lower percentage will apply during the initial and final stages of construction. The higher percentage will be approached as the work force includes larger numbers of workers with specialized skills not available in the local work force.

Approximately 45 percent of those workers moving into the area are expected to buy or rent houses. An additional 35 percent are expected to buy or rent mobile homes and the remaining 20 percent probably will rent apartments or sleeping rooms.

Workers who move and bring their families should make up about 70 percent of all workers moving into the area. The remaining 30 percent should be mostly single men or men who will live in the area during the week and return home on weekends. On the average, workers who bring their families will have about one school age child per family.

The Scottsboro-Hollywood area can be expected to absorb approximately 70 percent of the impact from movers. An additional 20 percent will be distributed in Browns Valley as far south as Guntersville and to the north as far as Bridgeport. The remaining 10 percent will be scattered among the small communities on Sand Mountain and the Cumberland Plateau which have good access to the site.

Using the percentages discussed above, impact estimates were prepared for selected employment levels (1,000 and 2,000 men) to provide some typical figures. These estimates are contained in Table 2.8-1. This table does not include estimates for effects on service-related functions such as housing construction, additional stores and businesses, etc. Table 2.8-2 contains the projected construction employment to help estimate the timing of the impact.

The following discussion details the estimated impacts due to an additional employment of 2,000 workers in Jackson County.

(1) Population impact - The 1970

population of Jackson County was 39,202 and the Scottsboro-Hollywood total was 9,625 (Scottsboro 9,324 and Hollywood 301). Thus, the total population influx of 1,400 is 3.6 percent of Jackson County's population and the 980 people locating in Scottsboro-Hollywood is a 10.2 percent

increase. Due to the potential for growth in Jackson County and especially Scottsboro - Hollywood, this population influx should be accommodated with no significant adverse impact.

(2) Impact on schools - The combined student enrollment in May 1973 for the Jackson County and Scottsboro city school systems was 9,454, grades 1-12; 3,376 of these students were enrolled in schools in the Hollywood - Scottsboro area, the communities most likely to sustain the major impact of students as a result of TVA construction activities. It is estimated that 420 students will be brought to the area, with 250 expected to enroll in the Hollywood - Scottsboro schools and the remaining 170 distributed among other Jackson County communities and schools.

As of September 1973, school facilities in the Hollywood - Scottsboro area accommodated 4,785 students. A new middle school under construction by the Scottsboro City School System will provide for an additional 500 students, making a total maximum student accommodation base of 5,285 by the beginning of the 1974-75 school year. With the May 1973 enrollment in the Hollywood - Scottsboro area as a base, the number of additional students which could be accommodated is 1,909. Taking into consideration the requirements for 1,300 additional permanent workers at the Revere Copper and Brass Corporation Plant, the Goodyear Tire and Rubber Plant, and TVA temporary and permanent employee impacts on these communities, the school systems should accommodate such growth with ease. Obviously, these communities are well aware of the potential increase in students to be served and have responded well in advance in the preparation of facilities to house students.

During the 1972-73 school year, the Scottsboro City School System spent \$680 per student in average daily attendance (ADA) for instructional services, including \$544 in state funds, \$54.40 in Federal funds and \$81.60 provided locally. The Jackson County School System spent \$564.60 per student (ADA), including \$395.22 in state funds, \$73.40 in Federal funds, and \$95.98 in local funds. Impact or not, the local school system would receive state and Federal funds based upon ADA and state school fund distribution formulas and would qualify for Federal programs applicable. The local fund amount would be affected by an influx of new students. Assuming an average local expenditure of \$90.00 per student in ADA, the 420 additional students (as a result of TVA construction activities) would increase the local operating costs of the two school systems by \$37,800. The 420 students represent the peak enrollment with the average in-and-out of students over the life of the project--210--or an average additional local cost of \$18,900 per year during construction.

(3) Impact on Economy; Personal Income -

In 1969, personal income in Jackson County totaled \$87,872,000 (BEA - Department of Commerce). An average annual wage of \$10,000 earned by the 600 workers moving into the area would be \$6,000,000 which is about 6.8 percent of the total. This magnitude of increase of resulting economic activity is expected to be within the capabilities of existing establishments to handle without expansion or significant increase in personnel.

(4) Impact on Economy; Wholesale Trade -

TVA's experience at Browns Ferry indicates that about 0.5 percent of the construction cost of a nuclear plant is spent on purchases and special contracts in the "local economy." "Local economy" is a variable term depending upon the item or service to be purchased. At Bellefonte, Scottsboro may provide certain generally available goods and services while Chattanooga or Huntsville might be the nearest source for more specialized needs. However, the basic evaluation is to determine whether or not the additional demand on the economy might create a "boom and bust" situation with its attendant hardships and economic dislocations. Therefore, for purposes of evaluation, the total expenditure is assumed to be made in Jackson County.

Wholesale trade in Jackson County totaled \$16,945,000 in 1967 (Economic Atlas). Based on the Browns Ferry study, the average annual expenditure in the local economy due to construction of the Bellefonte Plant is expected to be approximately \$500,000, which is about a 3 percent increase in annual wholesale trade. This level of increase would be within the range of existing establishments to accommodate without significant physical or personnel expansion. Thus, the infusion of this additional economic activity as well as that produced by increased personal income is not expected to create conditions which might produce an economic "bust" when construction is completed.

(5) Impact on housing - Tables 2.8-4 and 2.8-5 present various data on vacant housing in the Bellefonte area and larger regions. Numbers are contained in Table 2.8-4 to give an indication of the actual housing available. Percentages are given in Table 2.8-5 to enable some comparison of relative availability with the

201-County Tennessee Valley Region and the 16 Alabama counties in the region. Data are shown for all vacant dwelling units and those vacant dwelling units which have complete plumbing. Plumbing is used as a surrogate for housing quality since the 1970 Census did not include this evaluation.

A substantial number and percent of vacant dwelling units are in the category "Other" which means that they are not in the market for various reasons. Thus, for example, over one-half (94 out of 176) of the vacant dwelling units in Scottsboro are not available to a prospective tenant. For that reason, a better picture of housing availability is obtained by examining only those for rent or for sale.

In general, there are relatively fewer dwellings available for rent or for sale in the Bellefonte area than in other areas of the region. An exception is Stevenson's 3.50 percent rate of vacant-for-rent dwelling units. However, the total number of 28 is very small in terms of supplying the projected need. In general, this "tight" housing situation is expected to continue for some time due to continued economic growth which is expected to attract additional population into the area.

From 1960 to 1970, there was a spectacular growth in mobile homes in Jackson County which reflects, in part, the lack of suitable conventional housing. In 1960, there were 91 mobile homes (0.9 percent of the housing stock) while in 1970 there were 1,004 (8.4 percent of the housing stock). The 8.4 percent is about twice the percentage of mobile homes in the Tennessee Valley region (4.1 percent)

and in the 16 county area (4.8 percent). Of the 1,004 mobile homes in Jackson County, 212 are in Scottsboro, 74 in Stevenson, and 67 in Bridgeport.

Housing choice estimates in Table 2.8-1 can be considered the "demand" and housing vacancy information in Table 2.8-4 can be considered an indication of "supply". It is clear that the supply is not close to meeting the demand for dwelling units at the 2,000-employee level. This is based on the available vacant housing with plumbing in Scottsboro, Bridgeport, and Stevenson (85-90 dwellings compared to the demand for houses plus apartments - 390). Given the time lag between the 1970 Census and the projected demand for housing, adjustments in the housing market can be anticipated.

First, the demand pressures can be expected to accelerate construction of housing in the area. Due to the continued growth anticipated in the Bellefonte area, this could have a positive effect on the supply of standard housing after the peak of construction without creating an oversupply which could depress the market. Second, some adjustment in demands might occur to increase the demand for mobile homes and reduce demand for conventional housing. The data on mobile homes between 1960 and 1970 indicate an adequate marketing system and the existence of substantial concentrations in the towns indicate a level of management expertise sufficient to cope with additional demand. On the other hand, if the present proportion of mobile homes is a peak, the demand created during construction could tend to stabilize the mobile home developments.

(6) Impacts on traffic - An estimated 1,200 cars will travel to and from the plant site at the peak of construction. The 1970 average daily traffic on U.S. Highway 72 past

the plant site was about 3,700 (1970 Alabama Traffic Flow Map). Thus, the traffic near peak employment will be significantly increased and some congestion and delay is expected. However U.S. Highway 72 will be four-lane past the site before the start of construction which will provide increased carrying capacity and tend to reduce the effects of the increased traffic load on regular users.

2. Permanent employment impact - Various factors require that permanent operating personnel be onsite during the last half of the construction phase of the plant. The permanent supervisory, operational, and maintenance work force will eventually stabilize at around 170 people. Table 2.8-3 shows that these people will start working there very near the point of peak construction employment and will all be employed about 2 years before the estimated completion of construction. Their impact on the area will be in addition to that of the construction employees. Although this will place an additional demand on the services of the area, it will also provide an economic stimulus. At current salary scales, the combined work force can be expected to have an annual payroll of about \$2 million.

There are no previous surveys to provide a basis for estimating permanent employee housing choice, family size, or family composition. However, it should be noted that this group will choose a place to live on a somewhat different basis than construction workers. Whereas construction personnel may be willing to sacrifice urban services and convenience due to the relatively short time they will be living in the area, permanent employees will be more reluctant to do so. In addition to housing, they will be looking for good schools, adequate medical facilities, and convenient shopping.

3. Mitigation of impacts - In addition to those consultations with local and area officials described in section 1.4, future meetings with local leaders are planned to discuss school requirements and increased assistance for education, sewage collection and treatment, solid waste management, improvement of health services, and industrial development. TVA will continue to work with state and local officials and civic groups throughout the construction and operation of Bellefonte Nuclear Plant to mitigate possible adverse socio-economic impacts caused by the project. When construction begins on the Bellefonte Nuclear Plant, detailed and up-to-date information regarding the availability of housing will be acquired by TVA to assist employees in locating safe and sanitary dwellings. Until then an indication of housing availability in the Bellefonte area can be obtained through data from the 1970 Census of Housing (Table 2.8-4).

Table 2.8-1

ESTIMATED POPULATION EFFECTS  
BELLEFONTE NUCLEAR PLANT CONSTRUCTION EMPLOYEES

	<u>Employment Level</u>	
	<u>1,000</u>	<u>2,000</u>
Percent Movers	25	30
Number of Movers	250	600
Demand for:		
Houses	110	270
Mobile Homes	90	210
Apartments and Sleeping Rooms	50	120
Movers with Families	180	420
Movers without Families	70	180
School-Age Children	180	420
Total Population Influx	600	1400

Table 2.8-2

PROJECTED CONSTRUCTION EMPLOYMENTBELLEFONTE NUCLEAR PLANT

<u>Month</u>	<u>Projected Employment</u>
July 1974	0
October 1974	100
January 1975	450
April 1975	600
July 1975	850
October 1975	1,010
January 1976	1,150
April 1976	1,350
July 1976	1,500
October 1976	1,670
January 1977	1,850
April 1977	2,040
July 1977	2,150
October 1977	2,270
January 1978	2,250
April 1978	2,300
July 1978	2,240
October 1978	2,200
January 1979	2,070
April 1979	1,850
July 1979	1,660
October 1979	1,380
January 1980	1,090
April 1980	830
July 1980	630
October 1980	420
January 1981	300
April 1981	100
July 1981	0

Table 2.8-3

PROJECTED PERMANENT EMPLOYMENTBELLEFONTE NUCLEAR PLANT

<u>Month</u>	<u>Projected Employment</u>
April 1978	10
July 1978	30
October 1978	50
January 1979	70
April 1979	90
July 1979	155
October 1979	170 (Expected Total Permanent Employees)

Mean annual salary based on present pay scales is about \$11,250.

Table 2.8-4

BELLEFONTE NUCLEAR PLANT  
HOUSING VACANCY INFORMATION<sup>a</sup>  
JACKSON COUNTY AND SELECTED COMMUNITIES

	<u>For Sale</u>	<u>For Rent</u>	<u>Other<sup>b</sup></u>	<u>Totals</u>
<u>Jackson County</u>				
Number	68	249	589	906
Average Value or Monthly Rent	\$13,325 <sup>c</sup>	\$45	-	-
With all plumbing	47	90	341	478
<u>Bridgeport</u>				
Number	5	18	22	45
Average Value or Monthly Rent	\$ 8,150	\$48	-	-
With all plumbing	4	14	17	35
<u>Scottsboro</u>				
Number	28	54	94	176
Average Value or Monthly Rent	\$19,925	\$59	-	-
With all plumbing	25	30	81	136
<u>Stevenson</u>				
Number	4	28	20	52
Average Value or Monthly Rent	e	\$34	-	-
With all plumbing	e	12	17 <sup>f</sup>	29

- a. The source is the 1970 Census of Housing. This data covers vacant dwelling units suitable for year-round occupancy. Vacant seasonal dwelling units are excluded.
- b. Includes housing units: (1) sold or rented but awaiting occupancy; (2) held for occasional use; or (3) not on the market for some other reason, e.g., awaiting settlement of an estate, or personal reasons of owner.
- c. Average value is based on 56 housing units since value is tabulated only for vacant-for-sale 1-family houses which are on a place of less than 10 acres and have no business or medical office on the property. Value is not tabulated for mobile homes, trailers, cooperatives, and condominiums.
- d. Average rent is based on 160 housing units since rent is tabulated for all vacant-for-rent units except 1-family houses on a place of 10 acres or more.
- e. Summary count less than 5 - data suppressed.
- f. This is the difference between the total and "for rent" vacant units without plumbing. It may include some "for sale" units.

Table 2.8-5  
 Bellefonte Nuclear Plant  
 Comparison of Housing Utilization Rates

	Percent of year-round units					
	Vacant for Rent		Vacant for Sale		Other Vacant	
	<u>Total</u>	<u>With all plumb.</u>	<u>Total</u>	<u>With all plumb.</u>	<u>Total</u>	<u>With all plumb.</u>
201-County Tennessee Valley Region	2.45	1.64	0.74	0.63	3.69	1.97
16 Alabama Counties in Region	2.27	1.47	0.83	0.75	3.19	1.90
Jackson County, Alabama	2.00	0.70	0.53	0.36	4.55	2.63
Bridgeport	1.91	1.48	0.53	0.42	2.33	1.80
Scottsboro	1.67	0.93	0.87	0.78	2.92	2.51
Stevenson	3.50	1.50	0.50	n.a.	2.50	n.a.

2.8-14

Source: U.S. Census of Housing, 1970.

2.9 Other Impacts - The following potential environmental impacts have been considered in addition to those discussed elsewhere in this document.

1. Access facilities - The Bellefonte peninsula on Guntersville Reservoir contains approximately 500 acres of developable public land in excess of the acreage required for construction and operation of the proposed Bellefonte Nuclear Plant. Acquisition of this additional acreage was necessary since it is situated on the end of a peninsula and the location of the plant would limit access to it. An access route from Alabama Highway 72 across the Town Creek embayment and to the tip of the peninsula would allow the use of this valuable land for public recreation development while providing a required evacuation route in case of a plant emergency. Without this access, this area will be lost to future intensive public use.

Tentative plans provide for the permanent access to the site to be via a blacktop causeway across the Town Creek embayment. An earthfill will be made from a point near the northwest tip of the peninsula to an island from whence the earthfilled, culvert-supported causeway will connect to the west bank of the Town Creek embayment. The culverts will allow a 6-foot clearance for boats at the normal high-water level of 595 feet above mean sea level. The road from the west bank of the Town Creek embayment will connect with U.S. Highway 72 at a point about 3 miles northeast of Hollywood.

The lower sides of the earthfill affected by water will be riprapped, and the upper slopes will be grassed to prevent siltation and erosion.

The natural flow pattern in Town Creek consists primarily of run-off flowing into Guntersville from a drainage

area of 8.7 square miles. The daily average run-off flow is estimated to be 18 cfs. The construction of the causeway will not alter the magnitude of the net flow in the creek. In the immediate vicinity of the causeway, there will be a local increase in water velocity as the flow passes through the box culverts. For an average run-off, the velocity in the culverts is estimated to be only 0.12 ft/sec. Changes in the transport and deposition of sediment may also result but only in the immediate vicinity of the causeway. Sedimentation in the creek upstream from the causeway will not be generally increased.

Efforts will be taken to minimize siltation and bottom disturbances, such as scheduling the work over as short a period as possible in order to limit the exposure time.

TVA considered two alternative routes for the access road. The cost of the resource commitments for the alternatives in terms of land use, historical significance, public convenience and recreation, and the related economics of each were considered.

The most direct route would be the construction of a road from the plant to the existing county road which connects Hollywood and Bellefonte. This access route would be the least expensive and removes essentially no land from productive use. However, this route has two disadvantages: (1) it would significantly increase traffic through the old townsite of Bellefonte, and (2) it would preclude the public's use of approximately 500 acres of land on the end of the peninsula unless an evacuation route were provided. In order to utilize this area, an evacuation route should be provided which leads away from the plant in the unlikely event of an accident requiring evacuation. Such a route would leave the plant in a northerly direction crossing the Town Creek embayment.

The route across the Town Creek embayment requires the construction of an access road 2.7 miles long which will remove about 10 acres of land from productive use. This route is estimated to cost approximately \$160,000 more than the direct route discussed above. The Bellefonte Draft Environmental Statement stated this cost difference to be \$400,000. However, more detailed studies made since the draft statement was issued show that the total cost of the access via the Town Creek causeway is expected to be about \$1,070,000, while the total cost of upgrading the road through old town Bellefonte is expected to be about \$910,000. As stated above, the environmental impacts associated with building the causeway across the Town Creek embayment; the turbidity and siltation during construction, the more limited water transfer, reduced fish movement, and loss of some aquatic habitat in Town Creek embayment are minimal. The advantages of this route are that it minimizes possible damage or destruction to the historical structures in the Bellefonte townsite and the public convenience and recreation potential of the peninsula is enhanced.

The causeway access road is about 2 miles north of the temporary access road connecting Hollywood and Bellefonte and is thus closer to those workers coming from that direction. Provisions of the additional access road would save over 1,400,000 vehicle-miles during the period from completion of the access road to completion of the total project. At the time the Town Creek access road is to be completed, an estimated 180 cars would be arriving from the north and 270 from the south. These figures would increase to the peak about 2-1/2 years later of 310 and 410, respectively, for the day shift. Construction traffic

would then begin to decrease until completion of construction in about 2-1/2 more years.

The Bellefonte tract is important to recreation development on Guntersville Lake for several reasons:

1. Although much of the upper portion of the reservoir is in TVA ownership, it is generally in narrow strips which limit development. The south side of the reservoir borders the Sand Mountain escarpment, is extremely steep, and lacks road access. The north side of the reservoir extends into the gently sloping to flat valley area, and the lands acquired by TVA are subject to flooding. Most of this land is licensed to the State of Alabama as wildlife management areas. Addition of the Bellefonte tract to the public land base and development of the tip of the peninsula for public recreation would be a significant increase in upper Guntersville Lake recreation opportunities.
2. Recreational development on Guntersville has been traditionally concentrated at the end of the lake nearest the dam and the city of Guntersville. Future growth of other population centers such as the cities of Scottsboro, Hollywood, and Stevenson will necessitate a better dispersion of shoreline recreational developments and lake activities. Bellefonte peninsula is within 10 miles of each of these cities as well as on the same side of the lake.
3. The gentle topography and large size of the tract make it suitable for a number of types of recreation developments.

4. A preliminary recreation plan has been developed and includes development of a campground-park complex offering a complete range of camping facilities and passive recreation opportunities emphasizing the ecological and natural resources of the area. A system of foot trails, nature study opportunities, boat access area, and bank fishing opportunities are planned to enhance recreational opportunities.

Day use facilities including swimming, picnicking, playfields, etc., are also planned as a part of the complex. The feasibility of incorporating hunting into the total recreational package will be explored with the Alabama Department of Natural Resources.

It is estimated that the present worth of the recreation provided by this area, over the life of the plant, based on \$1.25 per visit<sup>1</sup> is \$2,800,000, (1985 dollars).

The development of the recreation facilities will be carried out in such a manner to minimize adverse impacts on the environs of the peninsula. The riparian woodlands along the tip of the peninsula, the steeper slopes, and known heron roosting areas will be left largely in their natural state. Facilities will be located for the most part in the mid-portion of the peninsula on land that is, at present, primarily open.

Protection of the areas indicated above and the planting of various tree and shrub species in the open areas to be developed along with natural succession is expected to improve the peninsula habitat.

In summary, the principal costs associated with recreational development of the peninsula include an incremental total cost of \$160,000 for access construction, approximately \$500,000 for development of the recreation area, and the impact on wildlife of some habitat removal and disturbance. Benefits derived from the recreational development include \$2,800,000 in recreation benefit over the life of the plant, reduced traffic through old town Bellefonte, and increased utilization of existing wildlife resources.

After considering the alternatives, TVA selected the indicated route across Town Creek as representing the best balance between cost, environmental impact, and the other considerations discussed.

Railroad access to the site will be provided by approximately 3 miles of new roadbed extending from the Southern Railway main line at a point about 1 mile west of Hollywood (Alternative B, Figure 2.9-1). The right of way for the access railroad will require about 65 acres of land.

TVA considered two alternate routes for the access railroad. Preliminary estimates show no significant differences in cost between the two routes, although potentially extensive excavation of rock could drive the cost of alternative A higher. Consideration of other resource commitments for these alternates is as follows:

1. Alternative A was slightly shorter than the one selected. It crossed the Town Creek embayment and extended in a generally

north-westward direction from the plant. The significant beneficial impact of the route was the enhancement of some land in its vicinity for potential industrial use. Adverse impacts included: (1) several large tracts of land and cultivated farm fields would be split; (2) at-grade crossings of two county roads would be necessary, with one road requiring extensive adjustment; (3) possibly two or three residences would be affected and might have to be relocated; (4) dust and noise inherent in construction; (5) temporary turbidity and siltation of the Town Creek embayment during construction of the crossing; (6) loss of some aquatic habitat in Town Creek embayment; and (7) requires approximately 185,000 cubic yards of borrow excavation. This route would require about 60 acres of land for right of way north of Town Creek.

2. The selected route, Alternative B, extends in a generally westward direction to a point on Southern Railway about 1 mile west of Hollywood. Beneficial impacts of this route are that (1) it would provide more direct rail access to potential industrial lands between the plant site and the city of Scottsboro with an acreage 4 to 5 times greater than alternate A; (2) the route is adjacent to property lines for a great portion of the length; and (3) requires about 90,000 cubic yards less borrow excavation than alternative A. Adverse impacts would be primarily the dust and noise inherent in construction, and the impact on Town Creek embayment due to the filling. These adverse impacts would be somewhat less than those for alternative A.

2. Aesthetics - The plant will be located on a broad plain of a peninsula. A wooded ridge on the southeastern edge of the peninsula separates the plain from the body of Guntersville

Reservoir. The north and northwestern edges of the site are penetrated by natural inlets from Town Creek embayment. The southwestern boundary of the site connects with the mainland. To reduce the visual impact of the large facilities, the structures are grouped in a diminishing progression of scale from the reactor, auxiliary, control, turbine, and service buildings to the office building and gatehouse. The materials vary to reflect the changes in scale--monolithic concrete for the larger solid masses, lighter fenestration for the turbine building, and precast concrete, brick, and glass for the office building and gatehouse.

Particular attention will be given to the site development and landscaping. Natural features of the terrain will be preserved as much as possible, and even utilized to reduce the impact of the installation on man and the environment. The landscaping will provide a harmonious transition between the natural setting and the plant site. The plant design, integrated with the landscape, will create an inviting and pleasant setting for both employees and visitors.

The location of the nuclear plant, amidst the surrounding recreational developments, provides a unique and interesting place to visit for both educational and recreational purposes. A visitors' center and overlook and a recreation area are to be provided for the site.

3. Archaeology - Two sites of potential archaeological significance in the project area are known to exist and have been previously

recorded by the Department of Anthropology of the University of Alabama (Appendix C). One of these sites (1 Ja 300) is in the area that will be affected by the construction of the intake. However, the site investigation will be completed prior to any construction activity that may affect the site.

4. Cemetery relocation and protection - Two old family cemeteries are located within the bounds of the property being acquired by the project (Appendix A). Both are inactive with no evidence of upkeep or interments in several decades. The most recent tombstone inscription found in the Shipp Cemetery is 1907. The most recent inscription found in the Finnell Cemetery is 1872. Field estimates place the number of graves in Shipp and Finnell Cemeteries at four and six, respectively.

The Shipp Cemetery is surrounded, except for an entranceway, by a rock wall and located within lands that have been pastured. Cattle have gotten into the cemetery. At least one monument is broken and the entire cemetery is overgrown with weeds.

The Finnell Cemetery is located in a pasture with no fence protecting it. It has obviously been used as pastureland. At least two monuments in this cemetery are broken.

Under these conditions, a larger number of graves than indicated by the initial count could exist in each cemetery. However, it is impossible to make an exact determination without disturbing the cemetery area.

The Shipp Cemetery is located within the area of proposed project construction and will require relocation to avoid being destroyed. The Finnell Cemetery is located outside the proposed structure

area but is within the general area; and further, its current access route will be severed by project construction. Project security measures could also preclude access to the portion of the peninsula on which the cemetery is located.

In order to facilitate plant construction, TVA would relocate these two cemeteries in accordance with a long-standing and well-accepted cemetery relocation policy. Relocation would be done with the consent of surviving relatives and in accordance with state and county health regulations and under the guidance of the appropriate Federal court. The cemeteries will be placed in comparable or superior locations and conditions when relocated.

5. Water use compatibility - Projection of the impact of the facility on the uses of surface and ground water resources of the region has been undertaken in order to assure that adequate consideration is given to alternate and shared uses of the water and to overall plans for development of the area. The watershed, flowrates, velocities, volumes, and characteristics of the water are given in Section 1.2, Environment in the Area, as baseline environmental data.

Because of the relatively small quantities of both radioactive and nonradioactive liquid discharges released to Gunterville Reservoir and the treatment of wastes as described in sections 2.4 and 2.5, the plant will have only minimal effects on the chemical and physical characteristics of the reservoir. The present usage of this portion of the Tennessee River will not be altered in any way by the construction and operation of the Bellefonte plant.

The Bellefonte plant will use a maximum of about 100 million gallons of process water per day which will not curtail known or projected industrial water uses of the average quantity of 23.5 billion gallons of water flowing by the site each day.

6. Land use compatibility - Use of the Bellefonte site for a nuclear plant would be a significant change in land use, but it is expected that this use would be compatible with both the existing and projected land uses in the surrounding area. Three aspects of compatibility are discussed below and are related to onsite uses, existing land use in the surrounding area, and projected use in the surrounding area.

(1) Onsite use compatibility - Agricultural use of the site will cease, at least during the period of construction and operation of the plant. The abandoned structures on the site will be demolished because their structural condition precludes any economic use.

Although there are no developed recreation facilities in the area and the only land in public ownership is the narrow shoreline strip, the site area now receives some visitation for recreation use. However, the use of this area is an insignificant part of the total visitation to Gunter'sville Reservoir which amounts to approximately 5.5 million visits per year.

(2) Existing land use compatibility - There are no offsite impacts which would significantly hinder the continuation of existing land uses in the surrounding area (Appendix A,

figure A-1). Agricultural and forestry activities may be reduced slightly by the access road, the railroad, and by the transmission lines, but the use of the remaining land can continue. Free access will be maintained to the sand and gravel operation so that it can continue uninterrupted. Town Creek Subdivision can continue development although the view from the homesites will be altered. The effect of this aesthetic alteration on the desirability of the subdivision is unknown.

(3) Future land use compatibility -

Development of land use in the Hollywood-Scottsboro area and the area adjacent to the Bellefonte site has been projected by several agencies. This is summarized in figure 2.9-2 which shows projected development around the site based on more detailed published reports. These reports include: "Sketch Regional Plan - Year 2000" (May 1971) and "Sketch Development Plan, Hollywood Alabama (March 1973), prepared by the Top of Alabama Regional Council of Governments (TARCOG) and "Land Development Plan and Sketch Throughfare Plan, Scottsboro, Alabama" (January 1971), prepared by Sanders and Associates. The regional plan is a broad concept of how future growth in the TARCOG region will likely be accommodated based on land suitability, transportation, economic and population trends, and resource potentials. The city plans present the various land use relationships in much more detail. Of particular importance to consideration of the Bellefonte plant is the projected pattern of residential, recreational, institutional, commercial, and industrial development in the area. TVA has also considered much of the land adjacent to the site as suitable for eventual industrial use.

One specific attribute of primary industrial land is rail transportation. In light of this and TARCOG's sketch plan, TVA coordinated the location of the necessary rail spur to the Bellefonte site with TARCOG to maximize its enhancement of the industrial potential of the remaining land. Hollywood's plan also recognizes the possible effect of the railroad on making additional land desirable for industrial use.

REFERENCES FOR SECTION 2.9

1. Principles and Standards for Planning Water and Related Land Resources, October 1973.



**FIGURE 2.9-1**

**Aerial Photography Showing  
Alternative Access Railroad  
Alignments and Bellefonte  
Nuclear Plant Layout**

Scale: 1:24,000



Date Prepared: Apr., 1974




FIGURE 2.9-2  
**PROJECTED LAND USE WITHIN 10 MILES OF THE  
 BELLEFONTE NUCLEAR PLANT SITE  
 (2000)**

Contour interval 100 feet

**LEGEND**

- URBANIZED
- INDUSTRIAL
- FOREST
- AGRICULTURE AND OPEN SPACE
- WATER
- BELLEFONTE SITE
- RECREATION AND WILDLIFE AREAS
- CITY LIMITS (1972)
- MAJOR HIGHWAY CORRIDORS



APRIL 1974

Projections based on the following reports: "Sketch Regional Plan—Year 2000" published in May 1971; "Sketch Development Plan—Hollywood, Alabama" published in March 1973, both prepared by the Top of Alabama Regional Council of Governments, and "Land Development Plan and Sketch Thoroughfare Plan—Scottsboro, Alabama" published in January 1971 and prepared by Sanders and Associates—Consulting Planners, Architects and Engineers.

### 3.0 ADVERSE ENVIRONMENTAL EFFECTS WHICH CANNOT BE AVOIDED

The CEQ guidelines require a discussion of any probable adverse environmental effects which cannot be avoided, such as water or air pollution, damage to life systems, urban congestion, threats to health, or other consequences adverse to the environmental goals set out in Section 101(b) of NEPA.

The environmental review of the proposed construction and operation of the Bellefonte plant evaluated the baseline data on appearance, quality, productivity, and usage of the preexisting environment in the area. Probable changes in these factors have been either calculated or estimated as a means of determining the degree of the change to be expected.

The following discussions summarize probable effects which cannot be avoided and the steps taken to minimize adverse environmental impacts.

1. Water pollution - Some unavoidable impacts to Gunterville Reservoir will occur during construction of the plant. These include some siltation as a result of grading, excavating, and dredging; discharge of small amounts of chemicals used in cleaning equipment; and discharge of the sewage treatment plant effluent.

These impacts will be minimized by the following means:

- . Dredging of the intake channel will be accomplished by a suction dredge with the spoil material being deposited in an upland fill area to avoid excessive siltation of the reservoir.

- . Berms, diversion dikes, check dams, sediment basins, fiber mats, netting, gravel, mulches, grasses, special

drains, and other control devices will be used to control surface drainage and erosion during grading operations.

. Soil and rock from excavation work will be used as fill or stored in compacted mounds until needed to prevent wind and rain erosion.

. Spoil material from excavation work will be wasted in preselected areas as fill, graded to conform to surrounding landscape, covered with topsoil, seeded, and mulched to avoid erosion.

. Impacts due to chemical discharges to the reservoir will be minimized by the use of holding ponds, neutralization, and other treatment which may be required to reduce concentrations substantially below harmful levels.

. Extended aeration treatment of sanitary wastes and chlorination of effluent will be provided during construction.

Operation of Bellefonte will result in small amounts of heat, chemical, sanitary, and radioactive liquid wastes being discharged into Guntersville Reservoir. Mitigation of possible related effects will be accomplished as follows:

. Closed-cycle natural draft cooling towers will minimize the quantity of waste heat discharged to the receiving waters.

. A diffuser will rapidly mix the heated cooling tower blowdown with unheated reservoir water.

. A 2-basin lagoon will remove settleable solids from makeup water filter plant sludges.

. Secondary treatment of the sanitary wastes with provision for effluent chlorination will be provided for the permanent plant.

. Radioactive liquid discharges will be reduced by treatment by evaporation and by extensive recycling.

As indicated, adequate treatment of liquid effluents is provided prior to being discharged to ensure that all applicable stream standards are met and that the quantities and concentrations released will be small enough to ensure that any adverse environmental effects are minimal and localized. Water, aquatic life, and life systems will be carefully monitored to detect possible adverse environmental effects, although some adverse effects may be undetectable.

2. Air pollution - The construction of Bellefonte will result in a minimal short duration impact to the atmosphere from selected burning of cleared brush and trash.

There will be some radioactive gaseous wastes released to the atmosphere and some negligible additions of nonradioactive gaseous emissions to the atmosphere. Some local accumulation of dissolved solids may take place on surfaces exposed to the drift from the cooling towers. In addition, large quantities of waste heat and moisture from the cooling tower plumes may result in some alteration of the local atmospheric conditions. During adverse weather conditions this increased moisture content may cause local fogging and icing. However, such occurrences resulting from the operation of the cooling towers should be infrequent. To the extent that local fogging and icing does occur, it represents an unavoidable adverse environmental effect.

Mitigation of the probable related effects from these discharges to the atmosphere is accomplished as follows:

. Brush and trash burning will be done in accordance with applicable state regulations and as atmospheric conditions permit.

. Radioactive gaseous waste will be held up 60 days to permit decay of essentially all noble gases except krypton-85 before release.

. Natural draft hyperbolic cooling towers disperse heat and moisture to the atmosphere about 500 feet above the ground.

. Cooling tower design will keep water losses due to drift from the cooling towers to a minimum.

No significant adverse environmental effects should be caused by these releases to the atmosphere.

3. Impact on land use - The construction and operation of the Bellefonte Nuclear Plant will result in a change in land use of approximately 1,500 acres from predominantly farming and pasture to industrial use. In addition, right of way easements will be obtained on approximately 1,550 acres of land, of which about 50 percent is in woodland, 25 percent in farming and pasture, and the remainder in uncultivated open land.

The land use adjustments are not judged to be significant adverse environmental impacts.

4. Damage to life systems - When the auxiliary cooling water and cooling tower makeup water passes through the traveling

screens, fish larvae and plankton will be drawn into the water intake. These will be destroyed in passing through the closed cooling system. To the extent that the plankton and larval fish drawn into the water intakes serve as a food source for aquatic life and the basis for harvestable fish production, their destruction is an adverse effect which cannot be avoided. However, since the quantity of water required for auxiliary cooling and cooling tower makeup represents only 0.4 percent of the average annual flow past the site, these effects should not damage significantly any life system.

5. Threats to health - The facility is being designed and constructed and will be operated in accordance with all applicable regulations in order that the health and safety of the public will be safeguarded.

Significant accidental releases of radioactive products at the plant or during transportation of radioactive materials are very improbable. Should such a release occur, implementation of the radiological emergency plans would mitigate the potential risk to the public.

6. Socioeconomic effects - The construction and operation of the plant will have an economic and social impact. Although the plant will provide an economic stimulus to the region, stress on present institutions, such as schools and housing facilities, will unavoidably result in placing a greater demand on both the public and private sectors to provide the necessary community services. TVA will work with appropriate local and regional authorities to minimize these stresses.

7. Conclusions - While the construction and the operation of Bellefonte will result in some adverse environmental effects which cannot be avoided, these effects should not conflict with the environmental goals set out in Section 101(b) of NEPA. If any significant adverse effects attributable to the construction or the operation of the plant become evident or through the various environmental monitoring programs are shown to be inimicable to Section 101(b) goals, appropriate steps will be taken to correct the situation.

#### 4.0 ALTERNATIVES

This environmental statement considers the ways in which the plant will interact with the environment by reevaluating the environmental consequences considered earlier and minimizing any further adverse environmental consequences that would affect the overall balance of environmental costs and benefits by studying and adopting appropriate alternatives. Analyses of alternative systems are described in sections 2.1 through 2.9. Alternative methods of generation and alternative plant sites are discussed in detail in sections 4.1 and 4.2 respectively.

4.1 Alternative Generation - The purchase of electric power in lieu of constructing additional generating capacity is not a feasible alternative. To supply equivalent amounts of power and energy on a year-round basis to TVA, another large electric utility with extensive transmission interconnections would have to install generating capacity in amounts slightly greater than that of the Bellefonte Nuclear Plant, build several high-capacity transmission lines to the TVA area, and transmit the power to TVA. To construct such facilities on another power system would not avoid an impact on the environment but would only create an environmental impact in another area. Even if the assumption is made that the plant locational factors and costs would be equal, the cost of transmission lines, the transmission line losses, the use of land for transmission line rights of way, and the exposure to transmission line outages would result in waste of natural resources, materials, and funds, and would provide a more costly and less reliable source of power for the TVA region than will the construction of additional TVA generating facilities.

Planning for this capacity addition required that considerations be given to maintaining a practical mix of conventional hydro, pumped-storage hydro, gas turbine, fossil-fired, and nuclear generating units. Since TVA expects to have the 1,530-MW Raccoon Mountain Pumped-Storage Project in operation by 1975 and over 1,000 megawatts of gas turbine peaking capacity on its system by 1978, a substantial amount of TVA's planned generating capacity is designed for peaking service. Studies of the system load characteristics and the characteristics of the existing generating facilities indicate that the installation of

additional pumped-storage or other peaking capacity is not an economical alternative in the 1979 period. The system needs, as indicated by TVA planning studies, required that detailed comparisons be made between base-loaded fossil-fired units and nuclear-fueled units.

The use of hydroelectric units was eliminated as an alternative because there are no hydroelectric sites in the TVA service area suitable for base-load hydroelectric generation in the amount required to serve the capacity and energy demands of this time period.

Gas-fired plants were not considered a feasible alternative because the quantity of natural gas required would not be available in the TVA area. The fuel requirements for a gas-fired plant of the approximate size required would consume about 170 billion cubic feet of natural gas each year. During the past 3 years, TVA has contacted all major suppliers of natural gas in the TVA area in order to secure a natural gas supply for the approximately 1,000 MW of gas turbines which TVA has installed or has under construction. Only limited success was achieved in obtaining a natural gas supply for these gas turbines. The natural gas contracted for is only available in the summer, and none could be obtained on a year-round basis. Based on these investigations, it was concluded that a natural gas supply was not available in the quantity required for a gas-fired plant of the capacity of the Bellefonte Nuclear Plant.

By its order No. 467 and rulemaking notices R-467 and R-468, which proposed a system of priority of service among classes of gas consumers based on type of use, the Federal Power Commission has indicated that it no longer considers natural gas an appropriate fuel for

the production of electric power in large fuel-burning installations.

Two major disadvantages in planning an oil-fired power plant the size of the Bellefonte plant are the uncertainty of a long-range fuel supply and the high cost of oil. In 1970 TVA began contacting the major oil companies in the United States to develop a dependable supply of fuel for gas turbines and for use in steam-electric generating plants. Letters of inquiry were sent to sixteen major oil companies in May 1970. Of the twelve companies that responded to the letters, eight indicated no interest at that time in supplying oil for power plants. Meetings were held with the remaining four companies which responded, and none was interested in a long-term contract for supplying the quantity of oil needed for a 2,600-MW oil-fired power plant. The suppliers indicated that this quantity of oil (20 to 24 million barrels per year) could not be supplied from domestic sources. Therefore, a long-term contract would be contingent on a supplier obtaining an oil import quota each year since the TVA operating area lies in Petroleum Administration for Defense (PAD) Districts 2 and 3. As a result of these inquiries, TVA concluded that the long-term requirements of an oil-fired steam-electric generating plant could not be assured. Since 1970 TVA has held discussions with three oil companies and these discussions have reaffirmed the conclusion that contracts for this quantity of oil are contingent on a supplier obtaining an oil import quota and that the oil supply could not be assured. TVA believes that an assured fuel supply must be available before a decision is made to construct a generating plant.

Air pollution control regulations have greatly increased the demand for low-sulfur fuel oil, and oil import quotas have placed a

greater burden on domestic supplies. Domestic demand for fuel oil has increased at a rate of about 5 percent per year since 1968 while the domestic production has increased at a rate of about 1.5 percent per year. Also, the ratio of domestic reserves to production decreased from 12.8 years in 1960 to about 9 years in 1970 when proven reserves were 29.6 billion barrels and production was 3.32 billion barrels. The increased demand and reduced domestic reserves will force more dependence on the restricted and uncertain foreign supplies. In 1970 foreign sources supplied 23 percent of the domestic oil requirements. The shortage of low-sulfur oil reserves and difficulty in securing a reliable foreign or domestic supply at this time make the selection of oil as fuel for a base-load plant the size of Bellefonte an unacceptable alternative.

Even if an adequate supply of fuel oil for the life of the plant were assured, the cost of oil as fuel would make the selection uneconomical for base-load capacity. On a heat content basis, low-sulfur fuel oil costs more than four times as much as nuclear fuel. The following table shows a comparison of approximate costs of nuclear and oil-fired plants of the 2,500-MW size category.

	<u>Nuclear</u>	<u>Oil-Fired</u>
Plant investment, \$/kW	261	175
Levelized fuel cost, $\phi/10^6$ Btu	15.6	70.0
Net plant heat rate - Btu/kWh	9,943	9,043.0
Annual production expense, mill/kWh:		
Plant investment	3.2	2.2
Operating and maintenance	<u>1.9</u>	<u>6.7</u>
Total	5.1	8.9
Difference	Base	3.8

This difference in annual production expense is estimated to represent an annual cost difference of about \$66.5 million.

TVA performed an analysis of the two remaining feasible alternative types of generation - coal-fired units and nuclear-fueled units - to meet the system needs in the TVA area. Estimates of the total installed cost, assessment of the technical aspects of the offerings, and other economic evaluations were made. A summary of the results of this analysis for plants of the 2,500-MW size category is tabulated below:

	<u>Coal-Fired Plant</u>	<u>Nuclear-Fueled Plant</u>
Plant investment - \$/kW	249.8	261
Levelized fuel cost - ¢/10 <sup>6</sup> Btu	25.0	15.6
Net plant heat rate - Btu/kWh	8,947.0	9,943
Estimated Annual Production Expense <sup>a</sup> - $\frac{\text{mill}}{\text{kWh}}$		
Plant investment	3.1	3.2
Operating and maintenance cost	<u>2.7</u>	<u>1.9<sup>b</sup></u>
Total	5.8	5.1
Difference	0.7	Base

- 
- a. Based on a 10-year present worth evaluation at 8 percent interest.  
 b. Includes estimated cost of nuclear insurance.

Based on the 0.7 mills/kWh difference indicated above, TVA estimates that the selection will result in an annual cost saving of about \$11 million when compared to a coal-fired alternative.

In terms of overall environmental impact, nuclear generation offers advantages over coal-fired generation. While modern coal-fired units reject about 20 percent less heat to the environment, they emit large quantities of combustion products to the atmosphere and consume large quantities of raw materials. The small amounts of radioactive materials released to the environment from a nuclear plant do not result in any significant environmental impacts. Although the above cost estimates for a coal-fired plant included TVA's best judgment on the cost of SO<sub>2</sub> removal facilities, such facilities are now in the preliminary developmental stage. TVA has no assurance that such facilities will be available on a proven and reliable basis for use on an alternative coal-fired plant for this time period.

Recently, states in the TVA region have adopted SO<sub>2</sub> emission standards which make the feasibility of a new coal-fired plant questionable. Although TVA is proceeding on a demonstration SO<sub>2</sub> removal program on unit 8 of the Widows Creek Steam Plant, a reliable SO<sub>2</sub> removal technology does not now exist. TVA is investigating the feasibility and economics associated with other means of reducing SO<sub>2</sub> emissions, such as coal washing and the burning of low-sulfur fuels, as a means of complying with adopted SO<sub>2</sub> emissions standards. Preliminary indications are that these measures may result in compliance with standards, but there are severe economic penalties associated with their implementation.

Consequently, economical and feasible solutions to the problems associated with SO<sub>2</sub> emissions are not available.

Additionally, the large quantities of coal required for operation of a coal-fired plant and the resulting ash produced present large-scale materials-handling requirements, both at the plant site and along transportation routes, which are significantly greater than for a nuclear plant.

The nuclear plant would require an annual commitment of about 200 tons of U<sub>3</sub>O<sub>8</sub> while the coal-fired plants using either low-sulfur or high-sulfur coal would require commitments of about 7 to 8 million tons of coal.

Based on achieving 80 percent removal, a sulfur content in low-sulfur coal of approximately 0.5 percent and a 3 percent content in high-sulfur coal, the coal-fired plants would release approximately 76,000 and 77,000 tons of SO<sub>2</sub> to the atmosphere respectively. In addition, based on the most stringent standards of any state within the Tennessee Valley, the respective plants would release about 56,000 and 55,000 tons per year of NO<sub>x</sub> and about 12,700 and 10,700 tons per year of particulates. Ash which must be handled on the plant sites would amount to about 1 million tons per year. In addition the SO<sub>2</sub> removal system could produce substantial quantities of residual slurries that could pose difficult disposal problems and significant environmental problems. Releases of similar constituents from a nuclear plant are negligible (see Section 2.5, Nonradioactive Discharges).

Radioactivity releases to the atmosphere from either type plant result in insignificant doses to the public. Doses resulting from operation of the nuclear alternative are described in Section 2.4, Radioactive Discharges, while the doses resulting from the coal-fired plant's operation are unknown.

Radioactive releases to receiving waters from the nuclear alternative would be so small as to be considered insignificant as described in Section 2.4, Radioactive Discharges. Releases of a similar nature from the coal-fired plant would be expected to be even less.

Land usage requirements are slightly less for the nuclear alternative.

After considering these factors, TVA decided that the nuclear alternative was more acceptable from both the standpoint of economics and environmental impact.

## 4.2 Alternative Sites

1. Site studies - Studies are made on a continuing basis to determine the best locations for adding electrical generating plants to the TVA power system. These studies have been made since the early 1950's as an integral part of TVA's planning process.

TVA has made extensive studies to identify and investigate sites meeting the basic requirements for future generating facilities. During the more recent years five general areas have been under investigation. These areas included:

1. The Mississippi River upstream and downstream from Memphis and on the Tennessee River including Pickwick Reservoir and the upstream end of Kentucky Reservoir extending from Pickwick Dam to Savannah, Tennessee
2. On the Tennessee River including Guntersville and Chickamauga Reservoirs
3. On the Tennessee River and tributaries extending upstream from Watts Bar Dam to John Sevier Steam Plant
4. On the Cumberland River upstream and downstream from Nashville
5. On the Tennessee and Cumberland Rivers extending from Johnsonville and Cumberland Steam Plants downstream to the Ohio River

More recently these studies have been further expanded to include the Tennessee River north of TRM 174; the Ohio River from Shawnee Steam Plant to Smithland, Kentucky; the Mississippi River from river mile 780 to Cairo, Illinois; and the upper east Tennessee tributary reservoirs of Cherokee, Norris, and Douglas.

As part of TVA's studies to identify sites which have the exacting requirements of power plant sites, preliminary site studies are conducted which include the following:

1. Map reconnaissance, aerial survey, and field reconnaissance
2. Land use and ownership assessment
3. Site access
4. Navigability of waterway
5. Transmission facility proximity
6. Topography
7. Proximity to population centers
8. Flood control studies
9. Cooling water availability
10. Site proximity relative to unique areas such as recreation areas, wildlife areas, or other areas requiring special consideration which would be impacted by the location of a generating plant on the site

As a result of these preliminary site studies, sites are identified for further study of physical characteristics including:

1. Foundation conditions
2. Archaeological studies
3. Meteorological conditions
4. Hydrological conditions

During the period 1967 through 1972 TVA identified 207 potential generating plant sites as part of its long-term power plant siting program. Preliminary studies of these sites warranted detailed investigations on 24 of the sites. In carrying out the detailed

studies, seismic tests were conducted on 21 of the sites and 18 of the sites were core drilled to determine foundation conditions. This site investigation program has been expanded in the more recent years with annual expenditures for site investigations increasing from \$499,000 in fiscal year 1971 to over \$1.1 million in fiscal year 1972.

When the contract was awarded for the nuclear steam supply system for the proposed plant, a total of 30 sites had been identified for preliminary site studies. Preliminary investigations had revealed that 8 of these sites had the desirable characteristics to warrant further and more detailed studies. For the reasons previously stated, onsite investigations were being conducted on the Tennessee River; therefore, knowledge of foundation conditions at potential sites was necessarily limited to the sites on the Tennessee River. These eight sites were considered as potential sites for the proposed plant and are listed below:

<u>Site</u>	<u>Reservoir</u>	<u>Location</u>
A	Kentucky	TRM 174L
B	Pickwick	TRM 215
C	Guntersville	TRM 369L
D	Guntersville	TRM 386.5R
E (Bellefonte)	Guntersville	TRM 392R
F	Guntersville	TRM 398.5R
G	Chickamauga	TRM 499L
H	Watts Bar	TRM 559R

The locations of these sites are identified on figure 4.2-1.

In planning to meet future load requirements at any given time several generating plants and several acceptable sites will be under consideration. The selection of the next site from the candidate sites will be a matter of sequence of developments, and candidate sites rejected for the first plant will continue to be considered for siting subsequent generating plants as part of the continuing process to determine the best locations for adding electrical generating plants to the TVA power system.

2. Area requirements - The TVA system, which with 23.3 million kilowatts of presently installed generating capacity is the Nation's largest, is interconnected at 26 points with neighboring systems with which TVA exchanges power. The TVA system is, in effect, part of a huge power network consisting of interconnected power systems.

TVA's system is a winter peaking system with major portions of the system demand concentrated in distinct areas. In addition to these load concentrations, interchange agreements totalling 2,060,000 kW with Mississippi Power & Light, the Southern Company, and the Illinois-Missouri group result in additional power flows to the south and west.

In order to study load growth and power flows in the system and to determine the transmission system changes required to accommodate alternative sites, the TVA power system has been divided into five study areas. These areas are shown on figure 4.2-2. The area divisions were selected to divide the system electrically according to concentration of load and generation centers (Memphis, Nashville, Knoxville, Chattanooga-Huntsville, and Muscle Shoals-Mississippi) in areas 1-5 respectively.

As shown in figures 4.2-2 and 4.2-3, areas 2, 3, and 5 are the areas with capacity deficiencies in the winter of 1980, and areas 1, 2, and 5 have summer deficiencies. However, much of the western portion of the TVA service area (areas 1 and 5) is included in an area in which the seismic conditions are not clearly defined. This area is in close proximity to an area in which major seismic activity has occurred as recently as the early 1800's. This area has been under study by TVA and TVA consultants to define the seismic conditions in the area. A report entitled Relationship of Earthquakes and Geology in the West Tennessee and Adjacent Areas was submitted in June 1972 to AEC's Director of Regulation for consideration in determining the seismic design criteria for this area. Therefore, sites A and B could not be considered for the proposed plant pending a determination on seismic design criteria for these sites.

While figure 4.2-2 indicates that at the time of initial operation of the Bellefonte Nuclear Plant surplus generating capacity occurs in Area 4 and the largest deficits occur in Area 2, it should be recognized that during the late 1960's when priorities were being established for site investigations, the load forecasts and planned scheduled operating dates for this plant were different from the situation depicted in this figure. One of the principal factors used during the late 1960's to establish priorities of the areas to be investigated was the availability of cooling water. The cooling system criteria for generating plants used at that time was once-through cooling. The economic advantages of the once-through cooling over auxiliary cooling methods such as cooling towers is estimated at \$40 to \$50 million on a plant the size of the proposed Bellefonte Nuclear Plant, thus, offering significant savings to the consumers of TVA power. The criteria used to design cooling systems were

based on temperature standards proposed by the Valley states, including Alabama and Tennessee, which were that maximum temperatures were not to exceed 93° F. after reasonable mixing and a 10° F. rise above ambient temperature. These criteria were proposed by Alabama in compliance with the Water Quality Act of 1965. Since the average flow on the Tennessee River near its mouth is about 65,600 cfs as compared to an average flow of about 26,500 cfs near the mouth of the Cumberland River, the Tennessee River offered substantially more opportunity for development of sites capable of meeting these criteria. The siting of a plant the size of the proposed Bellefonte Nuclear Plant on the Cumberland River would likely have required the installation of cooling towers depending on the particular location of the site on the Cumberland River. The portion of the Cumberland River where stream flows are the highest (near its mouth) is also located in the area where the seismic conditions had not been clearly defined. In the area where seismic conditions are defined the average annual flow is approximately 20,000 cfs. Additionally, flows on the Cumberland River are controlled by the Corps of Engineers whereas flows on the Tennessee River are controlled by TVA. These considerations, along with the fact that the Tennessee River passes through 3 of the 5 major load centers of TVA's service area, resulted in the establishment of the priorities used in site investigations in the late 1960's. TVA decided to investigate the Tennessee River Valley first with the Cumberland River Valley to follow close behind as these investigations were completed. After site investigations along the Tennessee River were well advanced and a significant amount of engineering data had been collected, as well as the substantial expenditure of funds, water quality thermal standards became less certain. In 1971, the State of Alabama and the Environmental Protection Agency could not agree on thermal standards for Alabama. This allowed EPA, under the

provisions of the Water Quality Act of 1965, to set the thermal standards for the State of Alabama. TVA received a letter from the Region IV Administrator, Environmental Protection Agency, dated December 17, 1971, stating the EPA was intensely pursuing the immediate adoption of proposed thermal standards for the States of Alabama and Tennessee. The Region IV Office informed TVA the EPA would not accept any maximums for the water of the Tennessee River Basin in Alabama other than the following:

"Temperature shall not be increased more than 5° F. above the natural prevailing background temperatures nor exceed a maximum of 86° F." and for Tennessee (Tennessee River only), "Temperature shall not be increased more than 3° C. above the natural prevailing background temperatures, nor exceed a maximum of 30.5° C." The revised Tennessee standard was adopted by the Tennessee Water Quality Board on December 14, 1971, and was approved by EPA on June 9, 1972. The revised Alabama standard was adopted by the Alabama Water Improvement Commission on July 18, 1972, and approved by EPA on September 18, 1972.

In light of these developments, one of the major criteria for selecting the Tennessee River Valley over the Cumberland River Valley in the late 1960's has become less important in siting since these criteria force the use of some form of auxiliary cooling. Nonetheless, since siting studies require considerable advanced planning, the data available on sites was, by necessity, limited to those sites along the Tennessee River where the data gathering had been initiated based on priorities established in the late 1960's.

Although regional and area energy requirements is one factor in the siting of new generation facilities, it is significant only to the extent that the transmission connections are significantly altered. While figure 4.2-2 shows an imbalance of load and supply at the

time of peak load conditions between the particular areas depicted, the system is not, in fact, divided since these areas are strongly interconnected with transmission lines. Thus, deficiencies in one area can readily be supplied by surplus capacities in other areas. In the case of area 4, the 1980 peak periods depicted in figure 4.2-2 do not result in major additions to the transmission system to connect areas 2 and 4. As evidenced by the transmission connections for the proposed Bellefonte Nuclear Plant described in Section 2.2, the transmission connections to the system run in the east-west direction and to the south with no direct connections to area 2. This evidences a transmission system that is strongly connected.

Of the six remaining sites four (sites C, D, E, and F) are located on Guntersville Reservoir in area 4. Figures 4.2-4 and 4.2-5 show the impact on the load and capacity for the winter and summer of 1980 resulting from locating the proposed plant in area 4. Figures 4.2-6 and 4.2-7 show the impact of locating the proposed plant at site G or H, both of which are located in area 3.

3. Site descriptions - Descriptions of the potential sites C, D, E, F, G, and H are given below.

(1) Site C - This site is located on the east shore of Guntersville Reservoir at TRM 369. The site is located 6 miles from the nearest town, Grant, Alabama, which has a population of 382, and 30 miles from the nearest city with a population over 25,000, Huntsville, Alabama, which has a population of 137,802. The site is located 16 miles from the nearest highway, 16.5 miles from the nearest railroad, and 28 miles from the nearest 500-kV transmission line. This 700-acre site would require the acquisition of an additional 375

acres of privately owned property. Most of the land on and around the site is sparsely developed with some second-home development occurring about 1.5 miles upstream. A major industry has located approximately 2.5 miles from the plant. The site has a suitable foundation, and development of the site would be generally compatible with projected land uses.

(2) Site D - This site is located on the west shore of Guntersville Reservoir at TRM 386.5. The site is located 4 miles from the nearest town, Scottsboro, Alabama, which has a population of 9,324, and 36 miles from the nearest city with a population over 25,000, Huntsville, Alabama, which has a population of 137,802. The site is located 1 mile from the nearest highway, 2.5 miles from the nearest railroad, and 13 miles from the nearest 500-kV transmission line. This 900-acre site would require the acquisition of an additional 700 acres of privately owned property. The site would be comparatively small and would probably require the removal and relocation of several significant structures.

In view of the scarcity of suitable power plant sites, prudent planning requires that, where practicable, sites be selected which have the potential for expanding the generating capacity. In addition, the site should provide room for flexibility in arranging and orienting the plant and related structures on the site and sufficient area to aid in reducing the visual impact of the facility. Site D does not meet these standards.

The exclusion area of the plant would include State Highway 35, some commercial establishments, a state maintenance building, and the city of Scottsboro's filtration plant. While 10 CFR part 100 permits a highway to traverse the exclusion area, the number of other

structures would, in TVA's opinion, be inconsistent with exclusion area requirements and thus would require removal and possible relocation. While such relocation is feasible, it would obviously impose serious economic penalties.

The city of Scottsboro's water intake is located on the downstream edge of the site. To prevent plant effluent from entering the Scottsboro intake, the plant discharge would have to be released into the Dry Creek embayment for its eventual return to the Tennessee River. Alternatively, the Scottsboro water intake would have to be relocated upstream from the site. In addition, required rail access would be longer at this site and there is a marked trend toward urbanization in the immediate vicinity.

Downstream from the site is part of the town of Scottsboro's permanent residential development. Future development plans anticipate further urbanization of this area. While this site has a suitable foundation and is favorably situated relative to transmission and access facilities, conflicting land use requirements and size limitations make it incompatible for a nuclear plant site at this time.

(3) Site E - This site is located on the west shore of Guntersville Reservoir at TRM 392. The site is located 3-1/2 miles from the nearest town of Hollywood, Alabama, which has a population of 865, and 7 miles northeast of Scottsboro, Alabama, which has a population of 9,324. The site is 39 miles from the nearest city with a population of 25,000, Huntsville, Alabama, with a population of 137,802. The site is located 2.5 miles from the nearest highway, 3.5 miles from the nearest railroad, and 12.3 miles from the nearest 500-kV transmission line. This 1,500-acre site would require the acquisition of an additional 1,260 acres of privately owned property.

The site contains and is adjacent to farmland with high potential for industrial development, and use as a nuclear plant site would be compatible with present and projected land uses in the vicinity.

(4) Site F - This site is located on the west shore of Guntersville Reservoir at TRM 398.5. The site is located 6 miles from the nearest town, Stevenson, Alabama, which has a population of 2,390, and 37 miles from the nearest city with a population over 25,000, Chattanooga, Tennessee, with a population of 119,082. The site is located 1 mile from the nearest highway, 2 miles from the nearest railroad, and 6 miles from the nearest 500-kV transmission line. This site would require the acquisition of an additional 900 acres of privately owned property. An important wildlife management area virtually surrounds the site. This wildlife area lies between the site and the reservoir and includes some small maintenance and office buildings and fields planted for wildlife food production. While it may be feasible to locate a plant on this site without destroying this wildlife management area, some encroachment would likely result. In TVA's judgment, such encroachment would be unwarranted so long as an alternative suitable site is available.

Additionally, seismic investigations at the site indicate that foundation rock at this site is at an unfavorable depth (in excess of 100 feet deep) and is believed to be badly weathered. When compared to the foundation conditions at alternative sites C, E, and G this site would be less desirable and more costly to develop for a nuclear plant. The site is located approximately 4,000 feet from the reservoir and therefore, would require a greater total length of water conduits than other alternatives.

Because of cost factors related to depth of foundation rock and the length of water conduits, along with encroachment on the wildlife management area, this site was judged to be less desirable than other alternatives.

(5) Site G - This site is located on the east shore of Chickamauga Reservoir at TRM 499 where the Hiwassee River enters the reservoir. The site is located 6 miles from the nearest town, Dayton, Tennessee, which has a population of 4,361, and 30 miles from the nearest city with a population over 25,000, Chattanooga, Tennessee, with a population of 119,082. The site is located adjacent to a highway, 19 miles from a railroad, and 3.5 miles from the nearest 500-kV transmission line. This 1,100-acre site would require the acquisition of an additional 900 acres of privately owned property. No intensive development is located near this site; however, it is just downstream and adjacent to the Hiwassee Island Game Management and Waterfowl Refuge Area which is of major importance to east Tennessee. The compatibility of the site with the continued existence of the wildlife refuge has not been determined. It is judged, however, that impacts of constructing a plant on this site would affect the refuge only during the construction period and no permanent damage to the refuge would result.

(6) Site H - This site is located on the west shore of Watts Bar Reservoir at TRM 559. The site is located 5 miles from the nearest town of Rockwood, Tennessee, which has a population of 5,259, and 25 miles from the nearest city with a population over 25,000, Oak Ridge, Tennessee, with a population of 28,319. The site is located 6 miles from the nearest highway, 8 miles from the nearest railroad, and 5 miles from the nearest 500-kV transmission line. This 1,000-acre site would require the acquisition of an additional

950 acres of privately owned property. The present and projected land use on and around this site is agriculture and openland. Use of the site for a nuclear plant would be compatible with these uses. However, on a comparative basis this site presents substantial cost disadvantages due to the topography of the area. These cost disadvantages would be reflected predominantly in the areas of rail access and site grading. While TVA analysis of the geology of this area indicates a suitable foundation is likely, permits to conduct onsite drilling have been denied, and to date it has not been verified whether the rock underlying the plant would provide a foundation suitable for the construction of a nuclear plant.

A review of the above site descriptions indicates that conflicts or questions existing at three of the sites (sites D, F, and H) make them less desirable at this time than the other three proposed sites. These include the conflict with the urbanizing growth of a nearby town at site D; the encroachment on an important wildlife sanctuary and the depth of the rock at site F; and the lack of information indicating the suitability of the rock for a nuclear plant foundation at site H. Since sites D, F, and H were either less suitable or their suitability was not fully determined, a detailed site evaluation was limited to sites C, E, and G.

These sites were investigated considering the economic and environmental cost of locating the proposed plant at each of the alternative sites.

3. Physical environment -

(1) Chickamauga site (site G) - For the site on the Chickamauga Reservoir, the following information of the physical environment of the area was known.

(a) Hydrology - At the normal pool elevation of 682.5, the Chickamauga Reservoir is 58.9 miles long and has an area of 35,400 acres with a volume of 628,000 acre-feet. The reservoir has an average width of nearly 1 mile, and navigation is provided by maintaining a minimum channel depth of 11 feet. The average annual flow at the Chickamauga Dam is 32,800 ft<sup>3</sup>/s.

The reservoir is located in a region which derives ground water from precipitation which over the 1931-55 time period had averaged about 48-55 inches per year. Some of the precipitation evaporates, runs off into streams, seeps into the soil to be absorbed or used by vegetation, or seeps downward to become ground water. The movement of ground water at the site would be dependent on the underlying geologic formations.

The site has ready access to the Tennessee River for an adequate supply of water for necessary heat dissipation, auxiliary cooling, and other plant needs.

(b) Seismology - The site lies within the Southern Appalachian Seismotectonic Province. The

maximum historic earthquake recorded in this province was in Giles County, Virginia, in 1897. This earthquake had an intensity of MM VIII.

(c) Meteorology - The site is located in the eastern Tennessee portion of the Southern Appalachian Region which is dominated much of the year by Azores-Bermuda anti-cyclonic circulation. This circulation is most pronounced in the fall and is accompanied by extended periods of fair weather and widespread atmospheric stagnation. In winter the normal circulation pattern becomes diffuse over southeastern states as the eastward moving migratory high and low pressure systems, associated with midlatitude westerly current, bring alternating cold and warm air masses into the area with resultant changes in regional and local wind direction, wind speed, atmospheric stability, precipitation, and other meteorological elements. In summer the migratory systems are less frequent and less intense and the area is under the dominance of the western edge of the Azores-Bermuda anticyclone with a warm moist air influx from the Atlantic Ocean.

The meteorology of this area provides a rather limited range of atmospheric conditions for transport and dispersion of plant emissions. Conditions are generally most favorable in winter through spring months when migratory pressure systems move alternately through the area, accompanied by moderate to occasionally high wind. Atmospheric dispersion is least favorable in the fall months when extended periods of atmospheric stagnation reach highest frequency.

(d) Population - The site is located 6 miles from the nearest town of Dayton, Tennessee, which has a population of 4,361, and 30 miles from the nearest city with a population over 25,000, Chattanooga, which has a population of 119,082. As shown in figure 4.2-8, the populations within 5, 10, and 50 miles of the site are 3,691, 16,768, and 683,226, respectively.

(e) Land requirements - The total land required for a nuclear plant on this site is about 1,100 acres. The property not presently in TVA ownership and required to provide the plant needs is approximately 900 acres. A proposed layout of the plant is shown on figure 4.2-11.

(f) Conclusion - From consideration of the above factors, TVA concluded that the Chickamauga Reservoir site would be physically suitable for the location of a nuclear plant.

(2) Guntersville Reservoir sites (sites C and E) - For the two sites located on the Guntersville Reservoir similar information was available for consideration of the above factors defining the physical environment.

(a) Hydrology - At the normal pool elevation of 595.0, the Guntersville Reservoir is 75.7 miles long and has an area of 67,900 acres with a volume of 1,018,000 acre-feet. The average annual flow at the Nickajack Dam at TRM 424.7 is 38,000 ft<sup>3</sup>/s and the average annual flow at the Guntersville Dam at TRM 349.0 is 41,000 ft<sup>3</sup>/s.

The Gunterville area derives ground water from precipitation which over the 1931-55 time period has averaged about 53 inches per year. The direction of ground water movement at each of the sites would be dependent on the underlying geologic formation.

Each of the sites has ready access to the Tennessee River for an adequate supply of water for heat dissipation, auxiliary cooling, and other plant needs.

(b) Seismology - The Gunterville sites lie within the Southern Appalachian Seismotectonic Province.

(c) Meteorology - The meteorological and climatological data sources for this area are the Widows Creek Steam Plant air monitoring network, the National Weather Service Cooperative Observer Station in Scottsboro, and limited data from the Browns Ferry Nuclear Plant meteorological station.

The Gunterville sites are located in a region which is dominated much of the year by the Azores-Bermuda anticyclonic circulation. This circulation is most pronounced in the fall and is accompanied by extended periods of fair weather, widespread atmospheric stagnation, and smog. In the winter the normal circulation pattern becomes diffuse over the southeastern United States as the eastward moving migratory high and low pressure systems, identified with the midlatitude westerly upper circulation, bring alternately cold and warm air masses into the area with resultant changes in wind, atmospheric stability, precipitation, and other meteorological elements. In summer the migratory systems are less frequent and less intense as

the area is under the influence of the western extension of the Azores-Bermuda anticyclonic circulation with frequent incursions of warm moist air from the Atlantic Ocean and Gulf of Mexico. Severe windstorms are comparatively infrequent and generally reach their peak intensity in winter and early spring when maximum air mass discontinuity occurs. Windstorms of short duration occur in summer with thunderstorms. The probability of tornado occurrence in the site area is extremely low. Maximum precipitation occurs in the winter and early spring with the frequent passage of migratory low pressure systems. Maximum short-period precipitation usually occurs with summertime thunderstorms.

Because of the prominent valley-ridge physiographical features of these sites, the local wind pattern is distinctively bimodal (northeasterly downvalley and southwesterly upvalley) within the lower 600-800 feet of the valley floor; above these levels the pattern becomes regional in character with more uniform directional distribution with slightly predominant southeasterly, southwesterly, and northerly winds.

The meteorology of the area indicates a wide range of atmospheric conditions for the transport and dispersion of radioactive waste emissions. Dispersion conditions are most favorable in winter through spring when migratory pressure systems move alternately through the area, accompanied by occasionally moderate to high winds. The least favorable conditions are in the fall when extended periods of anticyclonic circulation, or atmospheric stagnation, are most likely to occur.

(d) Population - Site C is located 6 miles from the nearest town, Grant, Alabama, which has a population of 382, and 30 miles from the nearest city with a population over 25,000, Huntsville, Alabama, which has a population of 137,802. As shown by quadrants in figure 4.2-9, the populations within 5, 10, and 50 miles of the site are 3,378, 13,112, and 653,925, respectively.

Site E is located 3.5 miles from the nearest town, Hollywood, Alabama, which has a population of 865, and 7 miles from Scottsboro, Alabama, which has a population of 9,324. It is located 39 miles from the nearest city with a population over 25,000, Huntsville, Alabama, which has a population of 137,802. As shown by quadrants in figure 4.2-10, the populations within 5, 10, and 50 miles of the site are 2,755, 18,405, and 837,658, respectively.

(e) Land requirements - Site C would require the acquisition of 375 acres of privately owned property to develop this 700-acre site. Site E would require the acquisition of 1,260 acres for developing this 1,500-acre site. The additional acreage required at site E is because the site lies on a peninsula and the entire peninsula would have to be acquired. Proposed layouts of sites C and E are shown in figures 4.2-12 and 4.2-13.

(f) Conclusion - From consideration of the above factors, TVA concluded that the Guntersville sites would be physically suitable for the location of a nuclear plant.

#### 4. Environmental considerations -

(1) Aesthetics - None of the sites considered is in a heavily populated location, and none is at a location frequented by large numbers of visitors.

All sites have been examined for potential visual impacts considering such factors as plant elevations relative to reservoirs and surrounding terrain, distances from well-travelled highways, and distances from waterways. None of the sites is highly elevated with respect to the reservoirs or surrounding terrain. Plant grade elevations vary from about 25 feet above the normal reservoir elevation at site C to about 35 feet for sites E and G. The distance from the reservoir to the powerhouse would vary from about 1,300 feet at site G to about 4,000 feet at site E, with site C at about 3,000 feet. Due to the hilly nature of the terrain at these sites, considerable natural screening is provided for installation at lower elevations. At any of the sites considered the plant would be visible from a state or U.S. highway.

Plant construction plans are coordinated with architectural personnel who route access roads, recommend leaving trees standing in strategic areas as visual screens, and otherwise reduce visual impacts. These practices would be followed at any site and visual impacts would not be expected to be significant except if natural draft cooling towers were utilized. The towers would be visible in the near vicinity of the plant site and their plumes could be visible for as much as 10 miles. The plumes, therefore, could be seen on some occasions from some small towns regardless of the site chosen. The towers themselves are considered to be visually acceptable.

Examination of the alternative sites to determine the visual impacts resulting from transmission line connections indicates that some differences exist. Where the lines leave

the plant overland, they can be screened by strategic routing, but where reservoir crossings are required the lines cause greater visual impacts. Therefore, the number of reservoir crossings required is considered as an indicator of the degree of impact. Of the three sites considered, site C would probably require four reservoir crossings, site E would require three reservoir crossings, and site G would require six reservoir crossings. Impacts of crossings can be minimized by use of double-circuit towers and strategic location of crossings. As discussed in section 2.2, a double-circuit crossing will be utilized at the Bellefonte crossing.

Regardless of the location selected, the design of the plant would have as an objective the creation of harmony between the plant and its setting. The architectural design and site development should provide an aesthetically pleasing appearance and mitigate the transition in land use.

It is concluded that through careful planning and coordination of plant design, the plant's visual impacts would be made acceptable at any of the sites considered.

(2) Recreation - The alternative sites were considered for the impacts on recreation potential which might occur due to the construction and operation of a nuclear plant.

Guntersville and Chickamauga Lakes are very similar in terms of suitability for recreation. Each has good sport fishing, clean clear waters, water contact sports, and the beautiful backdrop provided by the wooded Appalachian foothills. These two reservoirs combined attract almost 9,000,000 visits annually--5,358,000 at

Guntersville and 3,636,000 at Chickamauga. These visits occur at boat docks and resorts, state and local parks, wildlife areas, public access areas, and private residences located along the shoreline.

The sites considered on Guntersville Reservoir at TRM 369L (site C) and TRM 392R (site E) are in areas which have high capability for development for family boating activities and recreational lodging. Selection of one of these sites would result in a limited reduction in these potential recreation uses.

The site investigated on Chickamauga Reservoir at TRM 499L (site G) is less suited for recreation but could be used for limited development of facilities for boating and water contact sports. Selection of this site would have no appreciable effect on recreation uses in this area.

(3) Land use compatibility - Assessments of land use compatibility involved in constructing and operating a nuclear plant on each of the sites considered have been made. Present and projected uses of the areas surrounding the sites have been determined to identify potential conflicts. The following tabulation briefly describes some of the features considered in the assessments of sites C, E, and G.

(a) Site C - Most of the land on and around the site is very sparsely developed. Upstream, about 1.5 miles, some second-home development is occurring on the shoreline, and downstream about 2.5 miles, a major industry has located a plant. Development of the site for generating purposes would be generally compatible with projected land uses.

(b) Site E - This site contains and is adjacent to farmland with high potential for industrial development. Thus, use of this site for a nuclear plant would be compatible with present and projected land uses in the vicinity.

(c) Site G - No development is located near this site. However, it is just downstream and adjacent to the Hiwassee Island Game Management and Waterfowl Refuge Area which is of major importance to east Tennessee. The compatibility of the site with the continued existence of the wildlife refuge has not been determined. It is judged, however, that impacts of constructing a plant on this site would affect the refuge only during the construction period and no permanent damage to the refuge would result.

While some incompatibility has been identified, construction of a nuclear plant at any of the sites would not result in any significant impacts on long-term productivity of land of the areas involved. The largest amount of land involved are the transmission line rights of way. Where the transmission lines cross open fields or farmland, only minor restrictions are imposed. Where wooded areas are crossed, some benefits are realized by providing wildlife food and cover although some short-term forest products production may be adversely affected.

All sites are examined for archaeological and historical significance prior to any significant alteration of the site. This procedure may result in exploration of sites with archaeological and historical significance to an area and add to the knowledge of the history of the area.

(4) Impacts on fisheries and wildlife -

Studies of fish and other aquatic life inhabiting Gunterville and Chickamauga Reservoirs indicate that neither of these reservoirs is unique with regard to species populations.

A 1970 Chickamauga Reservoir fish population survey indicated on the basis of numbers 12 percent game fish, 55 percent rough fish, and 33 percent forage fish. Bluegill and other sunfish, largemouth bass, spotted bass, white crappie, and white bass dominated the game fish. Gizzard and threadfin shad were the dominant forage fish. Two species of buffalo and freshwater drum dominated the rough fish.

Results of recent surveys of fish populations in Gunterville Reservoir are presented in section 1.2 and appendix B. Results of the 1971 survey reveal considerable variation in the species composition of standing stocks, the variation being greater for young than for adult fish. Sites near, and especially immediately downstream from embayments (e.g., site E) can be expected to show large numbers of larval and young fish.

It is assumed that observance of EPA-approved water quality standards will adequately protect aquatic biota of these reservoirs. Consequently, releases from a nuclear plant at any site considered would not be expected to significantly affect aquatic resources of the area regardless of species population or distribution.

All of the sites considered are in the vicinity of wildlife management area or waterfowl refuge, the most significant one being site G which adjoins the Hiwassee Island Game

Management and Waterfowl Refuge. This refuge supports the largest concentration of geese in the valley region east of Wheeler Wildlife Refuge and is responsible for an annual hunter harvest of an estimated 2,000 to 5,000 geese per year. Some disturbance of wildlife inhabiting the nearby refuges or waterfowl using the areas seasonally would result during the plant construction period. The degree of this disruption cannot be predicted. However, after the major construction activities have ceased, the uses of the areas are expected to return to normal and the operation of a nuclear plant is not expected to significantly affect the wildlife of the areas.

5. Economic considerations - Cost estimates were prepared to establish cost differentials for constructing the proposed nuclear plant at sites C, E, and G. It was assumed that supplemental cooling facilities would be common to each of the sites; therefore, no cost differential was considered for supplemental cooling facilities. The analysis included the cost of access facilities, transmission connections, and site development. The transmission lines for each of the sites would be constructed in two steps which are coincident with the initial operation of units 1 and 2. Site-related costs are summarized in Table 4.2-2.

(1) Site C -

(a) Access facilities - U.S.

Highway 431 is about 16 miles from the site. An access road about 1,000 feet long would have to be constructed to connect the site with an improved light-duty road. About 3.8 miles of this road would have to be reconstructed. The remaining 12 miles of medium-duty road would

have to be improved, completing the connection of the plant site with U.S. 431.

An access railroad about 16.5 miles long and requiring two bridges would have to be constructed to connect the site with the existing L&N Railroad.

The cost of constructing access facilities to this site was estimated to be \$6.6 million.

(b) Transmission connections -

Step 1 would require unit 1 be connected to the 161-kV system. Under step 2, two 500-kV lines would be constructed which include a 36-mile line from the proposed plant site to Madison and a 37.7-mile line from the proposed plant site to TVA's existing Widows Creek Steam Plant.

The total cost of these connections is estimated to be \$14.66 million.

(c) Site development - With a

plant grade elevation of 616 feet, the excavation required would total 1.2 million cubic yards and the fill 1.0 million cubic yards. Rock is located approximately 30 feet below plant grade. The estimated cost of site development is \$3.5 million more than at site G which was estimated as a base.

(2) Site E -

(a) Access facilities - U.S.

Highway 72 is about 2.5 miles from the site. An access road about 4,000 feet long would have to be constructed to connect the site with an improved light-duty road. About 1.5 miles of this road would have to be reconstructed.

An access railroad 3.5 miles long would have to be constructed to connect the site with the existing Southern Railroad. The access railroad would have to cross U.S. Highway 72 which would most likely require a grade separation at that point.

The estimated cost of constructing access facilities to this site was estimated to be \$1.1 million

(b) Transmission connections -

System connections for the first Bellefonte unit would require that the existing Madison-Widows Creek 500-kV line and the Widows Creek-Scottsboro 161-kV line be looped into the plant site. Each 500-kV line would be 12.3 miles long for a total of 24.6 line-miles and the 161-kV loop totaling 2.4 miles. For the second generating unit, two 500-kV lines would be constructed. These 500-kV connections include a 19.9-mile line from the plant site to Widows Creek Steam Plant, and a 26-mile line from the plant site to Guntersville. The total cost of these connections is estimated to be \$11.99 million.

(c) Site development - With a plant grade elevation of 627 feet, the excavation required would total 0.8 million cubic yards and fill 0.4 million cubic yards. Rock is located about 20 feet below plant grade. The estimated cost of site development is \$1.0 million more than site G which was established as a base.

(3) Site G -

(a) Access facilities - Highway 60 passes near the plant site. Approximately 8 miles to the existing highway would require some maintenance for access to the site.

The nearest existing railroad is the Southern Railway 1 mile west of Charleston, Tennessee. Approximately 19 miles of railroad would be required for rail access to the plant site. Six bridges would be required--five over creeks and one over Interstate Highway 75. The cost of constructing access facilities to the site was estimated to be \$5.3 million.

(b) Transmission connections -

Step 1 would require the proposed Sequoyah-Watts Bar No. 1 500-kV line be looped into the plant site. The line passes 2 miles from the plant site, thus requiring 4 miles of line.

Step 2 would require the constructing of four 500-kV lines and two short 161-kV lines. The 500-kV connections include looping the Sequoyah-Franklin 500-kV line into the plant site a distance of 20 miles each, constructing a 49-mile line from the plant site to Raccoon Mountain, and constructing a 72-mile line from Widows Creek-Murphy Hill-Madison. The Sequoyah-Watts Bar 161-kV line would be looped into the plant site a distance of 6 miles each. The total cost of these connections is estimated to be \$25.575 million.

(c) Site development -

The excavation required would total about 0.3 million cubic yards and the fill about 0.5 million cubic yards. Rock is located 22 to 37 feet below plant grade. This site was estimated as a base for developing site development costs.

6. Conclusion - It was concluded that each of the three sites C, E, and G were suitable for a nuclear plant; however,

economic and environmental cost differences exist which make site E the preferred site for the proposed nuclear plant. As shown in Table 4.2-2, sites C and E have substantial economic advantage when compared to site G. In addition, as shown in Table 4.2-1, site G has greater potential for land use conflicts because of its close proximity to the Hiwassee Island Game Management and Waterfowl Refuge Area and requires the most extensive transmission and access facilities of any of the alternative sites. As a result of these considerations, site G was eliminated from consideration for locating the proposed plant.

Sites C and E are both on Guntersville Reservoir approximately 23 miles apart; therefore, many impacts would be very similar at each site. As shown in Table 4.2-2, site E has an economic advantage of approximately \$10.0 million. Site C requires the most extensive access facilities; but transmission facilities costs are less for site E. Both sites are relatively isolated with site E having a significantly smaller population within a 30-mile radius but a greater population within a 50-mile radius.

While land use plans indicate both sites (C and E) are compatible for use as a nuclear plant site, site E is in an area with no developed public recreation areas in the immediate vicinity of the site, and site C is located within 1.5 miles of some second-home development and within 3 to 5 miles of boat docks, private clubs, and a group camp.

When considering the economic advantage of site E along with the less extensive access facilities, lower populations within 30 miles of the site, and the greater land use compatibility, TVA selected site E, Bellefonte, as the preferred site for the proposed plant.

Table 4.2-1

SUMMARY OF SITE EVALUATION FACTORS

<u>Site</u>	<u>C</u>	<u>E</u>	<u>G</u>
1. Land Use (Acres)			
Total Site	700	1,500	1,100
Amount to be Purchased	375	1,260	900
2. Proximity to Populated Areas			
Nearest Town	Grant, Ala.	Hollywood, Ala.	Dayton, Tenn.
Distance - Miles	6	3	6
Population	382	865	4,361
Nearest City	Huntsville, Ala.	Huntsville, Ala.	Chattanooga, Tenn.
Distance - Miles	30	39	30
Population	137,802	137,802	119,082
Population			
5 miles	3,378	2,755	3,691
10 miles	13,112	18,405	16,768
20 miles	88,359	50,530	100,220
30 miles	223,524	106,860	287,274
40 miles	459,347	398,665	467,050
50 miles	653,925	837,658	683,226
3. Transmission Line Construction Required - Miles			
500 kV	72	70.5	165
161 kV	-	2.4	12
Number of River Crossings	4	3	6
4. Access Facilities			
Highway	Construct 1,000 ft Access Road	Construct 4,000 ft Access Road	Maintain 8 Miles of Highway
	Reconstruct 3.8 Miles of Road	Reconstruct 1.5 Miles of Road	
	Improve 12 Miles of Road		

Table 4.2-1  
(continued)SUMMARY OF SITE EVALUATION FACTORS

	<u>C</u>	<u>E</u>	<u>G</u>
Railroad			
Miles of Construction	16.5	3.5	19
Bridges	2	-	6
5. Site Grading - $10^6$ yd <sup>3</sup>			
Excavation	1.2	0.8	0.3
Fill	1.0	0.4	0.5
6. Land Use Compatibility	Second-home development 1.5 miles upstream. Major industry 2.5 miles downstream. Boat docks, private clubs, and group camps in vicinity of the site. Generally Compatible.	Site contains and is adjacent to farmland. No developed public recreation areas near the site. Compatible.	No intensive development near the site. Adjacent to a game management and waterfowl refuge. Generally Compatible Except for Possible Effect on Refuge During Construction.
7. Recreation	Limited Reduction in Recreational Activities.	Limited Reduction in Recreational Activities.	Limited Reduction in Recreational Activities.
8. Aesthetics	No Conflict.	No Conflict.	No Conflict.
9. Impacts on Fisheries and Wildlife			
Reservoir	Guntersville No Unique Species Population. No Significant Impact.	Guntersville No Unique Species Population. No Significant Impact.	Chickamauga No Unique Species Population. No Significant Impact.

Table 4.2-2


SUMMARY OF SITE-RELATED COSTS\*

(Thousands of 1972 Dollars)

<u>Item</u>	<u>C</u>	<u>E</u>	<u>G</u>
Access Facilities**			
Highway	1,600	250	100
Rail	5,000	850	5,200
Site Development	3,500	1,000	Base
Transmission System Connections	14,660	11,990	25,575
Land	<u>432</u>	<u>1,109</u>	<u>570</u>
Total Site-Related Cost	25,192	15,199	31,445
Difference	9,993	Base	16,246

\*Cooling facilities costs were judged to be comparable for same heat dissipation.

\*\*Barge facilities costs were judged to be about the same at each site.




4.2-34

**LEGEND**

Transmission lines in service	—————	115,161	69
Transmission lines authorized	- - - - -	238	0
Interconnection with other systems	—————	500 KV	345 KV
Substation or major switching station in service	▲		
Substation or major switching station authorized	△		
Hydro and thermal generating plants	★		
Hydro and thermal generating plants owned by others	○		
Approximate areas served by municipalities and cooperatives	■		
Retail distribution by municipalities	■		
Retail distribution by cooperatives	■		

**★ Sites Considered**  
**THE TVA POWER SYSTEM**






Figure 4.2-2  
 LOAD AND CAPACITY MAP  
 JANUARY 1980  
 Before Addition of Proposed Plant






Figure 4.2-3  
 LOAD AND CAPACITY MAP  
 SUMMER 1980  
 Before Addition of Proposed Plant



4.2-37







Figure 4.2-6  
 LOAD AND CAPACITY MAP  
 JANUARY 1980  
 Proposed Plant located in Area 3







Figure 4.2-8  
SITE G  
CUMULATIVE POPULATION STUDY







Figure 4.2-10  
SITE E  
CUMULATIVE POPULATION STUDY



Figure 4.2-11






Figure 4.2-12









Figure 4.2-13



## 5.0 SHORT-TERM USES VERSUS LONG-TERM PRODUCTIVITY

CEQ guidelines call for a discussion of the relationship between local short-term uses of man's environment and the maintenance and enhancement of long-term productivity. This requires an assessment of the construction and operation of the plant for cumulative and long-term effects from the perspective that each generation is trustee of the environment for succeeding generations.

In view of the foregoing environmental considerations, the immediate benefits to be derived from the initiation of this project should not noticeably curtail the long-range beneficial uses of the natural resources of the area. The cumulative effect of the plant will be the further localized shift of land usage to meet the demand for power.

There will be local short-term effects on the environment because of the construction of the facility. However, these effects will be minimized and will have no long-term effects on the environment. During operation there may be local short-term effects associated with radioactive, chemical, and thermal discharges. Releases of radioactive materials to unrestricted areas will be small fractions of the limits established in 10 CFR Part 20. Thermal and chemical discharges to the reservoir will be negligible.

Environmental monitoring programs will include the sampling and analysis of the air, water, aquatic life, and food web near the facility. This will provide a baseline inventory for detecting and evaluating any radiological impact which might lead to long-term effects in order that timely corrective action can be taken if required. Thus,

in the sense that each generation is trustee of the environment for succeeding generations, the plant will be constructed and operated in a manner to protect the environment so that succeeding generations will be enabled to attain full use of the environment.

## 6.0 IRREVERSIBLE AND IRRETRIEVABLE COMMITMENTS OF RESOURCES

The CEQ guidelines call for a discussion of any irreversible and irretrievable commitments of resources which would be involved in the construction and operation of the facility. This requires identifying the extent to which operation of the facility curtails the range of beneficial uses of the environment.

The construction and operation of the plant will involve the use of a certain amount of air, water, and land. Except for the site itself, the range of beneficial uses of the environment will not be curtailed and these are not irreversible. However, the site will continue to be dedicated to power production for the foreseeable future.

The annual requirement for natural uranium for each reactor is approximately 200 tons of  $U_3O_8$ . About 700 kilograms per year of  $U^{235}$  and about an equal amount of  $U^{238}$  will be consumed by each unit. Some of the uranium can ultimately be recycled for other uses. About 4,800,000 gallons of fuel oil will be required for the auxiliary boilers and diesel generators during tests. To the extent that this fuel is consumed and not subject to being recycled to other uses, it will be an irreversible and irretrievable commitment of resources. In addition to these resources, some byproducts which result from the operation of the plant must also be considered irreversible and irretrievable commitments of resources. These include damaged components which are radioactive, solid radwaste materials, and various chemicals which are used in the plant processes. Chemicals thus used will be widely dispersed to the environment and in most cases will have changed forms. Reclamation of these chemicals after discharge from the plant is impractical.

Since the ultimate disposition of the plant buildings and equipment has not been determined, it must be assumed that both land and construction materials will be irreversibly committed. It is unlikely, however, that more than the equipment and land directly in and beneath the reactor building will be ultimately irreversibly and irretrievably committed.

## 7.0 AGENCY REVIEW COMMENTS

Comments received from agencies that reviewed the draft environmental statement for Bellefonte and TVA's responses to these comments are contained in this section. The comments from each agency are identified by number in the margin of the page. Where the comments required responses, these responses are located behind each agency's letter of transmittal and are identified by number corresponding to the number identifying the agency comments.

The following is a list of the agencies that commented and their locations within this section.

<u>Agency</u>	<u>Section</u>
Advisory Council on Historic Preservation	7.1
Alabama Development Office	7.2
Atomic Energy Commission	7.3
Department of Agriculture	7.4
Department of Army	7.5
Department of Commerce	7.6
Department of Health, Education and Welfare	7.7
Department of Housing and Urban Development	7.8
Department of Interior	7.9
Department of Transportation	7.10
Environmental Protection Agency	7.11
Federal Power Commission	7.12
Responses to Mr. William E. Garner's comments on the proposed and alternate access railroad routes	7.13

**ADVISORY COUNCIL  
ON  
HISTORIC PRESERVATION**

WASHINGTON, D.C. 20240

April 30, 1973

Mr. F.E. Gartrell  
Director of Environmental Planning  
Tennessee Valley Authority  
Chattanooga, Tennessee 37401

Dear Mr. Gartrell:

This is in response to your request of March 6, 1973, for comments on the environmental statement for the Bellefonte Nuclear Plant project. Pursuant to its responsibilities under Section 102(2)(C) of the National Environmental Policy Act of 1969, the Advisory Council on Historic Preservation has determined that your draft environmental statement appears procedurally adequate, however, we have the following substantive comments to make:

A copy of the historical research report to be prepared by the University of Alabama at Birmingham should be sent to the Advisory Council upon completion, and should be included in the final environmental statement. Provided that this report indicates no sites of historic importance related to the town of Bellefonte or to Jackson County history, and provided that the vestiges of the town (the ca. 1845 tavern, the old stagecoach road, and the courthouse cistern) are undisturbed by construction of the plant facility, the Advisory Council has no further comment.

1

We wish to commend your discussion of historical, architectural, and archeological resources in the area of the plant site.

Sincerely yours,

  
Ken Tapman  
Compliance Officer

1. The contract for the historical investigation of the old town Bellefonte has not been finalized at this time. When the investigation is made and the report submitted to TVA, a copy will be transmitted to the council. See also the response to Department of the Interior comment No. 7.



STATE OF ALABAMA  
ALABAMA DEVELOPMENT OFFICE

May 28, 1973

R. C. "Red" Bamberg  
Director

W. M. "Bill" Rushton  
Assistant Director

George C. Wallace  
Governor

TO: Mr. M. I. Foster, Director  
Division of Navigation Development  
Regional Studies  
Tennessee Valley Authority  
Knoxville, Tennessee 27902

FROM: *Michael R. Amos*  
Michael R. Amos  
State Clearinghouse  
Policy Studies Division

SUBJECT: DRAFT ENVIRONMENTAL IMPACT STATEMENT

Applicant: Tennessee Valley Authority

Project: Draft Environmental Impact Statement  
for the Bellefonte Nuclear Plant  
in Jackson County

State Clearinghouse Control Number: ADO-13-73

The Draft Environmental Impact Statement for the above project has been reviewed by the appropriate State agencies in accordance with Office of Management and Budget Circular A-95, Revised.


The comments received from the reviewing agencies are attached.

Please contact us if we may be of further assistance. Correspondence regarding this proposal should refer to the assigned Clearinghouse Number.

Attachments

A-95/05

cc: Agencies contacted for comments:  
Conservation and Natural Resources  
Geological Survey of Alabama  
Top of Alabama Regional Council of Governments  
Alabama Development Office - Hyde

REQUEST FOR REVIEW OF ENVIRONMENTAL IMPACT STATEMENT

TO: Mr. Philip LaMoreaux  
Geological Survey of  
Alabama

CH Number

ADO-13-73

Applicant

Tennessee Valley Authority

Program

Draft Environmental Impact  
Statement for the Bellefonte Nuclear  
Plant in Jackson County

DATE: March 12, 1973

Return Prior to: As soon as possible  
Date

Please review the attached environmental impact statement and indicate your comment with respect to any environmental impact involved.

Comments: (Please check one block.)

- No comment (Environmental impact statement is in order and no additional comments are offered.)
- Comments (Elaborate below.)

Comment here:

The environmental impact statement for the Bellefonte Nuclear Plant in Jackson County is a very comprehensive one. However, the category of oil and gas potential was treated too lightly. The proposed plant site is situated on the Sequatchie anticline, a very positive geologic feature which has sharply folded Paleozoic sediments. It is the opinion of the Alabama Geological Survey that the Cambro-Ordovician sediments which underlie this area do possess good potential for production of oil or gas. This need not be a negative point, because if the subsurface in this region is proven productive of oil or gas, the area underlying the plant very possibly could be drained by a well outside of the plant area or the oil test well could be directionally drilled to tap the underlying hydrocarbons.

There are no coal deposits at the immediate plant site. The only coal that occurs in the vicinity underlie the cap rock of adjacent plateau areas. The nearest being approximately 1 mile east.

Signature

A handwritten signature in cursive script, appearing to read "Philip LaMoreaux".

Please Return Original to:

Alabama Development Office  
Office of State Planning  
State Clearinghouse  
State Office Building  
Montgomery, Alabama 36104

FORM CH-2a  
8/71

REQUEST FOR REVIEW OF ENVIRONMENTAL IMPACT STATEMENT

TO: Mr. Reynolds W. Thrasher  
Conservation and Natural  
Resources

CH Number ADO-13-73

Applicant Tennessee Valley Authority

Program Draft Environmental Impact  
Statement for the Bellefonte Nuclear  
Plant in Jackson County

DATE: March 12, 1973

Return Prior to: As soon as possible  
Date

Please review the attached environmental impact statement and indicate your comment with respect to any environmental impact involved.

Comments: (Please check one block.)

- No comment (Environmental impact statement is in order and no additional comments are offered.)
- Comments (Elaborate below.)

Comment here:

*See attached from Lane & Fish this*



*[Handwritten Signature]*  
\_\_\_\_\_  
Signature

Please Return Original to:

Alabama Development Office  
Office of State Planning  
State Clearinghouse  
State Office Building  
Montgomery, Alabama 36104

FORM CH-2a  
8/71

*File*

7.2-4  
STATE OF ALABAMA  
DEPARTMENT OF CONSERVATION AND NATURAL RESOURCES

64 North Union Street - Montgomery, Alabama 36104

GEORGE C. WALLACE  
GOVERNOR  
LAUDE D. KELLEY  
COMMISSIONER  
DNEY B. BLEDSON  
STANT COMMISSIONER

March 29, 1973

DIVISION OF GAME and FISH  
CHARLES D. KELLEY, DIRECTOR

MEMORANDUM

TO: Mr. Charles D. Kelley, Director  
Game and Fish Division

FROM: Ralph H. Allen, Jr., Chief *Ralph H. Allen Jr.*  
Game Management Section

SUBJECT: Review and Comments on the Draft Environmental Impact  
Statement Prepared by TVA on the Bellefonte Nuclear  
Plant in Jackson County

I do not have sufficient knowledge of nuclear physics to comment on the technical aspect of this statement. The statement uses the following to justify the plant on aquatic effects.

"It is assumed that observance of EPA approved water quality standards will adequately protect aquatic biota of these reservoirs. Consequently, releases from a nuclear plant at any site considered would not be expected to significantly affect aquatic reservoirs of the area regardless of species population or distribution."

The report does point out that there will be some adverse effects on Guntersville Lake as the result of siltation from ground excavations. The report also indicates some adverse effect on waterfowl resulting from disturbances during construction of the plant itself.

Monitoring of plant, animal and fish life will be carried out at periodic periods.

The statement has a cover-all which states: "If any significant adverse effects attributable to the construction or the operation of the plant become evident or through the various environmental monitoring programs are shown to be inimicable to Section 101(b) goals, appropriate steps will be taken to correct the situation."

MEMORANDUM

Mr. Charles D. Kelley

March 29, 1973

Page 2

I personally feel that the impact statement should contain a clause whereby TVA assumes full responsibility for mitigating in full any damages to fish and wildlife resources which may result from the project.

1

RHA:rlc

1. NEPA requires that environmental amenities and values be given appropriate consideration in decision making along with economic and technical considerations. Decision making with respect to the construction of the Bellefonte Nuclear Plant is the subject of this environmental statement. Our analysis has shown that no significant damage to the environment is to be expected. Should unexpected damage occur, TVA will decide on a course of action utilizing the appropriate decision-making procedure as required by NEPA.

It should be pointed out that NEPA in section 102(2)(c)(ii) recognizes that there may be adverse environmental effects from a project which cannot be avoided. In view of this and the insignificant impacts reasonably expected, it would not be appropriate for TVA to attempt to mitigate, in full, adverse environmental effects which are unavoidable or insignificant.

7.3-1

UNITED STATES  
ATOMIC ENERGY COMMISSION  
WASHINGTON, D.C. 20545



APR 23 1973

Dr. F. E. Gartrell  
Director of Environmental  
Planning  
Tennessee Valley Authority  
Chattanooga, Tennessee 37401

Dear Dr. Gartrell:

In response to your March 6, 1973, letter requesting comments on the TVA draft environmental statement on the Bellefonte Nuclear Plant, we will not comment or take other action until we receive your application for a Construction Permit. The nature of our action at that time will depend on subsequent agreements between our agencies.

Sincerely,

A handwritten signature in cursive script that reads "Daniel R. Muller".

Daniel R. Muller, Assistant Director  
for Environmental Projects  
Directorate of Licensing

TVA filed the application for a construction permit and its preliminary safety analysis report for the Bellefonte Nuclear Plant on May 14, 1973. In accordance with the Atomic Energy Commission's regulation 10 CFR Part 50, Appendix D, the AEC Directorate of Licensing commenced its review and in February 1974 issued a draft statement on the environmental considerations associated with the proposed issuance of a construction permit for the plant.



DEPARTMENT OF AGRICULTURE  
OFFICE OF THE SECRETARY  
WASHINGTON, D. C. 20250

APR 24 1973

Dr. F. E. Gartrell  
Director of Environmental Planning  
Tennessee Valley Authority  
Chattanooga, Tennessee 37401

Dear Dr. Gartrell:

We have had the draft environmental statement for the Bellefonte Nuclear Plant reviewed in the relevant agencies of the Department of Agriculture, and comments from Soil Conservation Service, an agency of the Department, are enclosed.

Forest Service, also an agency of the Department, informs us it has already sent its comments to TVA.

We are sending a copy of this letter, with enclosure, to the Director, Directorate of Regulatory Standards, Atomic Energy Commission, Washington, D. C. 20545, as requested.

Sincerely,

A handwritten signature in cursive script that reads "T. C. Byerly".

T. C. BYERLY  
Coordinator, Environmental  
Quality Activities

Enclosure

Soil Conservation Service, U.S.D.A., Comments on Draft Environmental Statement prepared by Soil Conservation Service in Tennessee for the Bellefonte Nuclear Plant.

This agency's concern is how well erosion is controlled and siltation avoided during and after construction. Erosion control practices as described on page 2.2-10 for transmission line construction are adequate. Siltation control measures to be applied during general grading for both the construction plant area and the permanent plant area as described on pages 2.7-6 to 9 will minimize the off-site and on-site siltation problem.

UNITED STATES DEPARTMENT OF AGRICULTURE  
FOREST SERVICE  
Southeastern Area, State & Private Forestry  
1720 Peachtree St, N.W. - Room 704  
Atlanta, Georgia 30309

1940

March 27, 1973



F  
L  
F.E. Cartrell, Ph.D.  
Director of Environmental Planning  
Tennessee Valley Authority  
Chattanooga, Tennessee 37401

The Draft Environmental Statement - Bellefonte Nuclear Plant, Jackson County, Alabama has been reviewed by the Resource Use and Management Unit of the Southeastern Area.

The statement adequately describes effects to the forest resources and possible effects of proposed activity on them.

Since a very large area will be modified by transmission lines, the impacts on forests will be significant. TVA outlines in the report, several practices to minimize this impact. If implemented, they will actually improve habitat for certain species of wildlife. We think they've done a good planning job to minimize damages to the forest resource.

Thank you for the opportunity of reviewing this statement.

*James E. Hefner*  
for FREDERICK W. HONING  
Area Environmental Coordinator



**DEPARTMENT OF THE ARMY**  
**NASHVILLE DISTRICT, CORPS OF ENGINEERS**  
 P. O. BOX 1070  
 NASHVILLE, TENNESSEE 37202

IN REPLY REFER TO  
 ORNED-P

20 April 1973

Dr. F. E. Gartrell  
 Director of Environmental Planning  
 Tennessee Valley Authority  
 Chattanooga, Tennessee 37401

Dear Dr. Gartrell:

Reference is made to your letter of 6 March 1973 forwarding a copy of the draft environmental impact statement for the proposed Bellefonte Nuclear Plant in Jackson County, Alabama, for our review and comments.

Beginning on page 2.2-1 of the draft statement a somewhat detailed discussion of the right-of-way requirements for transmission lines is presented. Evidently it is proposed to shear clear the entire length of right-of-way. As stated in the EIS, the "edge effect" resulting from this type clearing procedure does have many advantages; however, it is only logical that in some cases the shear clearing method will have disadvantages. The possibility of only minimal clearing for tower and line construction with no future clearing or chemical treatment should not be overlooked. This alternate method, which has been accomplished in the Nashville area by increasing the height of a few towers along the proposed route, could be applied to selected forested areas, highway crossings, stream or river crossings, and places of steep grade. The enhancement of wildlife habitat is judged within the statement to be an incidental beneficial consequence of the shear clearing method. It would be helpful if the areas along the right-of-way that are to be managed specifically for wildlife habitat were delineated, and to discuss and illustrate the areas which will require periodic chemical treatment. This delineation would enable reviewers of the statement to better judge the degree of impact (both favorable and adverse) associated with these two aspects. The plan delineating these areas would be even more beneficial if land use, vegetative cover, areas to be spanned, and, as mentioned in the statement, areas which could be used for growing Christmas trees and nursery stock were also depicted.

In section 4.1, Alternative Generation, the question of obtaining an adequate energy supply was discussed for several different alternative

1

2

ORNED-P

20 April 1973

Dr. F. E. Gartrell

methods of power production. It would appear to be appropriate to include a discussion in this section concerning the adequacy of the supply of pitchblende ( $U_3O_8$ ), the raw material for the type uranium to be used in the proposed plant. 2

It is stated on page 4.2-28 that no aesthetic conflicts will be associated with the proposed nuclear plant. Almost any structure, and especially one as large as that proposed, will conflict with the existing, relatively undeveloped landscape. The presence alone of such a structure should be considered a detriment to the visual integrity of the area. 3

On page B1-6 of the EIS (next to last paragraph) the manner by which the estimated weight of each species was calculated may read better if the sentence is modified to, "The estimated total weight by species harvested, etc. . . ." 4

On page B2-12, it is indicated that the existence of the Small-Mouthed Salamander in the area of the plant is considered uncertain. A determination as to whether or not this species exists in the project area should be made, and if so, what effect the proposed powerplant would have on it. 5

It should be noted that not all shoreline development serves as an enhancement to habitat diversity; therefore, it may be proper to identify the type of shoreline development, as referred to on page B4-5, that has evidently enhanced the aquatic habitat. 6

On page H-11, fish ova are included among the list of benthic organisms that may receive high doses of radioactivity. While the spawn of various species of fish may be exposed to radioactivity, we question the propriety of the arbitrary classification of fish ova as benthos. Briefly defined, the benthos community is composed of all those animals and plants living on the bottom of a lake or sea. Since the ova and spermatozoa of fish, or any other plant or animal gametes, are reproductive cells and do not represent the culmination of embryological development (which the organism releasing these gametes does), we feel that this classification may be erroneous. Also, not all fish eggs are demersal, as some (depending upon the species) may be attached to rooted aquatics or be semi-buoyant, and thus suspended above the substrate. 7

The following words were misspelled in the text of the draft EIS: Page B1-1, herbivorous; page B1-9, notatus; page B1-10, Sciaenidae; page B2-6, Sport; and page B3-18, Smilax. 8

ORNED-P  
Dr. F. E. Gartrell

20 April 1973

The opportunity to review the draft statement is appreciated.

Sincerely yours,

*For WILLIAM F. BRANDES, MAJOR, CE*  
WM. F. BRANDES  
Colonel, Corps of Engineers  
District Engineer

CF:  
Director  
Directorate of Regulatory Standards  
Atomic Energy Commission  
Washington, D.C. 20545

1. As stated on page 2.2-7, shear clearing will be performed only where transmission line routes traverse heavily wooded areas. Other open areas to be crossed will require no clearing except the occasional removal of existing tall trees or fast growing tree species located in hedge rows or scattered thickets and breaks. Of the 1,550 acres of right of way required for this project, only 750 acres are heavily wooded.

Although specific clearing plans for the proposed routes will not be formulated until the rights of way are surveyed and easements are obtained, TVA generally plans to implement several alternate clearing methods for sections of the Bellefonte-Widows Creek No. 2 and the Bellefonte-Guntersville 500-kV transmission lines. Portions of these lines will be constructed several years in advance of the nuclear plant operation. The costs and benefits of these trial clearing actions will be evaluated to determine preferred practices to be utilized for the remaining line construction for this project. The test clearing methods will include: (1) selective tree removal with spot applications of herbicides to control regrowth; and (2) localized use of tall towers to eliminate vegetation removal at river crossings, road crossings, and on some extreme slopes. (For additional discussion of tall tower uses refer to TVA Responses to AEC's Comments on Bellefonte Draft Environmental Statement - comment number 18.)

TVA will acquire the right to construct the proposed transmission lines across public and private property by means of an easement rather than purchase the property in fee. Under the terms of the easement, the landowner retains control of the property and may utilize it for a multitude of purposes as long as these uses do not interfere with the construction, maintenance, and safe operation of the transmission line. As such, private landowners often utilize the cleared area under the transmission line for pasture or growing a variety of crops. Consequently, TVA cannot establish wildlife management programs on these private lands. However, where consistent with landowner's plans, rights of way in wooded areas are planted with grasses of low-growing vegetation to improve habitat and food conditions for selected wildlife species. As an educational tool, TVA in cooperation with the Tennessee Game and Fish Commission has published a booklet for distribution to landowners in the TVA service area describing practices which may be employed to benefit various wildlife species on their property.

Where the transmission line corridors cross public lands, specific wildlife management programs are frequently developed jointly by TVA and the public agency controlling the property. For the proposed transmission line connections to Bellefonte Nuclear Plant, just such an undertaking is planned for a section of the Bellefonte-Widows Creek No. 2 line. Approximately 10.5 miles of this line will

be located within and parallel to the boundary of the Raccoon Creek Waterfowl Management Area. As agreed to with the State of Alabama Department of Conservation and Natural Resources - Division of Game and Fish, this right of way will be seeded following construction with a mixture of Kentucky 31 Fescue and White Clover. The treated area will be fertilized and maintained in a permanent fescue and clover sod, except where it is presently planted in row crops and/or rented to cooperative farmers. In these locations, sacrificial grain crops will be continued. (For additional discussion of wildlife habitat management, refer to TVA Responses to Second Set of AEC Comments on Bellefonte Draft Environmental Statement - responses 56 k and 56 l.)

The progressive steps required to develop plans for the construction of relatively long transmission lines often make it impossible to address specific elements of the construction and maintenance program in the earliest stages when the environmental statement is prepared. When this occurs, general program procedures are described to delineate anticipated actions. As in the matter of chemical maintenance of rights of way for the proposed transmission lines, it was stated that TVA utilizes various chemicals as one method of controlling vegetation regrowth that could jeopardize reliable operation of the transmission lines. Except for the direct application of chemicals to be used with the selective clearing tests for the initial transmission line sections, it is estimated that less than 5 percent of the other proposed transmission line right of way will be studied for possible chemical treatment. However, until the actual line routes have been surveyed and formally identified, specific chemical treatment plans cannot be established.

During the fiscal year ending June 30, 1971, a transition was made in TVA's right of way maintenance program from essentially complete herbicide control to primarily mechanical maintenance. Chemical maintenance is now limited to those areas which are both remote and inaccessible. Annually, 1.5 to 2 percent of all existing transmission line rights of way in the TVA service area are chemically maintained. It is anticipated that substantially less chemical treatment will be utilized on transmission lines to be constructed in the future. Further evidence of TVA's concern for the proper use of herbicides is reflected in TVA's curtailment of the use of 2, 4, 5-T esters for right of way maintenance because of the unresolved questions raised by the Environmental Protection Agency as to the long-term effects which may result from the use of these chemicals.

2. This question concerns a step in the fuel cycle that is not within the scope of this environmental statement. An extensive discussion of fuel resources is contained in Nuclear Fuel Supply (WASH-1242), Nuclear Fuel Resources and Requirements (WASH-1243), and related AEC publications.

3. Aesthetic impact is difficult to judge, for what is pleasing to one is an adverse impact to another. The plant will have an impact on the general area but not a conflict. The impact will be minimized through preservation of the natural growth and topographical features and well designed landscaping. The architectural design will consider the relationships of the masses and diverse physical forms in the complex, to provide a progression of small to large volumes, thus reducing the visual magnitude of the project to a comprehensible human scale.
4. This change has been made in the text.
5. The small-mouthed Salamander (Ambystoma texanerm) is found throughout the lower midwest from Indiana and Ohio to the Gulf Coast, west through Missouri and Arkansas, and east through the bluegrass region of Kentucky. The eastern extent of this species distribution barely touches the Jackson County area of Alabama.<sup>1</sup> While the species is not abundant in Alabama (personal communication with Dr. Robert Mount of Auburn University), it is not listed as a rare or endangered species<sup>2</sup> by the Alabama Department of Conservation and Natural Resources. We feel that a special search for this animal in light of the above information would not be practical. It is neither endangered nor would it likely be found in the plant site environs.
6. This comment is not within the context of the statement on B4-5. The statement refers to the naturally undulating shoreline or shoreline development in the limnological sense and not to manmade shoreline development such as structures, etc. The presence of macrophytes in shallow water in the vicinity of the Bellefonte site provides habitats for shoreline organisms, but it should not necessarily be construed as enhancement.
7. The ova in question are truly benthypelagic and as such fit well into the definition of the benthic community as given by Hutchinson in A Treatise on Limnology, Volume 2, pages 236-239. Ova can be considered as a part of the life cycle as an organism. While all fish eggs are not demersal, those that we are particularly concerned with are, in as much as we have noted only one bouyant egg type for the Tennessee River, that of the freshwater drum.
8. The typographical errors mentioned have been corrected in the text.

- 
1. Roger W. Barbour, 1971, Amphibians and Reptiles of Kentucky, University of Kentucky Press.
  2. Rare and Endangered Vertabrates of Alabama, 1972, Alabama Department Of Conservation and Natural Resources, Division of Game and Fish.



THE ASSISTANT SECRETARY OF COMMERCE  
Washington, D.C. 20230

April 6, 1973

Dr. F. E. Gartrell  
Director of Environmental Planning  
Tennessee Valley Authority  
Chattanooga, Tennessee 37401

Dear Dr. Gartrell:

The draft environmental impact statement for Bellefonte Nuclear Plant, which accompanied your letter of March 6, 1973, has been received by the Department of Commerce for review and comment.

The Department of Commerce has reviewed the draft environmental statement and has the following comments to offer for your consideration.

With regard to the cumulative warming effect on the river from the 30 or so TVA plants, we find a void. We understand that the Bellefonte Nuclear Plant's closed-cycle heat dissipation system will result in only a slight increase in water temperature of the river in that immediate vicinity. However, we feel that to make any valid long term evaluation of any amount of river warming and associated impacts, all environmental statements should include a model or study providing an appraisal of the total warming effect from all existing facilities in addition to the subject power plant rather than treating each project as a separate entity.

Also, in the draft environmental statement section dealing with alternative heat dissipation facilities (2.6-16,17), TVA explains that the dry cooling tower system is impractical because of severe engineering performance requirements on the turbines, etc. However, because of the potential environmental

1

2

advantages of such a system, we feel TVA should study this alternative further in light of the recent study titled "Research on Dry-Type Cooling Towers for Thermal Electric Generation for the Water Quality Office, EPA, November, 1970," which states manufacturers could supply dry cooling towers - matched to turbines and condensers - for the large nuclear power plants now being designed.

2

The period of release of radioactive gases to the free atmosphere during routine operations is not clear from the discussion starting on page 2.4-20. For example, the waste decay tanks, which eventually release half the noble gases and a third of the radioiodine are stated to operate on a 60-day filling and 60-day decaying cycle. This would appear to mean 6 releases per year. If each release occurred over a 24-hour period, the total release period would be 6 days per year. For such a release method, the average annual dispersion factor discussed in Appendix I is not appropriate.

3

We hope these comments will be of assistance to you in the preparation of the final statement.

Sincerely,

  
Sidney R. Galler  
Deputy Assistant Secretary  
for Environmental Affairs

1. While TVA believes that the potential for a cumulative warming effect on the Tennessee River from TVA steam plants may be an appropriate area for study, we do not agree that this should be included in every environmental statement in view of the remote and speculative nature of any cumulative effects. TVA agrees with the AEC Atomic Safety and Licensing Appeal Board, which has stated that the National Environmental Policy Act of 1969 (NEPA) and the AEC's regulations do not require a discussion of existing plants unless they have some demonstrated relationship or contact with the project under consideration. Wisconsin Electric Power Co. (Point Beach Nuclear Plant, Unit 2), ALAB-137, RAI-73-7, 491, 495 (July 17, 1973). Moreover, neither NEPA nor the AEC's regulations mandate the quantification of an environmental effect which is found to be insubstantial. Consumers Power Co. (Midland Plant, Units 1 and 2) ALAB-123, RAI-73-5, 331, 351, (May 18, 1973); Cf City of New York v. United States, 344 F. Supp. 929, 935 (E.D.N.Y. 1972); EDF v. Corps of Engineers, 325 F. Supp. 745, 758 (E.D. Ark. 1971), aff'd 470 F.2d 289 (8th Cir. 1972).

It should be noted that a permit issued by the Environmental Protection Agency (EPA) under section 402 of the Federal Water Pollution Control Act Amendments of 1972 (FWPCA) will be required for discharge of heated water from Bellefonte Nuclear Plant and other TVA steam plants. TVA believes that such permits issued by EPA pursuant to the FWPCA will not only assure adequate protection of aquatic life in the vicinity of the Bellefonte plant, but will also protect against any potential cumulative impacts.

2. The referenced study lists as one of its conclusions that "Turbine manufacturers are currently performing research on a new line of utility turbines especially designed for high backpressure operation and are also studying the feasibility of modifying present designs to operate at the high backpressure that will be encountered with dry-type cooling tower operation." The body of the document makes clear that turbines for dry cooling tower applications were not then commercially available for even 1,200-MW fossil-fired units. Development of turbines for nuclear units of that MW size is even more remote.

Since the decision must be based on the equipment which is commercially available to meet the required schedule, it is concluded that dry cooling towers are not a viable alternative heat dissipation method for Bellefonte. We are, however, presently in the process of obtaining the latest information from turbogenerator vendors, and will continue to study the situation.

It should be noted that the AEC has determined many times that dry cooling towers are not yet economically available and are not considered a viable alternative at this time. See, for example, the AEC final environmental statements on the following plants.

- Bailly Generating Station, Nuclear 1, pp. XI-5, 6  
(Feb. 1973), Docket No. 50-367
- Beaver Valley Power Station, Unit 1, pp. 9-9, 10  
(July 1973), Docket No. 50-334
- Catawba Nuclear Station, Units 1 and 2, p. 9-24  
(Dec. 1973), Docket Nos. 50-413, 414
- Crystal River, Unit 3, p. 11-5 (May 1973), Docket  
No. 50-302
- Diablo Canyon, Units 1 and 2, p. 12-14 (May 1973)  
Docket Nos. 50-275, 323
- Dresden Nuclear Power Station, Units 2 and 3,  
p. 9-5 (Nov. 1973), Docket Nos. 50-237, 249
- Duane Arnold Energy Center, p. 10-1 (March 1973),  
Docket No. 50-331
- Edwin I. Hatch Nuclear Plant, Units 1 and 2,  
p. XI-6 (Oct. 1972), Docket Nos. 50-321, 366
- Fort St. Vrain Nuclear Generating Station,  
p. XI-4 (Aug. 1972), Docket No. 50-267
- Grand Gulf Nuclear Station, Units 1 and 2, p. 9-26  
(Aug. 1973), Docket Nos. 50-416, 417
- Joseph M. Farley Nuclear Plant, Units 1 and 2,  
pp. XI-7,9 (June 1972), Docket Nos. 50-348, 364
- Indian Point Nuclear Generating Plant, Unit No. 2,  
p. XI-13 (Vol. 1) (Sept. 1972), Docekt No. 50-247
- Limerick Generating Station, Units 1 and 2, p. 11-1  
(Nov. 1973), Docket Nos. 50-352, 353
- R. E. Ginna Nuclear Power Plant, Unit 1, p. 9-5  
(Dec. 1973), Docket No. 50-244
- St. Lucie Plant, Unit No. 1, p. XI-8 (June 1973),  
Docket No. 50-335

3. The periods for release of radioactive gases from the Bellefonte Nuclear Plant are listed below for systems a-h discussed on pages 2.4-20 through 2.4-23 of the Bellefonte Draft Environmental Statement, Volume 1.

- a. Containment Purge - In the Bellefonte Draft Environmental Statement, it was conservatively assumed that there would be 24 containment purges for the two units per year. A more realistic estimate is 8 containment purges for the two units per year. A purge would be completed in about 8 hours.
- b. Instrument Room Purge - There will be about 50 instrument room purges for the two units per year. A purge would be completed in about two hours.
- c. Release Through Auxiliary Building Ventilation System - Releases from this system are continuous.
- d. Waste Gas Decay Tank Venting - It is assumed that there will be six gaseous decay tank ventings for the two units per year. Venting of gas decay tank would be completed in about 9 hours. It is expected that a period of approximately 7 days following the 60-day holdup period will be available to select optimum meteorological conditions for release of the tank contents.
- e. Steam Leakages - Releases from this source are continuous.
- f. Turbine Gland Sealing System Leakages - Releases from this source are continuous.
- g. Condenser Offgas - Releases from this source are continuous.
- h. Feedwater Leakage - Releases from this source are continuous.

From the aforementioned listing, it can be seen that some fraction of the annual gaseous discharges is released continuously while the remaining fraction is released at periodic intervals. Applying the average-annual dispersion factor to the periodic releases from the plant has the effect of averaging the concentration of radioactive gases to which an individual may be exposed as a result of several periodic releases. It is our judgment that such averaging is appropriate in preparing a realistic estimate of the impact of operation of a nuclear plant during its projected operating life (35 years for the Bellefonte Nuclear Plant), especially considering the commitment by TVA in the draft environmental statement to conduct periodic releases from the plant during favorable meteorological conditions.<sup>2</sup> It is of interest to note that the AEC performed all dose calculations for routine gaseous effluents "using annual-average site meteorological conditions and assuming that releases occur at a constant rate,"<sup>3</sup> in their Bellefonte Draft Environmental Statement.

## REFERENCES FOR SECTION 7.6

1. A projection of the environmental effects of the operation of the plant during the plant lifetime is called for in Chapter 5 of Regulatory Guide 4.2.
2. See page 2.4-15 of the Bellefonte Draft Environmental Statement and the response to AEC comment 22 in the document entitled "TVA Responses to AEC's Comments on Bellefonte Draft Environmental Statement."
3. See section 5.3.2.3, page 5-14, of the AEC Draft Environmental Statement for Bellefonte.



DEPARTMENT OF HEALTH, EDUCATION, AND WELFARE  
 REGION IV  
 50 7TH STREET N.E.  
 ATLANTA, GEORGIA 30323

OFFICE OF THE  
 REGIONAL DIRECTOR

April 3, 1973

RE: 253-3-73

Dr. F. E. Gartrell  
 Director of Environmental Planning  
 Tennessee Valley Authority  
 Chattanooga, Tennessee 37401

Dear Dr. Gartrell:

Subject: Bellefonte Nuclear Plant  
 Bellefonte, Alabama

We have received a copy of your Draft Environmental Statement for the subject project.

We have reviewed the data submitted and find that this plant should not have an adverse effect on the environment when it is in operation. We note that TVA does much of its own construction and this fact should help to eliminate pollution during construction. The plant site will not require the relocation of any families or businesses. We note that TVA will do all in its power to eliminate problems due to the large temporary construction work force in this relatively rural area.

We note that the exact location of the transmission lines has not as yet been decided upon, therefore, we do not know the effect of these lines on the environment.

Sincerely yours,

*James E. Groschelle*  
 Frank J. Groschelle  
 Regional Director

cc: Ms. J. McCoy  
 Mr. Paul Cromwell  
 Director, Directorate of  
 Regulatory Standards



DEPARTMENT OF HOUSING AND URBAN DEVELOPMENT  
 AREA OFFICE  
 DANIEL BUILDING, 15 SOUTH 20TH. STREET, BIRMINGHAM, ALABAMA 35233

AREA OFFICES:  
 Atlanta, Georgia  
 Birmingham, Alabama  
 Columbia, South Carolina  
 Greensboro, North Carolina  
 Jackson, Mississippi  
 Jacksonville, Florida  
 Knoxville, Tennessee  
 Louisville, Kentucky

March 21, 1973

REGION IV  
 REGIONAL OFFICE  
 ATLANTA, GEORGIA

IN REPLY REFER TO:

4.2PP

Mr. F. E. Gartrell  
 Tennessee Valley Authority  
 Chattanooga, Tennessee 37401

RE: Bellefonte Nuclear Plant

Dear Mr. Gartrell:

SUBJECT: Request for HUD Comments on Draft Environmental Impact Statement

We are pleased to acknowledge receipt of the above referenced request for HUD comments under the requirements of the National Environmental Policy Act of 1969 (PL 91-190).

We have reviewed the information submitted along with your referral and, to the extent of our available staff resources, have investigated the environmental impact, adverse effects, alternatives, short-term uses of the local environment and long-term productivity and irreversible and irretrievable commitment of resources which the project involves. From the information available to us, we find no basis for formal comment because of special HUD interest or expertise. However, we would call your attention to the areas indicated on the attached "HUD Comments on Draft Environmental Impact Statement" which we feel would assist your agency in the evaluation and execution of this project.

Should further clarification of our review be deemed necessary, please contact Mr. Peter W. Field, Director, Operations Division, #15 South 20th Street, (Daniel Building - Sixth Floor), Birmingham, Alabama 35233 at (205) 325-3697.

Sincerely,

Raymond M. Sherry  
 Assistant Director of Operations  
 Planning and Relocation

DHUD COMMENTS ON DRAFT  
ENVIRONMENTAL IMPACT STATEMENT

Project Identification:

Belleville  
Nuclear Plant

Project Location:

JACKSON COUNTY ALABAMA

The following includes the general caveats and remarks which we feel should be brought to the attention of any State, local or Federal agency which has requested DHUD review of and comment on a draft Environmental Statement under the Environmental Policy Act of 1969 and the CEQ Guidelines. We have checked those comments which seem to be particularly applicable to the draft statement identified above; however the letter of transmittal will amplify these general comments if appropriate.

COMMENTS

- Inasmuch as HUD has no direct program involvement in Historic sites or structures effected by the subject project, we defer to the Advisory Council on Historic Preservation with respect to Historic Preservation matters.
- HUD has direct program involvement in the Historic Preservation aspects of the proposed project and appropriate comment is included in the transmittal letter.
- The subject project effects an urban park or recreational area and appropriate comment is included in the transmittal letter.
- The subject project effects only rural parks and recreational areas and HUD therefore defers to the Forest Service of the Department of Agriculture, the Bureau of Outdoor Recreation, Bureau of Land Management, National Park Service and the Bureau of Sports Fisheries and Wildlife with respect to comments on the Parks, Forests and Recreational effects thereof.
- This project will probably involve a statutorily required HUD review under Section 4(f) of the Transportation Act of 1966. Therefore, we defer comment on the parks and recreational aspects of the project pending request by D.O.T. for such a review.

- This review covers the HUD responsibilities under Section 4(f) of the Transportation Act of 1966.
- The Draft Environmental Statement fails to reflect clearance or consultation with the appropriate local planning agency which is: \_\_\_\_\_
- The Draft Environmental Statement fails to reflect consultation or clearance with the appropriate areawide planning agency which is: \_\_\_\_\_
- The Draft Environmental Statement fails to reflect consultation or clearance with the appropriate State Clearinghouse as required by Circular A-95, Office of Management and Budget. The A-95 Clearinghouse of jurisdiction is: \_\_\_\_\_
- The project apparently requires the displacement of businesses or residences. The Draft Environmental Statement does not reveal full consideration of the requirements of the Uniform Relocation Assistance and Real Property Acquisition Policies Act of 1970 (Public Law 91-646). If relocation assistance is desired, please contact Mr. Peter Field, Director, Production Div., Daniel Bldg., 15 So. 20th Street, Birmingham, Ala. at 205-325-3697. In the local community the person or office most familiar with relocation resources is: \_\_\_\_\_
- The draft statement does not discuss apparently feasible alternatives which may have a more beneficial effect on the urban environment. See letter of transmittal for possibly overlooked alternatives.
- In general, HUD defers to other agencies with respect to establishing and enforcing air and water quality standards, thermal pollution standards, radiation and general safety standards. We have no formal jurisdiction over such matters and no comments contained herein should be construed as assuming such responsibility or jurisdiction.

- Since this project raises issues involving radiation safety, we recommend consultation with: Dr. Joseph Lieberman, Radiation Office, E.P.A., 5600 Fishers Lane, Parklawn Building, Rockville, Maryland 20852.
- We recommend that you write or call the Office of Management and Budget for a copy of "Directory of State, Metropolitan and Regional Clearinghouses under B.O.B. Circular A-95," and consult with such clearinghouses as appropriate.

3-12-73  
DATE

Donald R. James  
PREPARED BY  
(FIELD REPRESENTATIVE)

3-12-73  
DATE

J. Pope  
CONCURRED IN  
(PROGRAM MANAGER)



# United States Department of the Interior

OFFICE OF THE SECRETARY  
WASHINGTON, D.C. 20240

In reply refer to:  
PEP ER-73/363

JUN 19 1973

Dear Mr. Gartrell:

This is in response to your letter of March 6, 1973, requesting our comments on the Tennessee Valley Authority's draft statement, dated March 6, 1973, on environmental considerations for Bellefonte Nuclear Plant, Jackson County, Alabama.

Our comments are presented according to the format of the statement or according to specific subjects.

## Geology

The description of the geology and seismology presented in the draft environmental statement is not adequate for an independent assessment of the impacts related to constructing and operating the powerplant. The statement indicates that construction of the plant will have no adverse effect on geologic features, however, the data presented are not adequate concerning the physical properties of the geologic materials on which the station is founded. The methods of derivation of the seismic design criteria are not appropriately discussed and there is no indication of how the specified acceleration was used in design of the facility.

1

2

The AEC "Seismic and Geologic Siting Criteria for Nuclear Power Plants" (10 CFR100, proposed Appendix A) requires detailed investigations and analysis of geologic and seismic conditions. The results of such investigations and analysis and their applications to design and construction are usually presented in a Preliminary Safety Analysis Report (PSAR) to AEC by applicants for construction permits. As a result of previously established procedures between AEC and this Department, the Geological Survey acts as

advisor and consultant to AEC in earth-science matters concerned with licensing nuclear power reactors. The AEC has not as yet requested our review of the PSAR for the Bellefonte Plant. Since the draft environmental statement does not present sufficient data to judge whether the provisions of the above cited AEC criteria have been met, and since the PSAR for the plant is not available for our review, we do not have a basis at this time to comment on the suitability of the geologic and seismic environments for the construction and operation of the plant.

### Soils

In order to make the descriptive material more complete for the powerplant site as well as for the transmission line corridor, we suggest the environmental statement contain a special section on the soils of the area. The State Soil Scientist, Ernest A. Perry, for the Soil Conservation Service could furnish this information. Mr. Perry's address is Soil Conservation Service, Soil Conservation Building, P.O. Box 311, Auburn, Alabama 36830.

3

### Hydrology

According to the statement, approximately 148 cfs of water will be withdrawn for the closed cycle condenser cooling system and about 74 cfs will be returned as blowdown. Since the heated blowdown water will be returned through a diffuser, we do not foresee a heat pollution problem.

The plant will be constructed on Chickamauga Limestone which is about 1,400 feet thick in this area. According to the statement, the majority of the groundwater moves through the residual soil overlying the limestone and no solution channels were revealed in the more than 80 exploratory wells drilled at the site. Even though the exploratory wells revealed no cavities or solution channels, the final statement should reflect TVA's plans to suitably grout and seal any such cavities subsequently revealed.

4

Since groundwater movement in either the limestone or residual soils is expected to be toward the reservoir, it is unlikely that any potential groundwater contamination problems exist; however, we suggest that the final environmental statement show the location of all private wells and springs in close proximity of the site. The statement should also identify the effects that excavation will have on groundwater levels and nearby wells.

#### Historical and Archeological Significance of the Site

The proposed action will not directly affect any existing or proposed unit of the National Park System or any registered National Historic, Natural, or Environmental Education Landmark or any site now in process of registration as a landmark.

We believe the statement is generally adequate in its discussion of historical, archeological, and architectural resources. However, since at least one potential National Register property is involved with the proposal, we suggest that the statement provide a discussion of steps being taken to assure compliance with Section 106 of the National Historic Preservation Act of 1966 (80 Stat. 915) according to the procedures published in the "Federal Register" of February 28, 1973. It also appears desirable for the final environmental statement to contain a fuller discussion of measures that will be instituted to prevent or mitigate impacts on cultural resources stemming from the construction and operation of transmission lines.

#### Recreation

The recreation areas on the reservoir are mentioned on page 1.2-5 and projected recreation and wildlife areas within 10 miles of the site are plotted on figure 2.9-1. We suggest that the projected land use plan presented as figure 2.9-1 be expanded to also show the location of the proposed transmission lines and other plant facilities. Such a plot would be particularly helpful when assessing the impacts of the project on recreational resources. We also suggest that the final environmental statement include a description of the recreational facilities including the visitation rate.

### Radioactive Waste

The sources of solid radioactive wastes and the tritiated water from reactor operations are discussed. We believe that the environmental statement should provide more specific information concerning the radionuclides that will be present, their physical-chemical states, and their estimated concentrations. Additionally, the proposal to dispose of the wastes presents an additional environmental impact that should be evaluated in the impact statement. Since an environmental impact statement on the disposal site has not been prepared, we suggest that the Federal and State licensing provisions, criteria, and responsibilities for the Morehead, Kentucky disposal site be identified in regard to: (1) the hydrogeologic suitability of the site to isolate the buried Bellefonte wastes from the biosphere for specified periods of time; (2) current and continuing surveillance and monitoring at the disposal site; and (3) any remedial or regulatory actions that might be necessary throughout the required period of time involved.

11

12

### Radiological Effects of Accidents

It is pointed out on pages 2.3-2 and G-16 that the consequences of Class 9 accidents could be severe, but concludes that the probability of their occurrence is so small that their environmental risk is extremely low. We believe that it would be advisable to discuss the possible environmental impacts of an accident of this severity regardless of the low probability of occurrence.

13

### Terrestrial Monitoring

We suggest that selected wildlife species should be included in the terrestrial monitoring program.

14

### Ecological Considerations

The discussion on page 2.6-50 should indicate the various types of phytoplankton and zooplankton as well as fish larvae that will be included in entrainment losses.

15

16

Cumulative Impacts

We suggest that a section be added to the present section on "Environmental Impact of the Proposed Facility" that would discuss the cumulative radiological, thermal, and other environmental impacts which would result from the construction and operation of this plant along with the three other TVA nuclear plants currently under construction. Browns Ferry, Sequoyah, and Watts Bar are located at Tennessee river miles 294, 484.5 and 528, respectively.

17

Alternative Generation

It is suggested that the alternative generating capacity considered in sections 8.3 and 4.1 be expanded to quantify the environmental aspects of the alternative plant. It is suggested that sulfur dioxide, nitrogen oxide, and particulate emissions from a coal-fired steam plant be estimated and compared with the environmental impacts of the nuclear plant. This can be done by assuming the enforcement of local, State, and Federal regulations concerning the above mentioned pollutants.

18

We hope these comments will be helpful to you in the preparation of the final environmental statement.

Sincerely yours,



Deputy Assistant Secretary of the Interior

Mr. F. E. Gartrell  
Director of Environmental Planning  
Tennessee Valley Authority  
Chattanooga, Tennessee 37401


1. Since the issuance of the draft environmental statement, the Bellefonte Nuclear Plant PSAR has been published containing detailed geologic and seismic data. This information is contained in section 2.5 of the PSAR.
2. Seismic design is a matter which receives extensive review in the course of the safety analysis prior to licensing by AEC. Since seismic design is safety related, it is treated in considerable detail in the Preliminary Safety Analysis Report and is not considered necessary for the final environmental statement.
3. A description of soils in the vicinity of the plant site is given in section 1.2.4. However, the Bellefonte Nuclear Plant and its associated transmission facilities should have no impact on the soils of the area except in the immediate vicinity of structures.
4. TVA, as a matter of routine construction practice, will treat significant cavities by standardized grouting procedures, excavation, or other means as appropriate.
5. TVA's response is given in the attached table and map.
6. Current plans call for a maximum depth of excavation to extend to elevation 566 feet, in the powerhouse complex. Drilling in this area indicates that very few significant water-bearing openings occur below elevation 595 feet. The water table, in periods of high water level, reaches about elevation 621 feet, so that the maximum thickness of the water-bearing zone is about 26 feet.

The low porosity and permeability of the water-bearing zone, combined with its shallow depth of occurrence, indicates that effects of dewatering will not extend offsite.

7. Pursuant to the requirements of Section 106 of the National Historic Preservation Act of 1966 (80 Stat. 915), TVA is determining if there is any historical significance connected with the site in question. TVA is presently negotiating a contract with Dr. Roger Nance of the University of Alabama at Birmingham to investigate the historical significance of the old Bellefonte town site. If this investigation shows any historical significance connected with the site, TVA will then proceed with the appropriate review.

WELL AND SPRING INVENTORY WITHIN2-MILE RADIUS OF PLANT SITE

Map ident. No.	Location		Depth, feet	Estimated elevation, ft.	
	Latitude	Longitude		Ground	Water Surface
1	34°43'06"	85°56'34"	28	611	609
2	34°43'20"	85°56'26"	Unknown	621	Unknown
3	34°43'15"	85°56'19"	72	609	549
4	34°43'12"	85°56'11"	Unknown	-	Inaccessible
5	34°43'00"	85°56'11"	Inaccessible	610	Inaccessible
6	34°43'00"	85°56'10"	Inaccessible	-	Inaccessible
7	34°43'02"	85°56'09"	-	-	-
8	34°43'07"	85°56'06"	-	-	-
9	34°43'10"	85°56'02"	-	-	-
10	34°43'09"	85°56'00"	-	-	-
11	34°43'11"	85°55'58"	-	-	-
12	34°43'20"	85°55'58"	172	629	605
13	34°43'20"	85°55'46"	39	610	598
14	34°43'34"	85°56'07"	33	623	619
15	34°43'38"	85°55'55"	72	670	599
16	34°43'46"	85°55'57"	102	629	558
17	34°43'49"	85°55'57"	34	619	617
18	34°43'57"	85°55'49"	97	621	617
19	34°44'02"	85°55'47"	70	637	615
20	34°44'06"	85°55'45"	77	630	609
21	34°44'00"	85°55'12"	70	620	Inaccessible
22	34°44'00"	85°55'59"	-	-	-
23	34°43'56"	85°56'06"	55	617	568
24	34°44'00"	85°56'22"	135	640	616
25	34°43'55"	85°56'25"	131	630	616
26	34°43'48"	85°56'31"	48	640	628
27	34°43'28"	85°56'51"	200	-	-
28	34°43'30"	85°57'02"	68	634	609
29	34°43'21"	85°57'04"	72	630	599
30	34°43'40"	85°57'08"	52	638	638
31	34°43'03"	85°57'18"	-	-	-
32	34°42'58"	85°57'12"	125	620	609
33	34°42'51"	85°57'00"	72	604	595
34	34°42'37"	85°56'33"	116	639	591
35	34°41'50"	85°56'59"	-	-	-
S-1	34°41'36"	85°56'42"	-	-	-
S-2	34°41'36"	85°55'59"	-	-	-



BELLEFONTE NUCLEAR PLANT

LOCATIONS OF WELLS & SPRINGS

- Legend:
- 35 -- Well
  - S-1 -- Spring

Quad. No. 96NW

8. In developing routes for the proposed transmission lines, the National Register of Historic Places and other state and local inventories were consulted to determine if the proposed lines would conflict with any previously identified historical or archaeologically significant site. These reviews, although not all conclusive, failed to reveal any conflicts which would necessitate a route adjustment. However, following completion of an engineering survey to define specific routes for the proposed lines, a detailed professional field reconnaissance of the routes will be made by a qualified team of historians and archaeologists. Should this survey reveal the presence of any significant site on or in close proximity to the lines, an evaluation will be made to determine if the transmission line route or specific towers should be relocated. For archaeological sites, the possibility of recovering the artifacts will be studied. In the event a structure or other prominent historical property is identified, a determination will be made in conjunction with state and Federal historical agencies as to its eligibility for nomination to the National Register. In the event such a property is identified, appropriate steps to mitigate the conflict will be taken.
9. Location engineers in developing the proposed transmission line routes specifically avoided projections which might encroach upon known recreational, wildlife management, or other intense land use areas. As a result, very few conflict areas have been identified. A discussion of the land uses along the proposed transmission line route follow:

Bellefonte-Widows Creek No. 2, 500-kV Transmission Line  
(Proposed)

After leaving TVA property at Widows Creek Steam Plant, this transmission line crosses the Tennessee River on joint use towers with the Widows Creek-Raccoon Mountain 500-kV Line. Beyond the dense tree cover along the south river bank, the backlands extending to the lower slopes of Sand Mountain are presently used for pasture. The line then turns southwestward for some 12 miles and remains parallel at a distance of 2,000 to 3,000 feet from the river. The land located between the line route and the river is controlled by the State of Alabama and is managed as the Raccoon Creek Waterfowl Management Area. In conjunction with the State of Alabama Department of Conservation - Division of Game and Fish, a mutually acceptable line route and other specific habitat management plans have been developed to mitigate potential impacts from construction in this wildlife area. The land which lies between the base of Sand Mountain and the line is primarily small farm, pasture, and undeveloped land.

From the end of this 12-mile section, the line crosses a narrow point at the mouth of Coon Creek and ascends to the top of Sand

Mountain. At the Coon Creek crossing the only land development in the area consists of a small group of summer cottages which are located approximately 1 mile east of the proposed route.

After reaching the top of Sand Mountain, the line generally parallels the river southwestward to a point opposite the Bellefonte plant site. Along this route alternately open farm land, pasture, and wooded farm lots are traversed. The line projection was selected to widely avoid intrusion on the Pisgah community. There are no known recreational areas located along this line route.

In the vicinity of the proposed Bellefonte plant site, at TR mile 390.6, the line turns northwestward crossing the Tennessee River on common towers with the Bellefonte-Madison No. 2 Line. As indicated on figure 2.9-1, no formal recreational or wildlife management areas exist for several miles on either side of the river at this location.

Bellefonte-Guntersville 500-kV Transmission Line  
(Proposed)

This line, after crossing to the south bank of the Tennessee River, rises to the top of Sand Mountain en route toward the Guntersville, Alabama, area. Along this route, the line generally crosses open farm land and some undeveloped wooded lands. While avoiding several small rural towns, the line was specifically routed to eliminate an inlet crossing of Jones Creek (TR mile 389). This area, although not presently developed, has a good potential for water-based recreational uses.

The crossing of South Sauty Creek, which empties into Guntersville Lake at TR mile 374, was selected sufficiently upstream (approximately mile 4) and downstream from Bucks Pocket State Park to avoid conflicts with water-based recreational facilities in the Sauty Creek embayment or the state park. The crossing of South Sauty Creek will be accomplished with a single span. Structures will be placed 300 to 500 feet from the water edge and vegetation will be retained in this strip to minimize visual awareness of the crossing and to protect the banks from erosion.

Bellefonte-Widows Creek No. 1; Bellefonte-Madison  
500-kV Transmission Line and the 161-kV Station Service  
Supply Lines (Proposed)

Figure 2.9-1, section 2.9, and other information contained in Appendix A (Volume 2 of TVA's draft environmental statement) clearly define present land uses within a 10-mile radius of the proposed nuclear plant. All of the remaining transmission lines associated with this project exit the Bellefonte site in a northward direction. The crossing of Town Creek was selected to avoid disturbance to a small residential area located on the north bank of Town Creek embayment. The lines proceed northward on a common corridor to an intersection with the existing Widows Creek-Scottsboro 161-kV Line. Figure A-8 (Appendix A-Volume 2) accurately depicts the location of these lines.

In the vicinity of U.S. Highway 72, the right of way narrows to accommodate the two 500-kV lines which continue northward for approximately 9.5 miles where they will connect to the existing Widows Creek-Madison 500-kV Line. Beyond the range of the route depicted on figure A-8, the preferred route threads its way between the developed area at Hollywood, Alabama, to the south and Poorhouse Mountain to the north. Skirting the southwest side of Poorhouse Mountain, the line turns northward traversing mostly low undeveloped terrain along Pegues Branch before crossing Robinson and Mud Creeks. Continuing on this projection, the line passes the rural Community of Kyles before ascending to the flat area on the top of Crow Mountain and thence to an intersection with the existing Widows Creek-Madison 500-kV Line. The last 4 miles of this route are remote and sparsely populated.

As noted in the draft environmental statement, an alternate route east of Poorhouse Mountain was considered for these two 500-kV lines. However, this route was found to be less desirable than the preferred route because the land between Poorhouse Mountain and the Mud Creek embayment has significant residential and second-home development potential. Although located south of the Mud Creek Wildlife Management Area proper, the line has a conflict potential to wildlife along the upper reaches of the creek not specifically included in the managed area.

10. Recreation developments on the reservoir include:

State Parks

Lake Guntersville State Park - Marshall County, approximately 7 miles northeast of the City of Guntersville at Tennessee River mile (TRM) 362. Annual visitation for 1972: 233,000.

Buck's Pocket State Park - Marshall, Jackson, and DeKalb Counties; South Sauty Creek embayment, TR mile 374. No visitation data available.

Facilities at these state parks include marinas and boat-launching ramps, lodges, rental cabins, picnicking areas, campgrounds, a golf course, swimming facilities, and play fields.

#### County Parks

Marshall County Park - Marshall County, 1.5 miles north of the City of Guntersville, Tennessee River mile 358; a portion of the same park is located across the lake at TR mile 355. Annual visitation for 1972: 301,000.

Jackson County Park - Jackson County, 3.5 miles south of the City of Scottsboro, Dry Creek embayment, TR mile 382. Annual visitation for 1972: 161,000.

Facilities at these county parks include marinas and boat-launching ramps, swimming beaches, picnicking and camping areas, and play fields.

#### Municipal Parks

Guntersville Municipal Park - Guntersville, Alabama, Marshall County, Browns Creek embayment, TR mile 357. Annual visitation for 1972: 360,000

Goose Pond Colony - Jackson County, southwest of Scottsboro, North Sauty Creek embayment, TR mile 378. Annual visitation for 1972: 6,000.

Scottsboro Municipal Park - Scottsboro, Alabama, Jackson County, Roseberry Creek embayment, TR mile 382. Annual visitation for 1972: 50,000.

Stevenson Municipal Park - Stevenson, Alabama, Jackson County, Crow Creek embayment, TR mile 401. Annual visitation for 1972: 81,000.

South Pittsburg Municipal Park - South Pittsburg, Tennessee, Marion County, TR mile 418.5. Annual visitation for 1972: 6,000.

Facilities at these municipal parks include play fields, picnicking areas, boat-launching ramps, and a golf course.

Public Access Areas and Commercial Docks, Group Camps,  
Club Sites

There are 26 public access areas, 28 commercial docks, and several private group camps and club sites located primarily within the Marshall County portion of Gunter'sville Reservoir. Visitation to these areas in 1972 totaled 1,147,000 to the access areas; 1,518,000 to the commercial docks; and 142,000 to the group camps and club sites.

The annual visitation rates are from "Annual Survey of the Extent of Recreation Development and Use of TVA Lakes and Lake Frontage Property," published by TVA, Division of Reservoir Properties, 1972.

11. Table 1 shows the design isotopic content of radioactive waste to be shipped out annually. The second column shows the inventory for zero days decay. Normal onsite storage time will be 180 days and column 3 indicates the inventory at the end of this decay period (at time of shipment). These values are design basis and are not expected values. Using these values would indicate spent resin with an activity of about 200 Ci/ft<sup>3</sup> and evaporator bottom sludge activity of about 0.5 Ci/ft<sup>3</sup>. A survey of similar operating nuclear power plants would indicate more realistic activities of 0.5 Ci/ft<sup>3</sup> for spent resin and .03 Ci/ft<sup>3</sup> for evaporator bottoms.
 

Both the spent resin and evaporator bottom sludges will be mixed with cement before being loaded into a large volume (50 ft<sup>3</sup> - 150 ft<sup>3</sup>) container. After adequate time for solidification and decay, these containers will then be shipped out for disposal. Spent resins and evaporator bottom sludges may be mixed to provide better distribution of activity.
12. This portion of the nuclear fuel cycle is not appropriate for consideration in an individual impact statement. Environmental aspects of nuclear waste disposal are discussed in Environmental Survey of the Nuclear Fuel Cycle published by AEC in November 1972. It should be noted that the waste disposal facility must be licensed under the Atomic Energy Act of 1954.
13. The AEC Regulatory Guide 4.2 which provides guidelines for the preparation of environmental reports states:

The occurrences in Class 9 involves sequences of postulated successive failures more severe than those postulated for establishing the design basis for protective systems and engineered safety features and for site evaluation purposes. Their consequences could be severe. However, the probability of their occurrence is so small that their environmental risk is extremely low. Defense in depth (multiple physical barriers), quality assurance for design, manufacture, and operation, continued surveillance and testing, and conservative design are all applied to provide

7.9-14

Table I

DESIGN ESTIMATED SOLID WASTE ACTIVITY  
SHIPPED FROM PLANT (TWO UNITS)

<u>Isotope</u>	<u>Curies Shipped</u> <u>Per Year (Zero Decay)</u>	<u>Curies Shipped</u> <u>Per Year (6-Month Decay)</u>
$^3\text{H}$	$4.2 \times 10^2$	$4.1 \times 10^2$
$^{89}\text{Sr}$	$1.9 \times 10^1$	1.7
$^{90}\text{Sr}$	$1.8 \times 10^1$	$1.8 \times 10^1$
$^{90}\text{Y}$	$1.8 \times 10^1$	$4.5 \times 10^{-20}$
$^{91}\text{Y}$	$3.1 \times 10^1$	3.6
$^{129}\text{I}$	$6.0 \times 10^{-3}$	$6.0 \times 10^{-3}$
$^{131}\text{I}$	$6.0 \times 10^{-3}$	$9.0 \times 10^{-10}$
$^{134}\text{Cs}$	$3.7 \times 10^4$	$3.12 \times 10^4$
$^{136}\text{Cs}$	$1.8 \times 10^{-1}$	$1.8 \times 10^{-1}$
$^{137}\text{Cs}$	$1.0 \times 10^5$	$9.9 \times 10^4$
$^{137}\text{Ba}^m$	$9.3 \times 10^4$	0
$^{140}\text{Ba}$	$4.8 \times 10^{-3}$	$2.5 \times 10^{-7}$
$^{140}\text{La}$	$5.7 \times 10^{-3}$	$9.6 \times 10^{-36}$
$^{144}\text{Ce}$	$3.4 \times 10^1$	$2.2 \times 10^{-1}$
$^{144}\text{Pr}$	$3.4 \times 10^1$	0
$^{58}\text{Co}$	$3.5 \times 10^3$	$5.9 \times 10^2$
$^{60}\text{Co}$	$5.5 \times 10^1$	$5.1 \times 10^1$
$^{54}\text{Mn}$	$1.5 \times 10^2$	$9.9 \times 10^1$
$^{51}\text{Cr}$	$2.5 \times 10^2$	2.6
$^{55}\text{Fe}$	$6.8 \times 10^3$	$6.0 \times 10^3$
$^{59}\text{Fe}$	$4.5 \times 10^1$	2.7
$^{95}\text{Zr}$	$4.2 \times 10^3$	$6.0 \times 10^2$
$^{95}\text{Nb}$	<u><math>4.0 \times 10^3</math></u>	<u><math>1.1 \times 10^2</math></u>
Total	$2.5 \times 10^5$	$1.4 \times 10^5$

and maintain the required high degree of assurance that potential accidents in this class are, and will remain, sufficiently remote in probability that the environmental risk is extremely low. For these reasons, it is not necessary to discuss such events in the Environmental Report.

TVA agrees with this statement.

14. A revised nonradiological environmental monitoring program has been developed for the Bellefonte Nuclear Plant and is included in the final statement as Appendix L. It specifically identifies species included in the terrestrial monitoring program.
15. & 16. Fish larvae that have been identified thus far from Gunter'sville Reservoir appear in Table B1-9, Volume 2, and representative phytoplankton and zooplankton are listed in Tables B4-4 and B4-11. All species listed will probably be included in the entrainment losses.
17. TVA believes that any cumulative impacts from TVA projects are insignificant and are not appropriate for consideration in the environmental statement on an individual facility. However, TVA has considered cumulative impacts from radioactivity in the Tennessee River (see Appendix J). See response to the Department of Commerce, comment number 1, as to the cumulative thermal impacts.
18. This response is given in the final statement beginning on page 4.1-7.

DEPARTMENT OF TRANSPORTATION  
UNITED STATES COAST GUARD

MAILING ADDRESS: (GWS/83)  
U.S. COAST GUARD  
400 SEVENTH STREET SW.  
WASHINGTON, D.C. 20590  
PHONE: 202-426-2262



MAY 2 1973

- Dr. F. E. Gartrell, Director of  
Environmental Planning  
Tennessee Valley Authority  
Chattanooga, Tennessee 37401

Dear Dr. Gartrell:

This is in response to your letter of 6 March 1973 requesting comments on the draft environmental impact statement for the Bellefonte Nuclear Plant, Jackson County, Alabama.

The concerned operating administrations and staff of the Department of Transportation have reviewed the material submitted. The Federal Railroad Administration commented as follows:

"The Federal Railroad Administration is pleased to note that TVA has, in Volume 1 of the draft environmental impact statement, commendably explained its approach to inductive coordination problems. Since this is of considerable interest to us, as it obviously is to TVA, a recent technical paper on this subject is attached for consideration. This paper, by Messers Judkins and Thorson of Northern States Power Company, represents one of the best efforts in an area where little work has been done in several decades. The paper, entitled A System Approach to Inductive Coordination, was presented at the September 1972 meeting of the Communication and Signal Section of the Association of American Railroads."

The Department of Transportation has no other comments to offer nor do we have any objection to the project.

The opportunity for the Department of Transportation to review this statement is appreciated.

Sincerely,

J. D. McCANN  
Captain, U. S. Coast Guard  
Acting Chief, Office of Marine  
Environment and Systems

Enclosure



7.11-1

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
WASHINGTON, D.C. 20460

28 JUN 1973

OFFICE OF THE  
ADMINISTRATOR

Mr. Lynn Seeber  
General Manager  
Tennessee Valley Authority  
Knoxville, Tennessee 37802

Dear Mr. Seeber:

The Environmental Protection Agency has reviewed the document entitled "Draft Environmental Statement - Bellefonte Nuclear Plant" issued by TVA, March 21, 1973. Although we are pleased to provide the enclosed comments, it is our understanding that, in accordance with an imminent AEC-TVA agreement, the AEC will be preparing its own draft environmental statement on this facility. If such an agreement is consummated, EPA will, of course, analyze and comment on the AEC statement.

The waste treatment systems proposed for Bellefonte should be capable of limiting discharges to "as low as practicable" levels. However, if in the future the critical receptor moves closer to the plant, the thyroid dose limit proposed in Appendix I to 10 CFR Part 50 may be exceeded. Additional information concerning the potential for excessive doses via the cow-milk pathway is required.

Apparently TVA has concluded that it is not practicable to treat radioactive liquid wastes when their concentrations are less than  $10^{-4}$   $\mu$ Ci/cc. Information concerning the cost/effectiveness of using the waste management equipment to maintain lower effluent concentrations is necessary so that the reasonableness of this conclusion may be independently assessed.

By our calculations, there appear to be discrepancies between the assumptions used for source-term estimates by the AEC and the TVA. These discrepancies should be resolved and TVA should reevaluate their dose estimates using AEC models so that uniformity of review can be made as related to all other nuclear plants.

[Note date - June 28 and Air Mail - and received July 11]

Page 2 - Mr. Lynn Seeber

The thermal discharge from Bellefonte should comply with the applicable standards and the operation of the plant should not have a significant impact upon the aquatic environment. However, to facilitate a complete review of the plant, information regarding the discharge system and its impact should be released to all interested parties as soon as such information becomes available.

In light of our review of this draft statement and in accordance with EPA procedure, we have classified the project LO (Lack of Objections) and rated the draft statement as "Category 2" (Insufficient Information). We have enclosed a detailed explanation of our classification system for your information. In addition, we would be pleased to discuss our classification or comments with you or members of your staff.

Sincerely yours,



Sheldon Meyers  
Director  
Office of Federal Activities

Enclosures

ENVIRONMENTAL PROTECTION AGENCY

Washington, D.C. 20460

JUNE 1973

ENVIRONMENTAL IMPACT STATEMENT COMMENTS

Bellefonte Nuclear Plant

TABLE OF CONTENTS

	<u>PAGE</u>
INTRODUCTION AND CONCLUSIONS	1
RADIOLOGICAL ASPECTS	3
Radioactive Waste Management	3
Dose Assessment	4
Transportation	5
Reactor Accidents	6
NON-RADIOLOGICAL ASPECTS	8
Thermal and Biological Effects	8
Chemical Effects	10
ADDITIONAL COMMENTS	12

INTRODUCTION AND CONCLUSIONS

The Environmental Protection Agency (EPA) has reviewed the draft environmental statement for the Bellefonte Nuclear Plant prepared by the Tennessee Valley Authority (TVA) and issued on March 21, 1973.

Following are our major conclusions:

1. The proposed gaseous waste treatment systems should be capable of controlling the discharge of radioiodine to levels that are "as low as practicable." However, if in the future the critical receptor moves closer to the plant, the thyroid dose limit proposed in Appendix I to 10 CFR Part 50 may be exceeded. Additional information concerning the potential for excessive doses via the cow-milk pathway is required.
2. The final statement should include information concerning the cost-effectiveness of utilizing the liquid waste treatment system when radionuclide concentrations are less than  $10^{-4}$   $\mu\text{Ci/cc}$ .
3. The final statement should provide a summary of the assumptions used for source-term estimates. Any differences between the assumptions used by TVA and those used by the AEC should be discussed. TVA should reevaluate their dose estimates using AEC models so that uniformity of review can be made as related to all nuclear plants.
4. The proposed closed-cycle, natural-draft cooling tower system will prevent all but a small portion of the plant's waste heat from

reaching the Tennessee River. In addition, TVA indicates that they will operate the plant in conformance with Alabama water quality standards. In our opinion, operation of the facility, as proposed, should not have significant impact upon the aquatic environment.

However, to facilitate a complete review of the Bellefonte Nuclear Plant, (at the earliest practicable date) TVA should make available to EPA and all interested parties a final determination of the discharge system and an evaluation of its impact.

RADIOLOGICAL ASPECTSRadioactive Waste Management

The radioactive waste management systems proposed for the Bellefonte Nuclear plant are consistent with the current technology. Furthermore, the TVA policy of maintaining discharges of all wastes from its facilities at the lowest practicable levels is commendable. Through the combination of the TVA commitment and the waste management systems planned, the release of radionuclides to the environment, as a result of operating Bellefonte station, should be "as low as practicable."

Due to poor site meteorology, however, it appears that the offsite radioiodine concentrations may exceed the guidelines proposed in Appendix I to 10 CFR Part 50. To adequately evaluate the dose consequences of these iodine concentrations, additional information, as discussed later in these comments, should be included in the final statement.

Apparently TVA has concluded, based on a cost-effectiveness determination, that it is not practicable to treat radioactive liquid waste unless the concentrations of radionuclides exceed  $10^{-4}$   $\mu\text{Ci/cc}$ . The final statement should include information concerning the cost-effectiveness of using the waste management equipment to maintain lower effluent concentrations and discharges. This information is necessary so that an independent assessment may be made of the reasonableness of the proposed TVA criteria for providing treatment of the waste. 1

The draft statement indicates (page 2.4-16) that the flow from the condenser vacuum pump will by-pass the charcoal filter train under high- 2

flow conditions and will be released directly to the turbine building exhaust. An estimate of the frequency of releases by this pathway and the quantity of iodine discharged annually should be included in the final statement. 2

#### Dose Assessment

Using the standard Atomic Energy Commission assumptions, we estimate that the annual discharge of gaseous I-131 from the plant will be approximately 0.1 Ci/yr, which is consistent with the estimate presented in Table 2.4-6 of the draft statement. Our calculations indicate that this source-term produces I-131 concentrations approximately two orders of magnitude greater than those presented in Table I-5 of the draft statement. Apparently, the concentrations in Table I-5 were based on the source-term (0.001 Ci/yr) presented in Table 2.4-7 of the draft statement. Use of the annual release in Table 2.4-6 (0.088 Ci/yr) yields a site boundary thyroid dose estimate of approximately 70 mrem/yr to the thyroid of a one-year-old child from the cow-milk pathway. The discrepancies should be resolved, and the total gaseous release of iodine utilized for the thyroid dose estimates should be restated in the final statement. 3

From the information available on the site and the surrounding area, it appears that, although the potential thyroid dose from the nearest dairy farm is acceptable, there is land suitable for pasturage closer to the plant. Since the potential thyroid dose from dairy cows pastured there would exceed the currently allowable standard, the applicant should institute a program of monitoring and reporting for the location 4

of any milk cows in this area during the operational life of the facility.

Because of the magnitude of the potential dose through the cow-milk pathway, the applicant should reach a decision concerning the inclusion of provisions for backfitting the facility with additional iodine control systems. This decision, which will be partially based on this assessment of the likelihood of cows subsequently being located on this potential pasture, should be presented in the final statement. In addition, it is possible that an excessive thyroid dose could also occur through other environmental pathways (e.g., inhalation, ingestion of leafy vegetables). The final statement should, therefore, contain an evaluation of the potential dose through these pathways and discuss any mitigating or controlling actions which will be taken if the dose is excessive.

#### Transportation

EPA, in its earlier reviews of the environmental impact of transportation of radioactive material, agreed with the AEC that many aspects of this problem could best be treated on a generic basis. The generic approach has reached the point where on February 5, 1973, the AEC published for comment in the Federal Register a rulemaking proposal concerning the Environmental Effects of Transportation of Fuel and Waste from Nuclear Power Reactors. EPA commented on the proposed rulemaking by a letter to the AEC, dated March 22, 1973, and by an appearance at the public hearing on April 2, 1973.

Until such time as a generic rule is established, the EPA is continuing to assess the adequacy of the quantitative estimates of environmental radiation impact resulting from transportation of radioactive materials provided in environmental statements. The estimates provided for this station are deemed adequate based on currently available information.

#### Reactor Accidents

EPA has examined the AEC analysis of accidents and their potential risks which AEC has developed in the course of its engineering evaluation of reactor safety in the design of nuclear plants. The various categories of in-plant accidents are common to all nuclear power plants of given types. EPA, therefore, concurs with AEC's approach to evaluate the environmental risk for each accident class on a generic basis. AEC has in the past and still continues to devote extensive efforts to assure safety through plant design and accident analyses in the licensing process on a case-by-case basis. EPA, however, favors the additional step now being undertaken by AEC of a thorough analysis on a more quantitative basis of the risk of potential accidents in all ranges. We continue to encourage this effort and again urge the AEC to press forward to its timely completion and publication. EPA believes that this will result in a better understanding of the possible risks to the environment.

Discussion is underway between the two agencies to reach an understanding for timely EPA participation in the review and discussions of the results of the generic studies directed at quantitative

evaluation of accident risks. EPA asks to be kept informed of the scope and directions of these studies. EPA asks to be briefed periodically on the status and progress that have been made and EPA seeks to have prompt and complete access to the results of the studies. Concurrently, the results of EPA efforts which may contribute to the quantitative evaluation of accident risks will be provided to the AEC in a similar fashion. Meanwhile, EPA will continue its review of environmental impact statements in its areas of responsibility and will transmit its comments to AEC. We conclude that the level of safety developed through the present procedures and analyses on a case-by-case basis appears justified based on currently available information. However, we believe that the application of evaluative techniques and quantification procedures, now being pursued by AEC quantitative risk studies, should permit a more objective and consistent means of appraising accident risks. If unwarranted risks are identified during the course of the generic studies, EPA will make its views known. In this event, we are confident that the AEC will take appropriate action.

NON-RADIOLOGICAL ASPECTSThermal and Biological Effects

The proposed Bellefonte Nuclear Plant will have two pressurized water reactors with an electrical output of 2,664 megawatts. Condenser cooling will be accomplished by evaporative, natural-draft cooling towers within a closed-cycle system. Make-up water for the cooling system will be drawn from the Tennessee River at the rate of 4.20 cubic meters/second (148.5 cfs) and at an intake velocity of from .076 meters/second (.025 cfs) in winter to .073 meters/second (.024 cfs) in summer. Cooling-tower blowdown will be discharged downstream from the intake at the rate of 2.09 cubic meters/second (74 cfs).

Alabama water quality standards, applicable to the Tennessee River at the Bellefonte site, limit maximum stream temperature to 86°F with an allowable maximum rise over ambient stream temperature of 5°F. TVA has stated that they will operate the Bellefonte plant in compliance with these standards. This will be accomplished by holdup of the blowdown to the extent required to restrict heated discharges to time periods when the wet-bulb temperature is most favorable. However, TVA indicates (p. 2.6-9) "... there will be very limited times when the reservoir water temperatures are 86°F or more and blowdown will have to be discharged." This would result in a violation of Alabama water quality standards. Therefore, we recommend that the applicant explore methods for temporary retention (e.g. hold-up pond) which would preclude the need for blowdown discharge under adverse conditions.

Temperatures at Guntersville Dam are noted in the draft statement to have reached a maximum of 88.7°F (Page 2, 6-2); however, no indication is given as to whether this is due, at least in part, to operation of Widows Creek Stream Plant (the second largest fossil fired station in the TVA system) upstream on Guntersville Reservoir. Interaction between these facilities should be evaluated in the final statement.

TVA proposed to operate the cooling towers at two cycles of concentration. This will result in a two-fold increase in the dissolved solids present in the system, except during those periods when hold-up is required because of low flow releases from peaking power operation at Nickajack Dam. Under these conditions, increases in dissolved solids to approximately three times those in the river are anticipated. In our opinion, use of concentration factors of five or greater would appear desirable to reduce environmental damage. Such an increase in concentration factor could probably be incorporated without additional chemical treatment and would reduce make-up and blowdown requirements for the system. This would, consequently, reduce the potential for entrainment damage to organisms in the make-up water.

Design data for the cooling towers (including range, approach, wet and dry bulb temperatures, etc.) are not provided. This information should be made available in the final statement. We recommend, also, that TVA evaluate the provision of a waste hold-up pond to allow for equalization of blowdown, hold-up during periods of low-flow and/or high temperatures, and discharge in proportion to river flow.

TVA has not made a final determination on the diffuser system for the cooling tower blowdown. It is recommended that analyses of the diffuser and associated mixing zone be forwarded to EPA and other interested Federal and State agencies for review as soon as practicable. Further, TVA should provide for appropriate review and comment on this information prior to construction of the system.

13

Intake velocities through the intake canal and rotating screens appear acceptably low. However, as proposed, the canal dead-ends at the screens without provision for return of entrapped organisms. In our opinion, this design may be in conflict with the "best technology available" requirement of Section 316(b) of P.L. 92-500. We, therefore, recommend that the applicant explore alternative intake designs that would preclude this potential impact.

14

#### Chemical Effects

TVA is to be commended for investigating the installation and use of a closed-cycle system for non-radioactive chemical wastes, although it was decided not to incorporate the system at this time. We recommend that adequate space and piping be provided in the plant design to allow segregation of waste streams for ultimate treatment and reuse to accommodate installation of such a system should P.L. 92-500 require it. In addition, further evaluation should be made of other treatment processes. For example, secondary biological treatment or equivalent physical chemical treatment should be provided, in conformance with Alabama Water Quality Standards, for laundry and other waste streams

15

16

containing organic materials and/or ammonia and other nitrogen compounds.

16

Projected quantities and maximum concentrations (both before and after treatment) of pollutants from the cleaning operations conducted prior to unit startup, should be presented in the final statement.

17

7.11-15

ADDITIONAL COMMENTS

During the review we noted in certain instances that the draft statement did not present sufficient information to substantiate the conclusions presented. We recognize that much of this information is not of major importance in evaluating the environmental impact of the Bellefonte Nuclear Plant. The cumulative effects, however, could be significant. It would, therefore, be helpful in determining the impact of the plant if the following topics were addressed in the final statement.

1. An estimate of (1) the secondary coolant system leak rate and (2) the masses of coolant in the secondary system components; including the steam generators, hot wells, and feedwater piping system, should be presented in the final statement. 18
2. The design thermal power rating of the reactors should be presented in the final statement. 19
3. For the transportation accident discussed on page D-4, of the draft statement, the assumptions and the procedures used to calculate doses to the skin and the thyroid should be clearly stated. The values for the atmospheric dispersion factor (X/Q) should be given or referenced. 20
4. Based on our estimates, the Xe-133 concentration in the primary coolant appears to be several orders of magnitude low (Table 2.4-1). The final statement should provide the correct value and, if needed, provide corrected dose estimates based on the proper Xe-133 coolant inventory. 21

22

23

5. The numerical values for assumptions used for estimating radioactive effluents and the resulting doses should be presented in summary in the final statement (e.g., atmospheric dilution factors, deposition velocities, and internal recirculation filter decontamination factors). 24
6. Details of the milk production within 50 miles of the site should be presented in the final statement. 25
7. The frequencies of milk and vegetation sampling in the environmental surveillance program need clarification in the final statement. It should be noted that vegetation samples are insensitive indicators of iodine in milk. 26
8. The bases for the extrapolation of meteorological data from Sequoyah and Widows Creek site should be included in the final statement, particularly regarding temperature gradient data. 27
9. An assessment of the "background" levels of radionuclides discharged into the Tennessee River from other sources, such as Oak Ridge operations, and the details of radiological measurements made of samples in the "regional water," should be presented in the final statement. This assessment, as called for in the AEC regulatory Guide 4.2, should include peak and annual average concentrations. If possible, a mass-balance analysis of the available Clinch River - Tennessee River samples should be made to verify methodology used in the dose assessments. 28
10. A plot of the long-term dispersion factors ( $X/Q$ ) should be included in the final statement. 29

11. The final statement should indicate the size of tanks used on-site for storage of fuel oil, as well as the control measures to be employed to prevent air and water pollution from the oil. The final statement should indicate if the fuel oil is considered a volatile organic compound by the Alabama Regulations, Chapter 8, and should provide assurance that applicable state regulations will be met. 31
12. The environmental impact of air particulate emissions from the batch plant should be discussed in the final statement. The final statement should also discuss the compliance of the batch plant to the "Alabama Air Pollution Control Rules and Regulations" Chapter 4. 32
13. Based on the air pollutant emission rates for the oil-fired auxiliary steam generators, and using the EPA Office of Air Programs Publication No. AP-42 emissions factors, independent estimates were made for sulfur oxides (144.3 lbs/hr) and aldehydes (1.8 lb/hr) which are different than the emission rates presented on page 2.5-17 of the draft statement. These differences should be discussed in the final statement. 33
14. The draft statement (page 8.2-11) relates air pollutant emission (tons per year) to percentage of Secondary Ambient Air Quality Standards. The final statement should present calculations for these relationships. 34
15. On page 2.2-11 of the draft statement, a discussion of ozone production by energized high voltage transmission lines is presented. This discussion supports a final conclusion that the 500 KV transmission lines will produce levels of ozone that would be 35
- 36

"inconsequential." We believe that this conclusion is premature. The final statement should present data related to ozone measurements and sampling site locations that were used to support the statement that "As of 1972, TVA has accumulated approximately 5,300 mile-years of operation of its 500 KV transmission system with no known adverse effects attributed to the production of ozone from corona discharges."

36

16. Values for condenser flow of 466,000 gpm, delta T of 36°F and heat rate of  $7.8 \times 10^9$  BTU/hr are not consistent. Using the stated flow and delta T, a heat rate of  $8.4 \times 10^9$  BTU/hr is obtained.

37

Clarification of this issue should be provided in the final statement.

U.S. Environmental Protection Agency Procedures  
for Classifying Federal Projects and  
Associated Draft Environmental Impact Statements

Environmental Impact of the Project

**LO--Lack of Objections**

EPA has no objections to the proposed project as described in the draft impact statement; or suggests only minor changes in the proposed project.

**ER--Environmental Reservations**

EPA has reservations concerning the environmental effects of certain aspects of the proposed project. EPA believes that further study of suggested alternatives or modifications is required and has asked the originating Federal agency to reassess these aspects.

**EU--Environmentally Unsatisfactory**

EPA believes that the proposed project is unsatisfactory because of its potentially harmful effect on the environment. Furthermore, the Agency believes that the potential safeguards which might be utilized may not adequately protect the environment from hazards arising from this project. The Agency recommends that alternatives to the project be analyzed further (including the possibility of no action at all).

Adequacy of the Impact Statement

**Category 1--Adequate**

The draft impact statement adequately sets forth the environmental impact of the proposed project as well as alternatives reasonably available to the project.

**Category 2--Insufficient Information**

EPA believes that the draft impact statement does not contain sufficient information to assess fully the environmental impact of the proposed project. However, from the information submitted, the Agency is able to make a preliminary determination of the impact on the environment. EPA has requested that the originator provide the information that was not included in the draft statement.

**Category 3--Inadequate**

EPA believes that the draft impact statements does not adequately assess the environmental impact of the proposed project, or that the statement inadequately analyzes reasonably available alternatives. The Agency has requested more information and analysis concerning the potential environmental hazards and has asked that substantial revision be made to the impact statement.

If a draft impact statement is assigned a Category 3, no rating will be made of the project, since a basis does not generally exist on which to make such a determination.

7-11-20

1. Conservative estimates of the quantities of liquid wastes to be discharged annually and the expected activity concentrations of these wastes are shown in the following tabulation:

<u>Waste</u>	<u>Per Year</u>	<u>Concentration</u> <u>uCi/Gram</u>	<u>Ci/Year</u>
Laundry and hot shower waste	430,000	$5 \times 10^{-5}$	0.082
Chemical waste	51,000	$10^{-4}$	0.017
Miscellaneous leakage	44,000	$10^{-4}$	0.019
Sample drains	9,000	$10^{-4}$	0.003
Cask decon. waste	<u>374,000</u>	$10^{-5}$	<u>0.014</u>
	908,000		0.135

The present value of costs for processing this waste by evaporation and disposing of the solid waste is about \$350,000 over the expected life of the plant. The cost includes operating labor and maintenance expense, but does not include equipment depreciation. If the evaporator were required to process all waste, regardless of radioactivity concentration, the chances that major repairs or even replacement would be required would be much greater than if it had to process only the waste containing more than  $10^{-4}$  uCi/gram.

TVA considers that the small reduction in radioactivity release does not justify the cost.

2. TVA has evaluated the potential for releases due to the need to bypass the charcoal filters in the offgas line during startups. Based on our estimate of two cold startups per unit per year, the release of I-131 due to filter bypass is expected to comprise less than 5 percent of the total estimated iodine release for the site.
3. The annual iodine releases, as estimated by TVA and as used in concentrations and dose calculations in the TVA draft environmental statement, are 0.0013 Ci/yr. of I-131 and 0.0012 Ci/yr. of I-133. The I-131 release of 0.088 Ci/yr. listed in Table 2.4-6 of the Bellefonte Draft Environmental Statement is an error. Table 2.4-6 has been corrected in this statement.

Recent information indicates that the AEC Regulatory position for the Bellefonte Nuclear Plant regarding thyroid doses due to milk ingestion will be to calculate this dose to a child based on milk taken from the real cow yielding the highest dose (limiting cow). It has been determined that there are two milk cows located within 5 miles of the Bellefonte Nuclear Plant. The limiting cow is located 2.6 miles west-southwest of the plant. The average-annual atmospheric dispersion factor calculated for this location is  $1.1 \times 10^{-6}$  sec/m<sup>3</sup>. The estimated milk ingestion dose to the thyroid of a child is 0.17 mrem/yr.

TVA has also used the methods for calculation of iodine releases given in Regulatory Guide 1.42 to estimate the annual release of radioiodine. These methods yield annual releases of I-131 of 0.010 Ci/yr. and of I-133 of 0.013 Ci/yr. Using these release quantities, the limiting milk ingestion dose to the thyroid of a child is 1.3 mrem/yr.

It is concluded that the doses to a child due to milk ingestion at the limiting cow are below the guidelines of 15 mrem/yr. given in Regulatory Guide 1.42.

4. The cow census to be conducted semiannually will determine if any cattle are pastured on land closer to the plant than animals included in the sampling program. If cows are found closer to the plant, they will be included in the program.
  5. Since the estimated dose through the cow-milk pathway is "as low as practicable" at the nearest potential pasture, no provisions are planned for backfitting the facility with additional iodine control systems.
  6. The maximum individual dose to the thyroid of a 1-year-old child from iodine inhalation was discussed in Appendix I of the Bellefonte Draft Environmental Statement and was listed in Tables 2.4-13 and I-4 as 0.017 mrem/yr. (NNE, 950m). The adult<sup>1</sup> individual dose from iodine intake via leafy vegetable ingestion has been calculated to be 0.075 mrem/yr. assuming a 72 kg/yr. consumption of vegetables raised at the site boundary (NNE, 950m). These thyroid doses are not considered to be environmentally significant.
  7. TVA has evaluated these dose pathways (see response to the Environmental Protection Agency, comment 6) and feels that, based on this evaluation, no mitigating or controlling actions will be required.
  8. An examination of atmospheric data and cooling tower characteristics showed that, during the infrequent periods when the reservoir
- 
1. It is assumed that small children do not consume unprocessed leafy vegetables.

temperature is 86° F. or more, the temperature of the blowdown can be held to below 86° F. by blowing down only at night. The use of a hold-up pond for blowdown is not justified for the limited number of extended periods of low flow or high reservoir temperatures since blowdown can be withheld and released during the most favorable times by allowing the chemical concentration factor to increase temporarily. Also, the quantity of blowdown is so insignificant when diffused in the large volume of the reservoir that there is no significant advantage in proportioning the blowdown to the reservoir flow. On the rare occasions when the reservoir temperature exceeds 86° F., the situation could prevail for several days. A hold-up pond of the size required for such an extended period is not practical.

9. See response to the Department of Commerce comment No. 1.
10. At the present time, TVA feels that operating the cooling system at a concentration factor of two under normal conditions is the best balance between operation and environmental considerations. Even withholding blowdown for short periods of time, this method of operation will allow the system to be operated without additional chemical treatment to prevent scaling in the condenser and cooling towers or to adjust water quality of the effluent returned to the reservoir. Also, this operation ensures that normal chemical discharge concentrations create no significant impacts and results in no significant entrainment losses. Higher concentrations may require chemical treatment, resulting in higher levels of chemical releases.
11. The following parameters were used to design the cooling towers:

Range	- 34° F.
Approach	- 24° F.
Design wet bulb	- 55° F.
Design dry bulb	- 60° F.
12. See the response to Environmental Protection Agency comment No. 8.
13. A model study of various blowdown diffuser configurations is presently being conducted at the TVA Engineering Laboratory in Norris, Tennessee. TVA will make available the results of these tests and the details of the final diffuser design upon completion of the study.
14. The intake pumping station has been located at the head end of an inlet due to safety requirements and other considerations. The intake structure has been designed with an acceptably low approach velocity (approximately 0.2 ft/sec) in the inlet and across the traveling screens. Accordingly, provisions have not been made to return entrapped organisms capable of escaping the low velocity.

TVA has decided that the proposed intake structure at the head of an inlet, designed with low approach and screen velocities, results in no significant environmental impact; and, consequently, it is not necessary to consider provisions for return of entrapped organisms. In regard to section 316(b) requirements, EPA has initiated a proceeding to determine the "best technology available." Therefore, it would be premature at this time to judge that the Bellefonte intake structure design may be in conflict with the requirement of section 316(b).

15. Provisions will be made for the possible future installation of facilities for treating nonradioactive chemical wastes.
16. Secondary treatment processes that are presently available for waste effluents containing complex organic waste, including dissolved and/or suspended solids, nitrogen and/or nitrated compounds, ammonia and/or ammoniated compounds, etc., could require a combination of several processing operations. TVA is studying treatment methods and will provide facilities which will permit compliance with applicable Federal and state regulations.
17. An alkaline wash and an acid cleaning of the condensate feed-water system before initial operation is anticipated. Chemicals to inhibit corrosion will also be added to water used for hydrostatic testing, flushing, and storage following the cleaning. Tabulated below are the anticipated chemical requirements for preoperational activities for each generating unit.

Trisodium phosphate	24,000 pounds
Ammonia	100 pounds
Hydrazine	800 pounds
Hydroxyacetic acid	10,000 pounds
Formic acid	5,000 pounds
Ammonium bifluoride	1,250 pounds

It is expected that the steam generators will have to be cleaned after 5 to 8 years of operation and at a similar interval thereafter. Approximately 35,000 pounds of chemical in the form of a chelating agent solution is expected to be used to clean each steam generator.

None of the chemical cleaning or flushing solutions will be discharged directly to a receiving stream. Holding ponds will be used to contain the spent solutions so that the necessary processing can be accomplished to render the final pond effluent

acceptable for return to the river or for other use. Depending upon the constituents to be removed from the water, it may be necessary to perform one or more of the following operations: (1) neutralization, (2) sedimentation, (3) chemical precipitation, (4) absorption, and (5) evaporation. Solid waste resulting from the processing will be disposed of via land fill or packaging and burial as may be required.

The spent cleaning and flushing solutions will be processed before discharge so that applicable quality limits are met. Material removed by the cleaning process is generally iron oxide that occurs as rust, mill scale, or magnetite accumulations. In an alkaline wash, these materials are only suspended in the solution and will settle out in the quiescent ponds. From 1,000-3,000 pounds of iron oxide may be dissolved by an EDTA chemical cleaning of a steam generator, but this will be virtually completely removed in the holding ponds by chemical precipitation or other appropriate treatment.

18. Leak rates for the secondary coolant system were given in page 2.4-22 and 2.4-23 of the draft environmental statement.
19. The total mass of secondary system coolant is  $2.3 \times 10^6$  pound.
20. Design thermal power is 3,763 MW.
21. & 22. For the transportation accident discussed on page D-4 of the draft statement, the noble gas and iodine release, 1,000 Ci and 10 Ci respectively, represent the design basis conditions for fuel cask transportation accidents as specified in 10 CFR 71. The releases of various isotopes and parameters used in the dose calculations are given below.

Isotope	Quantity Released (Ci)	$\bar{E}_\alpha$ (Mev/dis)	$\bar{E}_\beta$ (Mev/dis)	Inhalation Dose Commitment Factor (mrem/Ci inhaled)
Kr-85	988	0.00206	0.241	
Xe-131m	10	0.0247	0.115	
Xe-133	2	0.0494	0.118	
I-131	10	0.376	0.200	$1.48 \times 10^9$

As discussed in the TVA draft environmental statement, it is assumed that there would be no gaseous releases without a substantial quantity of decay heat in the shipping container plus the addition of external heat such as from a fire. Thus, it is assumed that the thermal currents surrounding the container carry released fission gases to a height of 10 meters before they are dispersed in the environment. A centerline  $\chi/Q$  envelope for the 10 m release height and a wind speed of 1 m/sec was used for the individual doses, and a sector average  $\chi/Q$  envelope was used for the population doses

(see the attached figure for  $\chi/Q$  values). Population doses were calculated by assuming that the wind shifted over all 16 direction sectors equally during the course of the accident. The equations used to calculate the resulting external gamma, external beta, and thyroid inhalation doses are listed below.

$$D_{\gamma} = 250 \bar{E}_{\gamma} Q (\chi/Q),$$

$$D_{\beta} = 230 \bar{E}_{\beta} Q (\chi/Q),$$

and

$$D \text{ inhalation} = (BR) (DCF) Q (\chi/Q)$$

where

$D_{\gamma}$  is the external gamma dose, (mrem),

$D_{\beta}$  is the external beta dose, (mrem),

$D$  inhalation is the thyroid inhalation dose, (mrem),

$\bar{E}_{\gamma}$  and  $\bar{E}_{\beta}$  are the average gamma and beta energies respectively, (Mev/dis),

$Q$  is the quantity of radionuclide released during the accidents, (Ci),

$\chi/Q$  is the atmospheric dispersion factor, ( $\text{sec}/\text{m}^3$ ),


$BR$  is the breathing rate, ( $\text{m}^3/\text{sec}$ ), =  $2.315 \times 10^{-4} \text{ m}^3/\text{sec}$ ,

and

$DCF$  is the dose commitment factor for iodine (mrem/Ci inhaled).

It is assumed that the whole body receives external gamma dose only, and the skin receives external beta plus external gamma dose.

TRANSPORTATION ACCIDENT - BNP



23. Xe-133 concentration should read " $0.248 \times 10^{+2}$ ", not " $0.248 \times 10^{-2}$ ." The correct value was used in dose calculations.

24. & 25. Bases for releases are as follows:

The following tabulations [items (1) through (36)] are given in the format of Appendix 1 of AEC Regulatory Guide 4.2.

- (1) Reactor power: 3,763 MW thermal (292 FPD equilibrium fuel cycle)
- (2) a. Total uranium for first cycle:  
206,200 lb U  
b. Uranium loaded for equilibrium cycle:  
69,400 lb U/batch  
206,200 lb U total
- (3) Isotopic ratio in fresh fuel  
a. Initial loading: 1/3 core, 2.51% U-235  
1/3 core, 2.92  
1/3 core, 3.45  
b. Equilibrium cycle: 3.26% U-235
- (4) Expected percentage of leaking fuel = 0.25%
- (5) Escape rate coefficients:

<u>Element</u>	<u>Escape Rate Coefficient, s<sup>-1</sup></u>
Kr, Xe	$6.5 \times 10^{-8}$
Br, I, Cs, Rb	$1.3 \times 10^{-8}$
Mo, Nb, Ru	$2.0 \times 10^{-9}$
Te, Se, Sb, Sn	$1.0 \times 10^{-9}$
Sr, Ba	$1.0 \times 10^{-11}$
Y, La, Ce	$1.6 \times 10^{-12}$

- (6) Plant capacity: 80%
- (7) Number of steam generators: 2 per unit
- (8) Type of steam generator: Once through
- (9) Mass of primary coolant in system:  
a. Total: 557,000 lb  
b. In reactor: 199,000 lb
- (10) Primary coolant flow rate:  $150.5 \times 10^6$  lb/hr
- (11) a. Mass of steam in each steam generator: 6,890 lb  
b. Mass of secondary liquid in each steam generator: 37,700 lb  
c. Mass of primary coolant in each steam generator: 86,000 lb
- (12) Total active mass of secondary coolant:  $2.3 \times 10^6$  lb

- (13) Steam generator operating conditions
- Temperature (secondary side outlet): 612.9° F.
  - Pressure (average secondary side): 1,075 psig
  - Flow (secondary side):  $14.805 \times 10^6$  lb/hr
- (14) Condensate demineralizers:
- Number: 5/unit  
Size: 220 ft<sup>3</sup> of resin each  
Total flow rate:  $8.09 \times 10^6$  lb/hr  
Type: Mixed cation-anion resin, deep bed
- (15) The containment free volume is  $3.4 \times 10^6$  ft<sup>3</sup>.
- (16) The expected leak rate of primary coolant to the containment atmosphere is 10 lb/hr.
- (17) An internal air cleanup system, consisting of HEPA filters and charcoal adsorbers, is provided in the containment. The expected flow rate is 36,000 cfm. A decontamination factor of 10 is expected for iodine. Prior to purging, the system will be operated for 16 hours or until both I-131 and Sr-90 concentrations are below occupational maximum permissible concentration levels.
- (18) The containment is purged 4 times per year per unit, based on one refueling outage and 3 entrances for inspections or maintenance. The release is filtered through HEPA filters and charcoal adsorbers. The expected decontamination factor for iodine is 10.
- (19) Annual average letdown rate during power operation is 31,350 lb/hr per unit.
- About 73 percent, or 22,850 lb/hr, is let down continuously and is returned to the primary system. The liquid is cooled and depressurized, and is passed through a mixed-bed demineralizer (lithium-form cation, borate-form anion). About 20 percent of the time the flow is also passed through a mixed-bed demineralizer in which the cation resin is in hydrogen form. The liquid passes through a filter and the makeup tank before it is pumped back to the primary systems.  
  
Expected decontamination factors are 1 for noble gases and tritium, 10 for all other elements except Cs, Y, and Mo, and 1.22 for Cs, Y, and Mo.
  - Li and Cs are controlled by passing the letdown liquid through the mixed-bed demineralizer in which the cation resin is in hydrogen form. This unit is capable of removing Li and Cs.

- c. About 27 percent of the letdown flow, or 8,500 lb/hr, goes to the boron recovery system. The liquid passes through another mixed-bed demineralizer before it is fed to an evaporator. All of the recovered boric acid and the evaporator distillate are recycled. Approximately 187,000 lb/yr/unit of distillate is removed in order to keep the tritium concentration of the primary water below the maximum concentration, but this liquid is not discharged to the environment.
- d. The plant is designed for load follow. The liquid letdown, as a result of load follow operations, is a part of the 8,500 lb/hr average flow directed to the boron recovery system. None is diverted to the rad-waste system.
- (20) Noble gases and iodine are not separated from the portion of the letdown stream that is returned to the primary system (22,850 lb/hr).
- (21) The portion of the letdown stream that is directed to the boron recovery system (8,500 lb/hr) goes first to a holdup tank. Here part of the noble gas and hydrogen are separated from the liquid phase. Essentially all of the iodine remains in the liquid phase. The liquid is routed through a demineralizer and to an evaporator. In the evaporator the remaining noble gas and hydrogen are released from the liquid. Releases in the holdup tank and evaporator amount to about 99.9 percent of the noble gas and hydrogen in the letdown liquid. A very small fraction (less than  $10^{-5}$ ) of the iodine in the evaporator feed will be released with the noncondensables.
- Gases released in the holdup tank and evaporator are collected in a vent header, from which they are compressed and collected in one of two gas decay tanks. At least 60 days are required to fill a tank, and the gas is held for a minimum of 60 days more before it is released.
- (22) Releases from the gas decay tanks are passed through a HEPA filter and a charcoal adsorber. The expected decontamination factor for iodine is 10.
- (23) The primary coolant is degassed prior to each removal of the reactor vessel head for refueling or other purposes. Refueling will occur once per year. Over the life of the plant, head removals for purposes other than refueling probably will average less than one per year.

Degassing is initiated about a week prior to shutdown, during which time the hydrogen concentration is reduced to about 25 ccH<sub>2</sub>/kg water. This reduction is accomplished by reducing the hydrogen overpressure in the makeup tank. Released gas is

vented from the tank and is compressed for storage in a decay tank. Following shutdown, venting of the makeup tank is continued until the hydrogen concentration in the reactor coolant has been reduced to about 17 ccH<sub>2</sub>/kg water.

It is expected that approximately 90 percent of the gaseous activity will be removed from the coolant during degassing.

No significant removal of nongaseous radioactivity takes place as a result of coolant degassing.

- (24) A relatively small amount of hydrogen and noble gases may accumulate in the pressurizer during plant cooldown. This gas is vented to the reactor coolant drain tank, from which it is transferred to a gas decay tank by the waste gas compressor.
- (25) A primary-to-secondary leak rate of 4.6 lb/hr is assumed.
- (26) There is no blowdown from the steam generators.
- (27) The expected leak rate of steam to the turbine building is 1,700 lb/hr. A preliminary estimate of ventilation air flow through the turbine building is 600,000 cfm. It is discharged through the building roof. The discharge is not filtered.
- (28) The flow rate of gaseous effluent from the condenser vacuum pump discharge will have a flow rate between 5 SCFM to 30 SCFM. The discharge is filtered through a HEPA filter and charcoal adsorber, is mixed with part of the turbine building ventilation exhaust, and is released from the turbine building roof.
- (29) Primary steam is used in the gland seals. Effluent steam is passed through a gland seal condenser. The condensate is sent to the condenser hotwell. The noncondensable gases are piped to a point where they are mixed with a portion of the ventilation air exhausted from the turbine building.
- (30) The expected leak rate of primary coolant to the auxiliary building is 160 lb/d or 6.67 lb/hr. A preliminary estimate of ventilation air flow through the auxiliary building is about 180,000 cfm. It is discharged from the unit vent associated with the reactor containment. All discharge with potential contamination is filtered through charcoal adsorbers and the HEPA filters. A decontamination factor of greater than 10 is expected for halogens.

(31) Liquid waste effluents - The liquid waste disposal system is designed to collect and treat high-level (tritiated) and low-level (nontritiated) wastes separately. Tritiated liquid waste is treated and recycled to the primary system; it is not discharged.

- a. The estimated quantity of tritiated waste is 23,800 ft<sup>3</sup>/yr or 490 gal/d/two units. The nongaseous activity concentration in this liquid prior to treatment is estimated to be 5.4 u Ci/gram. The isotopic distribution is given below:

<u>Isotope</u>	<u>Concentration</u> <u>u Ci/gram</u>
Rb-88	0.872
Sr-89	1.60(-3)
Sr-90	5.66(-5)
Sr-91	9.52(-3)
Sr-92	2.85(-3)
Y-90	5.15(-5)
Y-91	1.64(-3)
Mo-99	0.779
I-131	1.14
I-132	0.736
I-133	1.29
I-134	0.148
I-135	0.630
Cs-134	0.144
Cs-136	6.09(-2)
Cs-137	0.314
Cs-138	0.236
Ba-139	2.47(-2)
Ba-140	1.99(-3)
La-140	8.30(-4)
Ce-144	1.90(-4)

There is one tritiated waste collector tank with a capacity of 3,300 ft<sup>3</sup>.

All of the tritiated waste is recycled following treatment.

Tritiated waste is processed with a 2-gal/min evaporator and a 20-gal/min mixed-bed demineralizer. It is assumed that the evaporator will remove all noble gases, and that the process decontamination factor for all other isotopes is 1,000. A demineralizer decontamination factor of 10 is assumed for all isotopes. The average decay time from primary loop to recycle is about 12 days.

- b. The estimated quantity of nontritiated (dirty) liquid waste is 4,800 ft<sup>3</sup>/yr, or 100 gal/d. The nongaseous activity concentration in this liquid prior to treatment is estimated to be less than 0.54 u Ci/gram. The isotopic distribution is one-tenth of the values given for tritiated waste under 31.a.

There is one nontritiated waste collector tank with a capacity of 3,300 ft<sup>3</sup>.

It is expected that none of the nontritiated waste will be recycled.

The nontritiated liquid waste is processed through a 30-gal/m auxiliary waste evaporator unless its radioactivity concentration is below 10<sup>-4</sup> u Ci/gram. If below 10<sup>-4</sup> u Ci/gram, the liquid is sent through a filter and is discharged. A DF of 1 is assumed for the filter. Evaporator distillate is filtered and discharged if below 10<sup>-4</sup> u Ci/gram. If above 10<sup>-4</sup> u Ci/gram, the distillate is recycled to the nontritiated waste holdup tank for reprocessing. A DF of 1,000 is assumed for the evaporator.

The average decay time from primary loop to discharge is about 60 days.

- c. (1) Laundry and hot shower waste is estimated to be 57,600 ft<sup>3</sup>/yr, or 1,180 gal/d. The activity concentration is expected to be less than 10<sup>-4</sup> u Ci/gram.

None of the laundry and hot shower waste will be recycled.

If below 10<sup>-4</sup> u Ci/gram, the laundry and hot shower waste is filtered and discharged. A DF of 1 is assumed for the filter. If above 10<sup>-4</sup> u Ci/gram, the waste is routed to the nontritiated waste holdup tank for processing with the auxiliary waste evaporator.

No decay time is assumed for laundry and hot shower wastes.

- (2) Spent fuel shipping cask decontamination water is estimated to be 50,000 ft<sup>3</sup>/yr, or 1,020 gal/d. The activity concentration is expected to be less than 10<sup>-6</sup> u Ci/gram.

None of this water will be recycled.

The water is processed through a filter (DF = 1) and is discharged.

The decay time from primary loop is greater than 90 days.

- (3) Chemical drain solutions are estimated to be 6,800 ft<sup>3</sup>/yr or 140 gal/d. The expected radioactivity concentration is  $10^{-4}$  uCi/gram.

None of this liquid will be recycled.

The liquid is discharged after filtration ( $DF = 1$ ) if the activity concentration is less than  $10^{-4}$  uCi/gram and if it contains no toxic chemicals. If above  $10^{-4}$  uCi/gram, the liquid will be drummed if it contains chemicals that would damage the evaporator. If above  $10^{-4}$  uCi/gram and if it contains no chemicals that would damage the evaporator, the liquid will be processed through the auxiliary waste evaporator ( $DF = 1,000$ ). The distillate will be filtered ( $DF = 1$ ) and discharged.

d. Not applicable.

- e. The estimated quantity of liquid from the turbine building is 312,000 ft<sup>3</sup>/yr or 6,400 gal/d. The expected activity concentration is  $4 \times 10^{-6}$  uCi/gram.

None of this liquid will be recycled.

The liquid will be collected in the turbine building sump tank and will be sampled prior to discharge.

No decay time is assumed from the steam generator to discharge.

- f. Spent regenerant solutions from the condensate demineralizers are expected to amount to 330,000 ft<sup>3</sup>/yr, or 6,800 gal/d. This is based on an assumed regeneration interval of 30 days per demineralizer vessel. The expected activity concentration is  $3 \times 10^{-4}$  uCi/gram.

The liquid will be collected in a spent regenerants tank, and will be processed through the 30-gal/min auxiliary evaporator at a time when it is not being used to process waste from the nontritiated waste collector tank. A process decontamination factor of 1,000 is assumed for all non-gaseous isotopes in the evaporator. If the liquid in the spent regenerants tank is below  $10^{-4}$  uCi/gram, it will be filtered ( $DF = 1$ ) and discharged.

It is anticipated that most of the spent regenerant liquid processed through the evaporator will be recycled to the secondary system.

The average decay time from the steam generator to discharge is 15 days.

- (32) Liquid waste discharges are diluted by the cooling tower blowdown. The minimum blowdown rate is 15,000 gal/min. The normal rate is 33,200 gal/min. The expected total annual flow is  $1.55 \times 10^{10}$  gallons.
- (33) Evaporator bottoms and demineralizer resins will be mixed with portland cement and allowed to solidify in a steel shipping container. The total quantity of solid waste to be shipped each year is estimated to be 2,860 ft<sup>3</sup>. An additional 12,000 ft<sup>3</sup> of evaporator bottoms from the concentration of spent regenerants may also be solidified, packaged, and shipped each year. The estimated activity in all solid wastes is  $2.5 \times 10^7$  curies per year. The total weight of solid waste is estimated to be about 1.5 million pounds per year.
- (34) The estimated quantity of dry waste shipped annually is 2,100 ft<sup>3</sup>. Most of the activity in dry waste shipments results from containment and auxiliary building filters. (Purification system filters are backflushables.) The total curies per year per unit for filter shipments is estimated to be 0.6 curies. For an individual drum or package containing a filter, the maximum expected activity is estimated to be approximately 0.2 curies.
- (35) This question is responded to in the answer to question 31.f.
- (36) Process and instrumentation flow diagrams for gaseous and liquid radwaste systems are given in the PSAR, figures 11.2-1, 11.2-2, 11.2-3, and 11.3-1.

It is believed that the dosimetry models for gaseous release are adequately explained in Appendix I of this environmental statement. Pertinent parameters used in the dosimetry models are listed below:

$\sigma_{zim}$  - Page 103, TID 24190, Meteorology and Atomic Energy, 1968

$\bar{E}_{\beta}$  - Table I-1

$\bar{E}_{\gamma}$  - Table I-1

BR(child) =  $0.29 \text{ m}^3/\text{hr}$  (page I-6)

BR(adult) =  $0.83 \text{ m}^3/\text{hr}$  (page I-6)

Isotope	DCF(Child, Inhalation)	DCF(Adult, Inhalation)
	mrem/Ci Inhaled	mrem/Ci Inhaled
I-131	$9.88 \times 10^9$	$1.93 \times 10^9$
I-132	$6.89 \times 10^9$	$6.98 \times 10^8$
I-133	$4.67 \times 10^9$	$5.20 \times 10^8$
I-134	$3.25 \times 10^9$	$3.27 \times 10^7$
I-135	$1.55 \times 10^9$	$1.61 \times 10^8$

$v_g$  - 0.01 m/sec

$M$  -  $0.647 \frac{\text{Ci}/\ell}{\text{Ci}/\text{m}^2\text{-day}}$

CR - 1  $\ell/\text{day}$  (for child and adult)

Isotope	DCF(Child, Ingestion)	DCF(Adult, Ingestion)
	mrem/Ci Ingested	mrem/Ci Ingested
I-131	$1.71 \times 10^{10}$	$3.34 \times 10^9$
I-133	$8.07 \times 10^9$	$8.98 \times 10^8$

ANNUAL, AVERAGE CHI-OVER-Q<sup>1</sup> (SEC/M<sup>3</sup>)

DOWNWIND DISTANCES (METERS)

	1132.	2414.	4023.	5633.	7242.	12070.	24140.	40233.	56327.	72420.
<u>Sector</u>										
N	2.87E-06	1.03E-06	5.10E-07	3.20E-07	2.26E-07	1.13E-07	4.49E-08	2.34E-08	1.54E-08	1.14E-08
NNE	8.46E-06	3.08E-06	1.53E-06	9.59E-07	6.79E-07	3.39E-07	1.35E-07	7.05E-08	4.65E-08	3.43E-08
NE	9.97E-06	3.63E-06	1.80E-06	1.13E-06	8.03E-07	4.01E-07	1.60E-07	8.35E-08	5.50E-08	4.06E-08
ENE	3.61E-06	1.27E-06	6.20E-07	3.86E-07	2.71E-07	1.34E-07	5.29E-08	2.74E-08	1.80E-08	1.32E-08
E	1.90E-06	6.49E-07	3.11E-07	1.91E-07	1.34E-07	6.51E-08	2.53E-08	1.30E-08	8.46E-09	6.19E-09
ESE	1.40E-06	4.84E-07	2.32E-07	1.43E-07	1.00E-07	4.90E-08	1.92E-08	9.86E-09	6.45E-09	4.74E-09
SE	1.20E-06	3.97E-07	1.87E-07	1.14E-07	7.90E-08	3.80E-08	1.46E-08	7.43E-09	4.83E-09	3.53E-09
SSE	2.50E-06	8.61E-07	4.13E-07	2.55E-07	1.78E-07	8.71E-08	3.40E-08	1.75E-08	1.15E-08	8.41E-09
S	5.36E-06	1.93E-06	9.51E-07	5.95E-07	4.20E-07	2.08E-07	8.27E-08	4.29E-08	2.83E-08	2.08E-08
SSW	1.46E-05	5.27E-06	2.61E-06	1.63E-06	1.16E-06	5.75E-07	2.29E-07	1.19E-07	7.85E-08	5.79E-08
SW	1.27E-05	4.55E-06	2.24E-06	1.40E-06	9.88E-07	4.90E-07	1.94E-07	1.00E-07	6.60E-08	4.86E-08
WSW	6.04E-06	2.31E-06	1.18E-06	7.53E-07	5.38E-07	2.73E-07	1.11E-07	5.83E-08	3.86E-08	2.86E-08
W	1.81E-06	6.82E-07	3.47E-07	2.21E-07	1.58E-07	8.00E-08	3.24E-08	1.70E-08	1.13E-08	8.35E-09
WNW	1.92E-06	6.88E-07	3.38E-07	2.12E-07	1.49E-07	7.40E-08	2.94E-08	1.53E-08	1.00E-08	7.40E-09
NW	2.01E-06	7.26E-07	3.58E-07	2.24E-07	1.58E-07	7.87E-08	3.13E-08	1.62E-08	1.07E-08	7.87E-09
NNW	3.01E-06	1.07E-06	5.24E-07	3.27E-07	2.30E-07	1.14E-07	4.49E-08	2.33E-08	1.53E-08	1.13E-08

7.11-36

<u>Sector</u>	<u>Site Boundary Distance (m)</u>	<u>Site Boundary Chi-Over-Q (sec/m<sup>3</sup>)</u>
N	882.	3.96E-06
NNE	947.	1.07E-05
NE	1340.	8.00E-06
ENE	1715.	2.05E-06
E	1110.	1.95E-06
ESE	985.	1.70E-06
SE	1009.	1.41E-06
SSE	1112.	2.56E-06
S	1454.	3.85E-06
SSW	1569.	9.46E-06
SW	1340.	1.02E-05
WSW	1224.	5.48E-06
W	749.	3.01E-06
WNW	737.	3.33E-06
NW	654.	4.06E-06
NNW	731.	5.31E-06

1. These atmospheric dilution factors ( $\chi/Q$ 's) were calculated using equation (1), page I-2. The term  $\exp(-\lambda x_m/u_j)$  which is evaluated and used in performing dose calculations was set equal to 1.0 in calculating these  $\chi/Q$ 's.

26. Grade A milk production by county for calendar year 1972 was obtained from the TVA Division of Agricultural Development. It was assumed that the milk production in a county was distributed equally over the area of the county to obtain the annual milk production (C.Y. 1972) per square mile for each county. From this information the attached 1972 milk production data, by sector and radial distance, were determined. The 1972 population dose from milk consumption was scaled up by a ratio of 1.99 (the ratio of estimated 2020 population within 50 miles to 1972 population within 50 miles) to obtain estimated 2020 population dose from milk consumption.

7.11-38

1972 MILK PRODUCTION WITHIN 50 MILES OF BNPMilk Produced in Each Zone  
(lbs/yr)

<u>Sector</u>	<u>Zone</u>				
	<u>0-10 Miles</u>	<u>10-20 Miles</u>	<u>20-30 Miles</u>	<u>30-40 Miles</u>	<u>40-50 Miles</u>
N	$1.72 \times 10^5$	$8.78 \times 10^5$	$4.08 \times 10^6$	$4.77 \times 10^6$	$7.57 \times 10^6$
NNE	$1.82 \times 10^5$	$5.25 \times 10^5$	$6.78 \times 10^5$	$1.03 \times 10^6$	$1.70 \times 10^6$
NE	$1.72 \times 10^5$	$5.35 \times 10^5$	$5.72 \times 10^5$	$1.29 \times 10^6$	$3.80 \times 10^6$
ENE	$1.72 \times 10^5$	$7.07 \times 10^5$	$4.15 \times 10^5$	$3.45 \times 10^6$	$1.20 \times 10^7$
E	$1.52 \times 10^5$	$1.10 \times 10^6$	$1.44 \times 10^6$	$3.68 \times 10^6$	$6.27 \times 10^6$
ESE	$1.62 \times 10^5$	$1.24 \times 10^6$	$2.03 \times 10^6$	$2.70 \times 10^6$	$3.42 \times 10^6$
SE	$1.72 \times 10^5$	$1.28 \times 10^6$	$1.79 \times 10^6$	$1.87 \times 10^6$	$3.36 \times 10^6$
SSE	$1.62 \times 10^5$	$1.26 \times 10^6$	$2.07 \times 10^6$	$1.56 \times 10^6$	$1.76 \times 10^6$
S	$1.82 \times 10^5$	$1.16 \times 10^6$	$2.13 \times 10^6$	$2.64 \times 10^6$	$3.62 \times 10^6$
SSW	$1.72 \times 10^5$	$7.38 \times 10^5$	$1.71 \times 10^6$	$2.07 \times 10^6$	$3.32 \times 10^6$
SW	$1.72 \times 10^5$	$8.98 \times 10^5$	$1.27 \times 10^6$	$1.81 \times 10^6$	$3.16 \times 10^6$
WSW	$1.72 \times 10^5$	$5.63 \times 10^5$	$1.57 \times 10^6$	$2.65 \times 10^6$	$4.40 \times 10^6$
W	$2.12 \times 10^5$	$5.25 \times 10^5$	$1.54 \times 10^6$	$3.11 \times 10^6$	$3.86 \times 10^6$
WNW	$1.82 \times 10^5$	$5.25 \times 10^5$	$1.36 \times 10^6$	$4.66 \times 10^6$	$1.46 \times 10^7$
NW	$1.72 \times 10^5$	$5.15 \times 10^5$	$2.52 \times 10^6$	$1.67 \times 10^6$	$2.75 \times 10^7$
NNW	$1.72 \times 10^5$	$5.96 \times 10^5$	$4.80 \times 10^6$	$7.31 \times 10^6$	$1.15 \times 10^7$

27. After the plant becomes operational, milk samples will be taken weekly when cows are on pasture. Vegetation samples are collected monthly to correlate the activity in grass with that found in milk. During seasons that cattle are not on pasture, if significant increases in radioactivity are seen in vegetation, the frequency of milk sampling will be increased from monthly to weekly.
28. Listed below are the procedures used for developing the extrapolated joint frequencies of wind direction and wind speed for the different stability classes.

Step 1 - A comparison was made between the limited (May 12-July 31, 1972) wind data from the Bellefonte temporary meteorological facility with the summer (1962-1970) wind data from the Widows Creek valley meteorological station. In general, the Widows Creek data were representative of the Bellefonte site. One exception was the higher occurrence of calm at the Widows Creek valley station. This was attributed to the high starting threshold of the wind speed sensors, i.e., 2-3 mi/h for the Widows Creek station as compared to 0.6 mi/h for the Bellefonte facility.

Step 2 - Based on the comparability of the summer wind data and on the similarity of terrain, it was assumed that the annual wind data for the two plant sites were also comparable. To make an allowance for the difference in sensitivity of the wind speed sensors, the 11.6 percent calm indicated from the Widows Creek data was reduced to 6 percent for the Bellefonte site. The remaining 5.6 percent calm was integrated into the 16 compass-point directions for the 1-3 mi/h class of the Widows Creek annual wind data. These adjusted data constituted the annual wind rose for the Bellefonte site.

Step 3 - A frequency distribution of calms was developed with respect to the 16 compass-point directions for the Sequoyah annual wind rose data for the period April 2, 1971-March 31, 1972. This was done by proportionally distributing the total 3.18 percent calm into the 0.0-0.5 mi/h class for each direction, based on the respective 1-3 mi/h wind speed frequencies.

Step 4 - Proportionality factors of wind direction and wind speed were established for the Bellefonte and Sequoyah wind rose data. These factors were then used to develop the joint frequency distributions of wind direction, wind speed, and stability (Pasquill classes A-G) for the Bellefonte site, based on the empirically derived Sequoyah joint frequency distribution.

Step 5 - The extrapolated Bellefonte joint frequency distribution was revised by applying a correction factor to allow for differences in the Bellefonte and Sequoyah Pasquill stability classes. The

two major considerations in the subjective determination of the differences were: (1) the variance in the tower heights aboveground of the Sequoyah temperature sensors ( $T_{33 \text{ ft}}$  and  $T_{300 \text{ ft}}$ ) and the Bellefonte temperature sensors ( $T_{130 \text{ ft}}$  and  $T_{33 \text{ ft}}$ ) would obviously result in a somewhat lower frequency of the most stable and most unstable conditions at Sequoyah as compared with Bellefonte; and (2) the more pronounced effects of the valley ridge terrain at the Bellefonte site would result in a slightly higher frequency of the more stable conditions, E-G, because of the earlier diurnal onset of the stable drainage wind regime.

29. See Appendix J.
30. Response given as part of response to Environmental Protection Agency comments numbered 24 and 25.
31. Fuel oil will be stored in two 100,000-gallon tanks located in the yard and in sixteen 18,700-gallon tanks located in the diesel generator building. The tanks in the yard will be diked to contain the oil in the event of rupture. The tanks in the diesel generator building will be embedded in concrete in the building substructure. The building will be a seismic category 1 structure and the tanks will be vented to the atmosphere through flameproof vents. Provisions will be made for collecting any spillage that may occur at locations where tanks are filled from rail cars and tank trucks.
32. As defined by the Alabama regulations, a "volatile organic compound" shall mean any compound containing carbon and hydrogen or containing carbon and hydrogen in combination with any other element which has a vapor pressure of 1.5 pounds per square inch absolute or greater under actual storage conditions. The fuel oil used to fire the auxiliary steam generators will have a vapor pressure of less than 1.5 pounds per square inch absolute; therefore, it is not considered a volatile organic compound and not subject to the regulations outlined for storage of volatile organic materials.
33. The concrete mixing "batch" plant will comply with particulate emission requirements of the Alabama Air Pollution Control Rules and Regulations by the installation of adequate hoods, fans, and ducts to transport dust from cement and fly ash silos and batchers to a dust collector. With these controls, there should be no significant amount of dust emitted to the ambient air.
34. The sulfur oxides emission on page 2.5-17 of the draft environmental statement was in error by a factor of 10; therefore, the sulfur oxides emission should be 143 lbs/hr. The aldehydes emission rate, using the EPA Office of Air Programs Publication No. AP-42 emission factor, would be 1.8 lb/hr.

35. The column "Percent of Secondary Ambient Air Quality Standard" (page 8.2-11) was derived using the calculated concentrations and the secondary ambient standards (page 2.5-17). The table referred to on page 8.2-11 was not intended to give a direct relationship between percent of standard and annual emissions but rather to show the insignificance of both concentrations and total emission.
36. As indicated in the discussion beginning on page 2.2-11 of the draft environmental statement and continuing in Appendix F, several monitoring programs including staged field and controlled laboratory tests have been conducted by other utilities to provide quantitative data on the production rates of oxidants by extra high voltage transmission lines at operating levels up to 765 kV. In addition to references listed in Appendix F, Commonwealth Edison Company, Chicago, Illinois, and ITT Research Institute recently published the results of a 19-month field investigation to determine if high voltage transmission lines generate measurable quantities of ozone.

The published results of these monitoring programs amply demonstrate the inconsequential effects of ozone generation by EHV transmission lines and further testing of these conclusions on the TVA system do not seem justified.

The statement of accumulated mile-year operation of the TVA 500-kV transmission system without known adverse effects from the production of ozone was not based on specific measurements or sampling. This statement was based primarily on more subtle observations by operating and maintenance personnel and other related indicators. Linemen, even in the performance of hot line work, reported no evidence of the odor produced by ozone which is detectable in very low concentrations (.02 to .05 ppm). Also, reasonable audible sound levels and measured radio noise readings were observed under numerous tests. Excessive levels would be obvious indicators of the presence of excessive corona discharges, the phenomenon directly responsible for the production of ozone.

37. The correct value for the condenser flow is 436,000 gal/min. The delta T is 36° F., and the heat rate is  $7.8 \times 10^9$  Btu/hr.

- 
1. Fern, W. J., R. I. Brabets. "Field Investigation of Ozone Adjacent to High Voltage Transmission Lines," Commonwealth Edison Company and ITT Research Institute presented at the IEEE PES Winter Meeting, New York, N.Y., January 1974, Transaction Paper T 74 057-6.

FEDERAL POWER COMMISSION  
WASHINGTON, D.C. 20426

IN REPLY REFER TO:

Dr. F. E. Gartrell  
Director of Environmental Planning  
Tennessee Valley Authority  
Chattanooga, Tennessee 37401

JUN 11 1973

Dear Dr. Gartrell:

This is in response to your letter dated March 6, 1973, requesting comments on the TVA's Draft Environmental Statement for the Bellefonte Nuclear Plant Units 1 and 2.

The following comments review the need for the facilities in regard to the adequacy and reliability of the affected power systems, and matters related thereto, in compliance with the National Environmental Policy Act of 1969, and the April 23, 1971, Guidelines of the Council on Environmental Quality.

In preparation of these comments, the Federal Power Commission's Bureau of Power staff has considered TVA's Draft Environmental Statement; related reports made in response to the Commission's Statement of Policy on Adequacy and Reliability of Electric Service (Order No. 383-2); and the staff's analysis of these documents, together with related information from other FPC reports. The staff generally bases its evaluation of the need for a specific bulk power facility upon long term considerations as well as upon the load-supply situation for the peak load period immediately following the availability of the new facility. It should be noted that the useful lives of the Bellefonte units are expected to be 30 years or more. During that period the units will make a significant contribution to the adequacy and reliability of the electric power supply in the TVA service area.

According to the Draft Environmental Statement the two-unit Bellefonte plant will have a nameplate generating capability of 2664 megawatts. Unit 1 is scheduled for September 1979 and Unit 2 for June 1980. These dates correspond with those given for two nuclear units of 1170 MW each projected by TVA in the April 1, 1973, response of the Southeastern Electric Reliability Council (SERC) to FPC Order 383-2. The units are not otherwise identified in the SERC report. In the discussion of the need for the Bellefonte units, at pages 1.3-4 through 1.3-7 in Volume 1 of the Draft Environmental Statement, it appears that 1055 MW has been used for Unit No. 1 and 1069 MW for Unit No. 2, and at page 1.3-7 reference is made to 1000 MW of replacement capacity for Unit No. 1. It would be convenient for the final environmental statement to specify clearly the capability to be associated with the Bellefonte Units.

The information on projected loads and generating capability for the period winter 1979-1980 through winter 1981-82, at page 1.3-4 Volume 1, shows reserve margins significantly less than 20 percent except for the summer of 1981, even with the proposed units in operation. TVA has established that a margin somewhat in excess of 20 percent is needed to maintain the desired reliability level of not more than one day loss-of-load probability in ten years.

Additional information, on loads and capacity of TVA combined with several other systems in its area, is available in the SERC report referred to above. These data show that the area-wide reserve margins, although greater than that of TVA alone, are still low enough during the period studied to support the need for the Bellefonte units (see tabulation below).

LOAD AND CAPACITY - TVA AREA  
WITH THE BELLEFONTE UNITS AS SCHEDULED

	<u>Winter</u> <u>1979-80</u>	<u>Summer</u> <u>1980</u>	<u>Winter</u> <u>1980-81</u>	<u>Summer</u> <u>1981</u>	<u>Winter</u> <u>1981-82</u>
Capacity MW	33,430	34,575	35,800	36,975	38,200
Peak Demand MW	31,087	27,064	32,561	28,328	34,215
Interchange MW <u>1/</u>	(2,060)	2,060	(2,060)	2,060	(2,060)
Load Served MW	29,027	29,124	30,591	30,388	32,155
Margin MW	4,403	5,451	5,209	6,587	6,045
%	15.2	18.7	17.0	21.7	18.8

WITHOUT THE BELLEFONTE UNITS 2/

Margin MW	3,233	3,111	2,869	4,247	3,705
%	11.1	10.7	9.4	14.0	11.5

1/ Seasonal diversity exchange with other systems. ( ) indicates receipt of capacity by TVA.

2/ Each at 1170 MW.

The TVA area is one of four sub-areas of SERC which are sufficiently interconnected that some capacity can be interchanged. Therefore, it is appropriate to consider the Bellefonte units in the context of total SERC reserves. In the SERC report, it is stated that the SERC regional reserve is expected to be 18.1 percent in summer 1980 and 19.1 percent in summer 1981. We consider these reserve margins, which include the Bellefonte units, to be barely adequate; without the Bellefonte plant the reserve level would be marginal.

We are in accord with TVA's conclusions that purchased power, hydroelectric sources, and gas turbines are not viable alternatives for the projected base load capacity of the Bellefonte plant, and that oil or natural gas would not be prudent economic choices for steam plant fuel.

The comparison of nuclear and coal plant economics appears to be based on an annual capacity factor of about 64 percent, which is realistic according to information available to Bureau of Power staff. The investment costs used in the comparison are within the range of costs projected by other utilities. The fuel costs, however, are lower than have been projected by many other utilities, especially for the coal-fired alternative plant. 2

Adequate discussion of the transmission lines to be associated with the Bellefonte plant is provided and it appears the facilities should be adequate to transmit the power from the plant.

We consider that the capacity to be provided by the Bellefonte plant is needed to assist TVA in meeting its projected loads.

In accordance with the request in the last paragraph of your letter, we are sending a copy of these comments to the Directorate of Regulatory Standards, Atomic Energy Commission, Washington, D. C. 20545.

Very truly yours,

  
T. A. Phillips  
Chief, Bureau of Power

1. The dependable capacity used for the Bellefonte units 1 and 2 is 1,170 MW each. Apparently, the Federal Power Commission surmised that the unit capacity could be obtained as a difference between the deficiencies for a 12-month delay (table, page 1.3-6) and the deficiencies for the units on schedule (table, page 1.3-4).
2. We agree that the fuel cost of 25 cents per million Btu used in the nuclear and coal-fired comparison is low by comparison to today's prices. The 25-cent coal cost was an estimate made in 1970 for use in comparing relative costs of coal-fired and nuclear generation. Current estimates reflect about 70 cents per million Btu for low-sulfur coal and 50 cents per million Btu for high-sulfur coal.

RESPONSE TO THE COMMENTS OF MR. WILLIAM E. GARNER ON THE PROPOSED AND  
ALTERNATIVE ACCESS RAILROAD ROUTES

As a result of a meeting on March 14, 1974, between Mr. William E. Garner, counsel for intervenors in the AEC licensing proceedings for the proposed Bellefonte Nuclear Plant, and Messrs. Beauchamp E. Brogan and David G. Powell of TVA, a reassessment of the routing of the access railroad to the plant was undertaken.

Mr. Garner commented that the alternate route across Town Creek would not cross as many large tracts of land as the proposed route. An investigation of property lines along the alternate route revealed that 11 tracts of land would be crossed on the alternate route, compared to 2 tracts on the proposed route. Tracts on the alternate route are not as large as the tract owned by Mrs. William E. Garner, et al., which the proposed route crosses. However, the proposed route does not cross as many property lines.

Mr. Garner commented that the proposed access route would conflict with the projected land use classification of urbanization in TVA's draft environmental statement. Figure 2.9-1 of the draft environmental statement has been revised to reflect projections in the "Sketch Development Plan, Hollywood, Alabama (March 1973)" and more details of the "Land Development Plan and Sketch Thoroughfare Plan, Scottsboro, Alabama (January 1971)." This revised figure is contained in this statement as figure 2.9-2. These studies show the projected pattern of residential, recreational, institutional, commercial, and industrial development in the area. The proposed route provides better access to more potential industrial land than does the alternate route.

Mr. Garner commented that he and Mrs. Garner plan commercial and residential development of their land, but that they have no developed or definite plans on how such development would take place. Further development of land use plans, both for the Garner property and for other property, could have an effect on the relative advantages for each route for the access railroad.

In addition to the above discussion, TVA has considered the following factors.

Preliminary cost estimates show no significant differences between the two routes, although potential rock excavation on the alternate route could make its cost higher.

The alternate route could require about 185,000 yds<sup>3</sup> of borrow excavation, while the proposed route would require about 90,000 yds<sup>3</sup>.

Two and possibly three residences would be affected and may have to be relocated along the alternate route, while the proposed route would involve no relocations.

There would be at-grade crossings of two county roads on the alternate route, with one crossing possible requiring a grade separation, while the proposed route has only one grade crossing of a county road.

An additional discussion of the rail access routes is in section 2.9 of this statement.

There would be no significant difference in the environmental effects of the two locations. However, the proposed route appears to offer advantages over the alternate which indicate that the proposed route should be selected.

## 8.0 BENEFIT-COST ANALYSIS

This section provides an overall assessment of the economic, technical, and other benefits of the Bellefonte Nuclear Plant weighed against the environmental costs, with the alternatives considered which would affect the balance of values.

TVA from its very inception has been deeply committed to the tasks of environmental improvement. The President in transmitting to Congress in 1933 the bill that became the TVA Act said that TVA ". . . should be charged with the broadest duty of planning for the proper use, conservation, and development of the natural resources of the Tennessee River drainage basin and its adjoining territory for the general social and economic welfare of the Nation." It is on the basis of these principles that TVA plans and conducts all its activities, be they planning, constructing, and operating a nuclear power plant; planning, building, and operating a water control project; providing research to develop a new fertilizer; setting aside areas for fish and wildlife; developing improved hardwood tree strains; or seeking ways to utilize the rugged scenic qualities of some of the region's natural streams. In all of these and many other varied resource development programs, TVA is deeply conscious of its responsibilities to the people in the TVA region and in the Nation. This posture invariably calls for a balancing of a variety of interests and, finally, decision and action in which differences are reconciled insofar as possible to best serve the needs of the greatest number over the longest possible time. Inherent in this is the requirement of finding a balance between the needs of man, including his need for useful employment, and the safeguarding of his physical environment.

In TVA electric power is regarded as a tool for economic development. Its use has been encouraged as a means for improving the quality of life in the region. Fitted into a comprehensive, unified development program, it has helped ease the burdens of drudgery; provide more jobs and more productive employment; bring the amenities of life to an ever-increasing number of people; and generally improve the health, education, and living conditions of the people.

An ample supply of low-cost electric energy, integrated with a total resource development program, has been a major factor in the progress achieved by the TVA region since 1933. Employment, income, and productivity have all increased with a shift from a primarily agricultural to an industrial economy.

The uses of electricity are many. To the residential user it provides lighting, refrigeration, cooking, washing and drying of clothes, heating, air conditioning, and education and entertainment via radio and television, to name but a few. Most stores, banks, and other commercial ventures are dependent on electricity for conducting business. In industry it is an essential element by which productivity has been increased with an attendant improvement in living standards. While in most industrial activities the cost of electric power is a small fraction of the total cost of production, without electricity modern industry could not provide the Nation with the goods and services it demands. In the aluminum, electrochemical, and metallurgical industries, electricity is a significant component required in the manufacture of these essential products.

The addition of the Bellefonte Nuclear Plant to the TVA system will enable TVA to continue to carry out its responsibility to provide an ample supply of electricity for the TVA region. The benefits of the plant include the value of the electrical power to be generated, the potential for reduction of releases of combustion products to the atmosphere which would be associated with a fossil-fired station of equal capacity, the recreational and educational value to visitors to the plant, increased payments to local governments in lieu of tax payments, and a stimulant to the economic growth of the region by helping to assure an abundant supply of electrical power and increased employment potentials.

The costs of the plant include the commitment of about 1,500 acres of land for the lifetime of the plant; the rejection of about  $1.56 \times 10^{10}$  Btu/h to the air directly and via Gunterville Reservoir from cooling tower blowdown; the consumptive use by evaporation of about  $74 \text{ ft}^3/\text{s}$  of water; minor releases of radioactivity to the air and to Gunterville Reservoir; erosion of soil during construction; a very low probability of releasing radioactivity due to an accident in the plant or an accident during the transport of radioactive materials; and the monetary costs to construct, operate, and maintain the plant.

TVA has attempted, insofar as practicable, to detail those items covered in the Atomic Energy Commissions' proposed guide (issued for comment in August 1972) for benefit-cost analyses for new nuclear facilities in sections 8.1 and 8.2. The weighing and balancing of benefits and costs of alternative sites and subsystems is presented in section 8.3.

While various benefits and environmental costs have been quantified, some are necessarily expressed in qualitative terms. For example, the effect of natural draft cooling towers on aesthetics is treated qualitatively. Moreover, of those factors subject to quantification, all cannot reasonably be expressed in monetary values. Although the number of Btu's added to the cooling water blowdown can be numerically quantified, translation of that number to a monetary value is not reasonable in view of the wide range of variables influencing the significance of the impact. Environmental impacts, therefore, are quantified in commonly used terms such as numbers of fish, gallons of water, and tons of earth.

In addition to analyzing the need for base-load electrical capacity additions, the Bellefonte Nuclear Plant environmental review included an analysis of the alternatives for limiting environmental impacts during the construction of the project and the environmental impacts which will result from operation of the plant. During this environmental review, the design concepts for the plant have been chosen so as to provide a plant which approaches a minimum impact plant.

Specific system design concepts were decided as follows:

Gaseous Radwaste - The gaseous radwaste system is being designed to provide a radioactive decay period of 60 days for radioactive gases.

Liquid Radwaste - The liquid radwaste system is being designed to permit recycling of tritiated water to the maximum extent practicable and to permit treating spent condensate demineralizer

regenerants during periods when radioactively contaminated as a result of primary system to secondary system leakage.

Heat Dissipation - Heat dissipation will be by means of closed-cycle natural draft cooling towers.

With normal operation from the plant the maximum radiation dose to the hypothetical individual will be about 1 percent of that received from natural background radiation and the population dose within 50 miles of the plant in the year 2020 is projected at about 0.005 percent of the dose from natural background radiation. Therefore, radiation resulting from operation of the Bellefonte Nuclear Plant will result in no undue risk to the health and safety of the public.

With closed-cycle natural draft cooling towers the plant will operate so as to meet applicable water temperature standards.

Conclusion - This environmental review has evaluated the expected environmental impacts of the proposed project and has considered alternatives which would lessen environmental impacts. After weighing the environmental and monetary costs and the technical, economic, environmental, and other benefits of the project and adopting certain alternatives which affect the overall balance of costs and benefits by lessening environmental impacts, TVA has concluded that the overall benefits of the project far outweigh the monetary and environmental costs.

8.1 Benefits - The benefits of the Bellefonte plant are detailed below and are summarized in Table 8.1-1.

1. Electric power produced and sold - Bellefonte Nuclear Plant includes two units with a dependable capacity of 1,170 MW electrical each, or a total plant dependable capacity of 2,340 MW electrical. The units are scheduled for commercial operation as follows: unit 1, December 1979, and unit 2, September 1980. Since capacity is planned for on a system basis, it is not possible to identify the specific loads which the Bellefonte nuclear units will serve. For the purpose of the benefit analysis, it has been assumed that the plant serves loads based on the incremental increase in loads for each class of customers estimated between F.Y. 1973 and F.Y. 1980. The estimated peak load and sales for these years are identified in the following table:

	<u>F.Y. 1973</u>		<u>F.Y. 1980</u>		<u>Increase</u>	
	<u>Actual</u>	<u>Percent</u>	<u>Estimated</u>	<u>Percent</u>	<u>Load</u>	<u>Percent</u>
	<u>Load</u>	<u>Total</u>	<u>Load</u>	<u>Total</u>	<u>Load</u>	<u>Total</u>
Peak Demand (MW)	18,888		29,300		10,412	
Estimated Sales (million kWh):						
Residential	30,637	29.6	46,279	28.7	15,642	27.0
Commercial	12,908	12.5	22,547	14.0	9,639	16.6
Industrial	37,085	35.8	55,259	34.1	18,174	31.4
Government	18,259	17.7	30,285	18.8	12,026	20.7
Other Sales	<u>4,584</u>	<u>4.4</u>	<u>7,090</u>	<u>4.4</u>	<u>2,506</u>	<u>4.3</u>
TOTAL SALES	103,473	(100)	161,460	(100)	57,987	(100)

The value of a unit of electric energy to the user varies widely depending on the availability and cost of alternative energy sources. No attempt was made to identify such values in this analysis. However, the price customers pay for electric energy presumably establishes a minimum value to the user. Based on the present rate structures of TVA and the distributors of TVA power, the following average prices to the ultimate consumer are estimated:

Residential	1.519 ¢/kWh
Commercial	1.421 ¢/kWh
Industrial	0.933 ¢/kWh
Government	0.788 ¢/kWh
Other	1.276 ¢/kWh

For the purpose of estimating the present value of the revenue received from the sale of this energy it has been assumed that the Bellefonte plant will operate as shown in the following table during its 35-year life:

<u>Years</u>	<u>Capacity Factor</u>	<u>Annual Net Generation (million kWh)</u>	<u>Total Transmission and Distribution Losses (million kWh)</u>	<u>Annual Energy Available For Sale (million kWh)</u>
1-15	80%	16,399	1,123	15,276
16-25	55%	11,274	772	10,502
26-35	40%	8,199	562	7,637

Using the energy available for sale and the current prices paid for electricity shown above, a discount rate of 8 percent, and the assumption that both units operate for the same time period, a value of the sales from the plant was estimated and is presented in the benefit description form. The results are summarized below:

ELECTRIC POWER PRODUCED AND SOLD - BELLEFONTE NUCLEAR PLANT

Levelized Annual Energy Generation (kWh)	14,779 x 10 <sup>6</sup>
Levelized Total Annual Losses (kWh)	1,012 x 10 <sup>6</sup>
Levelized Annual Energy Available for Sale (kWh)	13,767 x 10 <sup>6</sup>

	<u>Average Annual Energy Available For Sale - kWh</u>	<u>Value of Sales During Plant Life 1974 Dollars</u>	<u>Average Annual Value - Dollars</u>
Energy Sold:			
Residential	3,717 x 10 <sup>6</sup>	658,000,000	56,500,000
Commercial	2,285 x 10 <sup>6</sup>	379,000,000	32,500,000
Industrial	4,323 x 10 <sup>6</sup>	470,000,000	40,300,000
Government	2,850 x 10 <sup>6</sup>	262,000,000	22,500,000
Other	592 x 10 <sup>6</sup>	89,000,000	7,600,000
Total Sold	13,767 x 10 <sup>6</sup>	1,858,000,000	159,400,000

Historically, electricity rates have declined until the mid-1960's. Events of the more recent years have caused this trend to reverse. Higher prices for fuels, higher interest rates, increases in construction costs, and costs of pollution control equipment have been significant factors causing the increases in rates for electric utilities. It was necessary for TVA to increase its rate schedules in 1967, 1969, 1970, 1973, and 1974. The effect of these rate increases has resulted in the average cost of electricity to the consumer increasing by 85.9 percent. Thus, the use of current rates could significantly understate the future sale price.

2. Payments in lieu of taxes - Estimates of payments in lieu of taxes include estimates of payments to state and local governments by TVA and by distributors of TVA electricity. Estimates are based on current rates of payment related to the energy which will be generated by the plant.

3. Regional gross product - Benefits of the Bellefonte plant to regional gross product cannot be exactly quantified monetarily. However, a correlation has been made of the average annual dollar flow of gross product with the use of the Bellefonte electrical power in the TVA power service region. This correlation is based on using the average power generation and relationships between gross product and kilowatt-hours equivalent of all energy consumed. The industrial gross product factor was obtained as a product of the relationship between value added and kWh equivalent (Census of Manufacturers, 1967) and the relationship between gross product from manufacturing and value added by manufacturing (Census of Manufacturers, 1967 and Survey of Current Business). The numerical value of the industrial gross product factor was found by this method to be \$0.0649 per kWh. The commercial gross product factor was obtained by comparing gross product from commercial activities and an assumed electrical energy output of 25 percent of total energy input to the commercial sector (Energy in the American Economy, 1850-1975, Shurr and Netschert). Numerical values of this factor were \$0.187 per kWh for 1967 and \$0.184 per kWh for 1969. Giving slightly more weight to the recent figure, \$0.185 per kWh was selected as the commercial gross product factor. Industrial power consumed was assumed to include government use of electrical energy. The resulting average annual dollar flow of gross product is estimated at about \$890 million.

As noted above, no additional quantification to arrive at a monetary benefit is considered possible. This is because the comparison of dollar value of products produced and energy consumed does not consider other variables in the production of products, such

as wages of workers and efficiencies of individual production processes. It should be noted that a plentiful energy source has long been considered essential in the economic and industrial expansion of any region. As required by the TVA Act, as amended, TVA maintains an ample supply of electrical energy in the area in which it conducts its operations. A comparison of statistics in the TVA region with national statistics implies there are some beneficial effects of this plentiful energy source. In 1960 gross regional product was 2.26 percent of national; in 1970 this had increased to 2.69 percent. In 1960 personal income in the region was 64 percent of the national value; in 1970 this had increased to 75 percent. TVA considers that the ample availability of electricity as an energy source has helped realize these growth rates.

4. Recreation - As discussed in Section 2.9, preliminary plans for a recreational development on the peninsula indicate that the estimated present worth value of these benefits will be about \$2,800,000, (1985 dollars).

In addition, the recreational benefits of the visitor's center at the Bellefonte plant are estimated at 4,000 visits per year. This estimate of recreational visits is exclusive of the estimate of educational visits to the plant, which is given below. At a value of \$0.75 per visit, the annual value of these visits is estimated to be \$3,000.

5. Air quality - Since the Bellefonte plant is a baseload plant, approximately 5.2 billion kWh will be available during the baseload period to replace coal-fired generation which would otherwise have consumed about 2.3 million tons of coal per year. This will result in annual reductions in particulate emissions of about 2,300

tons, SO<sub>2</sub> emissions of about 119,000 tons, and NO<sub>x</sub> emissions of about 16,900 tons when based on replacing coal-fired generation which uses coal of the quality now being burned and current technology.

6. Employment - Benefits to employment have been listed as the average annual number of workers whose jobs could be related to the consumption of electrical power produced by the Bellefonte plant. An industrial employment factor, relating kWh equivalent consumed in manufacturing to employment in manufacturing, was determined from national data from the Census of Manufacturers, 1967. A value of 5.4588 workers per million kilowatthours was obtained. A commercial employment factor was obtained by analysis of data from Energy in the American Economy, 1850-1975, by Schurr and Netschert. For 1967 this relationship was 14.83 workers per million kWh; for 1969, 13.39 workers per million kWh. The intermediate value of 14 was chosen for estimating the commercial portion of the employment value listed. Based on the portion of the Bellefonte Nuclear Plant generation allocated to commercial and industrial use, the potential exists for expanding the number of new jobs by about 71,100.

7. Education - The educational benefits of the Bellefonte plant are estimated to be 60,000 visits per year after the plant is operations.. The annual value of these visits, at \$0.75 per visit, is \$45,000. Educational visits by persons to the plant during its construction are estimated to be about the same number as after the plant is operational.

Table 8.1-1

BELLEFONTE NUCLEAR PLANT - BENEFITS

## Direct Benefits

Expected Levelized Annual Generation in Kilowatthours	14,779,000,000
Dependable Capacity in Kilowatts	2,340,000
Proportional Distribution of Electrical Energy -	
Expected Levelized Annual Delivery in Kilowatthours:	
Residential	3,717,000,000
Commercial	2,285,000,000
Industrial	4,323,000,000
Government	2,850,000,000
Other	592,000,000

Annual Revenues from Electrical Energy Generated  
in Dollars

Residential	56,500,000
Commercial	32,500,000
Industrial	40,300,000
Government	22,500,000
Other	7,600,000

## Indirect Benefits

In Lieu of Tax Payments (Local, State), Dollars/Year	6,800,000
Regional Product	See Text
Environmental Enhancement	
Recreational	
Visitor's Center, Dollars/Year	3,000
Other, Total Present Worth Dollars (1985)	2,800,000
Air Quality (Potential to Reduce Pollutants in Tons/Yr)	
SO <sub>2</sub>	119,000
NO <sub>x</sub>	16,900
Particulates	2,300
Employment - Potential Jobs Provided	71,100
Education - Dollars/Year	45,000

8.2 Monetary and Environmental Costs - The monetary (generating) and environmental costs of the Bellefonte plant for the minimum impact and plant design combinations of subsystems are detailed below and are summarized in Table 8.2-1. In addition, incremental generating costs and differences in environmental costs for alternatives for the gaseous radwaste system and the heat dissipation system are summarized in Tables 8.2-2 and 8.2-3 respectively.

Generating costs - The generating costs for the alternative combinations of subsystems have been computed using the following assumptions: current plant capital cost estimates of \$580 million (1973 dollars); a power generating cost of 2.2 mill/kWh (\$0.0022 /kWh); a declining plant capacity factor as discussed in section 8.1-1; incremental generating costs for alternative subsystems as listed on Tables 8.2-2 and 8.2-3; an 8 percent discount rate; and an assumed plant lifetime of 35 years. The results are summarized in Table 8.2-1.

1. Effects on natural surface water body -

(1) Cooling water intake structure -

Mortalities of fingerling and adult fish are not expected as a result of the design of the cooling intake structure to provide a maximum intake channel velocity of less than 0.2 ft/s. Larval fish mortalities are expected as a result of the passage of water through the cooling water system as discussed in paragraph (2) below.

(2) Passage through the condensers and retention in closed-cycle cooling systems -

(a) Primary producers and consumers - Phytoplankton and zooplankton passing through the cooling water system should not survive. Estimates of total daily quantities (by weight) were made based on concentrations taken during limited sampling in 1971 and 1972, estimates of the withdrawal volumes, and the assumptions of uniform draw by the intake and uniformity of sample distributions in horizontal and vertical cross sections. Additionally, estimates of maximum phytoplankton standing crop were made by converting the number of cells to equivalent biomass.

Maximum plankton entrainment estimates for the summer season are 896 pounds/day (dry weight) of phytoplankton and 8,960 pounds/day (dry weight) of zooplankton.

The inherent weakness in the estimates of plankton amounts are as follows:

1. The samples are "grab" samples that are not replicated throughout a day.
2. Phytoplankton cell numbers may double in as short an interval as one day.
3. Zooplankton standing crop is estimated with limited numbers of samples.
4. Zooplankton standing crop may change drastically within as short an interval as one week.
5. Communities of phytoplankton genera are measured and

described - not species populations and/or size and age groups within species populations.

6. Only indirect biomass estimates have been made to date.
7. Season trends develop within phytoplankton stocks as the result of changing solar energy values. The future monitoring program would underestimate these trends during the winter and spring quarters and overestimate in the fall quarter since samples are taken during the first or second week of the quarter. However, present sample schedules fit existing flow or discharge cycles in the river.

(b) Fish - Larval fish which pass through the plant in the cooling waterflow will be killed in this passage due to the temperature rise in the condensers, the duration of exposure to high temperatures, and to mechanical shock. An accurate assessment of the effects on larval fish populations cannot be made at this time. Relatively high concentrations of larval fish are expected in the area since extensive littoral area and productive embayments exist immediately upstream of the plant site. Even though no estimates of actual fish mortalities are possible since insufficient sampling data are available, no significant adverse effect is expected on the reservoir fish population due to the limited withdrawal requirements of the closed-cycle cooling towers.

(3) Discharge area and thermal plume -

(a) Physical water quality -

The total plant heat rejection to Gunter'sville Reservoir will be  $3.5 \times 10^8$  Btu/h from cooling tower blowdown. The volume of water in the

mixing zone for cooling water discharges is expected to be very small.

(b) Dissolved oxygen - Observations of the dissolved oxygen levels in the water in the natural draft cooling tower circuit at TVA's Paradise Steam Plant indicate that the aeration provided by the tower fill maintains dissolved oxygen levels in the water near saturation levels. Since the maximum expected temperature in the cooling tower blowdown is 93°F and the saturation dissolved oxygen level at this temperature is about 6.8 mg/l, no discharge of blowdown water with dissolved oxygen content less than 5 mg/l is anticipated.

(c) Aquatic biota - It is TVA's judgment that there is no basis for assuming irretrievable loss of aquatic biota owing to thermal discharges of the plant. Due to the mixing provided by the blowdown diffuser, the applicable temperature rise criteria will be met at all times.

(d) Wildlife - No effects on any area wildlife forms are anticipated from the limited thermal discharges to Guntersville Reservoir.

(e) Migratory fish - It has been judged that a barrier, in the strict sense of preventing or significantly decreasing or retarding fish migration, will not result from the cooling tower blowdown discharge due to the limited amount of heat discharged.

(4) Chemical effluents - As discussed earlier in section 2.5, the concentrations of chemicals to be discharged

from the plant will be within water quality standards prior to discharge. No significant environmental costs are expected from the chemical discharges.

(5) Radionuclides discharged to water

body - Doses are calculated according to the methods described in Appendix H. Tritium doses are included for an annual release of 300 Ci. Maximum annual dose rates or dose commitments for each annual intake are reported. Population doses are estimated for the entire Tennessee Valley region.

(a) Aquatic organisms - Dose rates (rads/yr) are for internal and external exposure to benthic invertebrates living in the vicinity of the Bellefonte Nuclear Plant.

(b) People - external - Calculations of the external dose rate to people involved in above-water activities (skiing, fishing, boating), in-water activities (swimming), and shoreline activities are described in Appendix H. The external dose to people involved in shoreline activities is expected to be very small. The simplifying assumption is made that all persons participating in shoreline activities receive the same dose rate as a person boating or skiing. The estimated individual dose rate of  $2.6 \times 10^{-8}$  rem/yr from shoreline activities exceeds the more realistic estimates for above-water activities and in-water activities.

(c) People - ingestion - Maximum dose commitments to the thyroid for the water and fish pathways are shown for both the individual and the population.

(6) Consumption of water - Although estimated evaporation and drift loss rates total about  $74 \text{ ft}^3/\text{s}$  (147 acre-feet per day), no significant effects on either downstream water supplies or irrigation supplies occur due to the insignificant size of these loss rates relative to average streamflow ( $35,300 \text{ ft}^3/\text{s}$ ). Yearly evaporative losses would be a maximum of about 54,000 acre-feet.

(7) Plant construction -

(a) Physical water quality -

During the construction period there will be some dredging of material in Gunterville Reservoir. The use of closed-cycle cooling towers with relatively small makeup water and blowdown water requirements will result in smaller cooling water intake and discharge facilities than for once-through cooling. This will result in correspondingly smaller dredging requirements. All construction activity will be conducted so as to meet all applicable water quality standards. Thus, no dilution volume is required.

(b) Chemical water quality -

Chemicals used during construction, including but not limited to chemical cleansing agents, water treatment chemicals, and chemicals used in sewage treatment, will only be released to Gunterville Reservoir in solutions with concentrations which meet chemical water quality standards. Thus, no reservoir dilution volume is required.

(8) Other impacts - No other significant environmental effects have been identified for Gunterville Reservoir. The water surface in Town Creek embayment will be forced to a small channel by the access road causeway and water velocity will be increased

at the causeway opening. Boat traffic to Town Creek will be restricted to small craft by the size of the culvert passageway.

(9) Combined or interactive effects -

There is no evidence to indicate that the combined effects of a number of impacts on any population or resource is not adequately indicated by the measures of the separate impacts listed above.

(10) Net effect on Guntersville Reservoir -

The construction and operation of the Bellefonte Nuclear Plant, considering the alternatives utilized to minimize environmental effects, is not expected to have any noticeable effect on Guntersville Reservoir. Neither is it expected to prohibit any of the normal uses of the reservoir.

2. Effects on ground water -

(1) Raising or lowering of ground water

levels - Water withdrawals for the Bellefonte plant should have no effect on local ground water levels since relatively small quantities of water are withdrawn and since Guntersville Reservoir water levels are maintained according to TVA's reservoir operating guides. Normal fluctuations in water levels in the reservoir are from elevation 593 in winter to elevation 595 in late spring. Minor local ground water disturbances may occur as a result of plant construction, but no permanent ground water level changes are anticipated.

(2) Chemical contamination of ground

water - Chemicals discharged from the plant are at such concentrations when discharged that water quality standards are met. Within the plant tanks, drains, pipelines, and transfer and storage lines are isolated

from the ground by concrete and other barriers. Thus, no chemical contamination of ground water is expected.

(3) Radionuclide contamination of ground water -

(a) People - Dose commitments for the annual intake of ground water are based on the calculations described in Appendix H. Conservative assumptions are made for these calculations because accurate data are unavailable. Therefore, the population dose commitments from contaminated ground water are overestimated.

(b) Plants and animals - Calculations of doses to aquatic plants and animals living in the Tennessee River near the Bellefonte Nuclear Plant are described in Appendix H. Doses to organisms exposed to ground water are expected to be less than the estimates of the doses from Tennessee River water, Table H-6 of Appendix H, because of the dilution afforded by uncontaminated water.

(4) Other impacts on ground water - No other significant impacts on ground water have been identified.

3. Effects on air -

(1) Fogging and icing caused by evaporation and drift -

(a) Effects on local ground transportation - The analysis of effects on local ground transportation of fogging and icing of the heat dissipation alternatives is based on

the procedural methods described in section 2.6. As indicated in the same section, natural-draft cooling towers would affect ground transportation 80 hours per year. Closed-cycle mechanical-draft towers could affect ground transportation 495 hours per year. In the combined cycle, mechanical-draft cooling towers should affect ground transportation less often, or about 90 hours per year. Operation of spray canals in the closed cycle could affect ground transportation 530 hours per year. In the combined cycle, spray canal operation should affect ground transportation less, or about 82 hours per year. Fogging from operation of the cooling lake should affect ground transportation 4,068 hours per year.

(b) Effects on air transportation -

Analysis of Paradise Steam Plant natural-draft cooling tower plume behavior shows that the maximum extent of plumes or fogs from cooling tower systems is about 5 miles. Since the nearest airport is located at Fort Payne, Alabama, about 20 miles southeast of the site, no interference with commercial airport operation is anticipated from any heat dissipation alternative.

(c) Local effects on water

transportation - Closed-cycle natural-draft cooling towers should have no effects on water transportation and because of the distance from the river, the cooling lake should have no effect. Analysis of the effects of mechanical-draft towers on river fogging are based on the procedural methods described in section 2.6. These analyses showed that river traffic could be affected 240 hours per year when operating with

closed-cycle mechanical-draft cooling towers. Spray canals operating in the closed cycle could affect water transportation 305 hours per year. In addition to plume effects, water transportation could be affected by fogs resulting from heated water releases during combined cycle operation of cooling towers or spray canals. Water transportation could be affected 221 hours, 183 hours, and 231 hours for combined-cycle operation of mechanical-draft cooling towers, natural-draft cooling towers, and spray canals, respectively.

(d) Effects on plants -

Vegetation should not be damaged by fogs or plumes generated by the alternative cooling systems because daily exposure to excessive moisture should be of short duration (5 hours or less for all alternative schemes) and should occur most frequently during predawn and postdawn hours, periods when vegetation is normally exposed to naturally occurring high relative humidities and dew.

(2) Chemical discharge to ambient air -

Resulting annual average pollutants due to gaseous emissions from the plant's auxiliary boilers and diesel generators have been estimated assuming combustion of  $4.8 \times 10^6$  gallons per year of fuel oil with 0.5 percent sulfur content. Resulting annual average ambient concentrations for shorter averaging time periods assume a consumption rate of 1,815 gallons per hour. The expected emissions, as tons per year, and maximum concentrations, as percents of the ambient air quality standards shown in section 2.5 are given in the following table.

<u>Pollutant</u>	<u>Percent of Secondary Ambient Air Quality Standard</u>	<u>Emissions in Tons per Year</u>
Particulates	0.38	19.3
Sulfur dioxide	1.59	189.0
Carbon monoxide	$3.63 \times 10^{-5}$	0.09
Hydrocarbons	0.31	4.9
Nitrogen oxides	0.14	252.0

No odor originating from normal operation of the plant should be perceptible at any point offsite.

(3) Radionuclides discharged to ambient

air -

(a) People - external - Individual

and population external dose rates from the nuclides expected to be released to the air are computed as described in Appendix I. The maximum external dose to any organ, including the whole body, is the dose delivered to the skin. This dose rate is presented for all alternatives.

(b) People - ingestion -

Individual and population thyroid doses from the ingestion of iodine released to the air are computed as described in Appendix I. This dose rate is presented for all alternatives.

(c) Plants and animals - The

dose rate to plants and animals from radionuclides expected to be discharged to the air is assumed to be the same as the external dose rate to people.

(4) Other impacts on air - No other

significant impacts on the air have been identified.

4. Effects on land -(1) Preemption of land - Site land

requirements are about 1,500 acres for the base plant. Feasible alternatives for heat dissipation requiring additional land are discussed in section 2.6.

(2) Plant construction -(a) Noise effects on people -

Ambient noise levels due to construction of the Bellefonte plant are not expected to pose any problems to the surrounding population. The surrounding land has a low population density which will minimize the effects of construction noise.

(b) Accessibility of historical

sites - Old-town Bellefonte is west of the site. Its potential historical and archaeological significance is now being explored by the Alabama Historical Commission. Access to Bellefonte will not be affected by the location of the plant at this site.

(c) Accessibility of archaeo-

logical sites - The potential archaeological significance of the site is now being investigated. Two sites have been identified for further investigation; however, no access restrictions are contemplated.

(d) Wildlife - No effects on

wildlife are expected except for the dislocation of wildlife in the immediate site area.

(e) Erosion effects - The

average amount of soil displaced by erosion due to construction activities at the Bellefonte site is estimated to be about 770 tons per year throughout the construction period. This estimate includes the

effects of direct erosion of cleared land and also the displacement of dredge material in Guntersville Reservoir.

(3) Plant operation -

(a) Noise effects on people -

Operation of the plant is essentially noiseless at the site boundary except for the very infrequent operation of the air blast circuit breakers.

(b) Aesthetic effects on

people - Aesthetics cannot be quantified. The design of the Bellefonte Nuclear Plant has as one objective the creation of harmony between plant and environment. The architectural design and site development should provide an aesthetically pleasing appearance and mitigate the transition in land use of the project area from agricultural to industrial.

(c) Wildlife - No effects on

wildlife are expected except for the dislocation of wildlife in the immediate site area.

(d) Flood control - The

Bellefonte project has no implication for flood control.

(4) Salts discharged in drift from

cooling towers - During normal operation the cooling water chemical content will be approximately double the chemical content of the makeup water. However, for the proposed method of operation following periods of low or no streamflow when blowdown is withheld, the total dissolved solids concentrations within the cooling tower system are not expected to exceed about 500 mg/l. No significant effects are expected from drift discharges from the towers.

(5) Transmission route selection -(a) Preemption of land - The

Bellefonte plant will require 72.9 miles of new transmission lines. New land area required for transmission line right of way is estimated to be 1,550 acres.

(b) Land use and land value -

TVA attempts to locate new transmission lines so as to minimize the total effect of the lines on the environment. As planned at Bellefonte, no visually sensitive areas or areas of high population density are to be crossed.

At this time none of the transmission line rights of way for Bellefonte Nuclear Plant site has been acquired. Because of the location of the site, only rural farm, some rural nonfarm, and minor lake resort property will be affected by lines emanating from the plant. On the basis of continuing studies, these transmission lines will have no unusual impact on property values.

Recent investigations revealed no discernible loss in value attributable to the transmission lines outside the right of way proper. The only measurable impact occurs within the right of way where buildings are prohibited. Investigations in other agricultural, residential, and industrial areas throughout the TVA power service area show similar land value behavior characteristics, and TVA anticipates no adverse effects by transmission lines on land values from the Bellefonte Nuclear Plant. TVA can find no evidence that the presence of the transmission line system will inhibit orderly land development and normal transition in highest and best use from

agricultural use to residential, commercial, and industrial use when future demands require such transition.

(c) Aesthetic effects on

people - In the siting of new transmission lines for Bellefonte, the minimum of undesirable features has been sought. Unavoidable state and U.S. highway crossings will number 3, and major river crossings will number 3. However, no crest, ridge, or other high point crossings are expected. Also, no long views of transmission lines, either perpendicular or parallel to major roadways, are anticipated.

(6) Transmission facilities construction -

(a) Land adjacent to rights

of way - No permanent access roads are normally installed in conjunction with transmission line construction. Some existing field roads and lanes are improved and are left for use by the landowners. The lengths of such improved roads cannot be determined until lines are designed, right of way easements are acquired, and the possibilities of such roadways are discussed with the individual landowners.

(b) Land erosion - The removal

of existing trees and shrubs will increase the potential for erosion until new ground cover is planted and is well established. TVA minimizes this potential by a policy of minimum soil disturbance and speedy ground cover replacement during the transmission line construction phase.

(c) Wildlife - As indicated

earlier in section 2.2, the interface between a transmission line right of way and forested land will often produce or attract more kinds and numbers of animals than would occur in either habitat alone. No lasting

adverse effects on animal species or populations are anticipated during the brief construction period.

(7) Transmission line operation -

(a) Land use - Approximately 25 percent of the new transmission line rights of way are now under cultivation and can remain in this use if the individual owners so desire. An additional 25 percent is uncultivated open land. The remaining 50 percent is woodland which is in general in poor quality timber. As indicated in section 2.2, various uses of cleared rights of way are permitted. The percentage of rights of way for which no multiple-use activities are planned cannot be estimated since individual landowners have this option on their individual land holdings.

(b) Wildlife - Section 2.2 provides a discussion of wildlife effects. In summary, wildlife habitat is increased because of the interface between differing types of vegetation on the rights of way and off.

(8) Other land impacts - In a recently completed study for the Browns Ferry Nuclear Plant site, no significant changes to land values were discovered after 5 years of activity which included the major construction period for the plant. Investigations revealed no adverse effect on real estate values within 5 miles of the Browns Ferry Nuclear Plant site. Sale prices for farmland and rural residential properties equal or exceed prices of comparable properties in other areas of Limestone County. Lakefront subdivision lots in the 5-mile zone apparently are not as desirable as those downstream on the Elk River embayment, and any difference in value is attributable to

such factors as silt problems, prevailing winds, dock damage on the main channel, and poor road access. In no event did the investigations show any discernable effect, either adverse or otherwise, attributable to proximity to the nuclear plant site.

(9) Combined or interactive effects -

There is no evidence to indicate that the combined effects of a number of impacts on any population or resource is not adequately indicated by the measures of the separate impacts listed above.

(10) Net effects on land - The net

effect of the Bellefonte Nuclear Plant on the land resources is the commitment of about 1,500 acres of land for the use of power production during the plant's lifetime and the restriction on the use of about 1,550 acres of transmission line rights of way during the lifetime of these lines.

5. Cross category effects -

(1) Transportation - In a normal year

Bellefonte will receive about 12 truck shipments of new fuel; will make about 140 truck, or from 10 to 14 rail, shipments of spent fuel; and will make about 25 shipments of radioactive wastes. In addition, deliveries of fuel oil and chemicals will require receiving about 486 tank-truck shipments. After its disposal is required (around the seventh to twelfth year of plant operation, based on 2.5  $\mu\text{C}/\text{ml}$  primary coolant concentration) the transportation requirements for offsite disposal of tritium would be about 13 tank-truck shipments per year if shipped as liquid or about 60 truck shipments if shipped as solid. The environmental review has demonstrated that the transportation shipments to and from the plant, considering normal and accident conditions, can be accomplished with a minimum impact.

(2) Accidents - A spectrum of postulated accidents ranging in severity from trivial to very serious has been divided into 9 classes by AEC. This characterization of accidents by classifications brackets the qualitative assessment of environmental costs and benefits. Table 2.2-3 of section 2.3 gives a summary of the radiological consequences of the postulated accidents. This environmental risk, for the range of postulated accidents, considering the probability of occurrence indicates that the annual potential exposure to the population from all postulated accidents is a very small fraction of the exposure of the same population from natural background radiation and, in fact, is well within naturally occurring variations in background radiation levels.

Table 8.2-1

BELLEFONTE NUCLEAR PLANT - GENERATING AND ENVIRONMENTAL COSTS

Alternative	Plant with Minimal Environmental Impact	Current Plant Design
<b>Subsystems</b>		
Cooling	Closed-Cycle Natural Draft Cooling Towers	Closed-Cycle Natural Draft Cooling Towers
Gaseous Radwaste Treatment	Gas Absorption <sup>a</sup> or Cryogenic Distillation	60-Day Holdup
Liquid Radwaste Treatment	Filtration and Evaporation	Filtration and Evaporation
Chemical Treatment	Evaporation of Spent Demineralizer Regenerant Solutions	Neutralization of Spent Demineralizer Regenerant Solutions
Generating Cost	Total Value (1973 Dollars)	\$959.33 x 10 <sup>6</sup>
	Annualized	\$ 82.31 x 10 <sup>6</sup>
		\$958.95 x 10 <sup>6</sup>
		\$ 82.28 x 10 <sup>6</sup>

**Environmental Effects**

1. <u>Natural Surface Water Body</u>	Guntersville Reservoir		
1.1 Cooling Water Intake Structure	1.1.1 Fish Mortality	None Expected	None Expected
1.2 Passage through the Condenser and Retention in Closed-Cycle Cooling System of	1.2.1 Primary Producers and Consumers - Pounds per Year	See Text	
	1.2.2 Fish Mortality - Pounds per Year as Adults	See Text	

a. Minimum system with respect to primary impacts to offsite population due to plant gaseous releases.

Table 8.2-1

BELLEFONTE NUCLEAR PLANT - GENERATING AND ENVIRONMENTAL COSTS  
(continued)

Alternative		Plant with Minimal Environmental Impact	Current Plant Design
1.3 Discharge Area and Thermal Plume	1.3.1 Physical Water Quality - Btu/h Heat Rejection	$3.5 \times 10^8$	$3.5 \times 10^8$
	Acre-Feet of Water Affected - 5°F Isotherm	See Text	
	1.3.2 Oxygen Depletion - mg/l Decrease from Ambient Dissolved Oxygen Concentrations	See Text	See Text
	1.3.3 Aquatic Biota	See Text	
	1.3.4 Wildlife - Acres Affected by Thermal Discharge	0	0
	1.3.5 Fish Migration	No Thermal Barrier	No Thermal Barrier
1.4 Chemical Effluents	1.4.1 Chemical Water Quality - Dilution Volume to Meet Standards	0	0
	1.4.2 Aquatic Biota - Affected Population	0	0
	1.4.3 Wildlife - Acres Affected by Chemical Discharges	0	0

Table 8.2-1

BELLEFONTE NUCLEAR PLANT - GENERATING AND ENVIRONMENTAL COSTS  
(continued)

Alternative		Plant with Minimal Environmental Impact	Current Plant Design
	1.4.4 People - Lost User Recreational Days	0	0
1.5 Radionuclides Discharged to Water Body	1.5.1 Aquatic Organisms - rad/yr	$1.2 \times 10^{-1}$	$1.2 \times 10^{-1}$
	1.5.2 People, External - rem/yr man-rem/yr	$3.1 \times 10^{-5}$ 1.1	$3.1 \times 10^{-5}$ 1.1
	1.5.3 People, Ingestion - rem/yr man-rem/yr	$3.5 \times 10^{-5}$ 7.9	$3.5 \times 10^{-5}$ 7.9
1.6 Consumptive Use (Evaporative Losses)	1.6.1 People - Acre-Feet of Water Evaporated per Year	$4.5 \times 10^4$	$4.5 \times 10^4$
	1.6.2 Property - Acre-Feet of Water Evaporated per Year	Same as 1.6.1	Same as 1.6.1
1.7 Plant Construction	1.7.1 Physical Water Quality - Dilution Volume	0	0
	1.7.2 Chemical Water Quality - Dilution Volume	0	0
1.8 Other Significant Impacts		See Text	

Table 8.2-1

BELLEFONTE NUCLEAR PLANT - GENERATING AND ENVIRONMENTAL COSTS  
(continued)

Alternative		Plant with Minimal Environmental Impact	Current Plant Design
<u>1.9 Combined or Interactive Effects</u>		See Text	
<u>1.10 Net Effect</u>		None Noticeable	None Noticeable
<u>2. Ground Water</u>			
2.1 Raising/Lowering of Ground Water Levels	2.1.1 People - Gallons of Water Affected	0	0
	2.1.2 Plants - Acres Affected	0	0
2.2 Chemical Con- tamination of Ground Water	2.2.1 People - Gallons of Water Contaminated	0	0
	2.2.2 Plants - Acres Affected	0	0
2.3 Radionuclide Con- tamination of Ground Water	2.3.1 People rem/yr man-rem/yr	$1.7 \times 10^{-5}$ $1.3 \times 10^{-1}$	$1.7 \times 10^{-5}$ $1.3 \times 10^{-1}$
	2.3.2 Plants and Animals	See Text	
2.4 Other Impacts on Ground Water		None	None
<u>3. Air</u>			
3.1 Fogging and Icing Caused by Heat Dissipation System Evaporation and Drift	3.1.1 Ground Transportation - Hours per Year	80	80
	3.1.2 Air Transportation - Hours per Year	0	0

Table 8.2-1

BELLEFONTE NUCLEAR PLANT - GENERATING AND ENVIRONMENTAL COSTS  
(continued)

Alternative		Plant with Minimal Environmental Impact	Current Plant Design	
	3.1.3	Water Transportation - Hours per Year	0	0
	3.1.4	Plants - Acres Affected	0	0
3.2	3.2.1	Chemical Discharge to Ambient Air    Air Quality, Chemical	1.59% of standard	1.59% of standard
	3.2.2	Air Quality, Odor	No offsite odor	No offsite odor
3.3	3.3.1	Radionuclides Discharged to Ambient Air    People, External rem/yr man-rem/yr	1.0 x 10 <sup>-3</sup> 3.9	1.7 x 10 <sup>-3</sup> 7.9
	3.3.2	People, Ingestion rem/yr man-rem/yr	3.1 x 10 <sup>-5</sup> 2.2 x 10 <sup>-1</sup>	4.5 x 10 <sup>-5</sup> 3.3 x 10 <sup>-1</sup>
	3.3.3	Plants and Animals - rad/yr	1.0 x 10 <sup>-3</sup>	1.7 x 10 <sup>-3</sup>
3.4		Other Impacts on Air	None	None
4.		<u>Land</u>		
4.1	4.1.1	Preemption of Land    Land, Amount, in Acres	1,500	1,500
4.2	4.2.1	Plant Construction    People, Noise	No effects expected	No effects expected
	4.2.2	People, Accessibility of Historical Sites	No access restriction	No access restriction
	4.2.3	People, Accessibility of Archaeological Sites	No access restriction	No access restriction
	4.2.4	Wildlife	Site area only	Site area only
	4.2.5	Land, Erosion T/yr	770	770

Table 8.2-1

BELLEFONTE NUCLEAR PLANT - GENERATING AND ENVIRONMENTAL COSTS  
(continued)

Alternative		Plant with Minimal Environmental Impact	Current Plant Design
4.3 Plant Operation	4.3.1 People, Noise	See Text	
	4.3.2 People, Aesthetics	See Text	
	4.3.3 Wildlife Affected Area	Site area only	Site area only
	4.3.4 Land, Flood Control	No implication	No implication
4.4 Salts Discharged from Cooling Towers	4.4.1 People	See Text	
	4.4.2 Plants and Animals, Acres Affected	0	0
	4.4.3 Property Resources - Effect in Dollars per Year	0	0
4.5 Transmission Route Selection	4.5.1 Land, Amount, in Acres	1,550	1,550
	4.5.2 Land Use and Land Value	Restriction on right of way use No expected change in value outside right of way	
	4.5.3 People Aesthetics	See Text	
4.6 Transmission Facilities Construction	4.6.1 Land Adjacent to Right of Way	See Text	
	4.6.2 Land, Erosion	See Text	
	4.6.3 Wildlife	Habitat modification	Habitat modification
4.7 Transmission Line Operation	4.7.1 Land Use, right of way	Multiple use permitted	Multiple use permitted
	4.7.2 Wildlife	Habitat change	Habitat change

Table 8.2-1

BELLEFONTE NUCLEAR PLANT - GENERATING AND ENVIRONMENTAL COSTS  
(continued)

Alternative	Plant with Minimal Environmental Impact	Current Plant Design
4.8 Other Land Impacts - Land Value Effects	None	None
4.9 Combined Interactive Effects	See Text	
4.10 Net Effects	Commitment of 1,500 acre site and 1,550 acres of TVA right of way	
5. <u>Cross Category Effects</u>		
5.1 Transportation	5.1.1 Transport of Fuels and Radioactive Material	See Text
5.2 Accidents	5.2.1 Radiological Effects	See Text

Table 8.2-2

BELLEFONTE NUCLEAR PLANTALTERNATIVES FOR GASEOUS RADWASTE SYSTEMCOSTS WHICH VARY FROM BASE PLANT

<u>Alternative Gaseous Radwaste System</u>	<u>60-Day Holdup</u>	<u>Cyrogenic Distillation</u>	<u>Gas Absorption</u>
Incremental Generating Cost (thousands of dollars)	base	650	425
Dosage Rates to People from External Contact			
rem/yr	$1.7 \times 10^{-3}$	$1.0 \times 10^{-3}$	$1.0 \times 10^{-3}$
man-rem/yr	7.9	3.9	3.9
Dosage Rates to People from Ingestion			
rem/yr	$4.5 \times 10^{-5}$	$3.1 \times 10^{-5}$	$3.1 \times 10^{-5}$
man-rem/yr	$3.3 \times 10^{-1}$	$2.2 \times 10^{-1}$	$2.2 \times 10^{-1}$
Dosage Rate to Plants and Animals			
rad/yr	$1.7 \times 10^{-3}$	$1.0 \times 10^{-3}$	$1.0 \times 10^{-3}$

Table 8.2-3

BELLEFONTE NUCLEAR PLANTALTERNATIVES FOR HEAT DISSIPATION SYSTEMCOSTS WHICH VARY FROM BASE PLANT

<u>Alternative Heat Dissipation System</u>	<u>Cooling Lake</u>	<u>Spray Canal (Combined)</u>	<u>Spray Canal (Closed)</u>	<u>Mechanical Draft Towers (Combined)</u>	<u>Mechanical Draft towers (Closed)</u>	<u>Natural Draft Towers (Combined)</u>	<u>Natural Draft Towers (Closed)</u>
Estimated Incremental Generating Cost (thousands of dollars)	3,040	8,630	11,630	13,380	5,950	10,850	Base
Maximum Monthly Average Reservoir Heat Input (Btu/h)	$3.2 \times 10^8$	$15.6 \times 10^9$	$5.3 \times 10^8$	$15.6 \times 10^9$	$4.8 \times 10^8$	$15.6 \times 10^9$	$3.5 \times 10^8$
Water Consumed (acre-feet/day)	139	143	143	141	141	147	147
Transportation Affected (h/yr)							
Ground	4,068	82	530	90	495	12	80
Water	0	231	305	221	240	183	0
Additional Land Required (acres)	7,000	480	0	0	0	0	0
Estimated Structure Relocations	140	0	0	0	0	0	0
Erosion (tons/yr)	1,150	950	850	850	770	850	770

8.3 Weighing and Balancing of Alternative Generation, Alternative Sites, and Alternative Subsystems - In planning for a power system electrical capacity addition, the alternatives which are usually available are alternative forms of generating capacity, alternative sites for locating the capacity addition, and alternative design concepts in major plant systems.

1. Alternative generating capacity - An analysis of the alternatives for generating capacity addition in the time period when the Bellefonte plant is planned is given in section 4.1. The alternatives available were hydro, pumped-storage hydro, gas turbine, fossil steam, and nuclear generating units. Since base-load generation was required, the pumped-storage and gas turbine alternatives were eliminated since they are suitable for peaking only. Hydro units were not feasible because of a lack of sites for base-load generation of the amount required. Oil-fired and gas-fired units were rejected because an adequate fuel supply could not be assured.

The analyses showed that fossil steam and nuclear generation were the feasible alternatives for the required amount of base-load capacity. The analysis further showed that nuclear generation offered substantial advantages over the fossil generation both environmentally and economically. Based on this analysis, TVA decided that the nuclear generating capacity addition was more acceptable from the standpoint of economic and environmental impacts.

2. Alternative sites - From preliminary investigations of 30 potential sites for the proposed plant, eight sites were identified that had the desirable characteristics to warrant further

and more detailed study. Two of these sites (sites A and B) are located in the western portion of the TVA service area where the seismic conditions are not clearly defined. Therefore, these sites were eliminated from consideration as potential sites for the proposed plant pending a determination of the seismic design criteria. Of the six remaining sites four are located on Gunterville Reservoir (sites C, D, E, and F), one is located on Chickamauga Reservoir (site G), and one is located on Watts Bar Reservoir (site H). Conflicts or questions existed at three of the sites that made them less acceptable than the other three proposed sites. These included a conflict with the urbanizing growth of a local town, size limitations of the site, and economic penalties due to the possibility of highway relocation at site D, the encroachment on an important wildlife sanctuary, the depth of rock, and length of water conduit required at site F, and the additional cost of plant grading, rail access, and the lack of information indicating the suitability of the rock for a nuclear plant foundation at site H.

A detailed evaluation of sites C, E, and G was made considering the economic and environmental cost of locating the proposed plant at each of these alternative sites. It was concluded that each of these three sites was suitable for a nuclear plant.

A summary of the site evaluation factors is presented in Table 4.2-1, and a summary of the site-related economic costs is presented in Table 4.2-2 for these three sites.

Site G was found to have the greatest economic cost and the greater potential for land use conflicts because of its close proximity to the Hiwassee Island Game Management and Waterfowl Refuge Area and its more extensive transmission line and access facilities.

Sites C and E are both on Gunter'sville Reservoir approximately 23 miles apart, and many impacts would be very similar at each site. Land use plans indicated both sites are compatible for use as a nuclear plant; however, site E is in an area with no developed public recreation areas near the site, and site C is located within 3 to 5 miles of boat docks, private clubs, and a group camp.

Site E has an economic advantage of approximately \$10 million when compared to site C and over \$16 million when compared to site G. The population within 30 miles of site E is significantly less than the other two sites.

When considering the economic advantage of site E along with the less extensive access facilities, lower populations within 30 miles of the site, and the greater land use compatibility, TVA selected site E, Bellefonte, as the preferred site for the proposed plant.

3. Heat dissipation - The alternatives analyzed for heat dissipation were natural draft and mechanical draft wet cooling tower systems, spray canal systems, a once-through system utilizing bottom diffusers, dry cooling towers, and a cooling lake system. Analyses were performed using the following factors as a basis: feasibility, environmental considerations, and economic considerations. The analyses were carried to the extent required to determine the acceptability of each alternative when considering these factors.

Because there were some periods of insufficient riverflows by the plant site, it was determined that the temperature rise after mixing by a diffuser system would not meet applicable thermal

standards a sufficient amount of time to justify a completely open-cycle system. Thus a once-through cooling system utilizing only bottom diffusers was eliminated due to infeasibility. Dry cooling towers were not considered as an acceptable alternative because of lack of demonstrated feasibility for power plants of the size considered. Engineering details of turbine design, condenser design, and large dry tower designs are yet to be worked out. In addition, substantial economic penalties are associated with the use of dry towers and only insignificant environmental advantages could be realized at the proposed site. Details and environmental impacts for seven schemes for the remaining alternatives are discussed in section 2.6.

Estimates of environmental impacts were made as discussed above in section 8.2. The results are summarized in Table 8.2-3.

The cooling lake alternative would involve a lake of about 5,650 acres with a 29,000-foot-long dike dividing the lake and three dikes to impound the lake which would be 1,000, 4,000, and 6,000 feet long. The lake formed would be some 35 feet above the normal elevation of Gunterville Reservoir. While requiring the use of considerable land, the lake would provide the water cooling requirements of the proposed Bellefonte plant and could support a sizable sport fishery with reasonably intensive management. Such a lake would have the potential of attracting up to a quarter million fishing trips per year. In addition, the protective land, about 1,350 acres, adjacent to the lake necessarily acquired with that which would be inundated could be used to supply the desired access to the lake and could be

managed as a wildlife area. This land would have the potential to attract several thousand nonconsumptive wildlife users annually.

Selection of the cooling lake alternative would displace about 140 occupied structures. It is expected that fogs developed over the lake would frequently create a serious road hazard to travel on Highway 72. The cooling lake alternative would cost some \$3 million more than the proposed alternative.

A spray canal system would require a canal approximately 12,800 feet long and 200 feet wide. Three different arrangements and locations on the plant site were evaluated. One of the arrangements would require purchase of 480 additional acres of land. Blowdown holdup time would be longer for this alternative than for cooling towers because of the larger quantity of water in the system. One canal arrangement involved an intake located in Town Creek which might produce undesirable changes in the aquatic environment of the creek. Atmospheric plume lengths should be greater for spray canals than for cooling towers because the effluent would be dispersed much lower to the ground. As a result the spray canal alternative would cause the most fogging on Alabama Highway 40. A minor fogging potential would also exist for Alabama Highway 35. The spray canal schemes cost about \$8 to \$11 million more than the proposed alternative.

The mechanical draft cooling tower alternative would require four wood-filled cooling towers, each approximately 50 feet wide by 60 feet high by about 600 to 700 feet long. Selection of mechanical draft cooling towers would involve possible higher frequency of fogging and icing near ground level than the natural draft towers but possibly

less than for the spray canal alternatives. A smaller potential for fogging would exist for Alabama Highway 40, and an extremely small potential would exist for Alabama Highway 35. The use of mechanical draft towers would involve higher noise levels than the other alternatives. The two mechanical draft schemes would cost about \$6 million and \$13 million more than the proposed natural draft cooling system.

The use of natural draft cooling towers would require two towers about 500 feet in diameter and about 500 feet high. Use of natural draft towers would involve some increased ground-level and localized surface fogging and icing, but the effect on Alabama Highway 40 and U.S. Highway 72 would be less for this alternative.

However, a fogging potential associated with the roadway on Sand Mountain would exist for this alternative. The selection of natural draft towers has a \$3 million evaluated cost advantage over the next lowest cost alternative.

It was concluded that of the schemes considered for dissipating heat from the Bellefonte plant the closed-cycle natural draft cooling tower scheme resulted in the best balance of feasibility, environmental impact, and economic cost. Thus TVA has tentatively selected this method of heat dissipation for this plant and preliminary design is proceeding on this basis.

4. Chemical discharges - As discussed in Section 2.5, Nonradioactive Discharges, alternatives were considered for treatment of the regenerant solutions from the makeup demineralizer and the condensate demineralizer. The proposed system consists of neutralization of the chemical wastes from the makeup and condensate demineralizers and discharging them along with the other chemical wastes with the cooling

tower blowdown. The amounts and concentrations of the discharges from this system are given in Tables 2.5-1 and 2.5-2. The other alternatives would treat the chemical wastes from the makeup demineralizer and/or the condensate demineralizer by evaporation with the evaporator bottoms being disposed of by either onsite or offsite burial. The distillates would be recycled in the plant. Details of these systems are given in section 2.5.

The reduction of wastes discharged to the cooling tower blowdown and the relative costs of these alternatives are given in Tables 2.5-3 and 2.5-4. The implementation of any of these alternatives would result in an increase in impacts in other areas, such as an increase of materials usage and an increase in transportation.

There would be no significant reduction in environmental impacts by the implementation of any of these alternatives. The maximum reduction in the concentration of the affected parameters in the reservoir is less than the variation between the average and maximum concentrations naturally occurring at TRM 385.9. This reduction could only be achieved during a 4-hour period on those days that the demineralizer regenerant wastes would normally be discharged. It is concluded, therefore, that the additional expenditure of resources and increased impacts in other areas associated with the implementation of any of the alternatives considered is not justified. Thus TVA is proceeding with preliminary plant design based on providing neutralization of makeup and condensate demineralizer wastes and subsequent discharge of these treated plant wastes to Gunter'sville Reservoir.

5. Gaseous radwaste system - As discussed in section 2.4, alternatives for a gaseous radwaste treatment system were analyzed

during the environmental review process to determine the best system with respect to expected performance, proven reliability, and cost. The following alternatives were evaluated:

1. 60-day holdup
2. Cryogenic distillation
3. Gas absorption

Table 8.2-2 presents an evaluation of these alternatives. As shown in the table, the 60-day holdup system, assuming 0.25 percent fuel defects, results in an external annual dose rate to people of 1.7 mrem. The use of a cryogenic distillation system at a cost of \$650,000, or of a gas absorption system at \$425,000, would result in decreases to dosage rates to 1.0 mrem for each alternative. Neither the cryogenic distillation or gas absorption system has demonstrated performance and reliability in nuclear plant service. The cryogenic distillation system is a complex system compared to the gas decay system and could experience operating problems and presents the potential for accidental release of concentrated waste to the environment. The only experience to date with the gas absorption system has been with bench and pilot size systems.

Based on this analysis TVA has concluded that the 60-day holdup alternative, which results in a dose rate of 1.7 mrem per year, represents the best balance of economic cost, reduction in environmental impact, and feasibility. TVA believes the benefits to be gained by further reducing the radioactive gaseous releases are not commensurate with the cost associated with the reduction. The very low "fence post dose" is less than the numerical guidance provided by the proposed

Appendix I to 10 CFR Part 50. It also represents only about 1 percent of the naturally occurring background dose.

6. Liquid radwaste systems - Investigation of means to further reduce release of radioactive liquids to the environment and the subsequent weighing and balancing of alternatives resulted in the adoption of the proposed methods as described in section 2.4.

**It was judged that evaporation of radioactive condensate demineralizer regenerant solutions was preferable to release.** In addition, TVA presently plans to recycle tritiated liquid where practicable in order to minimize tritium discharge.

Both procedures reduce doses to the population while resulting in some increased impacts due to inplant doses, transportation, and commitments of ultimate disposal facilities and materials.

## 9.0 CONCLUSION

This environmental statement reflects the manner in which TVA has incorporated environmental considerations into the decision-making process for the Bellefonte Nuclear Plant.

The plant will interact with the environment in three principal ways: (1) release of minute quantities of radioactivity to the air and water, (2) release of minor quantities of heat to Gunterville Reservoir and major quantities to the atmosphere, and (3) change in land use from farming to industrial. Alternatives to minimize adverse environmental impacts have been considered, and alternatives were chosen for heat dissipation and radioactive waste treatment systems to reduce impacts to a minimum practical level. In addition, construction methods will be employed which minimize adverse impacts.

The plant as now designed closely approaches a minimum impact plant and can be constructed and operated without significant risk to the health and safety of the public.

Addition of the Bellefonte Nuclear Plant to the TVA system will enable TVA to continue to carry out its statutory responsibility to provide an ample supply of electricity for the TVA region.

After weighing the environmental costs and the technical, economic, environmental, and other benefits of the project and adopting alternatives which affect the overall balance of costs and benefits by lessening environmental impacts, TVA has concluded that the overall benefits of the project far outweigh the monetary and environmental costs, and that the action called for is the construction and operation of the Bellefonte Nuclear Plant.