

APR 2 1974

DOCKET NOS.: 50-438, 439, 452, 453 AND 460

APPLICANTS : TENNESSEE VALLEY AUTHORITY, DETROIT EDISON COMPANY AND WASHINGTON PUBLIC POWER SUPPLY SYSTEM

FACILITIES : BELLEFONTE NUCLEAR PLANT, UNITS 1 AND 2; GREENWOOD ENERGY CENTER, UNITS 2 & 3; WASHINGTON NUCLEAR PROJECT-1

SUMMARY OF GENERIC MEETING WITH BABCOCK & WILCOX (B&W) ON CONTAINMENT PEAK PRESSURE ANALYSIS

A generic meeting was held March 14, 1974 to discuss the methods B&W used to predict the mass and energy release to the containment as the result of a loss-of-coolant accident for all 205 fuel assembly plants. The affected applicants for these plants were invited to attend this meeting. A list of attendees is enclosed; the Detroit Edison Company was represented by Bechtel.

B&W presented information addressing concerns that the staff had raised regarding the conservatism of the CRAFT code to predict mass and energy to the containment following the initial blowdown. The slides given in these presentations are attached.

Significant points discussed are summarized below:

1. Comparison of CRAFT and REFLOOD

The REFLOOD code is used in B&W's ECCS analysis to compute the inlet flow rate to the core during the reflooding period. This code appears to be similar to the staff's FLOOD code that is used to predict mass and energy release to the containment during the reflooding period. B&W presented comparisons showing that CRAFT code predicted a greater mass and energy release than the REFLOOD code. The staff noted that the input assumptions used in the REFLOOD code were more typical of those for ECCS analysis and may not be conservative for containment analysis.

2. Quenching of Steam by the ECCS Water

The staff had stated that the assumption of complete steam-water mixing used by B&W reduced the steam flow into the containment and did not appear to be conservative. This assumption reduces the peak containment pressure by about 2 psi and reduces the containment decompression time. B&W presented data from the Combustion Engineering steam-water mixing

LB

Thorne

tests which indicate complete mixing exists if the liquid flow rate is sufficiently high. These tests were for cold leg ECCS injection whereas B&W's ECCS (CFT and LPI) injects into the downcomer. B&W also presented mixing results for steam and feedwater in the B&W once-through steam generator. However, no data were available for the geometry of the B&W downcomer.

3. Carryout Rate Fraction (CRAFT vs. FLECHT Data)

The CRAFT code was stated to calculate a carryout rate fraction of steam and water leaving the core of about 90% compared to about 80% from an average core channel of the FLECHT data. The CRAFT analysis appears to be conservative in this calculation.

4. Effect of Nucleate Boiling Heat Transfer in CRAFT

The staff had stated that for heated surfaces exposed to the primary coolant such as the core piping and steam generator tubes, the assumption of nucleate boiling heat transfer would be more realistic and would maximize heat flow to the containment. B&W stated that they already considered nucleate boiling in the core and primary metal surfaces. They presented analysis showing that the heat transfer coefficient in the steam generator tubes was sufficiently high so that a further increase would not increase containment pressure.

5. Conclusions

It appears that either the CRAFT code or the REFLOOD code with proper input can provide conservative mass and energy release data to the containment. The staff stated that the assumption of complete steam-water mixing in the CRAFT code had yet not been fully justified and that the REFLOOD code should be used with assumptions conservative for containment analysis instead of ECCS analysis. For plants that have been analyzed during the reflood period using the CRAFT code the staff will review the results on a case-by-case basis and make comparisons with the results of our FLOOD code.

Original Signed by

Don K. Davis, Project Manager
 Light Water Reactors Branch 2-3
 Directorate of Licensing

Original Signed by

Walt Jensen, Project Manager
 Containment Systems Branch
 Directorate of Licensing

Enclosure:

1. List of Attendees

OFFICE	Slides Shown at	Presentation
x886 LWR 2-3	L:CSB	
D.K. Davis, cjb	WJensen	
379/174	380174	

MEETING HELD MARCH 14, 1974
TVA, DEC AND WPPSS
BELLEFONTE 1 & 2, GREENWOOD 2 & 3, WNP-1

LIST OF ATTENDEES

Atomic Energy Commission

D. Davis
*A. Schwencer
*G. Lainas
T. Cox
J. Shapaker
W. Jensen
T. Greene
C. Anderson

Babcock & Wilcox

J. McFarland
C. Parks
G. Brazill
R. Bybee
I. Putney
K. Shieh
B. Dunn
M. Oren
J. Mecca

Washington Public Power Supply System

J. Kemp

Tennessee Valley Authority

J. Carter, III
G. Curtis

Bechtel

R. Boles, Jr.
J. Thiesing

United Engineers & Constructors

J. Daniel
K. Niyogi
W. Stromquist

Portland General Electric

D. Herborn

*Denotes Part-Time Attendance

Meeting Summary - Tennessee Valley Authority, Detroit Edison Company
and Washington Public Power Supply System

DISTRIBUTION:

AEC PDR
LPDR
✓ Dockets (5)
L Reading
LWR 2-3 Reading
VAMoore
RDenise
DSkovholt
RCDeYoung
DRMuller
RIreland
RAClark
KKniel
JStolz
ASchwencer
KGoller
DVassallo
WButler
PCollins
RSchemel
DZiemann
GKnighton
GDicker
BYoungblood
WRegan
SVarga
DEisenhut
JHendrie
HDenton
RTedesco
RMaccary
VStello
BGrimes
WGammill
JKasnter
RBallard
MSpangler
CLong
GLainas
RVollmer
VBenaroya
JKnight
SPawlicki
LShao

TNovak
Tippolito
DRoss
WHouston
DDavis
TCox
LEngle
DKartalia
JCohen
WPaton
CDomeck
GDittman
RLoose
RO (3)
EGoulbourne
RFraley, ACRS (16)
JShapaker
WJensen
TGreene
CAnderson

Slide 1


Containment Meeting
with Staff 3-14-74

PRESENTATION TOPICS

- I CRAFT - REFLOOD COMPARISON
- II JUSTIFICATION OF STEAM CONDENSATION
- III CARRY-OUT RATE FRACTIONS
- IV ENERGY SOURCES

Slide 2


REACTOR BUILDING PRESSURE HISTORY FOR MASS X ENERGY RELEASE
DEVELOPED BY CRAFT AND REFLOOD



DE Pump Suction Break 1.0
7/29/77 with vent-valve
out all slides


Slide 3

STEAM ENERGY TO CONTAINMENT
CRAFT VS REFLOOD



Slide 4
Dual HPI one LPI



COMPARISON OF REFLOOD RATES
CRAFT VS REFLOOD



Back press ~ 50 psia

Slide 5

FLOW SPLIT COMPARISON BETWEEN CRAFT AND REFLOOD




Slide 6

STORED ENERGY VERSES TIME FOR VARIOUS ENERGY SOURCES


— CRAFT

- - - REFLOOD

REACTOR COOLANT ENERGY






ENERGY STORED IN CORE




Slide 7

STORED ENERGY VERSES TIME FOR VARIOUS ENERGY SOURCES




Slide 8
Also Slide 22
on energy source

SECONDARY FLUID TEMPERATURE VS TIME




Slide 9

ENERGY TO CONTAINMENT




3/14/74
AFTERNOON SESSION
Slide 10

COMPARISON OF QUENCHING AND NON-QUENCHING IN CRAFT



TEST SECTION THERMOCOUPLES

Slide 11



X = 22 INCHES FOR 1/3 SCALE TESTS

= 14 INCHES FOR 1/5 SCALE TESTS

THERMOCOUPLES 32 36 NOT PRESENT IN 1/5 SCALE TESTS

Slide 12

SCALING OF FLOWS

TYPICAL COLD LEG FLOWS

STEAM 50 LBM/SEC

HPI 50 LBM/SEC

SCALING FACTORS 1/3 TEST = $(\frac{10^2}{28}) = .13$

1/5 TEST = $(\frac{6^2}{28}) = .05$

TYPICAL FLOWS SCALED

1/3

1/5

STEAM

6.5 LBM/SEC

2.5 LBM/SEC

HPI

47 GPM

28 GPM

TEST DATA AVAILABLE

<u>DATE</u>	<u>RUN #</u>	<u>SCALE</u>	<u>INJECTION (GPM)</u>	<u>STEAM FLOW (LBM/SEC)</u>
4/24/72	3	1/5	116	3.9
8/8/72	4	1/5	110	2.0
8/8/72	5	1/5	90	4.0
4/25/72	4	1/5	120	4.0
4/27/72	1	1/5	116	4.0
5/2/73	7	1/3	473	7.5
4/23/73	5	1/3	436	7.5

Slide 13


4/24/72

RUN 3

SCALE 1/5

INJECTION 116 GFM STEAM FLOW 3.9 LBM/SEC
117°F 517°F
PRESSURE 59 PSIA, T_{SAT} 292

ENERGY TO REMOVE SUPERHEAT 444 BTU/SEC
ENERGY TO QUENCH STEAM 4014 BTU/SEC
ENERGY SINK IN INJECTION 3000 BTU/SEC
PERCENT FULL SINK 75%



Slide 14

DATA SUMMARY

<u>DATE</u>	<u>RUN #</u>	<u>SCALE</u>	<u>INJECTION</u>		<u>STEAM FLOW</u>			<u>THERMOCOUPLE</u>		
			<u>GPM</u>	<u>°F</u>	<u>LBM/SEC</u>	<u>°F</u>	<u>READINGS</u>			
							<u>T_{SAT}</u>	<u>T₉</u>	<u>T₁₀</u>	<u>T_{10A}</u>
4/24/72	3	1/5	116	117	3.9	517	292	280	290	280
8/8/72	4	1/5	110	120	2.0	510	274	280	270	270
8/8/72	5	1/5	90	120	4.0	510	274	290	500	280
4/25/72	4	1/5	120	125	4.0	513	293	290	290	290
4/27/73	1	1/5	116	126	4.0	515	289	290	290	290
5/2/73	7*	1/3	473	117	7.5	410	289	240	220	220
4/23/73	5**	1/3	436	117	7.5	517	287	240	240	NF

* PERCENT TOTAL SINK 160%

** PERCENT TOTAL SINK 140%

Slide 15

8/8/72

RUN 5

SCALE 1/5

INJECTION

116 GPM

STEAM FLOW

4.0 LBM/SEC

120°F

517°F

PRESSURE

45 PSIA

T_{SAT} 274

ENERGY TO REMOVE SUPERHEAT

484 BTU/SEC


ENERGY TO QUENCH STEAM

4200 BTU/SEC

ENERGY SINK IN INJECTION


2540 BTU/SEC

PERCENT FULL SINK 60%




Slide 16

PIPE ELEVATIONS ARE DIFFERENT



Slide 17

CROSS SECTION OF NUCLEAR FACE-THROUGH STEAM GENERATOR



PRIMARY INLET NOZZLE

SUPERHEATER SECTION

STEAM
OUTLET NOZZ.

Feedwater Header
Nozzle

Feedwater Header

137 ⁷/₈ I D SHELL

Annular Feedwater
Heating Chamber

121 ³/₈ O D

Shell

BOILER SECTION

BROACHED PLATE
TUBE SUPPORTS

Shroud


ORIFICE
PLATES

PRIMARY OUTLET
NOZZLES

Tube Sheet

Slide 18

OTSG TEST ARRANGEMENT



Slide 19

CORRESPONDENCE AND SCALING

TEST

$$\overline{W}_{st} = 880 \text{ LBM/HR}$$

$$\overline{Q}_{fw} = 17 \text{ GPM}$$

LOOP #2 VENT VALVES MIGHT HAVE A FLOW OF 460,000 LBM/HR

SCALING FACTOR IS 520

GIVING NEEDED INJECTION OF 8840 GPM

ALSO ACCOUNT FOR DIFFERENCE IN INITIAL PY

$$\text{TEST } \Delta h = 93$$

$$\text{LPI } \Delta h = 181$$

GIVING FACTOR OF .51

RESULTING INJECTION FLOW NEEDED IS 4500 GPM

Slide 20


19 TUBE OTSG TEST RANGE

steam or feedwater flow	5000 - 9000 LBM/HR
Feedwater temperature	400 - 460 °F
Pressure	500 - 400 PSIA
Feedwater subcooling	30-150 BTU/LBM
Steam velocity	8-20 FT/SEC
Feedwater volumetric flow	13-23 GPM

IN ALL CASES FEEDWATER IS SATURATED AFTER MIXING CHAMBER

19 TUBE OTSG TEST CONFIRMED THAT FEEDWATER WOULD SATURATE FOR 27% AND 50% LOAD WITH FLOW RATES AS 10 FT/SEC.

Slide 21



CA-594-11

Source: NSS Power - 1 of 2084 MW

Slide 23

COMPARISON OF TREATMENT OF SECONDARY SIDE ENERGY TRANSFER AND MODELING OF STEAM GENERATOR TUBES - CRAFT

Review Slide 8 to initiate in Source Discussion

