

DEC 10 1975

Docket Nos. 50-438 ✓
50-439

Tennessee Valley Authority
ATTN: Mr. J. E. Watson
Manager of Power
818 Power Building
Chattanooga, Tennessee 37401

REF: REPORTABLE DEFICIENCY - ALTERATION OF RECORDS

Gentlemen:

Thank you for your letter dated November 18, 1975, pursuant to 10 CFR 50.55(e) regarding the above referenced item. We are looking forward to receipt of your final report on this matter.

Please refer to Control No. HO F2 in future correspondence in reference to this item.

Your cooperation is appreciated.

Sincerely,

Original signed by
H.D. Thorburn

John G. Davis, Acting Director
Division of Field Operations
Office of Inspection and
Enforcement

bcc w/cpy ltr dtd 11/18/75:

PDR
NSIC
TIC
LPDR
Region II
Central Files
IE Files
IE Reading Files

DDFO Reading File
Regional Coordinator G. C. Gower

OFFICE	FCEB	FCEBAC	DIR:DFO		
SURNAME	GCGower/mh	Gowdy	DAVIS		
DATE	12/10/75	12/10/75	12/10/75		

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

November 18, 1975



Dr. Donald F. Knuth, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Dear Dr. Knuth:

BELLEFONTE NUCLEAR PLANT UNITS 1 AND 2 - REPORTABLE DEFICIENCY -
ALTERATION OF RECORDS BY BRISTOL STEEL AND IRON WORKS, INCORPORATED
(BSIW)

Initial report of the subject deficiency was made to E. J. Vallish,
NRC-IE, Region II, on October 14, 1975. This is submitted as an
interim report; we expect to submit a second written report by
December 15, 1975.

A technical review of the documentation has been completed and actions
by Bristol Steel to bring the documentation for Division I Advance,
Division II Advance (excluding alterations to the documentation),
and Division I material to an acceptable technical level are complete
or are nearing completion. We have in preparation a report which will
provide a full account of the meetings and actions of both TVA and
Bristol Steel. It is expected that the report will be completed by
December 1, 1975, at which time implementation of corrective actions
by Bristol Steel will have been verified by TVA.


With regard to the alteration of documentation for a portion of the
Division II Advance material, we are continuing our review of the
altered documents to determine the extent and material affected.
Bristol Steel is attempting to identify alternate means, independent
of the altered documents, of ensuring material acceptability as
well as reverification of fabrication processes through reexaminations,
etc. A meeting between TVA and Bristol Steel representatives is scheduled

Dr. Donald F. Knuth

November 18, 1975

for November 19, 1975, to discuss these alternate means and TVA will at that time evaluate the acceptability of the alternates proposed by Bristol Steel. Evaluation of the TVA system for following contracts with BSIW is continuing.

Very truly yours,


J. E. Gilleland
Assistant Manager of Power

CC: Mr. Norman C. Moseley, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Region II - Suite 818
230 Peachtree Street, NW.
Atlanta, Georgia 30303