

NOV 10 1975

Docket No. 50-438

Tennessee Valley Authority
ATTN: Mr. J. E. Watson
Manager of Power
818 Power Building
Chattanooga, Tennessee 37401

REF: MISLOCATION OF CENTER POINTS FOR STEAM GENERATOR
BASE ANCHORAGES

Gentlemen:

Thank you for your letter dated October 30, 1975, pursuant to 10 CFR 50.55(e) regarding the above referenced item. We are looking forward to receipt of your final report on this matter.

Please refer to Control No. HO 1014F2 in future correspondence in reference to this item.

Your cooperation is appreciated.

Sincerely,

151

John G. Davis, Deputy Director
for Field Operations
Office of Inspection and Enforcement

bcc: w/cpy ltr 10/30/75
PDR
LPDR
NSIC
TIC
REGION II
IE Central Files
IE Files
Gower

OFFICE →	IE:FCEB	FCEB_C	DIR:DFO		
SURNAME →	GCGower:jb	HDHomburg	JGDavis		
DATE →	11/10/75	11/10/75	11/10/75		



831 Power Building
TENNESSEE VALLEY AUTHORITY
CHATTANOOGA, TENNESSEE 3740

REACTOR FACILITIES BRANCH
FILE COPY

October 30, 1975

Dr. Donald F. Knuth, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

50-438
439


Dear Dr. Knuth:

BELLEVILLE NUCLEAR PLANT UNIT 1 - REPORTABLE DEFICIENCY -
MISLOCATION OF THE CENTER POINTS FOR THE STEAM GENERATOR
BASE ANCHORAGES

Initial report of the subject deficiency was made to W. B. Swan, NRC-IE, Region II, on September 30, 1975. In compliance with paragraph 50.55(e) of 10 CFR Part 50, this is submitted as an interim report. The center points of the steam generator base anchorages were located 34 feet east and west of the reactor center instead of 34 feet 1-1/8 inches as specified on the drawings. Corrective action has been identified and appropriate design drawings have been revised and issued.

We expect to submit a second written report by December 19, 1975.

Very truly yours,



61 J. E. Gilleland
Assistant Manager of Power

CC: Mr. Norman C. Moseley, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Region II - Suite 818
230 Peachtree Street, NW.
Atlanta, Georgia 30303

5 0885

W