

830 Power Building
TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

50-438/439

JUN 9 1977

Mr. Norman C. Moseley, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Region II - Suite 818
230 Peachtree Street, NW.
Atlanta, Georgia 30303

Dear Mr. Moseley:

BELLEFONTE NUCLEAR PLANT UNITS 1 AND 2 - QUALIFICATION OF CABLE TRAY
SUPPORTS - BNP-6

On May 20, 1977, J. C. Bryant, NRC-OIE Section Chief, was informed that the subject nonconformance was determined to be reportable in accordance with 10 CFR 50.55(e). Enclosed is the first interim report. We expect to submit our final written report by September 15, 1977.

Very truly yours,



J. E. Gilleland
Assistant Manager of Power

Enclosure

cc: Dr. Ernst Volgenau, Director (Enclosure)
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555



ENCLOSURE

BELLEFONTE NUCLEAR PLANT UNITS 1 AND 2
INTERIM REPORT NCR NO. BNP-6
QUALIFICATION OF CABLE TRAY SUPPORTS

Description of Condition

The cable trays were qualified for different support conditions than were provided in the support design.

Corrective Action

The contractor is now performing a qualification analysis to determine the adequacy of the trays to meet existing support designs. Also TVA is developing standard qualification requirements to be put into contracts for design of cable trays and is developing a standardized design of cable trays and supports systems. TVA is continuing to review the problem and will address it further in the final report.