

OCT 17 1977

DISTRIBUTION

Docket File
NRC DPR
Local PDR
LWR #3 File
R. DeYoung
D. Vassallo
R. Williams
O. Parr
W. Pike
M. Rushbrook
OELD
I&E (3)
H. Smith
P. Check

BCC: J. Buchanan
T. Abernathy
ACRS (16)

Docket Nos. 50-438
and 50-439

Tennessee Valley Authority
ATTN: Mr. Godwin Williams, Jr.
Manager of Power
830 Power Building
Chattanooga, Tennessee 37201

Gentlemen:

SUBJECT: FUEL SURVEILLANCE PLANS FOR THE BELLEFONTE NUCLEAR PLANT

Reference: Letter, J. E. Gilleland to O. D. Parr, dated 9/6/77

Your letter of 9/6/77 requested that we reconsider our requirement of fuel surveillance programs for both Bellefonte units if they are the first two units to use the new Babcock & Wilcox Mark C 17 x 17 fuel. We understand that TVA is willing to conduct a fuel surveillance program on one Bellefonte unit but that in your view the requirement for both imposes an unnecessary burden on TVA. Nevertheless, our requirement for fuel surveillance programs at the first two units to use a new fuel remains unchanged.

We feel that any additional discussion of this matter can more usefully be held at the "staff position stage" of our review of the Bellefonte Nuclear Plant FSAR. It has been our experience that start up date forecasts are highly uncertain.

Sincerely,

Original Signed by

Olan Parr

Olan D. Parr, Chief
Light Water Reactors Branch No. 3
Division of Project Management

cc: See next page

OFFICE	LWR #3 DPM	<i>[Signature]</i>	LWR #3 DPM		
SURNAME	WPike	PCheck	OParr		
DATE	10/17/77	10/17/77	10/17/77		

Tennessee Valley Authority

cc: Herbert S. Sanger, Jr., Esq.
General Counsel
Tennessee Valley Authority
629 New Sprankle Building
Knoxville, Tennessee 37902

Mr. E. G. Beasley
Tennessee Valley Authority
400 Commerce Avenue, W9C 165
Knoxville, Tennessee 37902

Mr. T. Spink
Licensing Engineer
Tennessee Valley Authority
303 Power Building
Chattanooga, Tennessee 37401