



INSTITUTE FOR ENERGY AND ENVIRONMENTAL RESEARCH

6935 Laurel Avenue, Suite 201
Takoma Park, MD 20912

Phone: (301) 270-5500
FAX: (301) 270-3029
e-mail: ieer@ieer.org
<http://www.ieer.org>

**DECLARATION OF DR. ARJUN MAKHIJANI IN SUPPORT OF
EMERGENCY PETITION TO SUSPEND ALL PENDING REACTOR LICENSING
DECISIONS AND RELATED RULEMAKING DECISIONS
PENDING INVESTIGATION OF LESSONS LEARNED FROM FUKUSHIMA DAIICHI
NUCLEAR POWER STATION ACCIDENT**

I, Arjun Makhijani, declare as follows:

Introduction and Statement of Qualifications

1. I am President of the Institute for Energy and Environmental Research ("IEER") in Takoma Park, Maryland. Under my direction, IEER produces technical studies on a wide range of energy and environmental issues to provide advocacy groups and policy makers with sound scientific information and analyses as applied to environmental and health protection and for the purpose of promoting the understanding and democratization of science. A copy of my curriculum vitae is attached.
2. I am qualified by training and experience as an expert in the fields of plasma physics, electrical engineering, nuclear engineering, the health effects of radiation, radioactive waste management and disposal (including spent fuel), estimation of source terms from nuclear facilities, risk assessment, energy-related technology and policy issues, and the relative costs and benefits of nuclear energy and other energy sources. I am the principal author of a report on the 1959 accident at the Sodium Reactor Experiment facility near Simi Valley in California, prepared as an expert report for litigation involving radioactivity emissions from that site. I am also the principal author of a book, *The Nuclear Power Deception – U.S. Nuclear Mythology from Electricity "Too Cheap to Meter" to "Inherently Safe" Reactors* (Apex Press, New York, 1999, co-author, Scott Saleska), which examines, among other things, the safety of various designs of nuclear reactors.
3. I have written or co-written a number of other books, reports, and publications analyzing the safety, economics, and efficiency of various energy sources, including nuclear power. I am also the author of *Securing the Energy Future of the United States: Oil, Nuclear and Electricity Vulnerabilities and a Post-September 11, 2001 Roadmap for Action* (Institute for Energy and Environmental Research, Takoma Park, Maryland, December 2001). In 2004, I wrote "Atomic

Myths, Radioactive Realities: Why nuclear power is a poor way to meet energy needs,” *Journal of Land, Resources, & Environmental Law*, v. 24, no. 1 at 61-72 (2004). The article was adapted from an oral presentation given on April 18, 2003, at the Eighth Annual Wallace Stegner Center Symposium entitled, “Nuclear West: Legacy and Future,” held at the University of Utah S.J. Quinney College of Law. In 2008, I prepared a report for the Sustainable Energy & Economic Development (SEED) Coalition entitled *Assessing Nuclear Plant Capital Costs for the Two Proposed NRG Reactors at the South Texas Project Site*.

4. I am generally familiar with the basic design and operation of U.S. nuclear reactors and with the safety and environmental risks they pose. I am also generally familiar with materials from the press, the Japanese government, the Tokyo Electric Power Company, the French government safety authorities, and the U.S. Nuclear Regulatory Commission (“NRC”) regarding the Fukushima Daiichi accident and its potential implications for the safety and environmental protection of U.S. reactors.

5. The purpose of my declaration is to explain the reasons I believe that although the causes, evolution, and consequences of the Fukushima accident are not yet fully clear, the accident is already presenting new and significant information regarding the risks to public health and safety and the environment posed by the operation of nuclear reactors. I will also explain why I believe that integration of this new information into the NRC’s licensing process could affect the outcome of safety and environmental analyses for reactor licensing and relicensing decisions by resulting in either the denial of licenses or license extensions or the imposition of new conditions and/or new regulatory requirements. It could also affect the NRC evaluation of the fitness of new reactor designs for certification. It is therefore reasonable and necessary to suspend licensing and re-licensing decisions and standardized design certifications until the NRC completes its review of the safety and regulatory implications of the Fukushima accident.

Statement of Facts

6. Although many details about the Fukushima reactor accident remain unclear, the general contours of the accident are described in NRC Information Notice No. 2011-08 (March 31, 2011) (NRC Accession No. ML 110830824) as follows:

On March 11, 2011, the Tohoku-Taiheiyou-Oki earthquake occurred near the east coast of Honshu, Japan. This magnitude 9.0 earthquake and the subsequent tsunami caused significant damage to at least four of the six units of the Fukushima Daiichi nuclear power station as the result of a sustained loss of both the offsite and onsite power systems. Efforts to restore power to emergency equipment were hampered and impeded by damage to the surrounding areas due to the tsunami and earthquake.

Units 1, 2 and 3 were operating at the time of the earthquake. Following the loss of electric power to normal and emergency core cooling systems and the subsequent failure of backup decay heat removal systems, water injection into the cores of all three reactors was compromised, and reactor decay heat removal could not be maintained. The operator of the plant, Tokyo Electric Power Company, injected sea water and boric acid into the reactor vessels of these three units, in an effort to cool the fuel and ensure that the

reactors remained shut down. However, the fuel in the reactor cores became partially uncovered. Hydrogen gas built up in Units 1 and 3 as a result of exposed, overheated fuel reacting with water. Following gas venting from the primary containment to relieve pressure, hydrogen explosions occurred in both units and damaged the secondary containments.

Units 3 and 4 were reported to have low spent fuel pool (SFP) water levels.

Fukushima Daiichi Units 4, 5 and 6 were shut down for refueling outages at the time of the earthquake. The fuel assemblies for Unit 4 had recently been offloaded from the reactor core to the SFP. The SFPs for Units 5 and 6 appear to be intact. Emergency power is available to provide cooling water flow through the SFPs for Units 5 and 6.

The damage to Fukushima Daiichi nuclear power station appears to have been caused by initiating events beyond the design basis of the facilities.

7. In a March 21, 2011, briefing, Bill Borchardt, the NRC's Executive Director for Operations, stated that the NRC believes that hydrogen explosions occurred on March 12, 14, and 15 in the reactors of Units 1, 3, and 2 respectively, in that order. He also stated that the NRC believed that a hydrogen explosion had occurred at spent fuel pool of Unit 4 on March 15 due to overheated spent fuel in the pool. Briefing on NRC Response to Recent Nuclear Events in Japan, Transcript at 11.

8. According to Mr. Borchardt, the NRC believes that Units 1, 2, and 3 have likely sustained some degree of core damage. *Id.* Further, he stated that the loss of emergency AC power was caused by the tsunami and not the earthquake. Therefore, he concluded that the NRC believes that the "damage in Fukushima was not really caused by the earthquake; it was the tsunami that came afterwards." *Id.*

9. At the outset of the emergency, large volumes of sea water were used to cool the reactors. The salt water injections were then replaced by fresh water injections. While judgments have changed over time, and much remains uncertain, we note here that as of March 21, Mr. Borchardt also stated that "[t]he radiation releases and the dose rates that we've seen on site, I think, were primarily influenced by the condition of the Units Three and Four spent fuel pools." *Id.* at 21.

10. The French authorities also reported that sea water was used to cool spent fuel pools Units 3 and 4. *Communiqué de presse n°17 du mardi 22 mars 2011 à 10h00 Séisme au Japon - L'ASN fait le point sur la situation de la centrale nucléaire de Fukushima Daiichi : Les travaux en vue de rétablir l'alimentation électrique se poursuivent mais la mise sous tension n'est pas réalisée Paris, le 22/03/2011 10:27, <http://japon.asn.fr/index.php/Site-de-l-ASN-Special-Japon/Communiqués-de-presse> (March 22, 2011).* They also reported that three spent fuel pools (of Units 2, 3, and 4) appear to have experienced boiling at some point. *Note d'information : Situation des réacteurs nucléaires au Japon suite au séisme majeur survenu le 11 mars 2011 : Point de situation du 18 mars 2011 à 14 heures, Institut de Radioprotection et de Sécurité Nucléaire (March 18, 2011),*

http://www.irsn.fr/FR/Actualites_presse/Actualites/Documents/IRSN_Seisme-Japon_Point-situation-18032011-14h.pdf -- hereafter IRSN March 18, 2011)

11. In response to the Fukushima reactor accident, the NRC announced the formation of a “senior level agency task force to conduct a methodical and systematic review” of NRC processes and regulations. COMGBJ-11-0002, Memorandum from Chairman Jaczko to Commissioners, re: NRC Actions Following the Events in Japan at 1 (March 21, 2011) (NRC Accession No. ML110800456). The purpose of the task force is to “determine whether the agency should make additional improvements to our regulatory systems and make recommendations to the Commission for its policy direction.” *Id.*

12. Chairman Jaczko’s memorandum specifies both a near-term review and a longer-term review. For the near-term review, the Commission required the task force to evaluate issues “affecting domestic operating reactors of all designs” in areas that include “protection against earthquake tsunami, flooding, hurricanes; station blackout and a degraded ability to restore power; severe accident mitigation; emergency preparedness; and combustible gas control.” *Id.* at 1. The Commission instructed the task force to complete the report in 90 days. In the meantime, the task force was instructed to provide a 30-day “quick look report” and another “status” report in 60 days. *Id.*

13. The “longer term” review would begin “as soon as NRC has sufficient technical information from the events in Japan with the goal of no later than the completion of the 90 day near term report.” *Id.* at 2. The longer-term study should “evaluate all technical and policy issues related to the event to identify additional research, generic issues, changes to the reactor oversight process, rulemakings, and adjustments to the regulatory framework that should be conducted by the NRC.” *Id.* For the longer-term effort, the Commission instructed the task force to “receive input from and interact with all key stakeholders.” *Id.* The Commission specified that within six months after commencing the evaluation, the task force should “provide a report with recommendations, as appropriate, to the Commission.” *Id.*

14. The “Task Force to Conduct a Near-term Evaluation of the Need for Agency Actions Following the Events in Japan” (“Task Force”) has formed and its charter has been approved. The Task Force aims to accomplish the following:

- “Evaluate currently available technical and operational information from the events that have occurred at the Fukushima Daiichi nuclear complex in Japan to identify potential or preliminary near-term/immediate operational or regulatory actions affecting domestic reactors of all designs, including their spent fuel pools. The task force will evaluate, at a minimum, the following technical issues and determine priority for further examination and potential agency action:
 - External event issues (e.g. seismic, flooding, fires, severe weather)
 - Station blackout
 - Severe accident measures (e.g., combustible gas control, emergency operating

procedures, severe accident management guidelines)

- 10 CFR 50.54 (hh)(2) which states, “Each licensee shall develop and implement guidance and strategies intended to maintain or restore core cooling, containment, and spent fuel pool cooling capabilities under the circumstances associated with loss of large areas of the plant due to explosions or fire, to include strategies in the following areas: (i) Fire fighting; (ii) Operations to mitigate fuel damage; and (iii) Actions to minimize radiological release.” Also known as B.5.b.
- Emergency preparedness (e.g., emergency communications, radiological protection, emergency planning zones, dose projections and modeling, protective actions)
- Develop recommendations, as appropriate, for potential changes to NRC’s regulatory requirements, programs, and processes, and recommend whether generic communications, orders, or other regulatory actions are needed.”

Charter for the Nuclear Regulatory Commission Task Force to Conduct a Near-Term Evaluation of the Need for Agency Actions Following the Events in Japan at 1 (April 1, 2011) (NRC Accession No. ML11089A045).

15. With respect to the longer-term review, the Charter states that the short-term report will make: “[r]ecommendations for the content, structure, and estimated resource impact....” *Id.* at 1.

Statement of Professional Opinion

16. I agree with the Commission’s approach of conducting a long-term investigation of the regulatory implications of the Fukushima accident, in addition to its short-term investigation of whether immediate actions are needed. In my opinion, the longer-term investigation is necessary to address a number of respects in which the Fukushima accident is unprecedented in the sense that its characteristics are not anticipated in NRC safety regulations or environmental analyses. Thus, it is providing new and significant insights into the inadequacy of NRC regulations to protect public health and safety and the inadequacy of NRC environmental analyses to evaluate the potential health, environmental and economic costs of reactor and spent fuel pool accidents. This significant new information covers the following major topics:

- Unanticipated compounding effects of simultaneous accidents at multiple co-located reactor units, including spent fuel pools.
- Unanticipated risks of spent fuel pool accidents, including explosions.
- Frequency of severe accidents and explosions.
- Inadequacy of safety systems to respond to long-duration accidents.
- Nuclear crisis management with contaminated control and turbine buildings that have lost power
- Unanticipated aggravating effects of some emergency measures.
- Health effects and costs of severe accidents

- The hydrogen explosions at Fukushima and their implications for aircraft crash evaluations.

Unanticipated compounding effects of simultaneous accidents at multiple co-located reactor units, including spent fuel pools.

17. Perhaps the most unprecedented feature of the Fukushima accident is that three reactors and four spent fuel pools have been stricken at the same site. In the entire history of nuclear power, there has not been another major accident (level 5 or above) that has involved multiple major sources of radioactivity -- including multiple reactors and multiple spent fuel pools. For instance, the Fukushima Daiichi complex is the first to have experienced multiple hydrogen explosions in various facilities, all as part of the same event.

18. The NRC has long followed the practice of allowing new reactors to be built at existing sites, without examining the consequences of simultaneous failure of existing and new reactors through common mode failures such as complete station blackouts and loss of fresh water supply. The NRC also proposes to co-locate a significant number of new reactors at existing reactor sites. Examples include Bellefonte, Calvert Cliffs, Comanche Peak, Fermi, North Anna, Shearon Harris, Turkey Point, the South Texas Project, and Vogtle.

19. But the Fukushima accident graphically demonstrates that NRC's failure to evaluate the safety and environmental implications of co-locating multiple reactors was incorrect. Specifically, when a new reactor is to be sited at a location where there are existing reactors, the entire system at the site should be re-examined in addition to whatever additional impacts the new unit(s) might create. The EISs for these new reactors and the designs on which they rely should consider the significant new information revealed by the Fukushima accident about the potential for simultaneous multiple failures and accidents in existing and new reactors and/or spent fuel pools.

Unanticipated risks of spent fuel pool accidents, including explosions.

20. Another unprecedented feature of the Fukushima accident is that an explosion occurred in Unit 4 despite the fact that there was no fuel in the reactor. The entire core had been unloaded into the spent fuel pool prior to March 11, 2011; the reactor was down for maintenance. A loss of cooling apparently led to boiling and to hydrogen generation, which appears to be the likely cause of the major explosion and ensuing damage to the reactor building of Unit 4. Further, as noted above the spent fuel pools of Units 2 and 3 also appear to have experienced boiling of the cooling water at some point. It should be noted that much detail remains to be learned about all three spent fuel pools, especially as to what went on in the first week of the accident.

21. The apparent occurrence of spent fuel pool accidents at Fukushima significantly undermines the NRC's conclusion that high-density pool storage of spent fuel poses a "very low risk." *The Attorney General of Commonwealth of Massachusetts; the Attorney General of California; Denial of Petitions for Rulemaking*, 73 Fed. Reg. 46,204, 46,207 (August 8, 2008). That conclusion is all the more subject to question in light of the fact that spent fuel in U.S. pools is typically packed more tightly than in the pools at Fukushima. U.S. reactors, including reactors

that are candidates for license renewal, use high-density pool storage for spent fuel. Fukushima indicates that the NRC policy that allows such storage needs to be revisited. Given that onsite storage of spent fuel may continue for decades, these circumstances also call for a thorough reexamination of the spent fuel storage capacity, spent fuel pool location, and configuration of new reactor designs. For instance, should the construction and use of above ground-level spent fuel pools in reactor buildings be allowed, as is the case with the advanced boiling water reactor (“ABWR”)? The NRC should examine the potentially exacerbating relationship between reactor core accidents and spent fuel pool accidents, for both existing reactor designs and new reactor designs. In addition, environmental impact statements (“EISs”) for license renewal and new reactor licensing should reexamine the relative costs and benefits of measures to mitigate the environmental impacts of pool fires and/or explosions. Measures would include reducing the density at which fuel is stored in pools, using dry storage for as much of each reactor’s inventory of spent fuel as safety will allow, and dry storage of all spent fuel at closed reactors, a few years after closure.

Frequency of severe accidents and explosions

22. The NRC must also re-examine the frequency per reactor per year of spent fuel pool accidents as well as the frequency of core damage events. The NRC’s current spent fuel damage assessments are based on a best estimate of a spent fuel pool fire probability of about 2×10^{-6} per reactor-year, including the probability of structural failure during a seismic event NUREG-1353, *Regulatory Analysis for the Resolution of Generic Issue 82, “Beyond Design Basis Accidents in Spent Fuel Pools”*, at 5-5 and Table 5.1.3 (1989). This means one such accident for every 500,000 reactor-years. The NRC’s estimate of the frequency of spent fuel pool loss of cooling from all causes other than earthquake-induced structural failure is even lower: 1.5×10^{-7} . The conditional probability of a fire in the event of a loss of cooling is estimated to be 1.0 for a PWR and 0.25 for a BWR. *Id.* at 4-36. Based on this, the overall probability estimate in NUREG-1353 for a non-seismic-induced spent fuel pool fire for a PWR is $1.5 \times 10^{-7} \times 1.0 = 1.5 \times 10^{-7}$; for a BWR it is $1.5 \times 10^{-7} \times 0.25 = 4 \times 10^{-8}$ for a BWR – in the latter case is it one spent fuel pool fire every 25 million reactor-years. Hydrogen explosions originating in the spent fuel pool were not considered. Further, at least two spent fuel pools at Fukushima (Units 3 and 4) that seem to have experienced boiling as well as the destruction of the portions of the reactor building that are a barrier between the pool surface and the environment. According to the French safety authorities, the spent fuel pool in Unit 2 also experienced boiling. IRSN March 18, 2011 *op. cit.* One reactor building, that of Unit 4, appears to have experienced a hydrogen explosion, with the hydrogen apparently emanating from the spent fuel pool (see Paragraph 7 above). The explosion destroyed a good part of the reactor building. Any damage to the spent fuel pool structures and equipment, to the fuel assemblies in the pools, as well as to the racks remains to be fully assessed. It appears that the only way that a significant amount of hydrogen could originate in a spent fuel pool is through uncovering of the spent fuel and the reaction of the zirconium in the fuel rods with steam. Explosions destroyed substantial portions of the reactor buildings of Units 1 and 3 as well; it appears that there were also significant releases of radioactivity from the spent fuel pool of Unit 3. In view of these facts, the NRC’s estimate of loss of cooling probability accompanied by a fire is far too low, probably by orders of magnitude. It appears that the overall principal initiating event in the station blackout and failure of emergency core cooling was not the earthquake but the tsunami, though the earthquake may have caused equipment damage that

led to or contributed to some of the spent fuel pool problems. This indicates that the non-earthquake station blackout probabilities will need to be revisited. Further, the NRC's list of events leading to spent fuel structural failure does not include hydrogen explosions due to loss of emergency core cooling in the reactor (NUREG-1353, *op. cit.*, Table 4.7.1 at 4-36), which appears to have been the cause of the damage to the structures of reactor buildings 1 and 3 and possibly to the spent fuel pool of Unit 3. It may be that many details of the analysis will be different for each of the four spent fuel pools. Whatever the details, the events so far make it quite clear that the NRC needs to thoroughly reevaluate the probability of severe spent fuel pool accidents as well as the kinds of events that could initiate damage and major releases of radioactivity from spent fuel pools. Further, in view of the fact that three BWRs appear to have had core damage, the NRC also needs to evaluate whether presently operating reactors, notably (but not only) BWRs, meet the Commission's target of limiting annual core damage frequency to the 10^{-4} to 5×10^{-5} per reactor-year range for reactors (NUREG-1353, *op. cit.*, at ES-2 and ES-3).

23. In conducting its review, the NRC needs to thoroughly revisit its methods for estimating the probabilities and mechanisms of hydrogen explosions and fires in spent fuel pools (with and without a natural disaster component) as well as the methods for estimating hydrogen explosions, and meltdowns in existing and new light water reactor designs. For instance, the computer code used in evaluating the accidents assumes that "[t]he geometry of the fuel assemblies and racks remains undistorted." NUREG-1353, *op. cit.* at 4-8. To judge by the photographs and videos of the damage, this assumption is unlikely to be correct at least for spent fuel pools in Units 3 and 4. As another example, hydrogen generation due to partial uncovering of spent fuel but with water still remaining in the pool is not included. Rather, the computer program assumes that "[t]he water drains instantaneously from the pool." *Id.* This is important because if the investigation confirms that hydrogen was indeed generated in the spent fuel pool of Unit 4, the exothermic zirconium-steam reaction that creates it would be an additional source of heat for causing the accident to develop more rapidly and destructively than assumed by the NRC.

24. More generally, the events at three reactors and four spent pools have drastically changed the underlying frequency data that should go into the estimation of the probability of severe accidents at light water reactors. As a result, integration of the Fukushima data into NRC analyses of risks could lead to significant changes in design of new reactors and also lead to modifications at existing reactors, as would be required for protection of public health and safety under 10 CFR 50.109. Specifically, the Fukushima accident indicates that the basis of the NRC's conclusion in NUREG-1353 that dense storage of spent fuel in pools is safe and that dry storage is not warranted is incorrect.

Inadequacy of safety systems to respond to long-duration accidents

25. U.S. reactors appear to have insufficient backup power capacity to maintain safety equipment during a prolonged severe accident. The Fukushima accident, in which the emergency diesel generation system started but then failed very soon after the tsunami and the battery backup ran out of power in eight hours. The accident illustrates the serious environmental risk posed by insufficient backup power when catastrophic events destroy both offsite power supplies and onsite infrastructure. These risks need to be taken into account in safety and environmental analyses for all prospective NRC licensing decisions. The fact that

there was a complete station blackout at Fukushima accompanied by a failure of fresh water supply that forced sea water use for days (*Communiqué de presse n°17 du mardi 22 mars 2011 à 10h00 Séisme au Japon - L'ASN fait le point sur la situation de la centrale nucléaire de Fukushima Daiichi : Les travaux en vue de rétablir l'alimentation électrique se poursuivent mais la mise sous tension n'est pas réalisée Paris, le 22/03/2011 10:27*, <http://www.asn.fr/index.php/Haut-de-page/Presse/Actualites-ASN/Communique-de-presse-n-17-du-mardi-22-mars-2011-a-10h00>) clearly points to the need for a full review of the depth (in terms of number of levels) of backup systems, the length of time of emergency power supply operability, the location of these power supplies, and the relation of the power supplies to ad hoc emergency pumping and emergency water supplies, including in the context of potential major damage to multiple units at a single site.

Nuclear crisis management with contaminated control and turbine buildings that have lost power

26. Another critical and unanticipated feature of the Fukushima accident is that the control rooms of Units 1, 2, and 3 became highly contaminated in the course of the first week of the accident, according to the French safety authorities. IRSN March 18, 2011 *op. cit.*. This has made re-establishment of normal cooling more difficult, apart from the question of on-site or offsite power supply. Turbine buildings also became contaminated with radioactive water in the course of the accident. *Fukushima Daiichi Nuclear Power Station: the result of measurement of sub drain*, http://www.tepco.co.jp/en/press/corp-com/release/betu11_e/images/110331e18.pdf and *The detection of radioactive materials in the water on 1st basement of turbine building at the site of Fukushima Daiichi Nuclear Power Station: Press Release* (Mar 31,2011), <http://www.tepco.co.jp/en/press/corp-com/release/11033112-e.html>.

27. The loss of power in and radioactive contamination of the control rooms and turbine buildings points to the need to review the piping and ventilation arrangements of these facilities, and the likely need to isolate them more thoroughly from contaminated air and water during beyond-design-basis accidents. Based on the information available so far about the Fukushima event, the risks of turbine building contamination would appear to be greater for boiling water reactors than for pressurized water reactors since steam generated from primary water is used to directly drive the turbines; in PWRs the heated primary water is routed to steam generators and not to the turbines.

Unanticipated aggravating effects of some emergency measures

28. Light water reactors are not designed to be cooled by sea water. Thus, the fact that TEPCO was forced to use sea water for emergency cooling for an extended period is a critical feature of the accident that needs evaluation. For instance, salt from sea water deposited on the fuel rods may have blocked or partially blocked some cooling channels during the accident. This raises the question of whether the use of sea water may have aggravated the fuel damage. It also raises the question of whether salt deposits may have interfered with the neutron absorption capacity of the control rods thereby increasing the likelihood of an accidental criticality. An understanding of these issues is important to the understanding of the accident and to any design and or emergency operations changes that may be needed.

Health effects and costs of severe accidents

29. While a detailed evaluation will take time and more data, the Fukushima accident indicates that the health consequences of a severe reactor accident and/or spent fuel pool fire could be significantly greater than estimated by the NRC in EISs for license renewal and new reactor licensing. For instance, the NRC estimates an average population risk (population dose multiplied by probability) in a 50-mile radius of only 16 person-rem per year per spent fuel pool – or 480 rem in 30 years. The dose estimate was recently used in the 2009 draft Generic Environmental Impact Statement (“GEIS”) by the NRC. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants Appendices*, Draft Report for Comment, NUREG-1437, Volume 2, Rev. 1 at E-35 (July 2009). See also NUREG-1353, *op. cit.*, at ES-3. The estimate of 480 rem in 30 years translates into a probability of just 0.27 fatal cancers over 30 years in a population of more than 2.5 million (using a risk factor of 0.000575 fatal cancers per rem). The NRC’s best estimate of the total population dose in the event of an accident was 8 million person-rem (NUREG-1353, *op. cit.* at 5-4, Table 5.1.2) – which translates into 4,600 excess cancer deaths in a fifty-mile radius. The NRC put the worst case population dose estimate at just over three times the best estimate – 26 million person-rem. NUREG-1353, *op. cit.* Table 5.1.2 at 5-4. But if the probability is much higher for a single failure and if multiple failures can happen at the same site, then the number of expected fatal cancers would be higher, all other things being equal. Further, it is necessary to consider that the spent fuel pools in the United States are more typically full than the ones at Fukushima. In its review of Fukushima, the NRC should revisit the higher of the health damage estimates for spent fuel pool accidents at closed power plants in a 1997 study by Brookhaven National Laboratory. R.J. Travis, R.E. Davis, E.J. Grove, M.A. Azarm, *A Safety and Regulatory Assessment of Generic BWR and PWR Permanently Shutdown Nuclear Power Plants*, BNL-NUREG-52498, NUREG/CR-6451 (Brookhaven National Laboratory, 1997), http://www.osti.gov/bridge/product.biblio.jsp?osti_id=510336. NUREG-/CR6451 estimated the worst case population dose in a 50 mile radius at 81 million person-rem for both BWRs and PWRs. *Id.* at Tables 4-1 and 4-2. This is more than three times higher than in the estimate in NUREG-1353 cited above.

30. The Fukushima accident also indicates that the economic costs of a spent fuel pool accidents may be much higher than the current estimates used by the NRC. In NUREG-1353, the worst case property damage was estimated at \$30 billion (1988 dollars) in a 50-mile radius. *Id.* at Table 5.1.2. That amount is about \$50 billion in 2010 dollars (constant 2010 dollar estimates calculated using the Gross Domestic Product deflators of the U.S. Department of Commerce, as published by the St. Louis Federal Reserve at <http://research.stlouisfed.org/fred2/data/GDPDEF.txt> and rounded to the nearest \$10 billion). But in the Brookhaven study, the worst-case property damage in a 50-mile radius was estimated at \$280 billion for BWRs (*Id.* at Table 4-2), which would be about \$370 billion in 2010 dollars – or more than seven times the NUREG-1353 estimate cited above. The worst case damages in a 500-mile radius were estimated at \$546 billion for U.S. boiling water reactors (“BWRs”) plus 138,000 excess cancer deaths (*Id.* at Table 4-2) with a high population density. The damage amount would be about \$720 billion in 2010 dollars. Results were slightly higher for pressurized water reactor spent fuel pools. *Id.* at Table 4-1. The overall 500-mile population density

assumed in the Brookhaven study was lower than the population density near several U.S. reactors, notably in the Northeast. Further, the Brookhaven study itself notes its calculations would not “reasonably envelope” the situation (including projected population growth) at certain locations where there are reactors close to major metropolitan centers. “There are several existing plant sites (i.e., Indian Point, Limerick, and Zion) that precede the issuance of R.G. 4.7 and exceed the site population distributions generally considered acceptable by current NRC policy.”) *Id.* at 3-4 and footnote at 3-4. Moreover, certain assumptions of the 1997 Brookhaven study may prove optimistic especially in densely populated areas. For instance, the study assumes that the population could be evacuated in one day, should evacuation become necessary. *Id.* at 3-8. As another example, the relocation radius was only 10 miles, as per NUREG-1150. *Id.* at 3-8 and NUREG-1150, *An Assessment for Five Severe Accident Risks: An Assessment for Five U.S. Nuclear Power Plants: Final Summary Report*, U.S. Nuclear Regulatory Commission, Office of Nuclear Regulatory Research Vol. 1 at 2-20 (December 1990), <http://www.nrc.gov/reading-rm/doc-collections/nuregs/staff/sr1150/v1/sr1150v1-intro-and-part-1.pdf>. The relocation radius around Fukushima is greater than 10 miles. Moreover the U.S. advised its citizens early on to evacuate within a 50-mile radius of Fukushima Daiichi. This indicates that emergency management criteria and procedures need to be revisited.

31. In view of the severe crisis with multiple units at Fukushima in a densely populated industrialized country where there has been both direct and indirect economic damage, the 1997 Brookhaven study provides a reasonable starting point for a reevaluation of spent fuel accident consequences. Of course, Fukushima shows that the results of the Brookhaven study must be reviewed in the context of the potential for multiple failures at a single site in both reactors and spent fuel pools. Evacuation and population assumptions will likely need to be changed. As a result, both the monetary damages and health effects estimates may have to be revised upwards, possibly by substantial amounts in densely populated areas. Further, Fukushima is showing that there has already been indirect economic damage in industries like shipping and manufacturing that are not directly affected by fallout. While, the long-term and overall direct and indirect costs of the reactor and spent fuel damages from the Fukushima accident will take time to be tallied, it is clear that they will be enormous.

Hydrogen explosions and implications for aircraft crash evaluations

32. The Fukushima accident has revealed significant new information about the potential effects of hydrogen explosions. The estimated Unit 1 generation of hydrogen was 300 to 600 kg; for Units 2 and 3 it was 300 to 1,000 kg. Estimates were by an expert commissioned by AREVA. Matthias Braun, *The Fukushima Daiichi Incident*, AREVA, April 15, 2011, at 18, <http://www.wdr.de/tv/monitor//sendungen/2011/0407/pdf/areva-fukushima-report.pdf>. This indicates an urgent need to revisit the issue of aircraft crashes, deliberate or accidental, at existing reactors and spent fuel pools. The energy of the estimated amounts of hydrogen involved in the Fukushima explosions is far smaller than fuel in fully-loaded commercial jetliner – a type of crash that must be evaluated under NRC regulations. Five thousand gallons of jet fuel (not at all unusual for larger passenger jets -- the largest ones have much larger fuel capacities) have an energy content about four times as large as the largest estimate of the hydrogen explosions (1,000 kilograms of hydrogen gas) at Fukushima. Indeed, in light of Fukushima even a smaller, regional jet crash needs to be taken into account, especially for older

BWRs. Such damage needs to be evaluated both in the safety and environmental analyses. For instance, the Fukushima accident has demonstrated that evacuation planning in the circumstances of a natural disaster that is combined with a reactor accident is far more challenging than assumed by NRC emergency planning regulations.

Conclusions

33. As discussed above in pars. 16 through 32, the Fukushima accident has already revealed an enormous amount of new information regarding the safety vulnerabilities and environmental risks that need to be taken into account in licensing of new reactors, the re-licensing of existing reactors, early site permits, emergency procedures for protecting the civilian population, and approval of standardized reactor designs in rulemakings.

34. I believe that if the significant new information emanating from the Fukushima Daiichi accident is taken into consideration in NRC safety and environmental analyses, it is likely to fundamentally alter the outcome of those analyses in important ways. In the safety arena, consideration of this new information is likely to result in more rigorous regulation with respect to issues such as loss of offsite power, hydrogen explosion prevention, the siting of more than one reactor at a single site, spent fuel accident and reactor accident probabilities, the re-racking of spent fuel pools, permitting extended storage of spent fuel in pools after decommissioning, and emergency planning.

35. In the environmental and health arenas, consideration of this significant new information is likely to result in higher accident probability estimates, new accident mechanisms for spent fuel pools, higher accident cost estimates, and higher estimates of the health risks posed by light water reactor accidents. These increased risk and cost estimates will lead to much more serious consideration of alternatives for avoidance or mitigation of environmental risks. For instance, although the Commission has long rejected low-density pool storage combined with dry onsite storage as an alternative for mitigating the effects of catastrophic pool fires, that option may now prove to be very cost-beneficial. Present policy also does not require the transfer of all spent fuel from pools into dry casks at closed sites, as soon as safely possible after closure. A change of policy would be indicated by the scale of the disaster at Fukushima. In view of the large variation in potential damage and differences in emergency response needs, a plant-specific analysis will also be needed, including for all reactors in the Northeast.

36. It is likely that more (and more expensive) protective features will be needed to ensure a level of safety and security that will avoid the kinds of disastrous consequences occurring at Fukushima Daiichi. It is also likely that additional measures involving significant costs will have to be taken to reduce the likelihood and consequences of multi-reactor and/or spent fuel disasters. In light of this new information, a comparison between the economic attractiveness of a proposed new nuclear reactor or a proposed re-licensing of an existing reactor that might need modifications with other less risky and less expensive energy sources (such as wind, solar, and storage technologies such as compressed air) may well result in a decision that licensing of new reactors and re-licensing of existing reactors is not cost-effective.

37. Therefore, I believe it is reasonable and necessary for the NRC to suspend licensing and re-licensing decisions and standardized design certifications until the NRC completes its review of the regulatory implications of the Fukushima accident.

The facts presented above are true and correct to the best of my knowledge, and the opinions expressed therein are based on my best professional judgment.



Dr. Arjun Makhijani

19 April 2011

Date

Curriculum Vita of Arjun Makhijani

Address and Phone:

Institute for Energy and Environmental Research
6935 Laurel Ave., Suite 201
Takoma Park, MD 20912
Phone: 301-270-5500
e-mail: arjun@ieer.org
Website: www.ieer.org

A recognized authority on energy issues, Dr. Makhijani is the author and co-author of numerous reports and books on energy and environment related issues, including two published by MIT Press. He was the principal author of the first study of the energy efficiency potential of the US economy published in 1971. He is the author of *Carbon-Free and Nuclear-Free: A Roadmap for U.S. Energy Policy* (2007).

In 2007, he was elected Fellow of the American Physical Society. He was named a Ploughshares Hero, by the Ploughshares Fund (2006); was awarded the Jane Bagley Lehman Award of the Tides Foundation in 2008 and the Josephine Butler Nuclear Free Future Award in 2001; and in 1989 he received The John Bartlow Martin Award for Public Interest Magazine Journalism of the Medill School of Journalism, Northwestern University, with Robert Alvarez. He has many published articles in journals and magazines as varied as *The Bulletin of the Atomic Scientists*, *Environment*, *The Physics of Fluids*, *The Journal of the American Medical Association*, and *The Progressive*, as well as in newspapers, including the *Washington Post*.

Dr. Makhijani has testified before Congress, and has appeared on ABC World News Tonight, the CBS Evening News, CBS 60 Minutes, NPR, CNN, and BBC, among others. He has served as a consultant on energy issues to utilities, including the Tennessee Valley Authority, the Edison Electric Institute, the Lawrence Berkeley Laboratory, and several agencies of the United Nations.

Education:

- Ph.D. University of California, Berkeley, 1972, from the Department of Electrical Engineering. Area of specialization: plasma physics as applied to controlled nuclear fusion. Dissertation topic: multiple mirror confinement of plasmas. Minor fields of doctoral study: statistics and physics.
- M.S. (Electrical Engineering) Washington State University, Pullman, Washington, 1967. Thesis topic: electromagnetic wave propagation in the ionosphere.
- Bachelor of Engineering (Electrical), University of Bombay, Bombay, India, 1965.

Current Employment:

- 1987-present: President and Senior Engineer, Institute for Energy and Environmental Research, Takoma Park, Maryland. (part-time in 1987).
- February 3, 2004-present, Associate, SC&A, Inc., one of the principal investigators in the audit of the reconstruction of worker radiation doses under the Energy Employees Occupational Illness Compensation Program Act under contract to the Centers for Disease Control and Prevention, U.S. Department of Health and Human Services.

Other Long-term Employment

- 1984-88: Associate Professor, Capitol College, Laurel, Maryland (part-time in 1988).
- 1983-84: Assistant Professor, Capitol College, Laurel, Maryland.
- 1977-79: Visiting Professor, National Institute of Bank Management, Bombay, India. Principal responsibility: evaluation of the Institute's extensive pilot rural development program.
- 1975-87: Independent consultant (see page 2 for details)
- 1972-74: Project Specialist, Ford Foundation Energy Policy Project. Responsibilities included research and writing on the technical and economic aspects of energy conservation and supply in the U.S.; analysis of Third World rural energy problems; preparation of requests for proposals; evaluation of proposals; and the management of grants made by the Project to other institutions.
- 1969-70: Assistant Electrical Engineer, Kaiser Engineers, Oakland California. Responsibilities included the design and checking of the electrical aspects of mineral industries such as cement plants, and plants for processing mineral ores such as lead and uranium ores. Pioneered the use of the desk-top computer at Kaiser Engineers for performing electrical design calculations.

Professional Societies:

- Institute of Electrical and Electronics Engineers and its Power Engineering Society
- American Physical Society (Fellow)
- Health Physics Society
- American Association for the Advancement of Science

Awards and Honors:

- The John Bartlow Martin Award for Public Interest Magazine Journalism of the Medill School of Journalism, Northwestern University, 1989, with Robert Alvarez
- The Josephine Butler Nuclear Free Future Award, 2001
- Ploughshares Hero, Ploughshares Fund, 2006
- Elected a Fellow of the American Physical Society, 2007, "*For his tireless efforts to provide the public with accurate and understandable information on energy and environmental issues*"
- Jane Bagley Lehman Award of the Tides Foundation, 2007/2008

Invited Faculty Member, Center for Health and the Global Environment, Harvard Medical School: Annual Congressional Course, *Environmental Change: The Science and Human Health Impacts*, April 18-19, 2006, Lecture Topic: An Update on Nuclear Power - Is it Safe?

Consulting Experience, 1975-1987

Consultant on a wide variety of issues relating to technical and economic analyses of alternative energy sources; electric utility rates and investment planning; energy conservation; analysis of energy use in agriculture; US energy policy; energy policy for the Third World; evaluations of portions of the nuclear fuel cycle.

Partial list of institutions to which I was a consultant in the 1975-87 period:

- Tennessee Valley Authority
- Lower Colorado River Authority
- Federation of Rocky Mountain States
- Environmental Policy Institute
- Lawrence Berkeley Laboratory
- Food and Agriculture Organization of the United Nations
- International Labour Office of the United Nations
- United Nations Environment Programme
- United Nations Center on Transnational Corporations
- The Ford Foundation
- Economic and Social Commission for Asia and the Pacific
- United Nations Development Programme

Languages: English, French, Hindi, Sindhi, and Marathi.

Reports, Books, and Articles (Partial list)

(Newsletter, newspaper articles, excerpts from publications reprinted in books and magazines or adapted therein, and other similar publications are not listed below)

Hower, G.L., and A. Makhijani, "Further Comparison of Spread-F and Backscatter Sounder Measurements," *Journal of Geophysical Research*, 74, p. 3723, 1969.

Makhijani, A., and A.J. Lichtenberg, *An Assessment of Energy and Materials Utilization in the U.S.A.*, University of California Electronics Research Laboratory, Berkeley, 1971.

Logan, B. G., A.J. Lichtenberg, M. Lieberman, and A. Makhijani, "Multiple-Mirror Confinement of Plasmas," *Physical Review Letters*, 28, 144, 1972.

Makhijani, A., and A.J. Lichtenberg, "Energy and Well-Being," *Environment*, 14, 10, June 1972.

Makhijani, A., A.J. Lichtenberg, M. Lieberman, and B. Logan, "Plasma Confinement in Multiple Mirror Systems. I. Theory," *Physics of Fluids*, 17, 1291, 1974.

A Time to Choose: America's Energy Future, final report of the Ford Foundation Energy Policy Project, Ballinger, Cambridge, 1974. One of many co-authors.

Makhijani, A., and A. Poole, *Energy and Agriculture in the Third World*, Ballinger, Cambridge, 1975.

Makhijani, A., *Energy Policy for the Rural Third World*, International Institute for Environment and Development, London, 1976.

Kahn, E., M. Davidson, A. Makhijani, P. Caeser, and S. Berman, *Investment Planning in the Energy Sector*, Lawrence Berkeley Laboratory, Berkeley, 1976.

Makhijani, A., "Solar Energy for the Rural Third World," *Bulletin of the Atomic Scientists*, May 1977.

Makhijani, A., "Energy Policy for Rural India," *Economic and Political Weekly*, 12, Bombay, 1977.

Makhijani, A., *Some Questions of Method in the Tennessee Valley Authority Rate Study*, Report to the Tennessee Valley Authority, Chattanooga, 1978.

Makhijani, A., *The Economics and Sociology of Alternative Energy Sources*, Economic and Social Commission for Asia and the Pacific, 1979.

Makhijani, A., *Energy Use in the Post-Harvest Component of the Food Systems in Ivory Coast and Nicaragua*, Food and Agriculture Organization of the United Nations, Rome, 1982.

Makhijani, A., *Oil Prices and the Crises of Debt and Unemployment: Methodological and Structural Aspects*, International Labour Office of the United Nations, Final Draft Report, Geneva, April 1983.

Makhijani, A., and D. Albright, *The Irradiation of Personnel at Operation Crossroads*, International Radiation Research and Training Institute, Washington, D.C., 1983.

Makhijani, A., K.M. Tucker, with Appendix by D. White, *Heat, High Water, and Rock Instability at Hanford*, Health and Energy Institute, Washington, D.C., 1985.

Makhijani, A., and J. Kelly, *Target: Japan - The Decision to Bomb Hiroshima and Nagasaki*, July 1985, a report published as a book in Japanese under the title, *Why Japan?*, Kyoikusha, Tokyo, 1985.

Makhijani, A., *Experimental Irradiation of Air Force Personnel During Operation Redwing - 1956*, Environmental Policy Institute, Washington, D.C., 1985.

Makhijani, A., and R.S. Browne, "Restructuring the International Monetary System," *World Policy Journal*, New York, Winter, 1985-86.

Makhijani, A., R. Alvarez, and B. Blackwelder, *Deadly Crop in the Tank Farm: An Assessment of Management of High-Level Radioactive Wastes in the Savannah River Plant Tank Farm*, Environmental Policy Institute, Washington, D.C., 1986.

Makhijani, A., "Relative Wages and Productivity in International Competition," *College Industry Conference Proceedings*, American Society for Engineering Education, Washington, D.C., 1987.

Makhijani, A., *An Assessment of the Energy Recovery Aspect of the Proposed Mass Burn Facility at Preston, Connecticut*, Institute for Energy and Environmental Research, Takoma Park, 1987.

Makhijani, A., R. Alvarez, and B. Blackwelder, *Evading the Deadly Issues: Corporate Mismanagement of America's Nuclear Weapons Production*, Environmental Policy Institute, Washington, D.C., 1987.

Franke, B. and A. Makhijani, *Avoidable Death: A Review of the Selection and Characterization of a Radioactive Waste Repository in West Germany*, Health & Energy Institute, Washington, DC; Institute for Energy and Environmental Research, Takoma Park, November 1987.

Makhijani, A., *Release Estimates of Radioactive and Non-Radioactive Materials to the Environment by the Feed Materials Production Center, 1951-85*, Institute for Energy and Environmental Research, Takoma Park, 1988.

Alvarez, R., and A. Makhijani, "The Hidden Nuclear Legacy," *Technology Review*, 91, 42, 1988.

Makhijani, A., Annie Makhijani, and A. Bickel, *Saving Our Skins: Technical Potential and Policies for the Elimination of Ozone-Depleting Chlorine Compounds*, Environmental Policy Institute and Institute for Energy and Environmental Research, Takoma Park, 1988.

Makhijani, A., Annie Makhijani, and A. Bickel, *Reducing Ozone-Depleting Chlorine and Bromine Accumulations in the Stratosphere: A Critique of the U.S. Environmental Protection Agency's Analysis and Recommendations*, Institute for Energy and Environmental Research and Environmental Policy Institute/Friends of the Earth, Takoma Park, 1989.

Makhijani, A., and B. Franke, *Addendum to Release Estimates of Radioactive and Non-Radioactive Materials to the Environment by the Feed Materials Production Center, 1951-85*, Institute for Energy and Environmental Research, Takoma Park, 1989.

Makhijani, A., *Global Warming and Ozone Depletion: An Action Program for States*, Institute for Energy and Environmental Research, Takoma Park, 1989.

Makhijani, A., *Managing Municipal Solid Wastes in Montgomery County*, Prepared for the Sugarloaf Citizens Association, Institute for Energy and Environmental Research, Takoma Park, 1990.

Saleska, S., and A. Makhijani, *To Reprocess or Not to Reprocess: The Purex Question - A Preliminary Assessment of Alternatives for the Management of N-Reactor Irradiated Fuel at the*

U.S. Department of Energy's Hanford Nuclear Weapons Production Facility, Institute for Energy and Environmental Research, Takoma Park, 1990.

Makhijani, A., "Common Security is Far Off," *Bulletin of the Atomic Scientists*, May 1990.

Makhijani, A., *Draft Power in South Asian Agriculture: Analysis of the Problem and Suggestions for Policy*, prepared for the Office of Technology Assessment, Institute for Energy and Environmental Research, Takoma Park, 1990.

Mehta, P.S., S.J. Mehta, A.S. Mehta, and A. Makhijani, "Bhopal Tragedy's Health Effects: A Review of Methyl Isocyanate Toxicity," *JAMA* 264, 2781, December 1990.

Special Commission of International Physicians for the Prevention of Nuclear War and the Institute for Energy and Environmental Research, *Radioactive Heaven and Earth: The Health and Environmental Effects of Nuclear Weapons Testing In, On, and Above the Earth*, Apex Press, New York, 1991. One of many co-authors.

Makhijani, A., and S. Saleska, *High Level Dollars Low-Level Sense: A Critique of Present Policy for the Management of Long-Lived Radioactive Waste and Discussion of an Alternative Approach*, Apex Press, New York, 1992.

Makhijani, A., *From Global Capitalism to Economic Justice: An Inquiry into the Elimination of Systemic Poverty, Violence and Environmental Destruction in the World Economy*, Apex Press, New York, 1992.

Special Commission of International Physicians for the Prevention of Nuclear War and the Institute for Energy and Environmental Research, *Plutonium: Deadly Gold of the Nuclear Age*, International Physicians Press, Cambridge, MA, 1992. One of several co-authors.

Makhijani, A., "Energy Enters Guilty Plea," *Bulletin of the Atomic Scientists*, March/April 1994.

Makhijani, A., "Open the Files," *Bulletin of the Atomic Scientists*, Jan./Feb. 1995.

Makhijani, A., "'Always' the Target?" *Bulletin of the Atomic Scientists*, May/June 1995.

Makhijani, A., and Annie Makhijani, *Fissile Materials in a Glass, Darkly: Technical and Policy Aspects of the Disposition of Plutonium and Highly Enriched Uranium*, IEER Press, Takoma Park, 1995.

Makhijani, A., and K. Gurney, *Mending the Ozone Hole: Science, Technology, and Policy*, MIT Press, Cambridge, MA, 1995.

Makhijani, A., H. Hu, K. Yih, eds., *Nuclear Wastelands: A Global Guide to Nuclear Weapons Production and the Health and Environmental Effects*, MIT Press, Cambridge, MA, 1995.

Zerriffi, H., and A. Makhijani, *The Nuclear Safety Smokescreen: Warhead Safety and Reliability and the Science Based Stockpile Stewardship Program*, Institute for Energy and Environmental Research, Takoma Park, May 1996.

Zerriffi, H., and A. Makhijani, "The Stewardship Smokescreen," *Bulletin of the Atomic Scientists*, September/October 1996.

Makhijani, A., *Energy Efficiency Investments as a Source of Foreign Exchange*, prepared for the International Energy Agency Conference in Chelyabinsk, Russia, 24-26 September 1996.

Makhijani, A., "India's Options," *Bulletin of the Atomic Scientists*, March/April 1997.

Ortmeyer, P. and A. Makhijani, "Worse than We Knew," *Bulletin of the Atomic Scientists*, November/December 1997.

Fioravanti, M., and A. Makhijani, *Containing the Cold War Mess: Restructuring the Environmental Management of the U.S. Nuclear Weapons Complex*, Institute for Energy and Environmental Research, Takoma Park, October 1997.

Principal author of three chapters in Schwartz, S., ed., *Atomic Audit: The Costs and Consequences of U.S. Nuclear Weapons Since 1940*, Brookings Institution, Washington, D.C., 1998.

Franke, B., and A. Makhijani, *Radiation Exposures in the Vicinity of the Uranium Facility in Apollo, Pennsylvania*, Institute for Energy and Environmental Research, Takoma Park, February 2, 1998.

Fioravanti, M., and A. Makhijani, *Supplement to Containing the Cold War Mess - IEER's Response to the Department of Energy's Review*, Institute for Energy and Environmental Research, Takoma Park, March 1998.

Makhijani, A., "A Legacy Lost," *Bulletin of the Atomic Scientists*, July/August 1998.

Makhijani, A., and Hisham Zerriffi, *Dangerous Thermonuclear Quest: The Potential of Explosive Fusion Research for the Development of Pure Fusion Weapons*, Institute for Energy and Environmental Research, Takoma Park, July 1998.

Makhijani, A., and Scott Saleska, *The Nuclear Power Deception - U.S. Nuclear Mythology from Electricity "Too Cheap to Meter" to "Inherently Safe" Reactors*, Apex Press, New York, 1999.

Makhijani, A., "Stepping Back from the Nuclear Cliff," *The Progressive*, vol. 63, no. 8, August 1999.

Makhijani, A., Bernd Franke, and Hisham Zerriffi, *Preliminary Partial Dose Estimates from the Processing of Nuclear Materials at Three Plants during the 1940s and 1950s*, Institute for Energy and Environmental Research, Takoma Park, September 2000. (Prepared under contract to the newspaper USA Today.)

Makhijani, A., and Bernd Franke, *Final Report of the Institute for Energy and Environmental Research on the Second Clean Air Act Audit of Los Alamos National Laboratory by the Independent Technical Audit Team*, Institute for Energy and Environmental Research, Takoma Park, December 13, 2000.

Makhijani, A., *Plutonium End Game: Managing Global Stocks of Separated Weapons-Usable Commercial and Surplus Nuclear Weapons Plutonium*, Institute for Energy and Environmental Research, Takoma Park, January 2001.

Makhijani, A., Hisham Zerriffi, and Annie Makhijani, "Magical Thinking: Another Go at Transmutation," *Bulletin of the Atomic Scientists*, March/April 2001.

Makhijani, A., *Ecology and Genetics: An Essay on the Nature of Life and the Problem of Genetic Engineering*. New York: Apex Press, 2001.

Makhijani, A., "Burden of Proof," *Bulletin of the Atomic Scientists*, July/August 2001.

Makhijani, A., "Reflections on September 11, 2001," in Kamla Bhasin, Smitu Kothari, and Bindia Thapar, eds., *Voices of Sanity: Reaching Out for Peace*, Lokayan, New Delhi, 2001, pp. 59-64.

Makhijani, A., and Michele Boyd, *Poison in the Vadose Zone: An examination of the threats to the Snake River Plain aquifer from the Idaho National Engineering and Environmental Laboratory*, Institute for Energy and Environmental Research, Takoma Park, October 2001.

Makhijani, A., *Securing the Energy Future of the United States: Securing the Energy Future of the United States: Oil, Nuclear, and Electricity Vulnerabilities and a post-September 11, 2001 Roadmap for Action*, Institute for Energy and Environmental Research, Takoma Park, November 2001.

Makhijani, A., and Sriram Gopal, *Setting Cleanup Standards to Protect Future Generations: The Scientific Basis of Subsistence Farmer Scenario and Its Application to the Estimation of Radionuclide Soil Action Levels (RSALs) for Rocky Flats*, Institute for Energy and Environmental Research, Takoma Park, December 2001.

Makhijani, A., "Some Factors in Assessing the Response to September 11, 2001," *Medicine and Global Survival*, International Physicians for the Prevention of Nuclear War, Cambridge, Mass., February 2002.

Makhijani, Annie, Linda Gunter, and A. Makhijani, *Cogema: Above the Law?: Concerns about the French Parent Company of a U.S. Corporation Set to Process Plutonium in South Carolina*. A report prepared by Institute for Energy and Environmental Research and Safe Energy Communication Council. Takoma Park, MD, May 7, 2002.

Deller, N., A. Makhijani, and J. Burroughs, eds., *Rule of Power or Rule of Law? An Assessment of U.S. Policies and Actions Regarding Security-Related Treaties*, Apex Press, New York, 2003.

Makhijani, A., "Nuclear targeting: The first 60 years," *Bulletin of the Atomic Scientists*, May/June 2003.

Makhijani, A., "Strontium," *Chemical & Engineering News*, September 8, 2003.

Makhijani, A., and Nicole Deller, *NATO and Nuclear Disarmament: An Analysis of the Obligations of the NATO Allies of the United States under the Nuclear Non-Proliferation Treaty and the Comprehensive Test Ban Treaty*, Institute for Energy and Environmental Research, Takoma Park, Maryland, October 2003.

Makhijani, A., *Manifesto for Global Democracy: Two Essays on Imperialism and the Struggle for Freedom*, Apex Press, New York, 2004.

Makhijani, A., "Atomic Myths, Radioactive Realities: Why nuclear power is a poor way to meet energy needs," *Journal of Land, Resources, & Environmental Law*, v. 24, no. 1, 2004, pp. 61-72. Adapted from an oral presentation given on April 18, 2003, at the Eighth Annual Wallace Stegner Center Symposium titled "Nuclear West: Legacy and Future," held at the University of Utah S.J. Quinney College of Law."

Makhijani, A., and Michele Boyd, *Nuclear Dumps by the Riverside: Threats to the Savannah River from Radioactive Contamination at the Savannah River Site*, Institute for Energy and Environmental Research, Takoma Park, Maryland, March 2004.

Makhijani, A., and Brice Smith, *The Role of E.I. du Pont de Nemours and Company (Du Pont) and the General Electric Company in Plutonium Production and the Associated I-131 Emissions from the Hanford Works*, Institute for Energy and Environmental Research, Takoma Park, Maryland, March 30, 2004.

Makhijani, A., Peter Bickel, Aiyou Chen, and Brice Smith, *Cash Crop on the Wind Farm: A New Mexico Case Study of the Cost, Price, and Value of Wind-Generated Electricity*, Institute for Energy and Environmental Research, Takoma Park, Maryland, April 2004.

Makhijani, A., Lois Chalmers, and Brice Smith, *Uranium Enrichment: Just Plain Facts to Fuel an Informed Debate on Nuclear Proliferation and Nuclear Power*, Institute for Energy and Environmental Research, Takoma Park, Maryland, October 15, 2004.

Makhijani, A., and Brice Smith, *Costs and Risks of Management and Disposal of Depleted Uranium from the National Enrichment Facility Proposed to be Built in Lea County New Mexico by LES*, Institute for Energy and Environmental Research, Takoma Park, Maryland, November 24, 2004.

Makhijani, A., project director, *Examen critique du programme de recherche de l'ANDRA pour déterminer l'aptitude du site de Bure au confinement géologique des déchets à haute activité et à vie longue: Rapport final*, prepared for le Comité ocal d'Information et de Suivi; coordinator: Annie Makhijani; authors: Detlef Appel, Jaak Daemen, George Danko, Yuri Dublyansky, Rod Ewing, Gerhard Jentsch, Horst Letz, Arjun Makhijani, Institute for Energy and Environmental Research, Takoma Park, Maryland, December 2004

Institute for Energy and Environmental Research, *Lower Bound for Cesium-137 Releases from the Sodium Burn Pit at the Santa Susana Field Laboratory*, IEER, Takoma Park, Maryland, January 13, 2005. (Authored by A. Makhijani and Brice Smith.)

Institute for Energy and Environmental Research, *Iodine-131 Releases from the July 1959 Accident at the Atomics International Sodium Reactor Experiment*, IEER, Takoma Park, Maryland, January 13, 2005. (Authored by A. Makhijani and Brice Smith.)

Makhijani, A., and Brice Smith. *Update to Costs and Risks of Management and Disposal of Depleted Uranium from the National Enrichment Facility Proposed to be Built in Lea County New Mexico by LES*. Institute for Energy and Environmental Research, Takoma Park, Maryland, July 5, 2005.

Makhijani, A., "A Readiness to Harm: The Health Effects of Nuclear Weapons Complexes," *Arms Control Today*, **35**, July/August 2005.

Makhijani, A., *Bad to the Bone: Analysis of the Federal Maximum Contaminant Levels for Plutonium-239 and Other Alpha-Emitting Transuranic Radionuclides in Drinking Water*, Institute for Energy and Environmental Research, Takoma Park, Maryland, August 2005.

Makhijani, A., and Brice Smith, *Dangerous Discrepancies: Missing Weapons Plutonium in Los Alamos National Laboratory Waste Accounts*, Institute for Energy and Environmental Research, Takoma Park, Maryland, April 21, 2006.

Makhijani, Annie, and A. Makhijani, *Low-Carbon Diet without Nukes in France: An Energy Technology and Policy Case Study on Simultaneous Reduction of Climate Change and Proliferation Risks*, Institute for Energy and Environmental Research, Takoma Park, Maryland, May 4, 2006.

Makhijani, Annie, and A. Makhijani. *Shifting Radioactivity Risks: A Case Study of the K-65 Silos and Silo 3 Remediation and Waste Management at the Fernald Nuclear Weapons Site*, Institute for Energy and Environmental Research, Takoma Park, Maryland, August 2006.

Smith, Brice, and A. Makhijani, "Nuclear is Not the Way," *Wilson Quarterly*, v.30, p. 64, Autumn 2006.

Makhijani, A., Brice Smith, and Michael C. Thorne, *Science for the Vulnerable: Setting Radiation and Multiple Exposure Environmental Health Standards to Protect Those Most at Risk*, Institute for Energy and Environmental Research, Takoma Park, Maryland, October 19, 2006.

Makhijani, A., *Carbon-Free and Nuclear Free: A Roadmap for U.S. Energy Policy*, IEER Press, Takoma Park, Maryland; RDR Books, Muskegon, Michigan, 2007.

Makhijani, A., *Assessing Nuclear Plant Capital Costs for the Two Proposed NRG Reactors at the South Texas Project Site*, Institute for Energy and Environmental Research, Takoma Park, Maryland, March 24, 2008.

Makhijani, A., *Energy Efficiency Potential: San Antonio's Bright Energy Future*, Institute for Energy and Environmental Research, Takoma Park, Maryland, October 9, 2008.

Makhijani, A., *The Use of Reference Man in Radiation Protection Standards and Guidance with Recommendations for Change*, Institute for Energy and Environmental Research, Takoma Park, Maryland, December 2008.

Makhijani, A., *Comments of the Institute for Energy and Environmental Research on the U.S. Nuclear Regulatory Commission's Proposed Waste Confidence Rule Update and Proposed Rule Regarding Environmental Impacts of Temporary Spent Fuel Storage*, Institute for Energy and Environmental Research, Takoma Park, Maryland, February 6, 2009.

Makhijani, A., *Technical and Economic Feasibility of a Carbon-Free and Nuclear-Free Energy System in the United States*, Institute for Energy and Environmental Research, Takoma Park, Maryland, March 4, 2009.

Fundación Ideas para el Progreso, *A New Energy Model For Spain: Recommendations for a Sustainable Future* (originally: *Un nuevo modelo energético para España: Recomendaciones para un futuro sostenible*), by the Working Group of Foundation Ideas for Progress on Energy and Climate Change, Fundación Ideas , Madrid, May 20, 2009. Arjun Makhijani contributed Section 2.2. The cost of nuclear energy and the problem of waste.

Makhijani, A., *IEER Comments on the Nuclear Regulatory Commission's Rulemaking Regarding the "Safe Disposal of Unique Waste Streams Including Significant Quantities of Depleted Uranium,"* Institute for Energy and Environmental Research, Takoma Park, Maryland, October 30, 2009.

Makhijani, A., *The Mythology and Messy Reality of Nuclear Fuel Reprocessing*, Institute for Energy and Environmental Research, Takoma Park, Maryland, April 8, 2010.

CV updated October 11, 2010