

MAY 22 1975

Docket Nos. 50-438
and 50-439

Tennessee Valley Authority
ATTN: Mr. James E. Watson
Manager of Power
818 Power Building
Chattanooga, Tennessee 37401

Gentlemen:

During the course of our review of your construction permit (CP) application for the Bellefonte Nuclear Plant, Units 1 and 2, resolution of several items was scheduled for the post-CP time period. A tabulation of such items is attached. In this tabulation you will note that the status of most of these items (asterisked) requires additional information or documentation from the Tennessee Valley Authority. To enable us to resolve these items in a timely manner, your schedule and method of resolution is needed for each asterisked item by July 1, 1975.

Please contact us if you have any questions regarding this matter.

Sincerely,

Original Signed by
S. MacKay

A. Schwencer, Chief
Light Water Reactors Branch 2-3
Division of Reactor Licensing

Enclosure:
as stated

cc: See next page

APP
131

4

cc: Mr. R. H. Marquis
General Counsel
629 New Sprakle Building
Knoxville, Tennessee 37902

bcc: E. G. Beasley, Jr.
307 U.B.A.
Tennessee Valley Authority
Knoxville, Tennessee 37902

DISTRIBUTION

NRC PDR
LocalPDR
Docket File
LWR 2-3 Reading File
RDeYoung
VAMoore
FSchroeder
AKenneke
MWilliams
RKlecker
OELD
OI&E (3)
DDavis
EGoulbourne
JStolz
KKniel
ASchwencer**
DVassallo
OParr
WButler
ACRS (14)
JRBuchanan, ORNL
TBAbernathy, DTIE

OFFICE >	x7806 LWR 2-3	C-LWR 2-3:RL			
SURNAME >	DDavis	ASchwencer			
DATE >	5/22/75	5/1/75			

BELLEFONTE NUCLEAR PLANT, UNITS 1 AND 2

DOCKET NOS. 50-438 AND 50-439

POST-CP REVIEW ITEMS

<u>Item</u>	<u>Responsible TR Branch</u>	<u>Reference</u>	<u>Status</u>
*1. R&D Program	RSB	SER 1.7, 4.4, ACRS	BAW-10097 under review. Future PSAR Amendment is needed to reference this topical report.
*2. Airport Relocation Study	AAB	SER 2.2, PSAR Q2.52	Future PSAR amendment was proposed to refine crash probability. Another Amendment will be needed if FAA study leads to a significant change in airport characteristics.
*3. Location of Permanent Meteorological Tower	SAB	SER 2.3	Future PSAR amendment is needed to describe location of tower.
4. Geologic Review of Foundations	SAB & SEB	PSAR Q2.15, 2.76, 2.77, NRC ltr 3/25/75, TVA ltr 4/14/75 & 5/16/75	TVA's additional information under review.
5. Turbine Missiles	AAB	SER 3.5	Development of NRC staff position is not yet completed
*6. ATWS	RSB	SER 5.2.2, TVA ltr 9/30/74	BAW-10099 under review. Future PSAR Amendment is needed to reference topical report.
*7. Heatup-Cooldown Limits (10 CFR 50 Appendix G)	MTEB	SER 5.2.4	A B&W topical report is to be submitted and referenced in a PSAR amendment.

*Schedule needed from TVA for resolution of this item.

<u>Item</u>	<u>Responsible TR Branch</u>	<u>Reference</u>	<u>Status</u>
*8. Post-LOCA Cooling	RSB & EICSB	SER 7.3, TVA Ltr 10/7/74	Design criteria are needed from TVA.
*9. ECCS Testing	RSB	SER 6.3.4	Future PSAR amendment to address Reg. Guide 1.79 with provisions for testing crossover lines is needed.
*10. RPS II and Pressurizer Trip	EICSB	SER 7.2, ACRS	BAW-10085 under review. Future PSAR amendment is needed to reference topical report.
11. Instr. to Monitor Course of Accidents	EICSB	SER 18.6, ACRS	Reg. Guide is under development.
*12. RC Pump Overspeed	RSB	SER 18.7, ACRS	PSAR amendment is needed to report test results and B&W's evaluation of impact.
*13. Rock Anchor Tests	SEB & SAB	SER 18.4, ACRS	TVA to report results of testing.
*14. Operability Assurance Testing Program	MEB	PSAR Q3.83	Meetings to be held with TVA to discuss progress of testing program.
*15. Azimuthal Noding to Determine the Design RV Cavity Pressure and RV Support Loadings	CSB, SEB, & MEB	Recent licensing reviews	Meeting to be held with TVA to discuss recent analyses and the need to include similar analyses in the FSAR.

*Schedule needed from TVA for resolution of this item.