



April 19, 2011

SBK-L-11081
Docket No. 50-443

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Seabrook Station

Withdrawal of License Amendment Request 10-06
Request to Revise Technical Specification (TS) Sections 6.7.6.k, "Steam Generator (SG)
Program," and TS 6.8.1.7, "Steam Generator Tube Inspection Report,"
For Temporary Alternate Repair Criteria

Reference

NextEra Energy Seabrook, LLC letter SBK-L-10234, "License Amendment Request to Revise Technical Specification (TS) Sections 6.7.6.k, "Steam Generator (SG) Program," and TS 6.8.1.7, "Steam Generator Tube Inspection Report," for Temporary Alternate Repair Criteria," January 27, 2011 (ML 110330202)

NextEra Energy Seabrook, LLC (NextEra) submitted License Amendment Request (LAR) 10-06 for an amendment to the Technical Specifications (TS) for Seabrook Station. The proposed change would revise TS 6.7.6.k, "Steam Generator (SG) Program," to exclude portions of the SG tubes below the top of the SG tubesheet from periodic inspections during refueling outage 14 (OR14) in the spring of 2011 and the subsequent inspection cycle. In addition, this amendment request proposed to revise TS 6.8.1.7 "Steam Generator Tube Inspection Report."

The requested amendment would have been required if primary water stress corrosion cracking (PWSCC) had been detected during the steam generator tube inspections in the April 2011 refueling outage. The inspections completed with no indications of PWSCC; therefore, NextEra is withdrawing LAR 10-06.

A001
NRR

Should you have any questions regarding this letter, please contact Mr. Michael O'Keefe, Licensing Manager, at (603) 773-7745.

Sincerely,

NextEra Energy Seabrook, LLC



Paul Freeman
Site Vice President

cc: NRC Region I Administrator
G. E. Miller, NRC Project Manager
W. J. Raymond, NRC Senior Resident Inspector

Mr. Christopher M. Pope, Director Homeland Security and Emergency Management
New Hampshire Department of Safety
Division of Homeland Security and Emergency Management
Bureau of Emergency Management
33 Hazen Drive
Concord, NH 03305

Mr. John Giarrusso, Jr., Nuclear Preparedness Manager
The Commonwealth of Massachusetts
Emergency Management Agency
400 Worcester Road
Framingham, MA 01702-5399