

PMFermiCOLPEm Resource

From: Anand, Raj
Sent: Thursday, April 07, 2011 3:24 PM
To: latzyn@dteenergy.com
Cc: Muniz, Adrian; FermiCOL Resource
Subject: Fermi Unit 3 - 02.05.04 - Stability of Subsurface Materials and Foundations - Draft RAI No. 5687, Question # 20776

Nick,
Please let us know as to whether or not the following proposed license condition is considered appropriate to support the Fermi 3 COL:

"The applicant may not place fill material, other than concrete that meets the design, construction and testing of applicable ACI standards, underneath any Category I structure to a thickness greater than 5 feet"

Thanks,
Raj

Hearing Identifier: Fermi_COL_Public
Email Number: 828

Mail Envelope Properties (B46615B367D1144982B324704E3BCEED6ACF19C7FD)

Subject: Fermi Unit 3 - 02.05.04 - Stability of Subsurface Materials and Foundations -
Draft RAI No. 5687, Question # 20776
Sent Date: 4/7/2011 3:23:36 PM
Received Date: 4/7/2011 3:23:37 PM
From: Anand, Raj

Created By: Raj.Anand@nrc.gov

Recipients:
"Muniz, Adrian" <Adrian.Muniz@nrc.gov>
Tracking Status: None
"FermiCOL Resource" <FermiCOL.Resource@nrc.gov>
Tracking Status: None
"latzyn@dteenergy.com" <latzyn@dteenergy.com>
Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	394	4/7/2011 3:23:37 PM

Options
Priority: Standard
Return Notification: No
Reply Requested: Yes
Sensitivity: Normal
Expiration Date:
Recipients Received: