



the requirement of these recorders was to supply trend information to the operators. This information would allow them to follow the course of the accident and aid in making any manual changes needed during the course of the event. However, TVA was not able to commit at this meeting to meet our requirement of recorder functionality after a seismic event.

4. Check Valve Leakage Monitor

TVA indicated that a leakage monitor after the first check valve in the LPI line would be provided. This commitment is to be documented in Amendment 12 of the PSAR in TVA's response to AQ 6.42.

5. LPI-HPI Crossover Valves

In response to the staff's position in Q 7.25 and Q 6.79, TVA indicated that they would commit to providing remote manual operation for these valves. This will be documented in Amendment 12 of the PSAR.

6. Regulatory Guide 1.31

TVA indicated that they intend to comply with the intent of the staff's interim position on Regulatory 1.31 which will include some production testing. The staff will transmit this interim position to TVA. TVA will respond to this with their commitment in Amendment 12 to the PSAR.

7. Regulatory Guide 1.44

TVA indicated that in response to Q 5.4 they will indicate the test procedure (A-393-63) used for qualifying welding procedures. This will be documented in Amendment 12 to the PSAR.

8. Loose Parts Monitoring System

The staff indicated that our current position on loose parts monitoring systems was to require such a system be installed on the Bellefonte reactors. The present technology has produced several systems which have been extremely beneficial in several recently licensed facilities. TVA indicated that such a system would be installed on the Bellefonte reactors. The staff indicated that we would transmit our position to TVA. TVA indicated they would document their commitment in Amendment 12 to the PSAR.

Original Signed

Don K. Davis, Project Manager  
 Light Water Reactors Br. 2-3  
 Directorate of Licensing

OFFICE					
SURNAME	Enclosures:				
DATE	1.	Agenda			
	2.	Attendance List			

DISTRIBUTION:

Local PDR  
 AEC PDR (2)  
 Dockets (2)  
 LWR 2-3 Rdg  
 L Rdg  
 RCDeYoung  
 VAMoore  
 RDenise  
 DJSkovholt  
 IMuller  
 KGoller  
 DVassallo  
 WButler  
 OParr  
 JStolz  
 KKniel  
 ASchwencer  
 RClark  
 BSchemel  
 DZiemann  
 PCollins  
 RPurple  
 GKnighton  
 GDicker  
 BYoungblood  
 WRegan  
 SVarga  
 DEisenhut  
 JHendrie  
 VStello  
 RMaccary  
 RTedesco  
 HDenton  
 TNovak  
 RHouston  
 TIPPOLITO  
 DRoss

JKnight  
 SPawlicki  
 LShao  
 CLong  
 GLainas  
 VBenaroya  
 RVollmer  
 BGrimes  
 WGannill  
 JKastner  
 MSpangler  
 RBallard  
 GDickman  
 DKDavis  
 WPaton  
 RO (3)  
 EIGoulbourne  
 ACRS (16)  
 RZavadoski  
 JKohler  
 KMurphy  
 ASzukiewicz  
 JWeeks  
 RGustafson  
 FRosa

OFFICE >						
SURNAME >						
DATE >						

MAY 9 1974

ATTENDANCE LIST

Regulatory Staff

J. F. O'Leary  
E. G. Case  
A. Giambusso  
V. A. Moore  
D. J. Skovholt  
A. Schwencer  
R. Vollmer  
A. Garland  
J. Spraul  
D. K. Davis  
W. Paton

Tennessee Valley Authority

R. Davidson  
B. Cravasse  
T. Spink  
B. Mull  
J. Knight  
W. Aydelott  
W. Dibler  
D. Powel  
J. Burger