



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

April 4, 1991

Docket Nos. 50-438  
and 50-439

LICENSEE: Tennessee Valley Authority

FACILITY: Bellefonte Nuclear Plant, Units 1 and 2

SUBJECT: SUMMARY OF FEBRUARY 19, 1991 MEETING WITH TVA ON DESIGN BASIS  
ACCIDENTS ANALYSIS AND EQUIPMENT QUALIFICATION FOR BELLEFONTE,  
UNITS 1 AND 2 (TAC NOS. 79273 AND 79274)

On February 19, 1991, the NRC staff met with the TVA staff to discuss two position papers submitted by TVA on February 4, 1991, in support of its plans to reactivate the licensing process of Bellefonte, Units 1 and 2. Enclosure 1 lists the meeting attendees.

The first position paper (Enclosure 2) addressed TVA's position on the scope of the requirements for qualification of electrical equipment important to safety, and an alternative methodology for calculating the peak containment temperature resulting from a main steam line break inside containment. Based on TVA's presentation and subsequent discussions, the NRC staff informed TVA that any electrical equipment qualified to NUREG-0588 Category II guidelines, which fails during testing, should be replaced with equipment qualified to Category I requirements of NUREG-0588. The TVA staff indicated that if the staff were to formally take this position, TVA would consider it a backfit. The TVA staff stated that since the Bellefonte plant's construction permit safety evaluation was issued before July 1, 1974, the Commission's Statement of Policy (48 FR 2730) permits replacement equipment qualification to Category II requirements. However, TVA will make every effort to qualify the replacement equipment to Category I requirements if acquisition of suitable equipment does not adversely affect the Bellefonte's construction schedule. The resolution of the equipment qualification category issue was deferred to future discussions and correspondence.

The position paper also presents a revised method for calculating peak containment temperature for equipment qualification requirements. The NRC staff informed the TVA staff that substantial review effort will be required to review TVA's methodology. The staff members at the meeting indicated that they could not justify such review resources for Bellefonte review due to competing demands of other programs. The staff promised TVA that it will discuss the question of Bellefonte priority with the NRC management.

The second position paper discussed during the February 19, 1991 meeting related to the NRC staff's review of TVA's February 4, 1991 position paper on FSAR Accident Analysis (Enclosure 3). The TVA staff stated that it plans to revise the analysis of Bellefonte LOCA events using the RELAP/MOD2-B&W computer code. With regard to the analyses of non-LOCA events, the TVA staff plans to

NRC FILE CENTER COPY

*Memo 4*

revise some analyses described in the FSAR, will analyze some new events, and will not reanalyze those non-LOCA events that are not affected by subsequent regulatory changes.

The position paper also contained TVA's schedule for submittal and desired NRC approval of Topical Reports describing computer code methodology, evaluation model, and evaluation results. The staff requested that TVA revise the schedule dates of NRC approval of topical reports to allow NRC a minimum of 28 months for topical report approval. Additionally, TVA should provide its rationale for not reanalyzing some of the non-LOCA accidents. TVA agreed to provide a response to the NRC staff requests.

Original signed by

Mohan C. Thadani, Project Manager  
Project Directorate II-4  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Enclosures:

1. Attendance List
2. Position Paper of  
February 4, 1991  
on Equipment  
Qualifications
3. Position Paper of  
February 4, 1991  
on Accident Analysis

cc w/enclosure:  
See next page

OFC	: PDII-4/LA	: PDII-4/PM	: PDII-4/DD	: PDII-4/D	:
NAME	: MKrebs <i>mk</i>	: MThadani:as	: SBlack	: FHebdon	:
DATE	: 4/2/91	: 4/3/91	: 4/3/91	: 4/4/91	:

OFFICIAL RECORD COPY  
Document Name: BELLEFONTE MEETING SUMMARY

Meeting Summary, Memoranda for Trip Reports or Site Visits

Docket File

NRC PDR

Local PDR

F. Miraglia 12-G-18

J. Partlow 12-G-18

S. Varga 14-E-4

G. Lainas 14-H-3

F. Hebdon

S. Black

M. Krebs

M. Thadani

B. Wilson RII

J. Weschelberger 17-G-21

G. Walton RII

K. Barr RII

OGC 15-B-18

E. Jordan MNBB-3701

ACRS (10)

G. Hubbard

J. Lyons

H. Walker

J. Kudrick

M. Caruso

F. Orr

BLN Rdg. File

cc:

Mr. Marvin Runyon, Chairman  
Tennessee Valley Authority  
ET 12A  
400 West Summit Hill Drive  
Knoxville, Tennessee 37902

Mr. Edward E. Wallace  
Manager, Nuclear Licensing  
and Regulatory Affairs  
Tennessee Valley Authority  
5B Lookout Place  
Chattanooga, Tennessee 37402-2801

Mr. John B. Waters, Director  
Tennessee Valley Authority  
ET 12A  
400 West Summit Hill Drive  
Knoxville, Tennessee 37902

Mr. W. F. Willis  
Senior Executive Officer  
ET 12B  
400 West Summit Hill Drive  
Knoxville, Tennessee 37902

General Counsel  
Tennessee Valley Authority  
ET 11H  
400 West Summit Hill Drive  
Knoxville, Tennessee 37902

Mr. Dwight Nunn  
Vice President, Nuclear Projects  
Tennessee Valley Authority  
6A Lookout Place  
1101 Market Street  
Chattanooga, Tennessee 37402-2801

Dr. Mark O. Medford  
Vice President, Nuclear Assurance,  
Licensing and Fuels  
Tennessee Valley Authority  
6A Lookout Place  
1101 Market Street  
Chattanooga, Tennessee 37402-2801

Mr. Bruce Schofield, Site Licensing Manager  
Bellefonte Nuclear Plant  
Tennessee Valley Authority  
P. O. Box 2000  
Hollywood, Alabama 35752

Mr. W. J. Museler, Site Vice President  
Bellefonte Nuclear Plant  
Tennessee Valley Authority  
P. O. Box 2000  
Hollywood, Alabama 35752

Chairman, Jackson County Commission  
Courthouse  
Scottsboro, Alabama 35752-0200

Claude Earl Fox, M. D.  
State Health Officer  
State Department of Public Health  
State Office Building  
Montgomery, Alabama 36130

Regional Administrator, Region II  
U. S. Nuclear Regulatory Commission  
101 Marietta Street, N.W.  
Atlanta, Georgia 30323

Tennessee Valley Authority  
Rockville Office  
11921 Rockville Pike  
Suite 402  
Rockville, Maryland 20852

Mr. Richard F. Wilson  
Vice President, New Generation  
and BLN Construction  
Tennessee Valley Authority  
6A Lookout Place  
Chattanooga, Tennessee 37402-2801

Mr. Dan A. Nauman  
Senior Vice President, Nuclear Power  
Tennessee Valley Authority  
6N 38A Lookout Place  
1101 Market Street  
Chattanooga, Tennessee 37402-2801

Enclosure 1

NRC-TVA MEETING

BELLEFONTE NUCLEAR PLANT

FEBRUARY 19, 1991

ATTENDEES

Mohan C. Thadani  
George Hubbard  
Jim Lyons  
Harold Walker  
Jack Kudrick  
Mark A. Caruso  
Frank Orr  
Jeffery C. Seals  
Bob Bryan  
Malcolm Phillips  
Randy H. Ellison  
Chris Schieck  
Herb Estrada  
Bruce Schofield

ORGANIZATION

NRC/NRR/PDII-4  
NRC/NRR/SPLB  
NRC/NRR/SPLB  
NRC/NRR/SPLB  
NRC/NRR/SPLB  
NRC/NRR/SRXB  
NRC/NRR/SRXB  
TVA-Consultant  
TVA  
Winston and Strawn  
TVA-Consultant  
TVA-Consultant  
TVA  
TVA