

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8308030132 DOC. DATE: 83/07/27 NOTARIZED: YES DOCKET #
 FACIL: 50-438 Bellefonte Nuclear Plant, Unit 1, Tennessee Valley Au 05000438
 50-439 Bellefonte Nuclear Plant, Unit 2, Tennessee Valley Au 05000439

AUTH. NAME AUTHOR AFFILIATION
 KAMMER, D.S. Tennessee Valley Authority
 RECIP. NAME RECIPIENT AFFILIATION
 ADENSAM, E. Licensing Branch 4

SUBJECT: Forwards revised response to Item 3 re resolution of A-45,
 "Shutdown DHR Requirements" of util 830505 ltr addressing
 13 unresolved safety issues.

DISTRIBUTION CODE: B001S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2
 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID	CODE/NAME	LTTR	ENCL		ID	CODE/NAME	LTTR	ENCL
	NRR	DL/ADL	1	0	NRR	LB4 BC	1	0	
	NRR	LB4 LA	1	0	THADANI, M	01	1	1	
INTERNAL:	ELD	HDS2	1	0	IE	FILE	1	1	
	IE	DEPER/EPB	36	3	3	IE/DEPER/IRB	35	1	1
	IE	DEQA/QAB	21	1	1	NRR/DE/AEAB		1	0
	NRR	DE/CEB	11	1	1	NRR/DE/EHEB		1	1
	NRR	DE/eqB	13	2	2	NRR/DE/GB	28	2	2
	NRR	DE/MEB	18	1	1	NRR/DE/MTEB	17	1	1
	NRR	DE/SAB	24	1	1	NRR/DE/SGEB	25	1	1
	NRR	DHFS/HFEB40		1	1	NRR/DHFS/LQB	32	1	1
	NRR	DHFS/PSRB		1	1	NRR/DL/SSPB		1	0
	NRR	DSI/AEB	26	1	1	NRR/DSI/ASB		1	1
	NRR	DSI/CPB	10	1	1	NRR/DSI/CSB	09	1	1
	NRR	DSI/ICSB	16	1	1	NRR/DSI/METB	12	1	1
	NRR	DSI/PSB	19	1	1	NRR/DSI/RAB	22	1	1
	NRR	DSI/RSB	23	1	1	REG FILE	04	1	1
	RGN2		3	3	3	RM/DDAMI/MIB		1	0
EXTERNAL:	ACRS		41	6	6	BNL (AMDTS ONLY)		1	1
	DMB/DSS	(AMDTS)		1	1	FEMA-REP DIV	39	1	1
	LPDR		03	1	1	NRC PDR	02	1	1
	NSIC		05	1	1	NTIS		1	1

TOTAL NUMBER OF COPIES REQUIRED: LTTR 53 ENCL 46

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401
400 Chestnut Street Tower II

July 27, 1983

Director of Nuclear Reactor Regulation
Attention: Ms. E. Adensam, Chief
Licensing Branch No. 4
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Ms. Adensam:

In the Matter of the Application of) Docket No. 50-438
Tennessee Valley Authority) 50-439

Please refer to our letter dated May 5, 1983 in which we addressed 13 "Unresolved Safety Issues" (USI) pertaining to Bellefonte Nuclear Plant units 1 and 2. Enclosed is a revised response to item 3 (on page 19) under plant-specific efforts related to resolution of USI A-45. This revision is the result of further discussions between TVA and Babcock & Wilcox concerning this matter.

If you have any questions concerning this matter, please get in touch with W. T. Watters at FTS 858-2691.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

DS Kammer

D. S. Kammer
Nuclear Engineer

Sworn to and subscribed before me
this 27th day of July 1983

Paulette H. White
Notary Public
My Commission Expires 9-5-84

Enclosure

cc (Enclosure):

U.S. Nuclear Regulatory Commission
Region II
Attn: Mr. James P. O'Reilly Administrator
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30303

Babcock & Wilcox Company
P.O. Box 1260
Lynchburg, Virginia 24505
Attention: Mr. R. J. Ansell

Boo!
11

8308030132 830727
PDR ADOCK 0500043B
A PDR

1983-TVA 50TH ANNIVERSARY

An Equal Opportunity Employer

ENCLOSURE

REVISED RESPONSE TO USI A-45

Shutdown Decay Heat Removal Requirements

Bellefonte Nuclear Plant

- 3.. Emergency Procedure Guidelines - B&W is currently preparing Abnormal Transient Operating Guidelines (ATOG) as the Emergency Procedure Guidelines (EPG) for BLN to comply with NUREG-0737 item I.C.1. These EPGs deal with multiple failures of design basis DHR methods and look at alternate DHR means like "feed and bleed".