REGULATORY INFORMATION DISTRIBUTION STEM (RIDS)

ACCESSION NBR:8412180199 DOC.DATE: 84/12/13 NOTARIZED: YES DOCKET # FACIL:50-438 Bellefonte Nuclear Plant, Unit 1, Tennessee Valley Au 05000438 50-439 Bellefonte Nuclear Plant, Unit 2, Tennessee Valley Au 05000439

AUTH NAME

AUTHOR AFFILIATION

DOMER, J.A. RECIP. NAME.

Tennessee Valley Authority

RECIPIENT AFFILIATION

ADENSAM, E.

Licensing Branch 4

SUBJECT: Forwards B&W 841015 rept, "Best Estimate, Steam Generator Tube Rupture Analysis," per util 830916 commitment re TMI Action Item II.K.3.5.Rept utilizes B&W Version 5.0A of

REDBL5 computer code.

NOTES:

	RECIPIENT		COPIES		RECIPIENT		COPIES	
	ID CODE/NAME	7 .	LTTR	ENCL	ID CODE/NAM	Ε	LTTR	ENCL
	NRR/DL/ADL		1	0	NRR LB4 BC		1	0
	NRR LB4 LA		1	0	NRR LB4 PM	01	1	1.
INTERNAL:		41	6	6	ADM/LEMB		1	0
	ELD/HDS2		1	0	IE FILE		1	1
	IE/DEPER/EPB	36	1	1	IE/DEPER/IRB	35	1	1.
	IE/DQASIP/QAE	128	1	1	NRR ROE, M.L		1	1
	NRR/DE/AEAB		l.	0	NRR/DE/CEB	11	1	1
	NRR/DE/EHEB		1	1	NRR/DE/EQB	13	2	2
	NRR/DE/GB	28	2	2	NRR/DE/MEB	18	1	1
•	NRR/DE/MTEB	17	1	1	NRR/DE/SAB	24	1	1
	NRR/DE/SGEB	25	1	1	NRR/DHFS/HFE	B40	. 1	1
	NRR/DHFS/LQB	32	1	1	NRR/DHFS/PSR	3 ·	1	1.
	NRR/DL/SSP8		1.	0	NRR/DSI/AEB	26	1	1
	NRR/DSI/ASB		1	1	NRR/DSI/CPB	10	1	1 -
	NRR/DSI/CSB	09	í	1	NRR/DSI/ICSB	16	1	1.
	NRR/DSI/METB	12	1	1	NRR/DSI/PSB	19	1	1.
	NRR/DSI/RAB	22	1	1	NRR/DSI/RSB	23	1	1:
	REG ELLE	04	1	1	RGN2		3	3
	RM/DDAMI/MIB		1	·, 0	i,			
EXTERNAL:	BNL (AMDTS ONL	.Y)	1	1	DMB/DSS (AMD	TS)	1	1
	FEMA-REP DIV	39	1	1	LPDR	03	1	1
	NRC PDR	02.	1	1	NSIC	0.5	1	1.
	NTIS		1	1	PNL GRUEL, R		1	1

CHATTANOOGA, TENNESSEE 37401

1630 Chestnut Street Tower II

December 13, 1984

Director of Nuclear Reactor Regulation

Attention: Ms. E. Adensam, Chief

Licensing Branch No. 4

Division of Licensing

U.S. Nuclear Regulatory Commission Washington, D.C. 20555

Dear Ms. Adensam:

In the Matter of the Application of Tennessee Valley Authority

Docket Nos. 50-438 50-439

Please refer to TVA's September 16, 1983 response to D. G. Eisenhut's letter of February 8, 1983 concerning the resolution of TMI Action Item II.K.3.5, "Automatic Trip of Reactor Coolant Pumps - Steam Generator Tube Rupture Analysis." In that response, TVA indicated that a tube rupture analysis for Bellefonte using the RELAP 5 computer code would be performed in support of the hypothesis that the reactor coolant pump trip would not be initiated for a double-ended tube rupture. Enclosed is a copy of the subject analysis performed by Babcock and Wilcox (B&W) using version 5.0A of the REDBL5 code which is B&W's version of RELAP 5.

This analysis uses best estimate assumptions for a single double-ended steam generator tube rupture to demonstrate that loss of subcooled margin is precluded if the operator follows abnormal transient operating guidelines (ATOG) procedures for this event. The reactor coolant pumps will also remain operable during this transient where pump operation is preferred.

If you have any questions concerning this matter, please get in touch with K. Mali at FTS 858-2680.

8412180199 841213 PDR ADDCK 05000438 PDR PDR Very truly yours,

TENNESSEE VALLEY AUTHORITY

J. A. Domer

Nuclear Engineer

Sworn to and subscribed before me this 13th day of 1984

Notary Public

My Commission Expires

4/8/82

Enclosure

cc: U.S. Nuclear Regulatory Commission (Enclosure)

Region II

Attn: Mr. James P. O'Reilly Administrator

101 Marietta Street, NW, Suite 2900

Atlanta, Georgia 30323

An Equal Opportunity Employer

3001