



MEDIA FILTERS EACH 50% CAPACITY  
 (ONE SHOWN IN BACKWASH)  
 NOTE 1

NOTES:

1. FILTER BACKWASH IS INITIATED FROM A TIMER AND THE VALVES WILL FAIL IN THE POSITION THAT MAINTAINS THE DISCHARGE FLOW ON A AIR OR ELECTRICAL FAILURE.

Progress Energy Carolinas  
 Shearon Harris Nuclear Power Plant  
 Units 2 and 3  
 Part 2, Final Safety Analysis Report

Raw Water Distribution Systems

FIGURE 10.4-202

Rev. 2