SAMPLING AND WATER QUALITY SYSTEM
UNIT 1 ANNUNCIATOR
LOCATED IN TITRATION PANEL
1IX-IXPA-007



ITS-731
TITRATION ROOM PANEL
CHILLED WATER TEMP ABNORMAL

EMB-64C1
TITRATION ROOM PANEL
CHILLER FAILURE

480V MCC SXF3 COMPT D(R)
1ED-EMCC-57D1



FOR CHILLER UNIT INTERNAL WIRING, REFER TO SENTRY EQUIPMENT CORP. ELECTRICAL SCHEMATIC DWG NO. 5019510-5-4

EMB-640H
TITRATION ROOM CHILLER CAB - 0IX-IXPA-025
DUAL 5 TON UNIT

SAMPLING AND WATER QUALITY SYSTEM
UNIT 2 ANNUNCIATOR
LOCATED IN TITRATION PANEL
2IX-IXPA-007



TITRATION ERCW FAILURE
IPS-732

GENERAL NOTES:

1. THE SYSTEM SCHEMATIC REFLECTS TVA INTERFACES WITH THE COMMON EQUIPMENT SUPPLIED BY THE SBQ CORPORATION FOR SAMPLING & WATER QUALITY. FOR CIRCUIT OPERATION VENDOR DRAWINGS MUST BE USED.
2. ALL UNIID DESIGNATIONS ARE PREFIXED BY OYQ UNLESS OTHERWISE SHOWN.
3. PORTIONS OF THE SCHEMATIC ARE SHOWN OUT-OF-FUNCTION. THESE OUT-OF-FUNCTION PORTIONS ARE SHOWN FOR INFORMATION, WITH REFERENCES PROVIDED TO THE DOCUMENT WHICH CONTROLS THE EQUIPMENT.
4. ALL ELECTRICAL EQUIPMENT IS SHOWN IN ITS DE-ENERGIZED STATE

REFERENCE DRAWINGS:

SAMPLE AND WATER QUALITY DESIGN CRITERIA ---------- N4-YQ-D740
480V MOTOR CONTROL CENTER COMPARTMENT TYPICALS ---------- 5GW0747-RP
WIRING DIAGRAM LOCAL INSTRUMENTATION PANEL ---------- 5A81677-JL

SBQ CORP
WATER QUALITY SAMPLING, ANALYSIS, INSTRUMENTATION AND CONTROL SYSTEMS TVA CONTRACT 77K3-87395

TITRATION PANELS UNITS 1 & 2 POWER AND LIGHTING ---------- E2-7
UNIT 1 TITRATION PNL CONTROL WIRING DIAGRAM ---------- SBQ E2-1 THRU 3
UNIT 2 TITRATION PNL CONTROL WIRING DIAGRAM ---------- SBQ E2-4 THRU 6
TITRATION ROOM WATER CHILLER ---------- SENTRY 5019510-5-4
TITRATION & HOT SAMPLE ANNUNCIATION ---------- SBQ E1-1

MATPA ELECTRIC INC TVA CONTRACT 77K6-82C238
LIGHTING TRANSFORMERS ---------- MATRA 110160

B-K ELECTRIC PROD DIV TVA CONTRACT 77K5-820964
TRANSFER SW CKT BKR ASSEMBLY ---------- 50-21736-C

SYMBOLS:

AN / XAXX	SBQ CORP SAMPLING UNIT ANNUNCIATOR

REF DWG 5GW0747-RP-3 TYP 7TNO



480V MCC SXF3 COMPT E3(R)
1ED-EMCC-57E3

REF DWG 5GW0747-RP-3 TYP 7TNO



480V MCC SXF4 COMPT H1(L)
2ED-EMCC-58H1

ECA4-5
ECA4-7



PWR TRANS, SW 43-007
REF 50-21736-C
ECA4-8



480/120V CONTROL PWR XFMR
ET-007

120V BKR PANEL BOARD
LOCATED IN SBQ TITRATION RM PNL
1IX-IXPA-007



(TOP VIEW WITH SWITCH COVER REMOVED)
DETAIL A

PRC APERTURE CARD

Docket # 50-438
Control # 8305
Date 3-25-83 of Document
REGULATORY DOCKET FILE

| | | |