NOTES:
FOR GENERAL NOTES AND REFERENCE DRAWINGS SEE 5GW2740-EG-01.

6.9KV SWITCHGEAR 2ETI-B, 2EG-EMVS-07-B, MONITORING

6.9KV SWITCHGEAR 2ETI-B, 2EG-EMVS-07-B, MONITORING

PRC APERTURE CARD

NO.	ECN NO.	DATE	ORIG	DFTR	CHKD	SUPV	ENGR	UNIT	ENGR	APPD	RC	RC	PA	PA
3	1146,51	5-2-83	RCA	DC Lewis	PM	DAT								
DELETED SEAMS MONITOTING POINTS.														
2	773	11-19-79	RCA											
CHANGED 628F CONTACT TO EMLY CONTACT B ADDED 52S AUX CONTACT.														
1	467,51	7-6-79	RCA											
INCORPORATED THE NEW AND MODIFIED DESIGN REQUIREMENTS FOR AUX TRANSFERS AND VOLTAGE ANN. POINTS. ADDED BOP ISOLATOR TERMINAL POINTS AND SIGNAL POINTS.														

DESIGN T.C. Hill
DRWN
CHKD L.L. Mizzy
SUPV
INSP
ENGINEER W.L. Abbadge

SCALE EXCEPT AS NOTED

GENERAL
UNIT 2

SYSTEM SCHEMATIC
6.9KV CLASS 1E AC AUX PWR DISTRIBUTION SYSTEM

BELLEFONTE NUCLEAR PLANT
TENNESSEE VALLEY AUTHORITY
DIVISION OF ENGINEERING DESIGN

Q

SUBMITTED	RECOMMENDED	APPROVED
D.L. Abbadge	R.P. Bynum	W.L. Abbadge
KNOXVILLE 1/10/77	88 E	5GW2740-EG-09 R3

RECORD DRAWING AS CONSTRUCTED

REVIEWED
RC(CIVIL) N/A
RE(ELEC) L.L. Mizzy
RM(MECH) N/A

Docket # 50-438
Control # 8304050536
Date 3-25-83 of Document
ISOLATION MONITOR

1146