NOTES:
1. FOR SYMBOLS AND ADDITIONAL NOTES SEE SHEET 01.
2. 52H CONTACTS ARE SHOWN IN THEIR OPEN POSITION AND THEIR DESIGNATION IS SUFFIXED WITH -IN OR -OUT TO INDICATE THEY ARE CLOSED WHEN THE BREAKER IS RACKED IN OR RACKED OUT RESPECTIVELY.

SYMBOLS:
* FOR COMPLETE UNID NO., REPLACE YY WITH SWGR BD NO. REPLACE X WITH 3 FOR 2RA AND 4 FOR 2RB, AND REPLACE Z WITH 1 FOR 2RA AND 2 FOR 2RB. SEE SHEET 1 FOR FUSE TABULATION.
- LOW VOLTAGE SWGR TERMINAL
- MEDIUM VOLTAGE SWGR TERMINAL

13,800V-480V TRANSFORMER FEEDER

480V SWGR DC BUS FOR 2XA2

480V SWGR DC BUS FOR 2XB2

480V SWGR 2XA2 & 2XB2 SUPPLY BKR 52N

480V SWGR 2AX2 & 2XB2 EMER TIE BKR 52E

480V SWGR 2XA4 & 2XB4 BKR 52N

PRC APERTURE CARD

Docket # 50-438
Control # 8304050536
Date 3-25-83 of Document
REGULATORY DOCKET FILE

GENERAL
UNIT 2

SYSTEM SCHEMATIC
480V NORMAL AC AUXILIARY
POWER DISTRIBUTION SYSTEM

BELLEFONTE NUCLEAR PLANT
TENNESSEE VALLEY AUTHORITY
DIVISION OF ENGINEERING DESIGN

SUBMITTED	RECOMMENDED	APPROVED
W.L. Aldridge	J.E. Longmire	B.M. Hodges

KNOXVILLE 12-20-79 | B8 | E | 5GW2740-ED-17 | R2

RECORD DRAWING AS CONSTRUCTED

INSPECTED AND APPROVED FOR ISSUE
DESIGN PROJECT MANAGER

REVISED 1 SI 2-11-83 MINOR CHANGES.
REVISED 2 1133(3) 3-2-83 REPLACED 3 AMP FUSES WITH 6 AMP FUSES. MINOR CHANGES.