



- NOTES:
- FOR GENERAL NOTES AND REFERENCES, REFER TO 5G0640-EP-30.
  - INSTALLATION INSTRUMENT ROOM RELAY CABINET 2EY-IT-0000, (INCLUDING RELAYS 2EY-74-2301 AND 2EY-87-2301) IS PROVIDED ON TVA CONTRACT 7793-281304, WIRING BETWEEN CABINETS IS BY TVA.
  - THIS DRAWING SUPERSEDES OLD DRAWING D40-504900, SHEET 2, CONTRACT 76K4-823705, FOR CABINET DOCUMENTATION.

REFERENCE DRAWINGS:  
5G0644-J1-13 - - - WIRING DIAGRAMS, MISC. RELAY CABINETS

PRC  
APERTURE  
CARD

TVA ONLY  
SEE NOTE 2  
Docket # 50-238  
Control # 8364050536  
Date 3-25-83 of Document  
REGULATORY DOCKET FILE

COMPARISON DWS:  
5G0640-EP-30, 32-36

3	1034, 1140	3-2-81	REVISED LOAD, MISC. CHANGES
2	690, 91	4-3-79	TBE WAS TBA REVISED LOADS AND SEAMS TERM ADDED "N"
1	81	11-1-78	ADDED LOADS, SEAMS MONITORING POINT AND REORAN.
0	609		
DATE	BY	DATE	BY
11/1/78	W. B. STEWART		
SCALE		EXCEPT AS NOTED	
GENERAL UNITS 1 & 2			
SCHEMATIC DIAGRAM 250VDC NORMAL POWER DISTRIBUTION SYSTEM			
BELLEFONTE NUCLEAR PLANT TENNESSEE VALLEY AUTHORITY DIVISION OF ENGINEERING DESIGN			
DESIGNED BY	REVISIONS	APPROVED	
W. B. STEWART		R. M. BROWN	
KNOXVILLE 9-12-77		88 E 5G0640-EP-31	

SUBMITTED AND APPROVED FOR ISSUANCE