

PMLevyCOLPEm Resource

From: Snead, Paul [paul.snead@pgnmail.com]
Sent: Tuesday, February 08, 2011 3:56 PM
To: Bruner, Douglas
Subject: RE: Missing Transmission Line Information

Doug:

Regarding the CREC to Brookville West corridor. The 230-kV transmission line from CREC switchyard to Brookridge Substation (CB) that was originally described in the ER is not planned to be built. Although this line was certified, in the State's Site Certification, as starting at the CREC substation, plans are to start this line at the Citrus Substation and then proceed to Brookridge. The Citrus to Brookridge line information and the Brookridge to Brookville West line information is included in the USACE volumes. Also, even though certified, there are no current plans to build the proposed 230-kV lines from the proposed Citrus Substation to the Crystal River East Substation (CCRE). Consequently, these routes that are not planned to be built were not included in the material provided to the USACE for jurisdictional determinations.

The information for the impacted areas are available in the 7-volume set provided to the USACE. This information will be provided to you under oath and affirmation as requested.

Thanks,

Paul Snead
Supervisor
Environmental Services, Projects & Construction
Progress Energy
paul.snead@pgnmail.com
(919) 546-2836

From: Bruner, Douglas [<mailto:Douglas.Bruner@nrc.gov>]
Sent: Tuesday, February 08, 2011 12:54 PM
To: Snead, Paul
Cc: LevyCOL Resource
Subject: FW: Missing Transmission Line Information

Paul,

Please see below for the information that the SMEs can use for the CREC-Brookville corridor. If there are no wetlands affected along this route then, if available, the staff can still use non-wetland information similar to that provided for the other lines (FNAI database search, mapped observations of RTE species, and the T&E species table).

Again, this information will need to be submitted under oath and affirmation

Thanks,

Doug

From: Miller, Beverly M [<mailto:Beverly.Miller@pnl.gov>]
Sent: Tuesday, February 08, 2011 10:45 AM

To: Bruner, Douglas
Cc: Scherpelz, Robert I; 'Baber, Daniel'; Stegen, Amanda
Subject: FW: Missing Transmission Line Information

Doug,

We apologize, we didn't realize that we still need the information below until we got in to it a bit more. Is there any chance you could ask PEF for this information today? Thanks so much, Bev!

From: Baber, Daniel [<mailto:BBaber@icfi.com>]
Sent: Monday, February 07, 2011 5:44 PM
To: Miller, Beverly M
Cc: Stegen, Amanda
Subject: Missing Transmission Line Information

Hi Bev,

It appears the Transmission Line CD we received from Progress did not contain any information (other than a shape file) on the CREC to Brookville Station transmission line (i.e., wetland info, FNAI, FLUCFCS, etc). Please ask Progress to provide this information to us if it is available. As you know, we are meeting on Wednesday to review this information. See if they can provide it by Wednesday morning, if possible.

Thanks - Bill

Daniel W.(Bill) Baber | Environmental Scientist | 503.525.6167 | bbaber@icfi.com | icfi.com
ICF INTERNATIONAL | 317 SW Alder, Suite 800, Portland, OR 97204 | 503.525.6150 (f)



Please consider the environment before printing this e-mail.

Hearing Identifier: Levy_County_COL_Public
Email Number: 813

Mail Envelope Properties (7FD614EFA33B03448166AF44364F42AE0D5DABCA1C)

Subject: RE: Missing Transmission Line Information
Sent Date: 2/8/2011 3:56:22 PM
Received Date: 2/8/2011 3:56:29 PM
From: Snead, Paul

Created By: paul.snead@pgnmail.com

Recipients:
"Bruner, Douglas" <Douglas.Bruner@nrc.gov>
Tracking Status: None

Post Office: WN000075.oak.zone1.progress-energy.com

Files	Size	Date & Time
MESSAGE	3391	2/8/2011 3:56:29 PM

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: