




Commonwealth Edison
 One First National Plaza, Chicago, Illinois
 Address Reply to: Post Office Box 767
 Chicago, Illinois 60690

January 12, 1982

Mr. T. A. Ippolito, Chief
 Operating Reactors - Branch 2
 Division of Operating Reactors
 U.S. Nuclear Regulatory Commission
 Washington, DC 20555

Subject: Dresden Station Units 2 and 3
 Quad Cities Station Units 1 and 2
 Information Request Regarding
 Station Blackout, USI A-44
 (Diesel Generator History)
 NRC Docket Nos. 50-237/249 and
 50-254/265



- References (a): T. A. Ippolito letter to J. S. Abel dated July 9, 1981.
 (b): T. A. Ippolito letter to J. S. Abel dated July 20, 1981.

Dear Mr. Ippolito:

References (a) and (b) requested Commonwealth Edison to supply certain Diesel Generator history information for Dresden Units 2 and 3 and Quad Cities Units 1 and 2, respectively. This information, in the form of completed questionnaires, is provided in the attachments to this letter.

Please note that we made our best effort to obtain the requested information, but we were not able to supply everything requested. Where estimates were used, it is noted on the questionnaire.

Please direct any questions you may have concerning this matter to this office.

One (1) signed original and fifty-nine (57) copies of this transmittal with seven (7) copies of the completed questionnaire are provided for your use.

Very truly yours,

Thomas J. Rausch

Thomas J. Rausch
 Nuclear Licensing Administrator
 Boiling Water Reactors

A001
 3
 1/1

cc: Region III Inspector - Dresden
 Region III Inspector - Quad Cities

1m

8201220248 820112
 PDR ADOCK 05000237
 P PDR

3216N

P

TABLE 1

Diesel Generator Operations Data
Calendar Year 1976Plant Name Quincy Cities
Unit No. 132

Reason for DG Operation, & scheduled Duration of Run Tech. Spec Req'd Test	DG No.	Number of Starts	Number of Failures	Percent Loading of DG (KW)	Duration of Run Before Stop For Each DG Failure	Identification of Failure (Refer to attached LERs or Table 3)
QOS-6600-1 Monthly Op. Test (2hrs)	1	12	0	100		
	1/2	12	0	100		
	2	12	0	100		
QOS-6600-02 Return to Service or out of Service required Testing. (2hrs)	1	5	0	100		
	1/2	10	0	100		
	2	5	0	100		
QOS-6600-01 Return to Service or out of Service required Testing. (2hrs)	1	2	0	100		
	1/2	0	—	—		
	2	2	0	100		
*Refueling Outage Tests (1hr)	1	0	—	—		
	1/2	2	0	50		
	2	2	0	50		
DG Actual Demand Starts not for Testing Auto Starts	1	0	—	—		
	1/2	0	—	—		
	2	0	—	—		
Miscellaneous Tests (Specify Type) unable to Categorize (2hrs)	1	8	0	100		
	1/2	14	0	100		
	2	9	0	100		

Note: QOS-6600-1 and
QOS-6600-02 are
sometimes performed at
the same time.

TABLE 1

Diesel Generator Operations Data
Calendar Year 1977Plant Name Quad Cities
Unit No. 112

Reason for DG Operation, & scheduled Duration of Run Tech. Spec Req'd Test	DG No.	Number of Starts	Number of Failures	Percent Loading of DG (KW)	Duration of Run Before Stop For Each DG Failure	Identification of Failure (Refer to attached IERs or Table 3)
QOS-6600-1 Monthly Op. Test. (2hrs)	1	12	0	100		
	1/2	12	0	100		
	2	12	0	100		
QOS-6600-02 Return to Service or Out of Service required Testing (2hrs)	1	13	0	100		
	1/2	13	0	100		
	2	13	0	100		
QOS-6600-01 Return to Service or Out of Service required Testing (2hrs)	1	1	0	100		
	1/2	0	—	—		
	2	1	0	100		
Refueling Outage Tests (1hr)	1	2	0	50		
	1/2	2	0	50		
	2	0	—	—		
DG Actual Demand Starts not for Testing Auto Starts	1	1	0	100		
	1/2	1	0	100		
	2	1	0	100		
Miscellaneous Tests (Specify Type) Unable to Categorize (2hrs)	1	0	—	—		
	1/2	6	0	100		
	2	0	—	—		

Note: QOS-6600-1 and
QOS-6600-02 are
sometimes performed at
the same time.

TABLE 1

Diesel Generator Operations Data
Calendar Year 1975Plant Name Quind City
Unit No. 1A

Reason for DG Operation, & scheduled Duration of Run Tech. Spec Req'd Test	DG No.	Number of Starts	Number of Failures	Percent Loading of DG (KW)	Duration of Run Before Stop For Each DG Failure	Identification of Failure (Refer to attached LERs or Table 3)
QOS-6600-1 Monthly Op test (2hrs)	1	12	0	100		
	1/2	12	0	100		
	2	12	0	100		
QOS-6600-02 Return to Service or Out of Service Required Testing (2hrs)	1	9	0	100		
	1/2	20	0	100		
	2	9	0	100		
QOS-6600-01 Return to Service, or Out of Service Required Testing (2hrs)	1	2	0	100		
	1/2	2	0	100		
	2	2	0	100		
Reliefing Outage Tests (1hr)	1	0	—	—		
	1/2	2	0	50		
	2	2	0	50		
DG Actual Demand Starts not for Testing Auto Starts	1	1	0	100		
	1/2	1	0	100		
	2	1	0	100		
Miscellaneous Tests (Specify Type) Unable to Categorize (2hrs)	1	0	—	—		
	1/2	11	0	100		
	2	6	0	100		

Note: QOS-6600-1 and
QOS-6600-02 are some-
times performed at the
same time.

TABLE 1

Diesel Generator Operations Data
Calendar Year 1979Enclosure # 1082
Plant Name Quind City
Unit No. 1-2

Reason for DG Operation, & scheduled Duration of Run Tech. Spec Req'd Test	DG No.	Number of Starts	Number of Failures	Percent Loading of DG (KW)	Duration of Run Before Stop For Each DG Failure	Identification of Failure (Refer to attached IERs or Table 3)
Q05-6600-1 Monthly Op test (2hrs)	1	12	0	100		
	1/2	12	0	100		
	2	12	0	100		
Q05-6600-02 Return to Service or Out of Service Required Testing (2hrs)	1	9	0	100		
	1/2	20	0	100		
	2	9	0	100		
Q05-6600-01 Return to Service or Out of Service Required Testing (2hrs)	1	3	0	100		
	1/2	7	0	100		
	2	3	0	100		
Refueling Outage Tests (1hr)	1	2	0	50		
	1/2	2	0	50		
	2	0	-	-		
DG Actual Demand Starts not for Testing Auto Starts	1	0	-	-		
	1/2	3	0	100		
	2	0	-	-		
Miscellaneous Tests (Specify Type) Unable to Categoriec (2hrs)	1	0	-	-		
	1/2	11	0	100		
	2	6	0	100		

Note: Q05-6600-1 and Q05-6600-02 are sometimes performed at the same time.

TABLE 1

Diesel Generator Operations Data
Calendar Year 1980Plant Name West Co. P&S
Unit No. 182

Reason for DG Operation, & scheduled Duration of Run	DG No.	Number of Starts	Number of Failures	Percent Loading of DG (KW)	Duration of Run Before Stop For Each DG Failure	Identification of Failure (Refer to attached IERs or Table 3)
Tech. Spec Req'd Test						
QOS-6600-1 Monthly Op tests (2 hrs)	1	12	0	100		
	1/2	12	0	100		
	2	12	0	100		
QOS-6600-02 Return to Service or Out of Service Required Testing (2 hrs)	1	9	0	100		
	1/2	9	1	100		LER #3
	2	9	0	100		
QOS-6600-01 Return to Service or Out of Service Required Testing (2 hrs)	1	9	0	100		
	1/2	11	0	100		
	2	9	0	100		
Refueling Outage Tests (1 hr)	1	2	0	50		
	1/2	7	0	50		
	2	2	0	50		
DG Actual Demand Starts not for Testing						
Auto Starts	1	0	—	—		
	1/2	1	0	100		
	2	2	0	100		
Miscellaneous Tests (Specify Type)						
	1	0	—	—		
	1/2	0	—	—		
2	0	—	—			
Unable to Categorize (2 hrs)	1	0	—	—		
	1/2	0	—	—		
	2	0	—	—		
Note: QOS-6600-1 and QOS-6600-02 are sometimes						

TABLE 2

Diesel Generator Scheduled Downtime Record
 Calendar Year 1976

Plant Name Wood Creek
 Unit No. 1B2

Reason for Downtime	Hours of Downtime										Comments	
	Reactor shutdown					Reactor not shutdown						
	DGP ₁	DGP _{1/2}	DGP ₂	DGP	DGP	DGP ₁	DGP _{1/2}	DGP ₂	DGP	DGP		
Scheduled Maintenance												
Q05-6600-02 (1 1/2 limitation)	0	1	0			6	5	4				
Q05-6600-01 (7 day limitation)	0	0	0			4	25.5	0				
Time DG is unavailable for emergency service because of required tests	0	0	0			0	0	0				

TABLE 2

Diesel Generator Scheduled Downtime Record
Calendar Year 1977

Plant Name Quincy
Unit No. 1B2

Reason for Downtime	Hours of Downtime										Comments	
	Reactor shutdown					Reactor not shutdown						
	DCG 1	DCG 1/2	DCG 2	DCG	DCG	DCG 1	DCG 1/2	DCG 2	DCG	DCG		
Scheduled Maintenance												
QOS-6600-02 (1 1/2 hr. limitation)	2	0	2			10	10	10				
QOS-6600-01 (7 day limitation)	0	0	0			0	8	0				
Time DG is unavailable for emergency service because of required tests	0	0	0			0	0	0				

TABLE 2

Diesel Generator Scheduled Downtime Record
Calendar Year 1978Plant Name Chas. C. 125
Unit No. 122

Reason for Downtime	Hours of Downtime										Comments	
	Reactor shutdown					Reactor not shutdown						
	DGF 1	DGF 1/2	DGF 2	DGF	DGF	DGF 1	DGF 1/2	DGF 2	DGF	DGF		
Scheduled Maintenance												
EQS-6600-02 (1 1/2 hr limitation)	0	0	1			14	10	10				
EQS-6600-01 (7 day limitation)	4	8	0			0	24	0				
Time DG is unavailable for emergency service because of required tests	0	0	0			0	0	0				

TABLE 2

Diesel Generator Scheduled Downtime Record
 Calendar Year 1979

Plant Name Quincy
 Unit No. 1F2

Reason for Downtime	Hours of Downtime										Comments	
	Reactor shutdown					Reactor not shutdown						
	DGP 1	DGP 1/2	DGP 2	DGP	DGP	DGP 1	DGP 1/2	DGP 2	DGP	DGP		
Scheduled Maintenance												
QOS-6600-02 (17.5 hr limitation)	1	0	2			10	13	9				
QOS-6600-01 7 day limitation	0	0	168			2	50	0				
Time DG is unavailable for emergency service because of required tests	0	0	0			0	0	0				

TABLE 2

Diesel Generator Scheduled Downtime Record
Calendar Year 1980Plant Name Wind Cities
Unit No. 112

Reason for Downtime	Hours of Downtime										Comments
	Reactor shutdown					Reactor not shutdown					
	DGF 1	DGF 1/2	DGF 2	DGF	DGF	DGF 1	DGF 1/2	DGF 2	DGF	DGF	
Scheduled Maintenance QOS-6600-02 (1 1/2 hr limitation)	3	0	5			8	9	6			
QOS-6600-01 (7 day limitation)	72	0	24			0	142	0			
Time DG is unavailable for emergency service because of required tests	0	0	0			0	0	0			

TABLE 1

Diesel Generator Unscheduled Downtime Record
Calendar Year 1980-'77
 PLANT NAME
 Plant Name Quad Cities
 Unit No. 1/2

LER Abstract No. (Refer to attached LER Abstract)	Downtime Hours				Comments - If any of the reported failures would not have been a failure under emergency conditions, please explain here. Refer to attached LERs or the failures listed in Table 1.
	Total Hours	Troubleshooting	Parts, Delivery, etc	Repair/replace	
(1980) 2	2 1/4 hr				high engine temperature trip due to trip of cooling water pump - pump found to have a short
(1980) 3	1/2 hr				failed to start from control room - poor electrical contact between fuse and bent fuse clip in the DG control circuit.
(1979) 4	0				one of two starting air supply valves found closed - personnel error - other starting air system available for start if necessary
(1979) 5	6 1/2 hr				fuel filter found to be fouled - caused by sludge buildup on bottom of fuel storage tank.
(1979) 7	2 hr. 40 min.				air start motor failed to disengage - failure of air motor pilot solenoid valve - also, during subsequent testing, air starting valve sticking
(1977) 9	2 hr. 40 min.				field breaker would not close - failure of diode in the 800 rpm field breaker interlock circuit
(1977) 12	1 hr 25 min.				leak discovered in tubing leading from fuel line to pressure gauge -

TABLE 1

Diesel Generator Unscheduled Downtime Record
Calendar Year 19 80 - '77Plant Name Quad Cities
Unit No. 1e

LER Abstract No. (Refer to attached LER Abstract)	Downtime Hours				Comments - If any of the reported failures would not have been a failure under emergency conditions, please explain here. Refer to attached LERs or the failures listed in Table 1.
	Total Hours	Trouble-shooting	Parts, Delivery, etc.	Repair/replace	
(1976) 14	55 min.				monthly inspection time limit exceeded - maintenance man unaware of time limit
(1976) 15	5 min				maintenance time exceeded - procedure inadequacy
(1977) <u>19</u> NOT LER	1 hr 20 min				hole in diaphragm of pressure regulator on air start system and air start solenoid partially open

TABLE 1

Diesel Generator Unscheduled Downtime Record
Calendar Year 1980 - '77Enclosure 1 - Page 3
Plant Name Quad Cities
Unit No. 1

LER Abstract No. (Refer to attached LER Abstract)	Downtime Hours				Comments - If any of the reported failures would not have been a failure under emergency conditions, please explain here. Refer to attached LERs or the failures listed in Table 1.
	Total Hours	Trouble-shooting	Parts, Delivery, etc.	Repair/replace	
(1980) 1	33 hr. 10 min.				cooling water pump motor failure - IC RHR Vault sump inadequate and therefore DG #1 water pump 2/3 submerged.
(1979) 6	2 hr. 40 min.				fuel line leak discovered - worn gasket on the fuel line filter -
(1978) 8	12 hr 35 min.				preventative maintenance - fuel transfer ^{line} rerouted and replaced to prevent possible rust damaged
(1977) 10	2 1/2 hr.				no response registered on the voltage, cycles, or synchronization indicators - tachometer coupling loose on shaft.
(1977) 13	77 hr. 20 min.				field failed to flash - broken wire found on the capacitor across voltage suppression relay also, during retesting, voltage suppression rectifiers were damaged.
(1976) 16	18 1/2 hr.				failed to start - air solenoid valve dirty, consequently not opening to full open.

TABLE 3

Diesel Generator Unscheduled Downtime Record
Calendar Year 1980-'77Plant Name Quad Cities
Unit No. 2

LER Abstract No. (Refer to attached LER Abstract)	Downtime Hours				Comments - If any of the reported failures would not have been a failure under emergency conditions, please explain here. Refer to attached LERs or the failures listed in Table 1.
	Total Hours	Trouble-shooting	Parts, Delivery, etc	Repair/replace	
(1977) 17	4 1/4 hr				water level decrease in cooling water expansion tank - cooling water heat exchanger had a leak between shell and tube side -
(1977) 18 NOT LER	1 hr. 5 min.				upper starter motor Bendix drive found to be defective - Bendix spring on starter broke.

TABLE 4

Qualite Emergency Diesel Generator and
Auxiliary Equipment Modification Record

Enclosure 1 - Page 4

Plant Name Quad CitiesUnit No. 1

Equipment or procedure modified	Date of Mod.	Reason for Modification and Desired Improvement	Description of Modification
Diesel Generator M-4-1-73-16	9-4-74	prevent inadvertent isolation of coolers by three-way valves in cooler lines	provide instrumentation that monitors inlet and outlet pressure to raw water cooler gaug inlet and outlet temperatures to water coolers, and lube oil from engine temperature
Diesel Start Relay M-4-1-73-100	11-21-73	meet as a minimum, applicable NEMA Codes and O. 2G (horizontal acceleration) seismic criteria	replace the "HFA" type Diesel Start Relay with a 125 V D.C. industrial grade heavy duty relay having a contact circuit rating of 10 amps inductive load interrupt capacity utilizing "blow outs"
Start Failure Circuit M-4-1-74-25	4-13-74	prevent diesel from shutting off after an auto-start if the control switch is placed in STOP and then returned to AUTO, also, prevents depletion of starting air	modify the diesel starting circuitry to cover a condition when the start failure circuitry is in the energized configuration
Diesel Generator M-4-1-75-25	2-11-78	improve reliability of transient voltage suppression	replace the existing field diode selenium rectifier transient suppressors with "State of the Art" transient voltage suppressors
D/G Breaker Trip M-4-1-77-21	1-20-80	prevent motorizing of the diesel generator in the event a trip occurs while diesel generator is paralleled to the bus	provide a trip to the diesel generator 4kV breaker in the event the SDR relay operates

TABLE 4

Quinte Emergency Diesel Generator and
Auxiliary Equipment Modification Record

Enclosure 1 - Page 4

Plant Name Quad CitiesUnit No. 1

Equipment or procedure modified	Date of Mod.	Reason for Modification and Desired Improvement	Description of Modification
D/G Air Compressors m-4-1-77-25	9-15-80	prevent the possibility of blowing down the A-B accumulator set in the event of a rupture in the C-D set	install a check valve for the C-D diesel generator accumulator set upstream of the tie with the A-B set
Day Tank Oil Transfer Lines m-4-1-78-8	9-28-78	protect transfer lines from possible damage	install pipe sleeves on lines 1-5204-2 "G" and 1-5201-2 "G" under the new duct. Use the existing pipe as sleeve and install a new 1-1/4" line inside.
Main Feed Breakers m-4-1-78-16	2-23-79	4KV undervoltage functional performance test	install test switches on Unit 1 & 1/2 diesel generator auto-start circuits for 4KV undervoltage functional performance test

TABLE 4

Quinte Emergency Diesel Generator and
Auxiliary Equipment Modification Record

ENCLOSURE Page 1
Plant Name Quad Cities
Unit No: 1/2

Equipment or procedure modified	Date of Mod.	Reason for Modification and Desired Improvement	Description of Modification
Diesel Generator M-4-1/2-73-2	9-5-74	prevent inadvertent isolation of coolers by three-way valves in cooler lines	provide instrumentation that monitors inlet and outlet pressure to raw water cooler gauges, inlet and outlet temperatures to water coolers, and lube oil from engine temperature
Diesel Generator M-4-1/2-73-29	1-5-74	meet as a minimum, applicable NEMA Codes and O.2G (horizontal acceleration) seismic criteria	replace "HFA" type Diesel start Relay with a 125V D.C. industrial grade heavy-duty relay having a contact circuit rating of 10 amps inductive load interrupt capacity utilizing "blowouts"
Start Failure Circuit M-4-1/2-74-6	4-13-74	prevent diesel from shutting off after an auto-start if the control switch is placed in STOP and then returned to AUTO, also prevent depletion of starting air	modify the diesel starting circuitry to cover a condition when the start failure circuitry is in the energized configuration.
Diesel Generator M-4-1/2-75-4	1-27-78	improve reliability of transient voltage suppression	replace existing field diode selenium rectifier transient voltage suppressors with "State of the Art" transient voltage suppressors.
DG Air Compressor M-4-1/2-77-37	2-6-80	prevent the possibility of blowing down the A-B accumulator set in the event of a rupture in the C-D set.	install a check valve for the C-D diesel generator accumulator set upstream of the tie with the A-B set

TABLE 4

Quinte Emergency Diesel Generator and
Auxiliary Equipment Modification Record

Enclosure 1 - Page 4
Plant Name Quad Cities
Date No. 2

Equipment or procedure modified	Date of Mod.	Reason for Modification and Desired Improvement	Description of Modification
Diesel Generator M-4-2-73-16	9-5-74	prevent inadvertent isolation of coolers by three-way valves in cooler lines	provide instrumentation that monitors inlet and outlet pressure to raw water cooler gauges, inlet and outlet temperatures to water coolers, and lube oil from engine temperatures
Diesel Generator M-4-2-73-100	1-5-74	meet as a minimum, applicable NEMA Codes and 0.2 (horizontal acceleration) seismic criteria	replace "HFA" type Diesel Start Relay with a 125 V D.C. industrial grade heavy-duty relay having a contact circuit rating of 10 amps inductive load interrupt capacity utilizing "blowouts"
Start Failure Circuit M-4-2-74-25	4-13-74	prevent the diesel from shutting off after an auto-start if the control switch is placed in STOP and then returned to AUTO, also will prevent depletion of starting air	modify the diesel starting circuitry to cover a condition when the start-failure circuitry is in the energized configuration.
Diesel Generator M-4-2-75-25	1-25-78	improve reliability of transient voltage suppression	replace the existing field diode selenium rectifier transient voltage suppressors with "state of the Art" transient voltage suppressors
DG Air Compressor M-4-2-77-25	1-18-80	prevent the possibility of blowing down the A-B accumulator set in the event of a rupture in the C-D set	install a check valve for the C-D diesel generator accumulator set upstream of the tie with the A-B set

TABLE 4

Quinte Emergency Diesel Generator and
Auxiliary Equipment Modification Record

Enclosure 1 - Page 4

Plant Name Quad CitiesUnit No. 2

Equipment or procedure modified	Date of Mod.	Reason for Modification and Desired Improvement	Description of Modification
Main Feed Breakers m-4-2-78-16	12-4-79	4KV undervoltage functional performance test	install test switches on diesel generator auto-start circuits for 4KV undervoltage functional performance test

TABLE 1

**Diesel Generator Unscheduled Downtime Record
Calendar Year 1980**

Enclosure 1 - Page 3
Plant Name Dresden
Unit No. 2 & 3

IER Abstract No. (Refer to attached IER Abstracts)	Downtime Hours				Comments - If any of the reported failures would not have been a failure under emergency conditions, please explain here. Refer to attached IERs or the failures listed in Table 1.	
	Total Hours	Troubleshooting	Parts, Delivery, etc	Repair/replace		
(Unit 2)	1	29	2	7	20	
	2	42	2	7	33	
	3	1	0	0	1	
(Unit 3)	1	5	1	1	3	
	2	3	1	1	1	

TABLE 1

**Diesel Generator Unscheduled Downtime Record
Calendar Year 1978**

Enclosure 1 - Page 3
Plant Name Dresden
Unit No. 2 & 3

IER Abstract No. (Refer to attached IER Abstracts)	Downtime Hours				Comments - If any of the reported failures would not have been a failure under emergency conditions, please explain here. Refer to attached IERs or the failures listed in Table 1.
	Total Hours	Trouble-shooting	Parts, Delivered, etc	Repair/replace	
(Unit 2) 16	2	0	0	2	
17	4	0	0	3	
18	8	1	2	5	
19	10	1	1	8	
20	6	1	0	5	
21	10	1	0	9	
22	2	0	0	2	
(Unit 3) 3	0	0	0	0	Day tank low level.
4	0	0	0	0	Fuel storage tank low level.

TABLE 3

**Diesel Generator Unscheduled Downtime Record
Calendar Year 1979**

Enclosure 1 - Page 3
Plant Name Dresden
Unit No. 2 & 3

LER Abstract No. (Refer to attached LER Abstracts)	Downtime Hours				Comments - If any of the reported failures would not have been a failure under emergency conditions, please explain here. Refer to attached LERs or the failures listed in Table 1.
	Total Hours	Trouble-shooting	Parts, Delivered, etc	Repair/replace	
(Unit 2) 4	0	0	0	0	Fuel oil sample was not taken on time. Unable to shutdown D/G from control room.
5	4	1	0	3	
6	5	0	0	5	
7	2	0	0	2	
8	2	0	0	2	
9	0	0	0	0	
10	8	2	1	5	
11	3	1	0	2	
12	11	2	2	7	
13	12	1	3	8	
14	3	1	0	2	
15	5	1	0	4	

TABLE 1

Diesel Generator Operations Data
 Calendar Year 1976

Reason for DG Operation, & scheduled Duration of Run	DG No.	Number of Starts	Number of Failures	Percent Loading of DG (KW)	Duration of Run Before Stop For Each DG Failure	Identification of Failure (Refer to attached I.E.R.s or Table 3)
Tech. Spec Req'd Test						
Monthly Surveillance (1 hour) (1 start/test)	2	12	3	100	0	34, 36
	2/3	12	1	100	0	
	3	12	0	0	0	
5-Year Surveillance (1 hour) (1 start/test)	2	1	0	100	0	
	2/3	0	0	100	0	
	3	1	0	100	0	
DG Actual Demand Starts not for Testing	2					
	2/3					
	3					
Miscellaneous Tests (Specify Type)						

TABLE 3

**Diesel Generator Unscheduled Downtime Record
Calendar Year 1976**

Enclosure 1 - Page 3

Plant Name DresdenUnit No. 2/3

I.E.R. Abstract No. (Refer to attached I.E.R. Abstracts)	Downtime Hours				Comments - If any of the reported failures would not have been a failure under emergency conditions, please explain here. Refer to attached I.E.R.s or the failures listed in Table 1.
	Total Hours	Trouble-shooting	Parts, Del. (very, etc)	Repair/replace	
(Unit 2) 34	7	0	0	6	Cooling pump tripped on high ambient temperature.
35	8	0	0	8	
36	0	0	0	0	
37	5	0	1	4	
38	8	0	0	8	
(Unit 3) 12	0	0	0	0	During refueling outage, the engine speed could be decreased but not increased.
13	2	0	0	2	
14	8	0	0	8	
15	10	1	3	7	
16	2	0	0	2	
17	10	1	2	7	

TABLE 3

Diesel Generator Unscheduled Downtime Record
Calendar Year 1977

Enclosure 1 - Page 3

Plant Name DresdenUnit No. 2 & 3

IER Abstract No. (Refer to attached IER Abstracts)	Downtime Hours				Comments - If any of the reported failures would not have been a failure under emergency conditions, please explain here. Refer to attached IERs or the failures listed in Table 1.	
	Total Hours	Trouble-shooting	Parts, Delivery, etc.	Repair/replace		
(Unit 2) 23	0	0	0	0	River water spill in the 2/3 D/G's. D/G back in service before performing auto. start relay check.	
24	1	1	0	0		
25	8	1	1	6		
26	1	1	0	0		
27	8	1	0	7		
28	0	0	0	0		
29	16	2	4	10		
30	2	2	0	0		
31	1	1	0	0		
32	8	1	2	5		
33	10	1	0	9		
(Unit 3) 5	3	1	0	2		Storage fuel tank level <10K gallons as required per Tech. Specs.
6	2	0	0	2		
7	0	0	0	0		
8	8	0	0	8		
9	2	0	0	2		
10	0	0	0	0		
11	3	0	0	3	Cooling pump breaker trip caused by high ambient temperature.	

TABLE 4

Onsite Emergency Diesel Generator and
Auxiliary Equipment Modification Record

Enclosure 1 - Page 4

Plant Name DresdenUnit No. 2

Equipment or procedure modified	Date of Mod.	Reason for Modification and Desired Improvement	Description of Modification
2 Diesel Generator M12-2-76-86	10-77	Station personnel have means & procedure of manually setting governor at 60 Hz prior to engine shutdown.	Remove & jumper diesel governor raise limit switch over travel.
2 Diesel Generator M12-2-77-48	Cancelled 12-6-77	To provide submersible type pump in D.G. cooling water system.	Install D.G. cooling water submersible type pump.
2 Diesel Generator M12-2-78-15	7-78	To provide capability to blowdown D.G. air start piping.	Add valve to strainer to blowdown air start piping.
2 Diesel Generator M12-2-78-19	10-78	Tachometer needed to provide indication of D.G. RPM.	Install a tachometer on diesel engine.
2 Diesel Generator M12-2-78-21	8-79	This mod. will provide more reliability, supplying the operator with indication of bus tie to emergency bus breaker test position.	Install an alarm in control room to tell when diesel bus tie & emergency bus breaker is in test position.
2 Diesel Generator M12-2-78-22	9-79	Air start shutoff valve was once found closed. This mod. will provide alarm when air start shutoff valve is closed.	Alarm in control room to alarm when the air shutoff valve is in the closed position.
2 Diesel Generator M12-2-78-028	9-79	Increase air start capability of diesel generators.	Install multiple start air system for D.G.
2 Diesel Generator M12-2-78-40	8-79	Insure droop is at correct setting in standby.	Install droop alarm in control room.
2 Diesel Generator M12-2-79-35	11-79	Increases reliability of D.G. multiple air start system.	Revise D.G. multiple start circuitry to provide more positive relay action for multiple start.

TABLE 4

**Onsite Emergency Diesel Generator and
Auxiliary Equipment Modification Record**

Enclosure 1 - Page 4

Plant Name DresdenUnit No. 3

Equipment or procedure modified	Date of Mod.	Reason for Modification and Desired Improvement	Description of Modification
3 Diesel Generator M12-3-78-15	6-78	Provide blowdown capability in air start piping.	Add a valve to the strainer on the D.G. air start piping.
3 Diesel Generator M12-3-78-19	10-78	Tachometer needed to provide indication of D.G. RPM.	Install a tachometer on the diesel engine.
3 Diesel Generator M12-3-78-21	8-79	This mod. will provide more reliability, providing the operator with indication of bus tie to emergency bus breaker test position.	Install alarm in control room for diesel bus tie to emergency bus breakers when in test position.
3 Diesel Generator M12-3-78-22	4-79	Air start shutoff valve was once found closed. This mod. will provide alarm when air start shutoff valve is closed.	Alarm in control room to alarm when the air start system shutoff valve is closed.
3 Diesel Generator M12-3-78-28	9-79	Increases air start capability of diesel generators.	Install multiple start system for D.G.
3 Diesel Generator M12-3-78-40	8-79	To insure droop is in correct setting in standby.	Install droop alarm in control room.
3 Diesel Generator M12-3-79-35	N/A	Increases reliability of D.G. air start system.	Provide diesel generator multiple start circuitry to provide more positive relay action for multiple start.

TABLE 4

Quinta Emergency Diesel Generator and
Auxiliary Equipment Modification Record

Figure 1 - Page 4
Plant Name: Dresden
Unit No. 2/3

Equipment or procedure modified	Date of Mod.	Reason for Modification and Desired Improvement	Description of Modification
2/3 Diesel Generator M12-2/3-78-8	8-78	D.G.'s 2 & 2/3 currently share same window.	Provide annunciator windows for 2 & 2/3 diesel "AUTO STOP BLOCKED."
2/3 Diesel Generator M12-2/3-78-9	7-78	To provide capability to blowdown D.G. air start piping.	Add a valve to the strainer on the diesel generator air start piping to blowdown.
2/3 Diesel Generator M12-2/3-78-13	10-78	Tachometer needed to provide indication of D.G. RPM.	Install a tachometer on the diesel generator.
2/3 Diesel Generator M12-2/3-78-15	9-79	This mod. will provide more reliability, supplying operator with indication of bus tie to emergency bus breaker test position.	Install alarm in control room to tell when diesel bus tie & emergency bus breaker is in test position.
2/3 Diesel Generator M12-2/3-78-16	6-79	Air start shutoff valve was once found closed. This mod. will provide alarm when air start shutoff valve is closed.	Install alarm in control room to alarm when air start shutoff valve is in closed position.
2/3 Diesel Generator M12-2/3-78-19	10-79	Increases air start capability of diesel generators.	Install multiple start system for diesel generator.
2/3 Diesel Generator M12-2/3-78-27	8-79	To insure droop setting is correct when in standby.	Install droop alarm in control room.
2/3 Diesel Generator M12-2/3-79-21	Initiated 10-30-79 Not Comp.	To provide remote operation of valves under emergency conditions.	D.G. cooling water M.O. valve addition to replace hand-operated valves.
2/3 Diesel Generator M12-2/3-76-55	N/A	Failure of new submersible pump dictated installation of old pump.	Reinstall old style D.G. cooling water pump.
2/3 Diesel Generator M12-2/3-76-68	9-77	Existing surge suppressors have been prone to failure at Quad Cities.	Install heavier duty diesel generator surge suppressors.